

East Logan Water District
WORK ORDER 11174

Account # [REDACTED] Order Date 11/15/2016
Name CALLAHAN TP, REBECCA A Status MEDIUM
Address [REDACTED] Scheduled 11/15/16 09:51 AM
Telephone [REDACTED] Job # [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 55190839 ERT/INTERNAL ID# 10430416 READING 8887 LOCATOR TAG B14168947 READING IN / OUT

Description
Comment RT, BRN TRLR, M/YD 2ND

Requested By Rebecca Assigned To MAINTENANCE CREW Completed By
Start Date 11/15/16 Time : Completed Date 11/15/16 Time :

Make _____ Size/Type _____ Multiplier _____
Notes Meter box full of water... see whats going on. If it's her leak, let her know

Inventory Item And Description	Quantity Ordered	Quantity Used
Customer knows they have a small leak on the end. Also changed meter out old s&l		

Old - 8903
New - 0



Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 81568772
Flow: 098.4 Mid: 100.8 Hi: 099.9
Register Cust ID: 74698143
Register Fact ID: 74698143
Config: [X][X][X][X][] [] [] [] [] [] []

Sensus Meter SN: 81568772
Flow: 098.4 Mid: 100.8 Hi: 099.9
Register Cust ID: 74698143
Register Fact ID: 74698143
Config: [X][X][X][X][] [] [] [] [] [] []

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 11170

Account # [REDACTED]
Name **MONFEE, TOSHIA M**
Address [REDACTED]
Telephone [REDACTED]

Order Date 11/14/2016
Status MEDIUM
Scheduled 11/14/16 12:21 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 12839690	09000421	6264	B14167695	

Description
Comment LF,TRLR RT/CNR
Requested By Mr. Monfee Assigned To MAINTENANCE CREW Completed By
Start Date 11/15/16 Time : Completed Date 11/18/16 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
meter is turning slow, talked to owner, no real indication of our leak. Also changed meter and fill		

old - 6287
New - 0

 Sensus www.sensus.com Certified to NSF/ANSI 61-G	Order: 00395642 Line: 007 Date: 0616  Part No: A2DXX38GGXXX1XX Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK	Order: 00395642 Line: 007 Date: 0616  Part No: A2DXX38GGXXX1XX Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK
	Sensus Meter SN:  81568773 Flow:  Low: 098.1 Mid: 100.6 Hi: 100.0 Register Cust ID:  74698144 Register Fact ID: 74698144 Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Sensus Meter SN:  81568773 Flow:  Low: 098.1 Mid: 100.6 Hi: 100.0 Register Cust ID:  74698144 Register Fact ID: 74698144 Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature 

East Logan Water District
WORK ORDER 11168

Account # [Redacted]
Name HAGAN, TIMOTHY L
Address [Redacted]
Telephone [Redacted] Job #

Order Date 11/14/2016
Status MEDIUM
Scheduled 11/14/16 11:55 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 21164372 ERT/INTERNAL ID# 63814702 READING 2476 LOCATOR TAG B14891801 READING IN / OUT

Description
Comment LF, TAN HSE, MYD

Requested By Mr. Hagan Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date 11/16/16 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

uf

Sensus
www.sensus.com



Certified to
NSF/ANSI 61-G

Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 81568771

Sensus Meter SN: 81568771

Flow: 98.7 Mid: 100.7 Hi: 099.8

Flow: 98.7 Mid: 100.7 Hi: 099.8

Register Cust ID: 74698142
Register Fact ID: 74698142

Register Cust ID: 74698142
Register Fact ID: 74698142

Config:

Config:

Signature *Tim*

East Logan Water District
WORK ORDER 11163

Account # [Redacted]
Name BROWN, JAROD B
Address [Redacted]
Telephone [Redacted]

Order Date 11/11/2016
Status MEDIUM
Scheduled 11/11/16 03:39 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 27207628	09011200	7878	B14167553	

Description
Comment RT,TAN HSE, L/DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date 11/11/16 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used



Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 81568782

Sensus Meter SN: 81568782

Flow: 098.0 Mid: 100.8 Hi: 100.0

Flow: 098.0 Mid: 100.8 Hi: 100.0

Register Cust ID: 74698153

Register Cust ID: 74698153

Register Fact ID: 74698153

Register Fact ID: 74698153

Config: [X][X][X][X][] [] [] [] []

Config: [X][X][X][X][] [] [] [] []

Signature *Tm*

East Logan Water District
WORK ORDER 11123

Account # _____
Name **STANLEY, DONALD L**
Address _____
Telephone _____

Order Date 10/25/2016
Status MEDIUM
Scheduled 10/26/16 08:41 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 78785981 ERT/INTERNAL ID# 73606967 READING _____ LOCATOR TAG B14167989 READING IN / OUT _____

Description _____
Comment LF, TRLR OFF RD, 150' RT INTER

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes METER BOTTOM BUSTED, REPLACED METER. 10/25/16 OLD READING 3583 TM

Inventory Item And Description	Quantity Ordered	Quantity Used

Sensus
www.sensus.com



Certified to NSF/ANSI 61-G

Order: 00332572 Line: 001
Date: 1214
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DPR 5WHL4A 100G 6'SEN L/HSGPK

Order: 00332572 Line: 001
Date: 1214
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DPR 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 78785981

Sensus Meter SN: 78785981

Flow: _____
Low: 099.4 Mid: 101.0 Hi: 100.0

Flow: _____
Low: 099.4 Mid: 101.0 Hi: 100.0

Register Cust ID: 73606967
Register Part ID: 73606967

Register Cust ID: 73606967
Register Part ID: 73606967

Config:

Config:

Signature _____

East Logan Water District
WORK ORDER 11185

Account # [Redacted]
Name WHITE, EWING
Address [Redacted]
Telephone [Redacted] Job # _____

Order Date 11/17/2016
Status MEDIUM
Scheduled 11/17/16 10:17 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 32860895 ERT/INTERNAL ID# 39202744 READING 5057 LOCATOR TAG B14168904 READING IN / OUT _____

Description
Comment LF, BRK HSE, RT YD

Requested By IINDA Assigned To MAINTENANCE CREW Completed By _____
Start Date 11/17/16 Time _____ Completed Date 11/17/16 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Customer states mler box is wet

+ get reading

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Old SR changed out.</i>		
<i>Working at Customer's Cutoff</i>		

*Old - 5068
New - 0*



Order: 00395642 Line: 007	Order: 00395642 Line: 007
Date: 0616	Date: 0616
Part No: A2DXX38GGXXX1XX	Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK	Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK
Sensus Meter SN: 81568784	Sensus Meter SN: 81568784
Flow:	Flow:
Low: 098.9 Mid: 101.2 Hi: 100.0	Low: 098.9 Mid: 101.2 Hi: 100.0
Register Cust ID: 74698155	Register Cust ID: 74698155
Register Fact ID: 74698155	Register Fact ID: 74698155
Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature TM

East Logan Water District
WORK ORDER 10030

Account Name: WILLIAMSON, RICHARD D
Address: [Redacted]
Telephone: [Redacted]

Order Date: 10/1/2015
Status: MEDIUM
Scheduled: 10/01/15 11:13 AM
Order Type: CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361529	39202755	6941	B14167932	
Description	Replace meter per TJ			
Comment	RT, BLUE HSE, 100FT PAST DR O/			
Requested By TJ	Assigned to	MAINTENANCE CREW		Completed By <i>RICS SWIN</i>
Start Date <i>10/1/15</i>	Time <i>8:15</i>	Completed Date <i>10/1/15</i>		Time <i>5:21</i>
Make	Size/Type	Multiplier		
Notes				

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>This already been done but I had all just had no damage</i>		
<i>AM 12-7-16</i>		

marked in blue on the road and fence post
Box needs to be dug up and meter ~~to be~~ replaced

Duncan shape X road.

Let know ~~me~~ when ready

10/14 @ 1:15
Bud# 1510090846
ATT, LTC

Signature _____

ELWOOD HEIGHT DISTRICT
WORK ORDER 11269

Account # [REDACTED] Order Date 12/28/2016
 Name FULLER, TONY & MARSHA Status MEDIUM
 Address [REDACTED] Scheduled 12/28/16 08.19 AM
 Telephone [REDACTED] Job # [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418212	63153564	497	B14169931	

Description
 Comment ROCK HSE. LF CNR
 Requested By Brandon Assigned To MAINTENANCE CREW Completed By
 Start Date / / Time Completed Date / / Time
 Make Size/Type Multiplier
 Notes

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 1/31/17

id# 1612280374

LTC

Fixed 1/3/17
BG

2330 Ellis Rd.

Signature _____ User1

East Logan Water District
WORK ORDER 11108

Account # [Redacted]
Name DILL, RANDY
Address [Redacted]
Telephone [Redacted] Job # [Redacted]

Order Date 10/13/2016
Status MEDIUM
Scheduled 10/13/16 10:38 AM
Order Type MISCELLANEOUS

METER# WT 36635912 IRT/INTERNAL ID# 61287380 READING 5702 LOCATOR TAG B14169003 READING IN / OUT

Description
Comment LF, HSE OFF RD, LF 1ST DR, 2 M

Requested By Linda Assigned To MAINTENANCE CREW Completed By [Signature]
Start Date 1/1/16 Time Completed Date 10/14/16 Time

Make Size/Type Multiplier
Notes Brandon. talk to me about this. Leak, and needs suggestions to find it.

Inventory Item And Description	Quantity Ordered	Quantity Used

772-3191

Customer Leak

[Signature]

Signature _____

WORK ORDER 11266

Account # [REDACTED]
Name PURSLEY TP, PEGGY SUE
Address [REDACTED]
Telephone [REDACTED]


Order Date 12/27/2016
Status MEDIUM
Scheduled 12/27/16 03.09 PM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 36635913	64952914	2173	B14169593	2444
Description: Lock the meter, high usage and no reason!!!!				
Comment: RT, TRLR, LF YD AT P POLE				
Requested By Mrs.Pursley		Assigned To MAINTENANCE CREW		Completed By
Start Date 12/27/16		Time		Completed Date 12/27/16

Make _____ Size/Type _____ Multiplier _____
Notes 270-755-5645

Inventory Item And Description	Quantity Ordered	Quantity Used

Leak on their end. Meter is ~~locked~~ locked. Also painted a blue X where I think the leak is.

Signature 

East Logan Water District
WORK ORDER 11264

Account # [REDACTED]
Name FARMER, SHANE
Address [REDACTED]
Telephone [REDACTED]

Order Date 12/27/2016
Status MEDIUM
Scheduled 12/27/16 09:05 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 22796304	13198978	6406	B14169218	

Description WATER BUBBLING UP OUT OF METER!!! METER NOT TURNING ON THEIR SIDE!

Comment LF, YELLOW TRLR, 30' RT OF DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By *JKD/136*

Start Date *12/27* Time _____ Completed Date *12/27/16* Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Replaced Broken Pressure Reducer / no hit off

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *B6*

WEST LOUGH TERRACE DISTRICT
WORK ORDER 11260

Account # [REDACTED]
Name MAST, MILTON D
Address [REDACTED]
Telephone [REDACTED]

Order Date 12/22/2016
Status MEDIUM
Scheduled 12/22/16 03:32 PM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 54230314	63671876	3322	B14166499	3343

Description Customer has meter off, turn on and you will see water coming out of meter
Comment RT WH/HS R/YARD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 12/22/16 Time _____ Completed Date 12/22/16 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

the joint was loose just tightened up
no more leak

Signature T. [Signature]

WORK ORDER 11246

Account # [REDACTED]
Name BILBREY TP, ADRIAN LEE & REVENA
Address [REDACTED]
Telephone [REDACTED]

Order Date 12/14/2016
Status MEDIUM
Scheduled 12/14/16 10:39 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 41855162	63088722	2658	B14167841	

Description

Comment RT, GREY D-WIDE, LT/DR

Requested By Tyler

Assigned To MAINTENANCE CREW

Completed By

Start Date 12/14/16 Time : :

Completed Date 12/14/16 Time : :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Prator. MUA X by 12/16

Serial # 1612140602

Fixed
Pulled new tube

AFT
LTC.

Signature W. K. [Signature]

WORK ORDER 11247

Account # [REDACTED]
Name SWEETSIR---TP, LISA G
Address [REDACTED]
Telephone [REDACTED] JOB #

Order Date 12/14/2016
Status MEDIUM
Scheduled 12/14/16 09:56 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 65798149 ERT/INTERNAL ID# 58647067 READING 5135 LOCATOR TAG B14167049 READING IN / OUT

Description
Comment LT, TRLR, M/YD

Requested By Tyler Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date 12/14/16 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Job # 1612140522 X by 12/14/16

ATT

Bluegrass Gas

*Pulled new
service line
instead road
replaced better*

Signature 16

East Logan Water District
WORK ORDER 11263

Account # [REDACTED]
Name HEFFER, SHAWN M
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 12/22/2016
Status MEDIUM
Scheduled 12/22/16 03:54 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568831	74698202		B15401667	

Description

Comment RT OF DR

Requested By Linda

Assigned To MAINTENANCE CREW

Completed By

Start Date 12-22-16

Time

Completed Date 12-22-16

Time

Make _____ Size/Type _____ Multiplier _____

Notes Turn off meter if meter is turning because of busted pipes, etc. Please see if it is leaking

Inventory Item And Description	Quantity Ordered	Quantity Used

5263

Signature SM

East Logan Water District
WORK ORDER 11215

Account # _____ Order Date 12/5/2016
 Name FITZGERALD PATRICK Status MEDIUM
 Address _____ Scheduled 12/05/16 08:02 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056595	10178131	6646	B14169783	6658

Description _____
 Comment LF, GR TRLR IN CURVE, RT CNR
 Requested By Patrick Assigned to MAINTENANCE CREW Completed By _____
 Start Date 12/05/16 Time _____ Completed Date 12/05/16 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted meter bottom, replaced bottom
 0.5 gallons per min.

Signature _____

East Logan Water District
WORK ORDER 11236

Account # [REDACTED]
Name AICHER, FRANCIS
Address [REDACTED]
Telephone [REDACTED]

Order Date 12/8/2016
Status LOW
Scheduled 12/08/16 11:34 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605844	10164973	3195	B14169381	


Description
Comment RT, WOOD HOUSE LF CNR

Requested By Jerry Taylor Assigned To MAINTENANCE CREW Completed By *KD/BG*
Start Date _____ Time _____ Completed Date *12/8/16* Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Water standing across street from this address
*Checked Standing water (NO CH/DRENE) Piped/Dry holes
NO LEAK*

Inventory Item And Description	Quantity Ordered	Quantity Used



Signature *BG*

East Logan Water District
WORK ORDER 11196

Account # _____
Name **BROCK, WILLIAM**
Address _____
Telephone _____

Order Date 11/28/2016
Status MEDIUM
Scheduled 11/28/16 09:16 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361408	63066020	7862	B14167497	7898

Description _____
Comment **LF E/DN 200 BEYOND GATES READ**

Requested By **William Brock** Assigned To **MAINTENANCE CREW** Completed By _____
Start Date **11/28/16** Time _____ Completed Date **11/28/16** Time _____

Make _____ Size/Type _____ Multiplier _____
Notes **Texted Tyler. Box full of water**

Inventory Item And Description	Quantity Ordered	Quantity Used

Replaced cutoff ~~cut off needs to be replaced~~ - 7

Texted Tyler

Signature _____

East Logan Water District
WORK ORDER 11200

Account # [REDACTED] Order Date 11/28/2016
 Name STRAIT, DEBBIE L Status MEDIUM
 Address [REDACTED] Scheduled 11/28/16 01:22 PM
 Telephone [REDACTED] Job # [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271752	74600824	195	B15368803	

Description Grass white around the meter box & going down ditch line

Comment RT HSE RT DRIVE

Requested By Debbie Assigned To _____ Completed By _____

Start Date 11/28/16 Time _____ Completed Date 11/28/16 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

NO LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used

Checked by [Signature]

Signature H2/B.G.

East Logan Water District
WORK ORDER 11084

Account # [REDACTED] Order Date 10/4/2016
 Name ORDER, WORK Status MEDIUM
 Address [REDACTED] Scheduled 10/04/16 03:03 PM
 Telephone [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE
 METER# [REDACTED] METER/INTERNAL ID# [REDACTED] READING [REDACTED] LOCATOR TAG [REDACTED] READING IN / OUT [REDACTED]

WT No Num [REDACTED]
 Description [REDACTED]
 Comment [REDACTED]
 Requested By Mr. Byler 270-392-1339 Assigned To MAINTENANCE CREW Completed By [REDACTED]
 Start Date 10/12/16 Time [REDACTED] Completed Date 10/12/16 Time [REDACTED]

Make [REDACTED] Size/Type [REDACTED] Multiplier [REDACTED]

Notes Hughes Rd. between 675 and 742 ...soft spot across from meters. See if this is a leak. Also, he will be doing some fencing along here. Is there a water line here?

[Handwritten note: Check for leak]

Inventory Item And Description	Quantity Ordered	Quantity Used

*check for leak
 check where our line is*

Signature BG

WORK ORDER 11192

Account # [REDACTED] Order Date 11/21/2016
 Name HOSTEDLER ELL Status MEDIUM
 Address [REDACTED] Scheduled 11/21/16 10:53 AM
 Telephone [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	RT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 000063869521	56502030	9486	B14167710	

Description
 Comment RT,HSE OFF RD,LF DR
 Requested By Tyler Assigned to MAINTENANCE CREW Completed By
 Start Date 11/21/16 Time : : Completed Date 11/21/16 Time : :

Make _____ Size/Type _____ Multiplier _____
 Notes BRANDON... please check Tyler has water in ditch on main line side, but not picking up a residual
not a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

*If we have to do a
 Bud - a Turner or Herman Coy*

Signature BC

East Logan Water District
WORK ORDER 11148

Account # [REDACTED]
Name BROWN MICHAEL
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 11/3/2016
Status MEDIUM
Scheduled 11/03/16 04:19 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473770	70978961	1173	B14250481	

Description

Comment RT BRK R/DR

Requested By Michael Assigned To MAINTENANCE CREW Completed By [REDACTED]
Start Date / / Time Completed Date / / Time

Make _____ Size/Type _____ Multiplier _____
Notes Water coming up from meter box

Inventory Item And Description	Quantity Ordered	Quantity Used

Replace meter bottom

BC

Signature _____

WEST LOUISIANA WATER DISTRICT
WORK ORDER 11099

Account # [REDACTED]
Name LYONS, ALAN
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 10/10/2016
Status MEDIUM
Scheduled 10/10/16 12:49 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 55507403	52650310	2734	B14169526	

Description
Comment LF, BLOCK BLD, 20' LF GATE

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

1 Friendship Rd
Bud # 1610161340
LTC, WRECC

x by 10/12/16

10-20-16

b6

Signature _____

EAST LOGAN WATER DISTRICT
WORK ORDER 11119

Account # [REDACTED]
 Name OFFUTT, JANET C
 Address [REDACTED]
 Telephone [REDACTED] Job # [REDACTED]
 Order Date 10/24/2016
 Status MEDIUM
 Scheduled 10/24/16 08 49 AM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 40733073	09370470	6785	B14170067	

Description
 Comment RT, WH HSE, RT YD, RT P POLE
 Requested By Janet Offutt Assigned To MAINTENANCE CREW Completed By
 Start Date / / Time : Completed Date / / Time

Make _____ Size/Type _____ Multiplier _____
 Notes She says standing water about 15 ft from meter, and she has put out white flags

Inventory Item And Description	Quantity Ordered	Quantity Used

Own leak @ 10180 Franklin Rd
 Bud call please
 marked / blue paint
 25' radius of paint
 both sides of Rd
 X Halcomb Rd

referred to T4kw

Bud # 1610241563 X by 10/26

ATT

Signature Tm

East Logan Water District
WORK ORDER 11158

Account # [REDACTED]
Name VALJIEN, RICHARD
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 11/10/2016
Status MEDIUM
Scheduled 11/10/16 09:40 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 46202683	09643164	7564	B14172458	7591

Description
Comment RT,BEIGE HSE.FAR RT YD,CEM RD

Requested By Linda Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date / / Time :

Make _____ Size/Type _____ Multiplier _____

Notes Water in box, meter is turning. See if it is our leak or their's. Please call her if her leak, 270-772-0049 and text us whose leak it is. If ours, we will need the reading from the meter

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer's Leak

Texted Tyler

Signature TM

East Logan Water District
WORK ORDER 11102

Account # [REDACTED]
Name CAIN, BARBARA S
Address [REDACTED]
Telephone [REDACTED]

Order Date 10/11/2016
Status MEDIUM
Scheduled 10/11/16 11:01 AM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45221849	63097945	592	B14169199	1.00

Description
Comment LF, TRLR OFF RD, 20' RTGR DR

Requested By Linda Assigned To MAINTENANCE CREW Completed By
Start Date 10/11/16 Time 1:00 Completed Date 10/11/16 Time 1:00

Make _____ Size/Type _____ Multiplier _____

Notes Mr. Cain thinks he has a leak. He turned off meter and tried to drain his line, but there was no water in the line, according to him. Please make sure there is some sort of backflow preventer at his meter. Also, so you see evidence of a leak, either side of meter?

Inventory Item And Description	Quantity Ordered	Quantity Used

There is a back flow preventer on the meter
Sounded meter on & off no sound & also
Checked the register & its working correctly.
No indication of leak on our end. Noticed
"small amount of water coming in from
customer side

Signature TM

East Logan Water District
WORK ORDER 11098

Account # [REDACTED]
Name SMITH, TINA I
Address [REDACTED]
Telephone [REDACTED]
Order Date 10/10/2016
Status MEDIUM
Scheduled 10/10/16 09:50 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979834	71205586	2081	B14170134	2107

Description
Comment RT, RED BRK HSE, 40' LF GR DR
Requested By Mike Assigned To MAINTENANCE CREW Completed By
Start Date 10/10/16 Time Completed Date 10/10/16 Time

Make Size/Type Multiplier
Notes 270-847-9274 Mike Smith
Water in meter box: see if we have a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer leak, meter turning slow & coming from their side.
Called but no answer & left voicemail

Signature 

WORK ORDER 11085

Account # [REDACTED] Order Date 10/5/2016
 Name HUGHES, CHRIS L Status MEDIUM
 Address [REDACTED] Scheduled 10/05/16 08 43 AM
 Telephone [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER# [REDACTED] METER/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 48979811 09785122 6467 B14167344

Description
 Comment LF, WOOD SIDE HSE, 20' RT DR
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time :___:___ Completed Date 10/16/16 Time :___:___

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Create Dev-

Bid# 1610061244

X by 10/11/16

ATT

Fixed

Signature B67

LEWIS & CLARK DISTRICT
WORK ORDER 11090

Account # [REDACTED] Order Date 10/7/2016
 Name REESE, STEPHEN Status MEDIUM
 Address [REDACTED] Scheduled 10/07/16 09:15 AM
 Telephone [REDACTED] Job # [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78786041	73607027	797	B15347985	

Description
 Comment RT, 25 yds to right of drive
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date 1/1/16 Time _____ Completed Date 10/7/16 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes *Down Reese 361-254-1234*

Inventory Item And Description	Quantity Ordered	Quantity Used

*X W. Valley Dr -
Emergency*

Bud # 1610 070681

Notified: ATT, ATMOS, LTC

Signature *TM / KD*

WORK ORDER 11089

Account # [REDACTED]
Name ANDERSON, KIMBERLY S
Address [REDACTED]
Telephone [REDACTED]

Order Date 10/6/2016
Status MEDIUM
Scheduled 10/06/16 01:06 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 37668724	09879737	4049	B14170121	4651

Description
Comment LF, TAN HSE, M/LOT, O/FENCE
Requested By Mr. Anderson Assigned To MAINTENANCE CREW Completed By
Start Date 10/11/16 Time : : Completed Date 10/16/16 Time : :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted meter bottom, replaced bottom

Signature [Signature]

WORK ORDER 11123

Account # [REDACTED]
Name STANLEY, DONALD L
Address [REDACTED]
Telephone [REDACTED] ob #

Order Date 10/25/2016
Status MEDIUM
Scheduled 10/26/16 08 41 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78785981	73606967	3551	B14167989	

Description
Comment LF, TRLR OFF RD,150' RT INTER
Requested By Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 10/26/16 08 42 AM Completed Date 10/26/16 08 42 AM

Notes METER BOTTOM BUSTED. REPLACED METER 10/25/16 OLD READING 3583 TM

Signature _____

WORK ORDER 11163

Account # [REDACTED]
Name BROWN, JAROD B
Address [REDACTED]
Telephone [REDACTED] ob #

Order Date 11/11/2016
Status MEDIUM
Scheduled 11/11/16 03.39 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568782	74698153	7878	B14167553	

Description

Comment RT,TAN HSE. L/DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 11/11/16 11:20 AM Completed Date 11/11/16 11:20 AM

Notes changed out old sr1 meter, old reading 7891. 11/11/16 TM

WORK ORDER 11168

Account # [REDACTED] Order Date 11/14/2016
Name HAGAN, TIMOTHY L Status MEDIUM
Address [REDACTED] Scheduled 11/14/16 11.55 AM
Telephone [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568771	74698142	2476	B15451622	

Description
Comment LF, TAN HSE, M/YD
Requested By Mr Hagan Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 11/16/16 08:46 AM Completed Date 11/16/16 08:46 AM

Notes Brandon fixed leak and Tyler changed out old sr1 11/16/16 Old reading 2507

Signature _____

WORK ORDER 11170

Account # [REDACTED]
Name MONFEE, TOSHIA M
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 11/14/2016
Status MEDIUM
Scheduled 11/14/16 12:21 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568773	74698144	6264	B14167695	

Description

Comment LF,TRLR RT/CNR

Requested By Mr. Monfee Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 11/15/16 08 40 AM Completed Date 11/15/16 08 40 AM

Notes Meter is turning slow, talked to owner, no real indication of our leak Also changed out old sr1, old reading 6287
TM 11/18/16

Signature _____

ELWD Water District
WORK ORDER 11174

Account # [REDACTED]
Name CALLAHAN TP, REBECCA A
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 11/15/2016
Status MEDIUM
Scheduled 11/15/16 09:51 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568772	74698143	8887	B14168947	

Description

Comment RT, BRN TRLR, M/YD 2ND

Requested By Rebecca **Assigned To** MAINTENANCE CREW **Completed By** MAINTENANCE CREW

Start Date 11/15/16 08:33 AM **Completed Date** 11/15/16 08:33 AM

Notes Meter box full of water..... see whats going on. If it's her leak, let her know
This turned out to be the customers leak, (small), also changed out old sr1 meter. Old reading 8903 TM 11/15/15

Signature _____

WORK ORDER 11185

Account # [REDACTED]
Name WHITE, EWING
Address [REDACTED]
Telephone [REDACTED]

Order Date 11/17/2016
Status MEDIUM
Scheduled 11/17/16 10.17 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568784	74698155	5057	B14168904	

Description
Comment LF, BRK HSE, RT YD

Requested By LINDA Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 11/17/16 09.53 AM Completed Date 11/17/16 09 53 AM

Notes Customer states mter box is wet
Leaking at customer cutoff. Changed out sr1,old reading 5068. 11/17/16 TM

Signature _____

WORK ORDER 11249

Account # [REDACTED]
Name INSCO, WAYNE
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 12/14/2016
Status MEDIUM
Scheduled 12/14/16 04 31 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 9434391	9434391	2081		

Description
Comment LF, WOOD SIDE HSE, FAR LF YD A
Requested By Brandon Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 04/12/17 02 49 PM Completed Date 04/12/17 02:49 PM

Notes Brandon thinks there might be leak here, slightly pink when tested BUD call made
FIXED BG

Signature _____

WORK ORDER 11261

Account # [REDACTED] Order Date 12/22/2016
Name PRATHER, MARY E Status MEDIUM
Address [REDACTED] Scheduled 12/22/16 03:35 PM
Telephone [REDACTED] Job # [REDACTED] Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271634	74600706	37	B14169416	

Description

Comment LF,HSE OFF RD, RT DR

Requested By Tyler Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 12/23/16 01:00 PM Completed Date 12/23/16 01:00 PM

Notes Brandon notified customer they had a small leak

Signature _____

WORK ORDER 11274

Account # [REDACTED]
Name CARDWELL, JESSICA M
Address [REDACTED]
Telephone [REDACTED] Job # [REDACTED]

Order Date 12/29/2016
Status MEDIUM
Scheduled 12/29/16 10:25 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 63869452	63183986	2984	B14169980	

Description

Comment LF,WH HSE,RT YD READ 2

Requested By Shane Cole Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 01/12/17 02:00 PM Completed Date 01/12/17 02:00 PM

Notes Water in ditch between meter and road. He says meter is not turning Also, water has a brownish cast when turned on after sitting overnight.

Tyler / crew repaired leak, but service line needs replacing. Leak stopped for now.

Signature _____

WORK ORDER 12383

Account # 0
 Name MARR STEVE A
 Address
 Telephone () Job #
 Order Date 12/27/2017
 Status MEDIUM
 Scheduled 12/27/17 10:36 AM
 Order Type CHECK PRESSURE
 METER# ✓ ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 78786055 73607041 973 B14168390
 Description
 Comment LF, HSE, RT DR
 Requested By Mrs Marr Assigned To MAINTENANCE CREW Completed By
 Start Date 12/18 Time : Completed Date 12/18 Time :
 Make Size/Type Multiplier
 Notes Customer says their pressure has been low every since the break and the school. Please check.

Inventory Item And Description	Quantity Ordered	Quantity Used
They have a leak on		
there side		
I let them know		

Signature AC

WORK ORDER 12384

Account # _____ Order Date 12/27/2017
 Name WATER, COLEMAN FARM Status MEDIUM
 Address _____ Scheduled 12/27/17 01:17 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 49616586 61512449 7866 B14169708

Description _____
 Comment LF, ROCK HSE, 20' LF DR, 2ND
 Requested By Mr Coleman Assigned To MAINTENANCE CREW Completed By AC
 Start Date ____/____/____ Time ____:____ Completed Date 12/29/17 Time 12:00

Make _____ Size/Type _____ Multiplier _____
 Notes DELETED SERVICE LINE 3:45 PM 8,640 GAL LOST

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud# 1712270822

ATTN: WRECC

Signature _____

East Logan Water District
WORK ORDER 12389

Account # : 12389
Name THOMAS, LEWIS
Address
Telephone Job #

Order Date 12/29/2017
Status MEDIUM
Scheduled 12/29/17 08:14 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473717	07314929	4085	B14172382	

Description
Comment LF TAN HS LYARD

Requested By customer Assigned To MAINTENANCE CREW Completed By AC & TDJ
Start Date 1/1/ Time : Completed Date 12/30/17 Time 12:00

Make Size/Type Multiplier

Notes Water all around meter box
SERVICE LINE LEAK - REPLACED SERVICE LINE 33' O.D. LOST

Inventory Item And Description	Quantity Ordered	Quantity Used
10' 3/4" P.E. SERVICE LINE		
1- 3/4" CUT OFF		
1- 3/4" THREADED 90		
1- 3/4" MALE COMPRESSION COUPLING		

X Boston Rec

LTC
WRECC

1712290319

Signature _____

WEST LOUGH TREAT DISTRICT
WORK ORDER 12245

Account # _____ Order Date 11/8/2017
Name PAUL, MICHAEL E II Status MEDIUM
Address _____ Scheduled 11/08/17 03:58 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 54111858 63097903 2952 B14167801 2976

Description
Comment LF,TAN DBL-WIDE MYD

Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
Start Date 11/08/17 Time _____ Completed Date 11/08/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

X H.C. JENNINGS R2 #1711090910 ITC

Inventory Item And Description	Quantity Ordered	Quantity Used

Old reading 2976

Order: 00449645 Line: 004	Order: 00449645 Line: 004
Date: 0817 	Date: 0817 
Part No: A2DXX38GGXXX1XX	Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK	Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK
Sensus 	Sensus 
Meter SN: 83431893	Meter SN: 83431893
Flow: 	Flow: 
Low: 098.4 Mid: 100.8 Hi: 099.9	Low: 098.4 Mid: 100.8 Hi: 099.9
Register 	Register 
Cust ID: 89480641	Cust ID: 89480641
Register 	Register 
Fact ID: 89480641	Fact ID: 89480641
Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature A.C.

WORK ORDER 11876

Account # _____ Order Date 7/13/2017
 Name CAGE DEBBIE Status MEDIUM
 Address _____ Scheduled 07/13/17 10:47 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 69361534 63066146 4248 B14167789

Description
 Comment LT, TAN TRLR, LT/DR
 Requested By Debbie Cage Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____:____ Completed Date ____/____/____ Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

New-0
 old- 4264
 meter
 was
 not reg. proper
 &
 they have a
 on their 20

Sensus
 www.sensus.com

NSF Certified to NSF/ANSI 61-G

Order: 00436047 Line: 003	Order: 00436047 Line: 003
Date: 0417 	Date: 0417 
Part No: A2DXX38GGXXX1XX	Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK	Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK	DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN:  82995166	Sensus Meter SN:  82995166
Flow: 	Flow: 
Low: 098.1 Mid: 101.2 Hi: 100.4	Low: 098.1 Mid: 101.2 Hi: 100.4
Register Cust ID:  89283375	Register Cust ID:  89283375
Register Fact ID: 89283375	Register Fact ID: 89283375
Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature 

East Logan Water District
WORK ORDER 11326

Account #
Name FISHER, CINDY M
Address
Telephone

Order Date 1/18/2017
Status MEDIUM
Scheduled 01/18/17 05:32 PM
Order Type CHECK METER

METER# WT 51170296 ERT/INTERNAL ID# 09645279 READING 8805 LOCATOR TAG B14166760 READING IN / OUT

Description Needs new meter lid 270-542-2542

Comment RT, TRLR, LF CNR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____

Start Date 1/19/17 Time _____ Completed Date 1/19/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Fixed

Actual address is 7540 Cave Springs Rd
box needs to be replaced. Locate due to Logan
tele on the same side as box.
reading for 7540 (348)

X^{BY} 1/27/17

Bud # 1701250422

X St - Buckville Rd.

LTC, NRECC

*replaced box
at 7540 Cave Springs
Reading - (335)
1-25-17*

*Workorder placed @ wrong address,
called this and went to correct
account & made wo & notes
see attached —*

Signature *[Signature]*

East Logan Water District
WORK ORDER 11435

Account #
Name VACANT** , ***
Address
Telephone

Order Date 2/20/2017
Status MEDIUM
Scheduled 02/20/17 08:26 AM
Order Type CHANGE OUT METER

METER# WT 51170323 ERT/INTERNAL ID# 08841646 READING 742 LOCATOR TAG LOG HS EOL 2 MT READING IN / OUT

Description
Comment LOG HS EOL 2 MTRS M/YD

Requested By Mr. Bell Assigned To MAINTENANCE CREW Completed By

Start Date 2/20/17 Time : : Completed Date 2/20/17 Time : :


Make _____ Size/Type _____ Multiplier _____
Notes _____


Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced service tube from main to service + changed meter & put MXU on it.		


New - 0
old - 742


N - 36.88
W - 086.75


Sensus
www.sensus.com




Order: 00390547 Line: 001
Date: 0416 
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Order: 00390547 Line: 001
Date: 0416 
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN:  81271699


Flow: 


Low: 095.8 Mid: 100.6 Hi: 099.8

Register Cust ID:  74600771


Register Fact ID: 74600771

Config:

Sensus Meter SN:  81271699

Flow: 


Low: 095.8 Mid: 100.6 Hi: 099.8

Register Cust ID:  74600771

Register Fact ID: 74600771

Config:

Part 1 MS20R-C1-TC-X-AL
MXU ID 15415586 Date 10/16



Signature 

East Logan Water District
WORK ORDER 11350

Account #
Name KENDRICK, SUE L
Address
Telephone Job #

Order Date 1/26/2017
Status MEDIUM
Scheduled 01/26/17 11:38 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 65798113	58647031	3213	B14169452 8235	0000


Description
Comment LF,LF OF YD
Requested By Tyler Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

~~Checked for~~
~~and changed c~~
Checked for
and changed c
SR2...



Order: 00395642 Line: 007
Date: 0616
Part No: A2DXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 81568807
Flow: _____
Low: 098.1 Mid: 100.5 Hi: 099.7
Register Cust ID: 74698178
Register Fact ID: 74698178
Config: ☒☒☒☒☐☐☐☐

Signature B. G.

East Logan Water District
WORK ORDER 12304

Account # _____ Order Date 11/29/2017
Name POWELL, LARRY J Status MEDIUM
Address _____ Scheduled 11/29/17 03:20 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 50056570 09815582 766 B14685560

Description _____
Comment LF, WH BRK HSE, LF, FRONTAGE R

Requested By Daniel Assigned to MAINTENANCE CREW Completed By _____
Start Date 11/29/17 Time _____ Completed Date 11/29/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Service line repair
BUD# 1711291624
ATT, BG GAS

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 nut		
1- 3/4 coupling		
2- 3/4 inserts		
Short piece of 3/4 pipe		

Fixed

3-GALS Red A
Minut

Signature *A. C.*

East Logan Water District
WORK ORDER 11468

Account # _____ Order Date 3/1/2017
Name WAGONER, JAMES Status MEDIUM
Address _____ Scheduled 03/01/17 03:53 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 20322382 59536119 4925 B14167861

Description _____
Comment RT, TAN D-WIDE, MYD
Requested By Brandon Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date 03/01/17 Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Fixed

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>Second Meter turned off at curb stop-</u>		

X JK William
House off the Road
Meter - R of Dr
Across creek

Bud# 1703061314
LTC, ATT

Signature BG

East Logan Water District
WORK ORDER 11350

Account # _____ Order Date 1/26/2017
Name KENDRICK SUE L Status MEDIUM
Address _____ Scheduled 01/26/17 11.38 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568807	74698178	3213	B14169452	

Description _____
Comment LF,LF OF YD
Requested By Tyler Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 02/08/17 01 40 PM Completed Date 02/08/17 01 40 PM

Notes Checked for leak and changed out meter BG 02/08/17 old reading 3235

Signature _____

East Logan Water District
WORK ORDER 11876

Account # _____ Order Date 7/13/2017
Name CAGE, DEBBIE Status MEDIUM
Address _____ Scheduled 07/13/17 10:47 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82995166	89283375	4248	B14167789	

Description _____
Comment LT, TAN TRLR, LT/DR
Requested By Debbie Cage Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 07/13/17 08 13 AM Completed Date 07/13/17 08 13 AM

Notes Meter wan't reg , and they had a leak on their side Changed out meter Old reading 4264 07/13/17

Signature _____

East Logan Water District
WORK ORDER 12036

Account # _____ Order Date 9/12/2017
Name FARMER, SHANE Status MEDIUM
Address _____ Scheduled 09/12/17 08.12 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 83431871	89480619	6860	B14169218	
Description	Went to check meter & water was spraying out, but meter not turning			
Comment	LF, YELLOW TRLR, 30' RT OF DR			
Requested By	Mrs Farmer	Assigned To	MAINTENANCE CREW	Completed By MAINTENANCE CREW
Start Date	09/12/17 03 34 PM			Completed Date 09/12/17 03 34 PM

Notes Old SRI had a busted meter bottom Tyler changed out the meter Was not causing the meter to turn.

Signature _____

WORK ORDER 11347

Account # _____ Order Date 1/24/2017
 Name _____ Status MEDIUM
 Address 191 MELODY RIDGE Russellville, KY 42276 Scheduled 01/24/17 02:46 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51780826	09906845	7869	B14167189	

Description 20' east of gas post
 Comment RT, BROWN HSE, LF CNR
 Requested By Mr Nye Assigned To MAINTENANCE CREW Completed By _____
 Start Date 1/25/17 Time _____ Completed Date 1/26/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X 11w/100 X buy
~~1/27~~ 1/27

no leak, low spot that
 holds water when it rains

Bud # 1701250448

ATT, Atmos, LTC, Texas Gas

Signature 

WORK ORDER 11355

Account # _____ Order Date 1/26/2017
 Name GIPSON, EARL Status MEDIUM
 Address _____ Scheduled 01/26/17 03:42 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 68434124	62202148	1448	B14169752	

Description
 Comment LT "S" CURVE W/HSE LF OF DR BY
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/6/17 Time _____ Completed Date 2/6/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes work for 10 L-C-C in 1.5 mi

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud# 1701270585 X by 01/31/17

LTC, WRECC
 ^
 clear

Signature BG

WORK ORDER 11351

Account # _____ Order Date 1/26/2017
 Name BOISSEAU, NANCY Status MEDIUM
 Address _____ Scheduled 01/26/17 11:39 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51780741	09133896	7469	B14168288	

Description _____
 Comment LFT TAN TRLR CENTER OF TRLR
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____:____ Completed Date 2-10-17 Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 2/30/17

Bud# 1701241510

AT&T, LTC

*Changed out Cts
From Meter to Main.
good to go.*

B.G.

Signature

EAST LOGAN WATER DISTRICT
WORK ORDER 11418

Account # _____ Order Date 2/14/2017
Name COOK, RICKY Status MEDIUM
Address _____ Scheduled 02/14/17 03:29 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 30895754	09100493	2157	B15278738	7730

Description Water standing by meter

Comment LF, BIEGE TRLR, LF CNR


Requested By Mr. Cook Assigned To MAINTENANCE CREW Completed By _____

Start Date 2-15-17 Time _____ Completed Date 2-15-17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Brandon repaired a leak across the road from this address the other day. No indication of leak on our end.

Signature 

East Logan Water District
WORK ORDER 11416

Account # _____ Order Date 2/14/2017
 Name SWORDS, VERNON Status MEDIUM
 Address _____ Scheduled 02/14/17 11:33 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 81271633 74600705 351 B14969515

Description _____
 Comment LFT WHITE TRLR MID YD
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/14/17 Time _____ Completed Date 2/14/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes would like replaced

Inventory Item And Description	Quantity Ordered	Quantity Used

Emergency

Bud # 1702140993

LTC, WRECC

Signature RG

WORK ORDER 11406

Account # _____
Name PRICE, EDWARD IV
Address _____
Telephone _____

Order Date 2/9/2017
Status MEDIUM
Scheduled 02/09/17 10:09 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979803	10093966	3371	B14170144	

Description _____
Comment LF BRK HSE MYD

Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
Start Date 2/13/17 Time _____ Completed Date 2/13/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes reads 0.0719

Inventory Item And Description	Quantity Ordered	Quantity Used

X Dennis Coriath by 2/13

Buff# 1702090719

ATT

Signature BG

East Logan Water District
WORK ORDER 11366

Account # _____ Order Date 1/31/2017
 Name KINSER, ANGELO Status MEDIUM
 Address _____ Scheduled 01/31/17 04 18 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 39340292	10507232	3941	B14167576	

Description

Comment RT, WH/HS M/YD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____

Notes See if there is a leak here & get reading, IF meter is turning fast please see customer Monthly reading from Tyler 5979

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer Leak

Test Brandon



Signature _____

East Logan Water District
WORK ORDER 11353

Name HAGAN, TIMOTHY L
Order Date 1/26/2017
Status MEDIUM
Scheduled 01/26/17 02:28 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81568771 ERT/INTERNAL ID# 74698142 READING 89 LOCATOR TAG B14891801 READING IN / OUT

Description
Comment LF, TAN HSE, M/YD
Requested By Mrs Hagan Assigned To MAINTENANCE CREW Completed By
Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes Please see if this is leaking again. Customer says it stopped after we fixed leak, but now box, and ditch have started filling with water again.

Inventory Item And Description	Quantity Ordered	Quantity Used

Tested Standing water and water in meter
For leak. Water ok...

East Logan Water District
WORK ORDER 11318

Name WILLIAMS, CHRISTIE

Order Date 1/10/2017
Status MEDIUM
Scheduled 01/10/17 02:38 PM
Order Type CHECK FOR LEAK ON OUR SIDE

ob #

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45221799	62208768	3963	B15042625	

Description

Comment RT,HSE,LF CNR

Requested By TYLER

Assigned To MAINTENANCE CREW

Completed By

Start Date 1/1/17 Time

Completed Date 1/10/17 Time

Make _____ Size/Type _____ Multiplier _____

Notes 63 Thursday 1701101240 Success 12:15

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud# 1701101240

ATmos, LTC, WRECC

Signature BC

East Logan Water District
WORK ORDER 11338

Account # 0000 000
Name WEBB, TINK
Address
Telephone

Order Date 1/20/2017
Status MEDIUM
Scheduled 01/20/17 03:23 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69361396 ERT/INTERNAL ID# 63066008 READING 5074 LOCATOR TAG B14162900 READING IN / OUT

Description
Comment LF, HSE OFF RD, LF GR DR, 2ND

Requested By Tink Assigned To MAINTENANCE CREW Completed By
Start Date 1/20/17 Time Completed Date 1/20/17 Time

Make Size/Type Multiplier
Notes Tink called to say water is pouring out of one of the two meters at the road

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer Leak

Called Brandon

Signature BG

East Logan Water District
WORK ORDER 11343

Account#
Name HARRIS, KIM
Address
Telephone

Order Date 1/24/2017
Status MEDIUM
Scheduled 01/24/17 08:34 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684161	59596249	5430	B14167688	

Description
Comment RT, BRK, LT/YD

Requested By Linda
Assigned To MAINTENANCE CREW
Completed By
Start Date 1/23/17 Time
Completed Date 1/23/17 Time

Make _____ Size/Type _____ Multiplier _____

Notes Higher usage and wet around meter. See if there is a leak here.
Brandon checked. Customer has a leak on her side of meter. Not leaking on our side. Brandon talked with the customer.

See her leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature BG

EAST Logan Water District
WORK ORDER 11249

Account #	---	Order Date	12/14/2016
Name	INSCO WAYNE	Status	MEDIUM
Address		Scheduled	12/14/16 04:31-PM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG
WT 44137461	63215377	2081	B14169456

READING TR / OUT

Description
Comment LF, WOOD SIDE HSE. FAR LF YD A
Requested By Brandon Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date / / Time :

Make _____ Size/Type _____ Multiplier _____
Notes Brandon thinks there might be leak here. slightly pink when tested. BUD call made

Inventory Item And Description	Quantity Ordered	Quantity Used

LTC Bud 1612141099
ELWD
M. d Valley Pipeline

Signature B.G.

WEST LEBANON TREATMENT DISTRICT
WORK ORDER 11567

Account # _____ Order Date 4/4/2017
 Name NOE, LARRY E Status MEDIUM
 Address _____ Scheduled 04/04/17 01:33 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 48431547 09726859 7107 B14167264
 Description _____
 Comment LF/BRK HSE/LF/YD
 Requested By Larry Assigned To MAINTENANCE CREW Completed By _____
 Start Date 04/02/17 Time 0:21 Completed Date 04/02/17 Time 10:30

Make _____ Size/Type _____ Multiplier _____
 Notes Meter box full of water, please check for leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Cell - 846-5918

He thinks we have a leak - Meter not turning - but full of water - + rainwater has never caused this problem.

Bud # 1704091017

ATT, LTC, Reville Sewer

our leak
 - need Bud called
 X @ Nature Dr
 marked in blue
 both sides

B.G

Signature

East Logan Water District
WORK ORDER 11314

Account #
Name COLLINS, HAROLD W
Address
Telephone Job #

Order Date 1/10/2017
Status MEDIUM
Scheduled 01/10/17 08:57 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81004645	74516481	92	B14168160	97

Description
Comment LF,WH HSE,LF YD

Requested By Jerry Taylor Assigned To MAINTENANCE CREW Completed By
Start Date 1/10/17 Time 9:00 AM Completed Date 1/10/17 Time 9:00 AM

Make _____ Size/Type _____ Multiplier _____
Notes Intermittent pressure problems

Inventory Item And Description	Quantity Ordered	Quantity Used

No indication of a leak

Signature 

East Logan Water District
WORK ORDER 11529

Account # _____ Order Date 3/29/2017
 Name SHIFFLETT, FOUNTAIN W Status MEDIUM
 Address _____ Scheduled 03/29/17 08:08 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361549	63066161	4541	B14167816	

Description _____
 Comment LF, A FRAME HSE, 15' LF DR
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time _____ Completed Date 3/29/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

← Mud River Valley
 X by 03/31
 Replaced to Main...
 Bin # 170329 0346
 AT7, LTC

WORK ORDER 11483

Account # _____ Order Date 3/7/2017
 Name APPLING, PHILIP E Status MEDIUM
 Address _____ Scheduled 03/07/17 03:18 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979863	63097825	2034	B14167608	

Description _____
 Comment RT, YELLOW HS M/YD
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time _____ Completed Date 3/29/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Chandlers Rd
 Bud # 1103071230
 LTC, WRECC

Replaced to Main

R.G.

Signature

East Logan Water District
WORK ORDER 11536

Account #
Name LAMBRIGHT, JOHN A
Address
Telephone

Order Date 4/3/2017
Status MEDIUM
Scheduled 04/03/17 10:07 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056544	10091661	3879	B14165750	

Description:
Comment LF GRAY HS L/CNR T/LF GO TO 26
Requested By Brandon Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 04/03/17 10 08 AM Completed Date 04/03/17 10 08 AM

Notes Fixed on 04/03/17 BG 4K lost



Signature

East Logan Water District
WORK ORDER 11469

Account # _____
 Name LAMAR, NICKIEA M
 Address _____
 Telephone _____
 Order Date 3/1/2017
 Status MEDIUM
 Scheduled 03/01/17 03:53 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418170	10104849	6593	B14167730	

Description _____
 Comment LF,WH/HSE,RT/DR
 Requested By Brandon Assigned To MAINTENANCE CREW Completed By _____
 Start Date 3/1/2017 Time _____ Completed Date 3/1/2017 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Proctor Mill

1703061315
LTC, ATT

Signature BG

WORK ORDER 11498

Account # _____ Order Date 3/14/2017
 Name CART, JESSICA N Status MEDIUM
 Address _____ Scheduled 03/14/17 03:06 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 35804825 63238008 4011 B14170083 4/11
 Description _____
 Comment RT, WH HSE RT CNR
 Requested By New customer Assigned To MAINTENANCE CREW Completed By _____
 Start Date 3/14/17 Time _____ Completed Date 3/14/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Please check for leak around this address

Inventory Item And Description	Quantity Ordered	Quantity Used

~~PROPOSED WORK~~

X by 3/14/17

Dad called on 3/14/17

ATT, WRECC

Tic

Signature _____

East Logan Water District
WORK ORDER 11467

Account # _____
 Name BANKS, JESSE & BARBARA
 Address _____
 Telephone _____ Job # _____
 Order Date 3/1/2017
 Status MEDIUM
 Scheduled 03/01/17 03:52 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979877	09964029	3354	B14165334	

Description _____
 Comment RT TAN HSE 100' LF DR
 Requested By Brandon Assigned To MAINTENANCE CREW Completed By _____
 Start Date 03/23/17 Time _____ Completed Date 03/23/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Sycamore Duncan

1703061311
LTC, WRECC

Signature BC

East Logan Water District
WORK ORDER 11517

Account # _____
 Name STRICKLIN, JANET L
 Address _____
 Telephone _____ Job # _____
 Order Date 3/21/2017
 Status MEDIUM
 Scheduled 03/21/17 04 04 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473797	07229653	9809	B14172253	

Description _____
 Comment LF,TRLR OFF RD,ACROSS/2634 CEM
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date 03/23/17 Time _____ Completed Date 03/23/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Van Hooten X by 03/23/17
 Bud # 1703211557
 LTC, WRECC

Signature B G

East Logan Water District
WORK ORDER 11466

Account # _____ Order Date 3/1/2017
 Name HAYES CHRISTOPHER R Status MEDIUM
 Address _____ Scheduled 03/01/17 03 38 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361471	63066083	2289	B14167238	

Description _____
 Comment RT,WH/HSE R/DR
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date 3/1/17 Time _____ Completed Date 3/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 3/3

Bud # 1703011306

LTC, WRECC

Fixed

Replaced line to main.

Signature 

East Logan Water District
WORK ORDER 11490

Account # _____ Order Date 3/9/2017
 Name THOMPSON, ERNEST Status MEDIUM
 Address _____ Scheduled 03/09/17 12:53 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 68553084 62326771 584 B14170181
 Description _____
 Comment LF, BARN, LF CNR
 Requested By Mrs. Thompson Assigned To MAINTENANCE CREW Completed By _____
 Start Date 3/9/17 Time _____ Completed Date 3/9/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes She says we fixed leak on our side not long ago area has never dried up See if there is a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

She may have more than one meter —
 She said at the house.

Checked meter at the house where the leak was.
 Sounded the meter & didn't hear a thing. There
 is water about 10ft from box but its rain water
 standing in ruts Tested & didn't show chlorine.
 It has rained alot over the past few months.

(0.2)
 i



Signature



East Logan Water District
WORK ORDER 11472

Account # _____ Name DENNEY STUART A Order Date 3/2/2017
Address _____ Status MEDIUM
Telephone _____ Job # _____ Scheduled 03/02/17 03:48 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170317	72175795	702	B14167308	761

Description _____
Comment RT, TRLR OFF RD. 30' LF DR
Requested By Mr. Denny Assigned To MAINTENANCE CREW Completed By _____
Start Date 3/2/17 Time _____ Completed Date 3/15/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted meter bottom, meter was turning with busted bottom
But when fixed meter kept turning.
Has low Pressure.

Signature 

East Logan Water District
WORK ORDER 11456

Account # _____ Name WHITE, LONNIE Address _____ Telephone _____ Job # _____

Order Date 2/27/2017 Status MEDIUM Scheduled 02/27/17 11:15 AM Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 37668904 ERT/INTERNAL ID# 09443850 READING 8853 LOCATOR TAG B14169853 READING IN / OUT _____

Description _____ Comment LF, OLD HSE, RT YD 3RD

Requested By Linda Assigned To MAINTENANCE CREW Completed By _____

Start Date ____/____/____ Time ____ Completed Date 2/27/17 Time ____

Make _____ Size/Type _____ Multiplier _____

Notes Mrs. White says it is wet around meters located there. Please see if we have a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Checked Meter and tested water, OK no leak

Signature B.G.

East Logan Water District
WORK ORDER 11348

Account # _____
 Name CORNETT, CAROLYN
 Address _____
 Telephone _____ Job # _____
 Order Date 1/25/2017
 Status MEDIUM
 Scheduled 01/25/17 08:32 AM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 19338549 ERT/INTERNAL ID# 08617059 READING 9141 LOCATOR TAG B14167457 READING IN / OUT _____

Description
 Comment RT, WH/HSE, 25 FT LT/DR UNDER
 Requested By Steven Taylor Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date 1/25/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Patched Leak on service tube...

B. G.

Signature

East Logan Water District
WORK ORDER 11431

Account # _____ Order Date 2/17/2017
Name HART PHILLIP C Status MEDIUM
Address _____ Scheduled 02/17/17 12:45 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 46202628 ERT/INTERNAL ID# 61287446 READING 2738 LOCATOR TAG B14167271 READING IN / OUT _____

Description _____
Comment RT TAN HSE, MDDL YD
Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____ Completed Date ____/____/____ Time ____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 02/22

Bad # 1702171006

ATT, LTC, WRECC
Clear

Signature _____

East Logan Water District
WORK ORDER 11413

Account #
Name MURPHY, TERESA I
Address
Telephone Job #

Order Date 2/13/2017
Status MEDIUM
Scheduled 02/13/17 02:11 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361415	64887910	1584	B14172456	

Description
Comment LF BRK R/CNR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 2/17/17 Time _____ Completed Date 2/17/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Replaced meter to be replaced

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 2/15/17

Bud# 1702131373

Atmos, LTC, Texas Gas, Wrecc

Signature BG

East Logan Water District
WORK ORDER 11958

Account # _____ Order Date 8/11/2017
Name HAMPTON, RICKEY L Status LOW
Address _____ Scheduled 08/11/17 10:36 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82460025	75071641	292	B14892793	38

Description _____
Comment LF,HSE IN FLD,LF BEFORE 68
Requested By Ricky Assigned To MAINTENANCE CREW Completed By _____
Start Date 8/11/17 Time _____ Completed Date 8/11/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Barely dripping around check valve / regulator. According to customer

Inventory Item And Description	Quantity Ordered	Quantity Used

270-999-6264 Rickey Hampton
Did not see a drip from check valve or reg.

East Logan Water District
WORK ORDER 11961

Account # _____ Order Date 8/11/2017
 Name ORDER WORK Status MEDIUM
 Address _____ Scheduled 08/11/17 02:19 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT No Num _____
 Description INTERSECTION OF 79 & A COLLINS
 Comment _____
 Requested By PAGE BARKER Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time _____ Completed Date 8/11/17 Time _____
 Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

1708111.302

LTC

Fixed

TM

Signature

WORK ORDER 11973

Account #
Name HART, KATHY & MIKE
Address
Telephone Job #

Order Date 8/21/2017
Status MEDIUM
Scheduled 08/21/17 09 30 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979859	08885795	865	B14168057	

Description
Comment RT BRK ON HILL 2 MTRS M/YD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____ Completed Date 8/21/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer Leak!

Signature Tm

WORK ORDER 11903

Account # _____ Order Date 7/26/2017
 Name HURT, JAMES D Status MEDIUM
 Address _____ Scheduled 07/26/17 08:50 AM
 Telephone _____ Job # _____ Order Type CHECK METER

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 51780799 72752294 302 B14167546 0.318

Description WATER STILL COMING THROUGH THE METER, WHEN METER IS CUT OFF
 Comment RT, TRLR/OFF RD RT/DR
 Requested By JIM Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/1/17 Time _____ Completed Date 8/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced cut off		

Jeff Allen

Lead Tech

[Handwritten Signature]

Signature

East Logan Water District
WORK ORDER 11916

Account #
Name EATON, TIFFANY M
Address
Telephone Job #

Order Date 7/31/2017
Status MEDIUM
Scheduled 07/31/17 12 20 PM
Order Type CHECK FOR LEAK ON OUR SIDE


METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 09476814 5178 B14169525


Description
Comment LF, WH HSE, 15' LF DR, 3 METER

Requested By TIFFANY EATON Assigned To MAINTENANCE CREW Completed By
Start Date 7/31/17 Time Completed Date 7/31/17 Time

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced 6 ft service line		



Signature 

East Logan Water District
WORK ORDER 11877

Account # _____ Order Date 7/14/2017
Name HERMON, NANCY Status MEDIUM
Address _____ Scheduled 07/14/17 08:03 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 39119188	61287405	2244	B15277256	

Description Very low pressure
Comment LF HSE OFF RD M/FIELD 2nd METE

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 07/14/17 Time _____ Completed Date 07/14/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes on h/m

Inventory Item And Description	Quantity Ordered	Quantity Used

212-843-8133

Signature B6

WORK ORDER 11655

Account # _____ Order Date 7/6/2017
 Name LEACH, DAVID Status MEDIUM
 Address _____ Scheduled 07/06/17 10:57 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170355	09441660	8692	B14167803	

Description
 Comment RT, HSE OFF RD, LF GR DR, O/FE

Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
 Start Date 07/06/17 Time _____ Completed Date 07/06/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Mr. Leach has fixed his leak says we have a very small leak on our side Might be too muddy right now, but told him we would check soon

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature BG

East Logan Water District
WORK ORDER 11753

Account # _____ Order Date 6/26/2017
Name WATKINS, NELSON Status MEDIUM
Address _____ Scheduled 06/26/17 08:15 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50180738	10619399	9019	B14166794	

Description
Comment RT GRAY TRLR MID YD O/FENCE
Requested By Nelson Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time _____ Completed Date 6/26/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Said water coming out of meter box

Inventory Item And Description	Quantity Ordered	Quantity Used

Replaced old paper gaskets, customer fixed his leak...

Signature B.G.

WORK ORDER 11772

Account #
Name LEACH, DAVID
Address
Telephone

Order Date 6/30/2017
Status MEDIUM
Scheduled 06/30/17 08 07 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170355	09441660	8658	B14167803	

Description

Comment RT, HSE OFF RD, LF GR DR. O/FE

Requested By Mr Leach

Assigned To MAINTENANCE CREW

Completed By

Start Date / / Time :

Completed Date 6/30/17 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Checked Meter, leak on customer, talked with Mr. Leach...

Signature B.G.

WORK ORDER 11709

Account # _____ Name COLLINS, HENRY TP Address _____ Telephone _____ Job # _____ Order Date 6/6/2017 Status MEDIUM Scheduled 06/06/17 03:53 PM Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979810	10066028	5820	B14168823	

Description _____
 Comment LF BR/HS ACROSS FROM LAST MTR
 Requested By Chip Collins Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____:____ Completed Date ____/____/____ Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
 Notes Acct is inactive and should be locked. Get reading, and see if there is a leak around there.

Inventory Item And Description	Quantity Ordered	Quantity Used
Chip Collins - 893-8418		

Not a leak

Signature TM

East Logan Water District
WORK ORDER 11731

Account Name HENDRICKS, WILLIAM B
Address
Telephone Job #
Order Date 6/19/2017
Status MEDIUM
Scheduled 06/19/17 08:15 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 56120968	71205583	2643	B14166793	

Description
Comment RT, BRK HSE, 25' LF DR
Requested By Bill Hendricks Assigned To MAINTENANCE CREW Completed By
Start Date 6/19/17 Time 8:15 AM Completed Date 6/21/17 Time 1:00 PM

Make _____ Size/Type _____ Multiplier _____
Notes Called Sunday... water standing ... said CK has fixed 5 leaks there in 5 years.
Revised 6/21/17

Inventory Item And Description	Quantity Ordered	Quantity Used

X High leak
or
Midway Dr
Marked by June 21 - 9:00 AM
ATT
LTC
LTC RWC
R. Williams Sewer
706190421

Signature B.E.

East Logan Water District
WORK ORDER 11726

Account # _____ Order Date 6/14/2017
 Name BRAY, TIM Status MEDIUM
 Address _____ Scheduled 06/14/17 04 12 PM
 Telephone _____ Job# _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 33123408 09141087 5393 B14166010
 Description _____
 Comment RT,GRAY/HSE M/YD
 Requested By BG Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____ Completed Date 6/12/17 Time ____

Make _____ Size/Type _____ Multiplier _____

Notes
new 1/2" dia pipe replaced

Inventory Item And Description	Quantity Ordered	Quantity Used

X buy 06.14.17

x Fred Stratton

Bud# 1706141587

LTC

Signature *BG*

WORK ORDER 11693

Account #
Name GOODALL -- TP COLUMBUS F
Address
Telephone Job #

Order Date 5/31/2017
Status MEDIUM
Scheduled 05/31/17 08:32 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69361411
ERT/INTERNAL ID# 63066023
READING 4909
LOCATOR TAG B14167686
READING IN / OUT

Description
Comment EOL ON LFT BY M M T/A T/R

Requested By BG Assigned To MAINTENANCE CREW Completed By

Start Date 5/31/17 Time 8:32 AM Completed Date 6/15/17 Time

Make Size/Type Multiplier

Notes

NEED LINE REPLACED

Inventory Item And Description	Quantity Ordered	Quantity Used

X Bahaat Red (right by Bahaat Co. line)

X by 06.09.17

Bud# 1706071034

ATT

Signature *BG*

East Logan Water District
WORK ORDER 11692

Account # _____ Order Date 5/31/2017
Name HUDNALL MARTY Status MEDIUM
Address _____ Scheduled 05/31/17 08:31 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 69361398 63066010 5671 B14167162

Description _____
Comment LF GRAY TRLR R/DR

Requested By BG Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____:____ Completed Date 5/31/17 Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Eldon Belcher

Bua# 1706071027

X by 06.09.17

LTC, WRECC

Signature BG

WORK ORDER 11746

Account # _____ Order Date 6/21/2017
 Name HERMON, NANCY Status MEDIUM
 Address _____ Scheduled 06/21/17 04:10 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 39119188 61287405 2083 B15277256 2241

Description _____
 Comment LF HSE OFF RD M/FIELD 2nd METE

Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
 Start Date 6/22/17 Time _____ Completed Date 6/22/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer has leak

15,800 or less

Signature IM

WORK ORDER 11688

Account # _____
 Name DUNCAN KEVIN L
 Address _____
 Telephone _____ Job # _____
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 65798112 58647030 8558 B14167378
 Description _____
 Comment _____
 Requested By BG Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date 6/19/17 Time ___:___
 Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Fixed

*X Sycamore Duncan
ER London*

X by 06.09.17

Bird # 1706071020

LTC, WRCC

Signature B.G.

WATER DISTRICT
WORK ORDER 11683

Account # _____ Order Date 5/30/2017
 Name BILYEU, DAKODA C Status MEDIUM
 Address _____ Scheduled 05/30/17 11:51 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 60599719	39215143	8586	B14168926	

Description 20' before meter has been wet for at least 2 weeks

Comment RT, BRK HSE, RT DR

Requested By Dakota Bilyeu Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

^ Hwy 100
 noted 5/30/17 @ 3:30 pm
 by

17705301493
 ATT
 ATMS
 LTC

Signature _____

East Logan Water District
WORK ORDER 11710

Account # _____ Order Date 6/7/2017
Name ANDERSON, MICHAEL S Status MEDIUM
Address _____ Scheduled 06/07/17 10:57 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 39340880	09877624	1524	B14167420	

Description _____
Comment RT. TAN HSE. LF DR
Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____ Completed Date 6/7/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____

Notes Meter is turning leak between meter and house. Please make sure its not in the box on our side.

Inventory Item And Description	Quantity Ordered	Quantity Used

*Replace cover of front door meter
with appropriate...*

Signature _____

EAST LOGAN WATER DISTRICT
WORK ORDER 11690

Account # _____ Order Date 5/31/2017
 Name GREGORY, LISA Status MEDIUM
 Address _____ Scheduled 05/31/17 08:28 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605877	09528452	9178	B14167085	

Description
 Comment LF TRLR 25' L/DR
 Requested By BG Assigned To MAINTENANCE CREW Completed By _____
 Start Date 5/1/17 Time 6:30 Completed Date 6/1/17 Time 6:45

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 06/02

X Morgantown
 Bud # 1705310493

LTC, WRECC

East Logan Water District
WORK ORDER 11689

Account # _____ Order Date 5/31/2017
Name HOLLOWAY, MATT Status MEDIUM
Address _____ Scheduled 05/31/17 08:27 AM
Telephone: _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 37330401	10467071	9279	B14165425	

Description _____
Comment LF L/LONG GR DR
Requested By BG Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date 6/2/17 11:27 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 06/02/17

Bud # 1705310496 X Morgantown Rd

LTC, WRECC

Signature BG

East Logan Water District
WORK ORDER 11682

Account # _____ Order Date 5/29/2017
 Name MCLEAN, RHONDA L Status MEDIUM
 Address _____ Scheduled 05/29/17 11:24 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473696	71205603	2676	B14168602	

Description _____
 Comment LT, BRK, LT DR
 Requested By Josh Montgomery Assigned To MAINTENANCE CREW Completed By _____
 Start Date 5/1/17 Time _____ Completed Date _____ Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Josh reported possible leak at this address

Inventory Item And Description	Quantity Ordered	Quantity Used

Fixed 5-29-17

Signature BC

East Logan Water District
WORK ORDER 11680

Account # _____ Order Date 5/26/2017
 Name NISSLEY, AMOS Status MEDIUM
 Address _____ Scheduled 05/26/17 02:02 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 28577168 39220350 3810 B14168749

Description
 Comment RT, METAL BLD, ACROSS/L YD 10'
 Requested By MR NISSLEY Assigned To MAINTENANCE CREW Completed By _____
 Start Date 5/13/17 Time _____ Completed Date 5/13/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Goodman

X by - 05/31/17

Bid # 170526 1271

LTC

Signature BC

WORK ORDER 11681

Account #
Name EATON, TIFFANY M
Address
Telephone

Order Date 5/29/2017
Status MEDIUM
Scheduled 05/29/17 11:22 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT	09476814	5056	B14169525	

Description
Comment LF, WH HSE, 15' LF DR, 3 METER

Requested By Tiffany Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date 5/30/17 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes Says it is wet/muddy around box. Also, says lid is busted in. Please get the meter number for this address.

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature BC

East Logan Water District
WORK ORDER 11583

Account # _____ Order Date 4/13/2017
 Name NORRIS, SANDY J Status MEDIUM
 Address _____ Scheduled 04/13/17 01:30 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 36982641	61287339	2310	B14167920	

Description _____
 Comment LF,WH/HSE/LCNR
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

On them

X by 4/18

Built # 1704131437

LTC

5-11-17

B.G.

Signature

East Logan Water District
WORK ORDER 11597

Account #
Name MARTIN, ROGER
Address
Telephone Job #

Order Date 4/18/2017
Status MEDIUM
Scheduled 04/18/17 11:06 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473740	63184016	3223	B14166790	

Description
Comment RT STONE FRONT LFT OF DR

Requested By TYLER Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

x Downey RL

ON CUSTOMER...

Bill # 1704181113
ATTN: LITA WRELL

Signature B.G.

EAST LOGAN WATER DISTRICT
WORK ORDER 11671

Account #
Name THOMASON, LORI L
Address
Telephone Job #

Order Date 5/24/2017
Status MEDIUM
Scheduled 05/24/17 08 07 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69361467 ERT/INTERNAL ID# 63066079 READING 4853 LOCATOR TAG B14167233 READING IN / OUT

Description
Comment LF, TAN HSE LF YD

Requested By Tyler Assigned To MAINTENANCE CREW Completed By
Start Date 5/24/17 Time Completed Date 5/24/17 Time

Make Size/Type Multiplier
Notes There was a leak fixed in Dec 2014 by C.R. & K...
Small leak on the m...

Inventory Item And Description	Quantity Ordered	Quantity Used

X Morgantown Rd

X by 05/26/17

Bud # 1705240951

LTC

BG

Signature

WORK ORDER 11664

Account #
Name BAGWELL VICKI S
Address
Telephone Job #

Order Date 5/19/2017
Status MEDIUM
Scheduled 05/19/17 03 02 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 54230316
ERT/INTERNAL ID# 09873937
READING 6499
LOCATOR TAG B14169904
READING IN / OUT

Description
Comment LT, WH/HS. R/DR

Requested By Linda Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___:___ Completed Date 06/16/17 Time ___:___:___

Make _____ Size/Type _____ Multiplier _____

Notes Customer has leak please make sure not on us and see if you can tell if it is leaking close to meter

Replaced tubing

Inventory Item And Description	Quantity Ordered	Quantity Used

X by 5/25/17

X Sandy gap

Brid# 1705231638

LTC, WRECC

Signature *BG*

East Logan Water District
WORK ORDER 11653

Account # _____ Order Date 5/17/2017
Name BEACHY, JAMES E Status MEDIUM
Address _____ Scheduled 05/17/17 08:53 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 41110201	08885378	226	B14169489	

Description _____
Comment LF, OLD HSE. RT YD. 2ND
Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
Start Date 5/17/17 Time 10:48 Completed Date 5/17/17 Time 10:48

Make _____ Size/Type _____ Multiplier _____
Notes Phone call said ground stays wet around the meter. Please check this. They had a leak.

Inventory Item And Description	Quantity Ordered	Quantity Used

by 5-19-17 Friday
240 + 254 around
Marked in blue (flag)
X 6880 -
ATT -- marked P.A. 5-17-17
LTC
LTKWU
TX Coal - clear
WRELL - clear
1705171409

Signature 136

East Logan Water District
WORK ORDER 11575

Account #
Name BURGETT, SHELBY L
Address
Telephone Job #

Order Date 4/10/2017
Status MEDIUM
Scheduled 04/10/17 08:20 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45335742	09105223	4934	B14167696	

Description
Comment LT, BRK, MYD, READ 2

Requested By Shelby Assigned To MAINTENANCE CREW Completed By
Start Date / / Time Completed Date 4/10/17 Time

Make Size/Type Multiplier
Notes

Inventory Item And Description	Quantity Ordered	Quantity Used

Clampon leak, good to go... needs to be Replaced

Signature B.G.

WORK ORDER 11601

Account # _____ Order Date 4/19/2017
 Name PLAINVIEW GENERAL BAPTIST Status MEDIUM
 Address _____ Scheduled 04/19/17 02:14 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 45221852 08794630 60 B14172340 _____
 Description _____
 Comment RT, BRK M/YARD, BY CHURCH
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____:____ Completed Date 4/19/17 Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Replaced damaged part of CTS...

X Boston Rd

X by 04/21/17



Bud# 1704191495

LTC, WRECC

Signature B.G.

WATER DISTRICT
WORK ORDER 11598

Account # _____
Name SWEATT, FRED TP
Address _____
Telephone _____

Order Date 4/18/2017
Status MEDIUM
Scheduled 04/18/17 11 43 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 47975088 ERT/INTERNAL ID# 63637265 READING 671 LOCATOR TAG B14167533 READING IN / OUT (7)

Description
Comment RT WH/TRLR L/DR

Requested By THOMAS DUFFEY Assigned To MAINTENANCE CREW Completed By _____

Start Date ____/____/____ Time ____:____:____ Completed Date ____/____/____ Time ____:____:____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Druid # 704181084 x by 4/20

LTC

Just by the way

Killed at curb stop need to check next week to make sure not a possible second leak.

Signature *B.G.*

East Logan Water District
WORK ORDER 11622

Account # _____ Order Date 5/2/2017
 Name SULLIVAN, CAROLYN Status MEDIUM
 Address _____ Scheduled 05/02/17 12:57 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 48979796 09755875 8038 B14167426 3047
 Description _____
 Comment RT, BRK HSE, MDDL YD
 Requested By Carolyn Sullivan Assigned To MAINTENANCE CREW Completed By _____
 Start Date 5/1/17 Time _____ Completed Date 5/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

no leak, their cut off was full of mud & rain water.

Signature FM

ORDER NUMBER 11020

Account #		Order Date	5/4/2017
Name	HOUCHENS, LOYD	Status	MEDIUM
Address		Scheduled	05/04/17 12:13 PM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473810	07365067	9593	B14169743	

Description

Comment LF, BRK HSE, LF IN FIELD O/FEN

Requested By MR LOYD Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

BUD - 1705040711
 LTC - requested they mark Thur.
 Repair line on 5-5-17

our leak
 repaired 5-5-17

Signature bc + TM

East Logan Water District
WORK ORDER 11594

Account #
Name KEMP, RUSSELL S
Address
Telephone Job #

Order Date 4/18/2017
Status MEDIUM
Scheduled 04/18/17 10:17 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 42088278 ERT/INTERNAL ID# 09727127 READING 107 LOCATOR TAG B14166968 READING IN / OUT

Description
Comment RT, BRK HSE. 15' LF OF LF CNR

Requested by TYLER Assigned to MAINTENANCE CREW Completed By
Start Date 04/12/17 Time Completed Date 04/12/17 Time

Make Size/Type Multiplier
Notes REPLACEMENT SERVICE TUBES MADE'S DIRECTWORK

Inventory Item And Description	Quantity Ordered	Quantity Used

X Franklin Rd

Bud # 1704181094
ATT, LTC, Riville Sewer

Signature BG

WORK ORDER 12163

Account # _____ Order Date 10/18/2017
 Name BANTON, LAURA E Status MEDIUM
 Address _____ Scheduled 10/18/17 04:13 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 30318299	39220373	5342	B14167456	

Description _____
 Comment LF, TAN HSE, LF YD @ G. VALVE
 Requested By Ryan Fynboe Assigned To MAINTENANCE CREW Completed By _____
 Start Date 10/18/17 Time _____ Completed Date 10/18/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes While mowing, sank into area at side yard. Check for leak
 Ryan - 270-847-6700 called the leak in

3 GPM

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature AC/TM/OB

WORK ORDER 12167

Account #	---	Order Date	10/19/2017		
Name	SAVAGE, SANDI	Status	MEDIUM		
Address		Scheduled	10/20/17 09:54 AM		
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE		
METER#	ERT/INTERNAL ID#	READING	LOCATION TAG	READING IN / OUT	
WT 69361491	63066103	2085	B14820652		
Description	LF,WH/HSE R/CNR-LIGHT POLE				
Comment	LF,WH/HSE R/CNR-LIGHT POLE				
Requested By	Danny Haley	Assigned To	MAINTENANCE CREW	Completed By	MAINTENANCE CREW
Start Date	10/20/17 09:56 AM	Completed Date			10/20/17 09:56 AM

Notes: There is a leak here. Andy is exposing the corp and turning it off as this acct has been inactive for 3 years.

3 GPM

BWA 1710190581

LTC | WRELL

Signature _____

East Logan Water District
WORK ORDER 12211

Account #
Name WAGONER, JAMES
Address
Telephone Job #
METER# ERT/INTERNAL ID#
WT 20322382 59536119

Order Date 10/31/2017
Status MEDIUM
Scheduled 10/31/17 04:01 PM
Order Type CHECK FOR LEAK ON OUR SIDE
READING LOCATOR TAG READING IN / OUT
5195 B14167861

Description
Comment RT TAN D-WIDE, M/YD

Requested By Marci Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes 9092

Inventory Item And Description	Quantity Ordered	Quantity Used

*Done
spoke w/ customer*

LA, DB

Signature

West Logan Water District
WORK ORDER 12207

Account # _____ Order Date 10/30/2017
Name SHERMAN, CRAIG & THERESA Status MEDIUM
Address _____ Scheduled 10/30/17 02:29 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 44043836	09839018	2745	B14169112	

Description _____
Comment LF, WH DBL WIDE, RT CNR
Requested By Theresa Sherman Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date 10/30/17 Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes She said water was coming out of the white thing in her yard Please see if either of us has a leak
Handwritten note: LEAK ON CUST. SIDE. SPENT WATER? OF SO HOMEOWNER CAN REPAIR

Inventory Item And Description	Quantity Ordered	Quantity Used

Accepted to Daniel

Signature _____

East Logan Water District
WORK ORDER 12200

Account # _____ Order Date 10/30/2017
 Name ELAMON, RUTH ANN & DANNY Status MEDIUM
 Address _____ Scheduled 10/30/17 08:05 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170333	61750522	8927	B14168637	9021

Description _____
 Comment _____
 Requested By Ruth Ann Elamon Assigned To MAINTENANCE CREW Completed By DB
 Start Date 10/1/17 Time 8:57 Completed Date 10/13/17 Time 8:57

Make _____ Size/Type _____ Multiplier _____

Notes She says its still leaking around box even with meter turned off.

No LEAK ON OUR SIDE

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 12169

Account # _____ Order Date 10/20/2017
 Name ORDER, WORK Status MEDIUM
 Address _____ Scheduled 10/20/17 03:15 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT No Num _____
 Description 2086 Sycamore Rd
 Comment _____
 Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____
 Start Date 10/24/17 Time _____ Completed Date 10/24/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes BUD# 1710200549
 LTC, WRECC
New tubing from main to meter

Inventory Item And Description	Quantity Ordered	Quantity Used

Fixed
3 gal per min

Signature A. C. T.

EAST LOGAN WATER DISTRICT
WORK ORDER 12159

Account # _____
 Name CROPPER, CHARLES
 Address _____
 Telephone _____
 Meter# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 66684152 59596240 7054 B14167057
 Description WATER STANDING IN DITCH AT CORNER OF PROPERTY
 Comment LT, BRK, FAR LT/YD
 Requested By CATHY CROPPER Assigned To MAINTENANCE CREW Completed By _____
 Start Date 10/17/17 Time _____ Completed Date 10/17/17 Time _____
 Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Oct 19th
12 30
Ex - November 7th Bud # - 17710170919

10-24-17 Fixed 5-gal per min
Att - Cleared

Signature ACT

WORK ORDER 12060

Account # _____ Order Date 9/18/2017
 Name LEACH, DAVID Status MEDIUM
 Address _____ Scheduled 09/18/17 09:54 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 48979843 61287447 4925 B14167709 _____
 Description _____
 Comment RT, WH/HSE, LF/DR
 Requested By David Leach Assigned To MAINTENANCE CREW Completed By _____
 Start Date 9/18/17 Time _____ Completed Date 1/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Water running in ditch he thinks we have a leak

BND # 1710161469

Inventory Item And Description	Quantity Ordered	Quantity Used
FRONT OF PROP BOTH SIDES OF Rd.		
LTC		

10-24-17
Fixed

4 Gal Per Min

Signature A. C. T.

East Logan Water District
WORK ORDER 12170

Account # _____
 Name ORDER, WORK
 Address _____
 Telephone _____ Job # _____
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____

Order Date 10/20/2017
 Status MEDIUM
 Scheduled 10/20/17 03:16 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

WT No Num _____
 Description Homer / 79, main line

Comment _____
 Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____
 Start Date 10/19/17 Time _____ Completed Date 10/19/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes BUD# 1710200554
 ATT, LTC

do not find anything

Inventory Item And Description	Quantity Ordered	Quantity Used

EAST LOGAN WATER DISTRICT
WORK ORDER 12103

Account # _____ Order Date 10/3/2017
Name BYRNS, STEPHANIE I Status MEDIUM
Address _____ Scheduled 10/03/17 01 32 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 51780801 09592301 391 B14652825

Description _____

Comment RT BRK M/YD

Requested By TYLER Assigned To MAINTENANCE CREW Completed By _____

Start Date 10/3/17 Time _____ Completed Date 10/3/17 Time _____

Make _____ Size/Type _____ Multiplier _____


Notes SERVICE LING LEAK SHORT SIDE

BUD# 1710161478

Inventory Item And Description	Quantity Ordered	Quantity Used
FRONT OF PROP.		
LTC		
WRECC		

X Road -
Chandlers Rd / Dogwood

Fixed

Signature 

East Logan Water District
WORK ORDER 12080

Account #
Name MILLER, JOSEPH G
Address
Telephone Job #

Order Date 9/26/2017
Status MEDIUM
Scheduled 09/26/17 11:45 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 68553075 ERT/INTERNAL ID# 62326762 READING 1125 LOCATOR TAG B14172360 READING IN / OUT

Description

Comment RT OF REEVES RD, LF CNR OF TRA

Requested By Joseph Miller Assigned To MAINTENANCE CREW Completed By

Start Date 9/21/17 Time Completed Date 9/23/17 Time 11:30

Make Size/Type Multiplier

Notes Check for leak across the road from this meter is water

1709241233

Inventory Item And Description	Quantity Ordered	Quantity Used
2 - 3/4 Brass fittings 1 - 3/4 PVC fittings		

Signature A. C.

WORK ORDER 11971

Account # _____ Order Date 8/18/2017
 Name GREATER LIFE APOSTOLIC CHURCH Status MEDIUM
 Address _____ Scheduled 08/18/17 09:16 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 67163189 60838650 751 B14168760

Description _____
 Comment _____
 Requested By GENE BUSH Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/18/17 Time _____ Completed Date 8/18/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Fixed 8-18-17

Bad #1 1708180485

LTC, Texas Gas, WRECC

13 gpm ?

2" Sp. 3/4" ETS
 2.4 hrs

Signature

East Logan Water District
WORK ORDER 12073

Account # _____ Order Date 9/25/2017
Name MAJORS -- TP, FLOSSIE Status MEDIUM
Address _____ Scheduled 09/25/17 07:58 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 32789103 10378841 5053 B14167565

Description
Comment RT,WH/HSE LF/DR

Requested By Flossie Majors Assigned To MAINTENANCE CREW Completed By _____
Start Date 9/25/17 Time _____ Completed Date 9/25/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes *REplaced 4" Turb (NG) from 1/2" to 1/4" test
Small leak on gate side = Very small HO USE*

LEAK @ METER BOX ON SL. REPLACE SERVIC LNG 1709271387

Inventory Item And Description	Quantity Ordered	Quantity Used

4 gal per minute

Signature A. C. Flossie E4

East Logan Water District
WORK ORDER 12099

Account #
Name GREGORY, REBECCA
Address
Telephone Job #

Order Date 10/2/2017
Status MEDIUM
Scheduled 10/02/17 12:23 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 47418187 ERT/INTERNAL ID# 09318186 READING 8699 LOCATOR TAG B14167513 READING IN / OUT

Description
Comment LF TAN D-WIDE R/DR

Requested By Tyler Assigned To MAINTENANCE CREW Completed By
Start Date 10/3/17 Time Completed Date 10/3/17 Time

Make Size/Type Multiplier
Notes BUD - 1710021436 Emergency locate for Tuesday a.m.

LTC
WRECC
X Sycamore

Fixed

Replaced Tubing under the Road 75' of tubing

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *A.G.* *Deen*

WORK ORDER 12094

Account #
Name POWELL, BOBBY
Address
Telephone Job #

Order Date 9/29/2017
Status MEDIUM
Scheduled 09/29/17 10.46 AM
Order Type CHECK METER

METER# WT 81004708 ERT/INTERNAL ID# 74516544 READING 58 LOCATOR TAG B15415577 READING IN / OUT

Description DRIPPING AT REGULATOR

Comment R of drive, R of LTC pedestal

Requested By Andy Assigned To MAINTENANCE CREW Completed By

Start Date 9/29/17 Time : Completed Date 9/29/17 Time :

Make _____ Size/Type _____ Multiplier _____
Notes Tightened WP Regulator

Inventory Item And Description	Quantity Ordered	Quantity Used

2

Signature A.C.

EAST LOGAN WATER DISTRICT
WORK ORDER 12078

Account # _____ Order Date 9/25/2017
Name SWORDS, VERNON Status MEDIUM
Address _____ Scheduled 09/25/17 12:29 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271633	74600705	604	B14969515	

Description _____
Comment LFT WHITE TRLR MID YD
Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____:____ Completed Date 09/25/17 Time ____:____:____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

X Friendship
Emergency locate
Bud# 1709251235
Atmos, LTC, WRECC FIXED

Signature AC Tm

WORK ORDER 12083

Account # _____ Order Date 9/26/2017
 Name BARKER PAGE Status MEDIUM
 Address _____ Scheduled 09/26/17 01:07 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473738	07303889	6279	B15089413	6280

Description _____
 Comment RT, WOOD SIDE HSE. RT GR DR
 Requested By Sarah Miller Assigned To MAINTENANCE CREW Completed By DR LTM
 Start Date 9/26/17 Time _____ Completed Date 9/27/17 Time 12:46

Make _____ Size/Type _____ Multiplier _____

Notes Sarah 270-731-9986

BAD METER GASKET BAD REPLIED BOTH

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 11994

Account #
Name ANDERSON, CHARLES B
Address
Telephone Job #

Order Date 8/28/2017
Status MEDIUM
Scheduled 08/28/17 11:04 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 40548989	63249657	4922	B14169961	

Description

Comment RT, 1/2 BRK HSE, LF CNR

Requested By ANDERSON

Assigned To MAINTENANCE CREW

Completed By MAINTENANCE CREW


Start Date 08/29/17 02:06 PM

Completed Date 08/29/17 02:06 PM

Notes CUSTOMER'S LEAK, METER TURNIGN SLOWLY. READING 4964 TM 08/29/17

7 1/2 hrs 1-1/2 cu Small leak on 1/2 BRK HSE

49901



Signature



East Logan Water District
WORK ORDER 12017

Account #
Name GREGORY, JASON D
Address
Telephone Job #

Order Date 9/5/2017
Status MEDIUM
Scheduled 09/05/17 01:33 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 52473761 07306232 1953 B14166555

Description
Comment LF BRK L/CNR OF HS

Requested By Tyler Assigned To MAINTENANCE CREW Completed By
Start Date 9/8/17 Time : Completed Date 9/8/17 Time :

Make Size/Type Multiplier
Notes New line from main to meter

Inventory Item And Description	Quantity Ordered	Quantity Used

X Chandlers Rd

X 09/07/05

Bar# 1709051557

LTC, WRECC



Biped 9-8-17
New tube pulled under road

Signature A.L. 9-8-17

WORK ORDER 12058

Account # _____ Order Date 9/18/2017
 Name COOPER ELIZABETH Status MEDIUM
 Address _____ Scheduled 09/18/17 08:28 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 60628213	63183735	3706	B14170082	

Description _____
 Comment RT, HSE OFF RD, RT GR DR, 2 ME

Requested By Elizabeth Cooper Assigned To MAINTENANCE CREW Completed By _____
 Start Date 9/18/17 Time _____ Completed Date 9/18/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Check for service line leak
Met at bottom

Inventory Item And Description	Quantity Ordered	Quantity Used

1709180341

LTC

X Anderson Store

Signature A.C.

East Logan Water District
WORK ORDER 12057

Account # _____
 Name PRICE, MICHAEL W
 Address _____
 Telephone _____ Job # _____
 Order Date 9/18/2017
 Status MEDIUM
 Scheduled 09/18/17 08:19 AM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 51780730 ERT/INTERNAL ID# 09144720 READING 7971 LOCATOR TAG B14969489 READING IN / CUT _____

Description _____
 Comment RT,WH/HSE,FAR LT/YD
 Requested By Michael Price Assigned To MAINTENANCE CREW Completed By _____
 Start Date 9/18/17 Time _____ Completed Date 9/18/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Leak in main

Inventory Item And Description	Quantity Ordered	Quantity Used
Meters Nut		

X Watson
 or
 3 Poplars

Emergency locate

LTC
 WRECC

1709180335

Signature A.C. 9-18-17

WORK ORDER 12054

Account # _____ Order Date 9/15/2017
 Name COLE, KAYLA B Status MEDIUM
 Address _____ Scheduled 09/15/17 09 02 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 46202644 ERT/INTERNAL ID# 10495956 READING 9681 LOCATOR TAG B15261814 READING IN / OUT _____

Description WATER IN DITCH

Comment LF,TRLR,LF/YD

Requested By CHARLES SHELTON Assigned To MAINTENANCE CREW Completed By _____

Start Date 9/16/17 Time _____ Completed Date 9/16/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes

Repaired part of line

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud #1709/5 1386

ATT

*AC Bond
9-16-17 Saturday*

Signature

A.C. 9-16-17

East Logan Water District
WORK ORDER 12055

Account # _____ Order Date 9/15/2017
Name FARMER TP, FLOYD R Status MEDIUM
Address _____ Scheduled 09/15/17 10:51 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 22261643	08833460	2391	B14170218	2424

Description _____
Comment LF, BRK HSE, RT YD
Requested By Mr. Farmer Assigned To MAINTENANCE CREW Completed By _____
Start Date 9/15/17 Time _____ Completed Date 9/15/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature A.C.

East Logan Water District
WORK ORDER 11883

Account # _____ Order Date 7/18/2017
Name COLE KAYLA B Status MEDIUM
Address _____ Scheduled 07/18/17 11 38 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 46202644 10495956 9629 B15261814

Description _____

Comment LF,TRLR,LF/YD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____

Start Date 8/23/17 Time _____ Completed Date 8/23/17 Time _____


Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Patched full we can pull new line

Please check!

Area marked in blue both sides marked
x- 68/80



East Logan Water District
WORK ORDER 12030

Account # _____ Order Date 9/9/2017
Name GALIPEAU, PETFR Status MEDIUM
Address _____ Scheduled 09/11/17 07:45 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51780737	09805255	411	B15279044	

Description
Comment RT, BRK HSE, 20' RT OF DRIVE

Requested By Peter Assigned To MAINTENANCE CREW Completed By _____

Start Date 9/11/17 Time _____ Completed Date 9/11/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes On Saturday, Peter called to say yard between houses was wet, suspected we had the beginnings of a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Emergency locate
10-2-17 Express

ATT
Atmos
LTC
Tx Gas - clear

1709110264

24,000 gal

Signature [Signature]

East Logan Water District
WORK ORDER 12000

Account # _____ Order Date 8/30/2017
 Name HOLLOWAY, SHELLIE L Status MEDIUM
 Address _____ Scheduled 08/30/17 09:51 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473746	07229679	7845	B14172373	

Description _____
 Comment RT, BEIGE DW, RT YD @ PWR POLE
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/30/17 Time _____ Completed Date 8/30/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes *1" x 1" x 1"*

Inventory Item And Description	Quantity Ordered	Quantity Used

X Basham Lane X by 09/07/15
 Bud# 1709051551
 ATT, LTC, WEECC
 1/2 split spraying out 4' leaving about 2 months

Signature *[Handwritten Signature]*

EAST LOGAN WATER DISTRICT
WORK ORDER 12009

Account #
Name VANDERPOOL GEORGE & LESLIE
Address
Telephone Job #

Order Date 8/31/2017
Status MEDIUM
Scheduled 08/31/17 01:49 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473743	07306106	1208	B14168664	

Description

Comment LF TRLR L/DRIVE

Requested By George

Assigned To MAINTENANCE CREW

Completed By

Start Date 8/31/17 Time

Completed Date 8/31/17 Time

Make _____ Size/Type _____ Multiplier _____

Notes Spraying in meter box

Replaced Meter Bottom

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature

East Logan Water District
WORK ORDER 11896

Account #
Name **STOVALL, JASON D**
Address
Telephone

Order Date 7/24/2017
Status MEDIUM
Scheduled 07/24/17 11:09 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 32807041 ERT/INTERNAL ID# 10403977 READING 6800 LOCATOR TAG B14167322 READING IN / OUT

Description LEAK IN MIDDLE OF ROAD

Comment RT BROWN HSE, MIDDLE YD

Requested By *R* Assigned To MAINTENANCE CREW Completed By

Start Date / / Time : Completed Date 7/24/17 Time :

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

*Bud # 1707241363
ATT, Atmos, LTC*

*Fixed
7-26-17*

Signature *DG*

East Logan Water District
WORK ORDER 11274

Account # 0
Name CARDWELL, JESSICA M
Address
Telephone Job #

Order Date 12/29/2016
Status MEDIUM
Scheduled 12/29/16 10:25 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 63869452	63183986	2984	B14169980	

Description
Comment LF,WH HSE,RT YD READ 2

Requested By Shane Cole Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Water in ditch between meter and road. He says meter is not turning. Also, water has a brownish cast when turned on after sitting overnight.

Inventory Item And Description	Quantity Ordered	Quantity Used

1-12-17

TM

Signature _____

EAST LOGAN WATER DISTRICT
WORK ORDER 11353

Account #
Name HAGAN, TIMOTHY L
Address
Telephone b #

Order Date 1/26/2017
Status MEDIUM
Scheduled 01/26/17 02:28 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568771	74698142	167	B14891801	

Description

Comment LF, TAN HSE. MYD

Requested By Mrs. Hagan

Assigned To MAINTENANCE CREW

Completed By

Start Date ___/___/___ Time ___:___

Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Please see if this is leaking again. Customer says it stopped after we fixed leak, but now box, and ditch have started filling with water again

Inventory Item And Description	Quantity Ordered	Quantity Used

No leak, spoke with customer...

Signature

B.G.

East Logan Water District
WORK ORDER 11897

Account # _____ Order Date 7/24/2017
Name HART, RAY Status MEDIUM
Address _____ Scheduled 07/24/17 12:09 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473759	07330248	9747	B14169785	

Description _____
Comment LF, WH HSE, MYD

Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____ Completed Date 7/24/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes Mr Hart says water across road from his meter, on west side

Inventory Item And Description	Quantity Ordered	Quantity Used

Already Located!

Fixed
8000

BL

Signature _____

East Logan Water District
WORK ORDER 11949

Account #
Name MCPHERSON MICHAEL K
Address
Telephone Job #

Order Date 8/7/2017
Status MEDIUM
Scheduled 08/07/17 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48431525	09403754	7207	B14170249	


Description
Comment RT, GREEN HSE. 20' RT DR

Requested By M McPherson Assigned To MAINTENANCE CREW Completed By
Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Some leak at 2470



8-10-17

PC

Signature

East Logan Water District
WORK ORDER 11974

Account #
Name TOOTHMAN, GLENN A
Address
Telephone ob #

Order Date 8/21/2017
Status MEDIUM
Scheduled 08/21/17 09 31 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82994977	89283186	43	B14168030	265

Description
Comment LF, HSE OFF RD, LF DR, 2ND

Requested By Glenn Toothman Assigned To MAINTENANCE CREW Completed By
Start Date 8/23/17 Time : Completed Date 8/23/17 Time :

Make _____ Size/Type _____ Multiplier _____

Notes
Customer Leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature TM

East Logan Water District
WORK ORDER 11888

Account # _____ Order Date 7/19/2017
 Name DAVENPORT, RONNIE Status MEDIUM
 Address _____ Scheduled 07/19/17 11:07 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 69361516 63066128 5104 B14166919 5361

Description _____
 Comment RT NEXT GR DR R/DR
 Requested By Mrs. Davenport Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/19/17 Time _____ Completed Date 8/19/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Meter box is full of water ..please see if there is a leak, and whose leak it is.

Inventory Item And Description	Quantity Ordered	Quantity Used

Did not see anything to indicate a leak on either end.

Check this please
 LA 8-26-17

Signature TM

East Logan Water District
WORK ORDER 11994

Account # _____ Order Date 8/28/2017
Name ANDERSON CHARLES B Status MEDIUM
Address _____ Scheduled 08/28/17 11.04 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 40548989 63249657 4922 B14169961 491.4

Description
Comment RT, 1/2 BRK HSE, LF CNR

Requested By ANDERSON Assigned To MAINTENANCE CREW Completed By _____
Start Date 8/28/17 Time _____ Completed Date 8/28/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer's leak meter is turning slowly

Signature IM

WORK ORDER 11956

Account # _____ Order Date 8/11/2017
 Name WATKINS, CELIA Status MEDIUM
 Address _____ Scheduled 08/11/17 08 18 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 46202682 09644759 7507 B14168780 75.36
 Description 270-726-0939 water coming out of meter
 Comment RT, YELL HSE, RT/YD
 Requested By Mr Huffman Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/11/17 Time _____ Completed Date 8/11/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted meter bottom, replaced bottom

Signature Tms

East Logan Water District
WORK ORDER 11985

Account #
Name **TURNER, JAMES JR**
Address
Telephone

Order Date 8/24/2017
Status MEDIUM
Scheduled 08/24/17 03:34 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 22201647	64952906	69	B14166799	

Description
Comment LF, WH HSE, LF YD, 2ND

Requested By Jim Turner Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date 8/24/17 Time :

Make _____ Size/Type _____ Multiplier _____

Notes: water in ditch around meter, close to fence maybe Please check it out

water in ditch around meter, close to fence maybe Please check it out

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *Tm*

WORK ORDER 11875

Account # _____ Order Date 7/12/2017
Name TUCKER, ROBERT C SR Status MEDIUM
Address _____ Scheduled 07/12/17 03 50 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 39090832 08827612 5584 B14170030

Description _____
Comment LF, BRK HSE, RT YD, BRICK WALL

Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____ Completed Date 7/12/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud # 1707121506

X by 07/14/17

ATT, LTC, WRECC

Needs to be fixed

TM

Signature

WORK ORDER 11890

Account # _____ Order Date 7/20/2017
 Name PRICE, THOMAS M Status MEDIUM
 Address _____ Scheduled 07/20/17 10 14 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 82460044 75071660 93 B14168289

Description _____
 Comment LF, TAN HSE DN RD, LF AT INTER
 Requested By Jo Orange Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature

WORK ORDER 11886

Account # _____ Order Date 7/19/2017
Name PRICE, THOMAS M Status MEDIUM
Address _____ Scheduled 07/19/17 08:17 AM
Telephone _____ Job # _____ Order Type CHECK METER
METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 82460044 75071660 93 B14168289
Description _____
Comment LF, TAN HSE DN RD, LF AT INTER
Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
Start Date ____ / ____ / ____ Time _____ Completed Date ____ / ____ / ____ Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Rd. crew hit meter mowing....customer called, reported problem, had crew turn off meter. Crew is supposed to repair their line today. Check to make sure nothing further is damaged

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *BL*

WORK ORDER 11477

Account # _____ Order Date 3/6/2017
 Name KEMP, RUSSELL S Status MEDIUM
 Address _____ Scheduled 03/06/17 08:47 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 42088278 09727127 68 B14166968
 Description _____
 Comment RT, BRK HSE, 15' LF OF LF CNR
 Requested By Mrs. Kemp Assigned To MAINTENANCE CREW Completed By _____
 Start Date 03/06/17 Time _____ Completed Date 03/06/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes *to be used to replace hime*

Inventory Item And Description	Quantity Ordered	Quantity Used

WORK ORDER 12363

Account # 16
Name WILSON, JUDY G
Address
Telephone Job #

Order Date 12/18/2017
Status MEDIUM
Scheduled 12/18/17 02:07 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 81004658 74516494 209 B14169543

Description
Comment RT, LOG HSE, RT CNR

Requested By Sarah Moore Assigned To MAINTENANCE CREW Completed By

Start Date 12/18/17 Time _____ Completed Date 12/19/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Standing water in ditch, main on opposite side of road is this a service tube leak?? Andy checked and yes it is
Will be pulling new line under road.
BUD call 1712181310 marked by 8 am 12-19-17 LJC G. P. S.

Inventory Item And Description	Quantity Ordered	Quantity Used
1 3/4 Brass Coupling		
1- 3/4 Bolt Clamp		
2- 3/4 inserts		

2 Gal per minute

Signature A. C.

East Logan Water District
WORK ORDER 12366

Account # _____ Order Date 12/19/2017
Name POWELL, AMANDA L Status MEDIUM
Address _____ Scheduled 12/19/17 08:56 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 42228894 61287396 6689 B14169945

Description _____
Comment LF, HSE OFF RD, LF DR @ Rd
Requested By david yoder Assigned To MAINTENANCE CREW Completed By _____
Start Date 12/19/17 Time _____ Completed Date 12/19/17 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes check for leak... says someone almost hit meter. Andy says it is a service tube leak. BUD call

Inventory Item And Description	Quantity Ordered	Quantity Used
3- 3/4 INSEITS		
1- 3/4 Nut		
1 3/4 Coupling		
1- 3/4 BALL COUPLING		
10ft 3/4 PIPE		

X Joe Anderson
↑ 100

3-Gals Per minute

ATT -



1712190706

Signature A. C.

WORK ORDER 12344

Account # 02 Order Date 12/11/2017
 Name THOMPSON, TERESA M Status MEDIUM
 Address , Scheduled 12/11/17 08:16 AM
 Telephone Job # Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 68434131	62202155	5338	B14167240	

Description
 Comment RT BRK RT SIDE OF YD
 Requested By ANDY Assigned To MAINTENANCE CREW Completed By
 Start Date 12/11/17 Time : : Completed Date 12/11/17 Time : :
 Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
2 - 3/4 couplings		
5 - 3/4 inserts		
5 - 3/4 Tubing		

Bud# 1712110428

ATT, LTC WRECC

20 Gals per minute

~~20~~

12 Hrs

Signature

A.C.

East Logan Water District
WORK ORDER 12341

Account # _____ Order Date 12/6/2017
Name GALIPEAU, PETER Status MEDIUM
Address _____ Scheduled 12/06/17 04:05 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51780737	09805255	612	B15279044	

Description _____
Comment RT, BRK HSE, 20' RT OF DRIVE
Requested By Peter Assigned To MAINTENANCE CREW Completed By AC & DB
Start Date ____/____/____ Time ____:____:____ Completed Date 12/7/17 Time 10:00

Make _____ Size/Type _____ Multiplier _____

Notes Peter called in a leak about 10' from meter

11/20/16/16

Inventory Item And Description	Quantity Ordered	Quantity Used

BROKEN BELL - CUT OUT & REPLACED 10' 3" PVC w/KNOCKOUTS
2 HR REPAIR TIME
BOIL WATER ±30 CUSTOMERS
SAMPLES PASSED
72000 GAL LOSS/FLUSH

Signature _____

WORK ORDER 12319

Account # _____ Order Date 12/4/2017
 Name SHOULDERS, BRIAN S Status MEDIUM
 Address _____ Scheduled 12/04/17 02:38 PM
 Telephone _____ Job # _____ Order Type ABNORMAL SMELL/COLOR

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 46202632	09204546	5496	B14250084	

Description

Comment RT BRN HSE, LF DR, READ 2

Requested By Mrs Shoulders Assigned To MAINTENANCE CREW Completed By _____

Start Date 12/7/17 Time _____ Completed Date 12/7/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Please check and possibly flush at meter?? Customer states particles of black coming through and clogs screens

Inventory Item And Description	Quantity Ordered	Quantity Used
flushed line		
WATER FLUSHED INCLUDED IN LEAK LOSS FOR MAIN BREAK 12-7-17		

Signature 

WORK ORDER 12303

Account # _____ Order Date 11/29/2017
 Name DUNCAN TP. ANTONIO P Status MEDIUM
 Address _____ Scheduled 11/29/17 12:30 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 37339774	71971532	2179	B15196956	

Description Meter has been ran over & water is running out

Comment RT. WH HSE.LF DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____

Start Date 11/29/17 Time _____ Completed Date 11/29/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Customer Leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Sept Daniel

DB

WORK ORDER 12293

Account # _____ Order Date 11/27/2017
 Name HUMBLE, MIKE Status MEDIUM
 Address _____ Scheduled 11/27/17 02 45 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 81568801 74698172 1105 B14165988

Description _____
 Comment WJ/HS R/DR
 Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____
 Start Date 11/27/17 Time _____ Completed Date 11/27/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes X-68 BYPASS
 BUD# 1711270925
 ATT
 LTC
 RUSSELLVILLE CITY

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 4" Saddle - 3/4"		
60FT Tubing		
2- 3/4 INSETS		
Regravelled The driveway		

Signature A. C.

WORK ORDER 12284

Account # _____ Order Date 11/22/2017
Name OFFUTT, CINDY Status MEDIUM
Address _____ Scheduled 11/22/17 08.10 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 69361501 63066113 3633 B14167107

Description _____

Comment RT,WOOD/HSE LF/DR

Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____

Start Date 12/1/17 Time _____ Completed Date 12/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes X Old 79 Loop
BUD# 1711220417
ATT, LTC

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 Coupling		
4' 3/4 Pipe		

4 Gal's
Per Minute

Signature

A. C.

WORK ORDER 12271

Account # _____ Order Date 11/16/2017
 Name WELLS, MANDY Status MEDIUM
 Address _____ Scheduled 11/16/17 01:51 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69352005	63056287	1094	B14166416	

Description _____
 Comment LR, BRK HSE LF CNR
 Requested By Mrs Wells Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Just David
Rec'd - 11-17-17
AC / DB / TNG

WORK ORDER 12263

Account # _____ Order Date 11/14/2017
 Name TRENT B Status MEDIUM
 Address _____ Scheduled 11/14/17 03:58 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69352009	63056291	8611	B14169792	8718

Description
 Comment RT GRAY HSE, LF YD READ 2
 Requested By Mr Trent Assigned To MAINTENANCE CREW Completed By _____
 Start Date 11/15/17 Time _____ Completed Date 11/15/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Meter box is full of water, and he also has a high water bill. Please check for a leak and advise him on what is found

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer has leak. Pumped box out & meter was turning & water coming in from backside of box (outside of box). Tried knocking on door no one answered & called & left v-mail.

Signature *Tom*

East Logan Water District
WORK ORDER 12259

Account #
Name BOYD, EDWARD L
Address
Telephone

Order Date 11/14/2017
Status MEDIUM
Scheduled 11/14/17 09:16 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056565	68995871	2481	B14652526	

Description
Comment RT, RT OF DR, LONG TUBING

Requested By Daniel Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date 11/14/17 Time 11:49

Make _____ Size/Type _____ Multiplier _____

Notes Probably needs new service line replace

No Leak Found Service Line crosses Road 2 Houses To The North.

No service crossing at this address

Inventory Item And Description	Quantity Ordered	Quantity Used

DB

Signature _____

WORK ORDER 11323

Account # _____ Order Date 1/13/2017
 Name HEAD, GERALD W Status MEDIUM
 Address _____ Scheduled 01/13/17 08:19 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418228	73543855	1049	B14170212	

Description _____
 Comment RT, BRK HSE, RT DR
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date 1/13/17 Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes No CL FOUND NO LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used

Bud # 1701121357
 LTC, WRECC

JB

Signature _____

WORK ORDER 11739

Account #
Name HOLDER, DONNA M
Address
Telephone Job #

Order Date 6/21/2017
Status MEDIUM
Scheduled 06/21/17 09:13 AM
Order Type MISCELLANEOUS

METER# WT 000001 ERT/INTERNAL ID# 61913686 READING 5715 LOCATOR TAG B14167150 READING IN / OUT

Description

Comment LF, ORANGE/BRK RT/DR

Requested By Tyler

Assigned To MAINTENANCE CREW

Completed By DIS AC

Start Date 6/21/17 Time 9:13

Completed Date 6/21/17 Time 5:00

Make _____ Size/Type _____ Multiplier _____

Notes Customer called night before, leak on their side, couldn't turn meter off. Tyler said our cutoff is broken, and needs replacing
Tyler found and turned their valve off

REPLACED CUTOFF

Inventory Item And Description	Quantity Ordered	Quantity Used
7" SETTER		1
3' - 3/4" PE SERVICE LINE		3
1 - 3/4" x 3/4" COMPRESSION COUPLING		1

BUD # 1706210827

X by 06.23.17

X Old 79 Loop

ATT, LTC

Signature _____

East Logan Water District
WORK ORDER 12243

Account # _____ Order Date 11/8/2017
Name DELK, LYNDEL JOE Status MEDIUM
Address _____ Scheduled 11/08/17 03:16 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605863	63717606	2189	B14169355	

Description _____
Comment RT,TAN HSE,LF DR
Requested By Mr. Delk Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time ____:____:____ Completed Date 11/8/17 Time ____:____:____

Make _____ Size/Type _____ Multiplier _____

Notes He thinks state dept may have damaged while mowing See if there is a leak, and whose leak it is Phone # 270-542-7420

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer Leak

Signature *AC*

WORK ORDER 12059

Account # _____ Order Date 9/18/2017
 Name REESE, STEPHEN Status MEDIUM
 Address _____ Scheduled 09/18/17 09 01 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 78786041 73607027 1241 B15347985 1263

Description At the valve!!!!
 Comment RT, 25 yds to right of drive

Requested By David Reese Assigned To MAINTENANCE CREW Completed By _____
 Start Date 9/18/17 Time _____ Completed Date 9/18/17 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes
 Replaced 2" BS Pass Pressure Reducing Station

Inventory Item And Description	Quantity Ordered	Quantity Used

Valve needs replacing

X-WEST VALLEY RD
 1710120827
 LTC
 DTT
 ATMOS

10-30-17
 Fixed

Signature TM J.C.D.

LOGAN WATER DISTRICT
WORK ORDER 11895

Account #
Name LOGAN COUNTY AIRPORT
Address
Telephone Job #

Order Date 7/24/2017
Status MEDIUM
Scheduled 07/24/17 11 08 AM
Order Type CHECK METER

METER# WT 30318377 ERT/INTERNAL ID# 39220326 READING 2363 LOCATOR TAG B15346883 READING IN / OUT 2441

Description METER HAS BEEN DAMAGED DUE TO MOWING

Comment LF, AIRPOR, METAL BLD. 55' RT

Requested By Assigned To MAINTENANCE CREW Completed By

Start Date 8/13/17 Time Completed Date 8/13/17 Time

Make Size/Type Multiplier

Notes

Replaced meter at location

Inventory Item And Description	Quantity Ordered	Quantity Used

*Just 1.0
Replaced meter 1.0.*

Signature *TN*

EAST LOGAN WATER DISTRICT
WORK ORDER 12093

Account # 1
Name BROWN, GARLAND
Address
Telephone

Order Date 9/11/2017
Status MEDIUM
Scheduled 09/11/17 01:34 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81271737 ERT/INTERNAL ID# 74600809 READING 630 LOCATOR TAG B14167664 READING IN / OUT

Description He says he may have a leak, but can't tell for sure meter is under water.

Comment LF, 2ND METER

Requested By Mr. Brown Assigned To MAINTENANCE CREW Completed By

Start Date 9/12/17 Time : Completed Date 9/12/17 Time :

Make _____ Size/Type _____ Multiplier _____

Notes Fixed leak on one side

Inventory Item And Description	Quantity Ordered	Quantity Used

1709210614

LTC

50' radius

Signature A.C.

East Logan Water District
WORK ORDER 12063

Account #
Name SACRA, ROY B
Address
Telephone

Order Date 9/18/2017
Status MEDIUM
Scheduled 09/18/17 04:21 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 65798137	58647055	1800	B14167845	

Description
Comment RT, STONE HSE, LT/DR

Requested By custiner Assigned To MAINTENANCE CREW Completed By
Start Date 9/12/17 Time : Completed Date 9/12/17 Time :

Make Size/Type Multiplier

Notes mowing and found a possible leak

found leak

Inventory Item And Description	Quantity Ordered	Quantity Used

ATT
Bluegrass Gas
70" 200324 Katherine Johnson

Signature A. C.

WORK ORDER 11645

Account #
Name LOGAN CO FISCAL COURT
Address
Telephone Job #

Order Date 5/15/2017
Status MEDIUM
Scheduled 05/15/17 10 31 AM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056553	09209045	7537	B14167519	7543

Description
Comment RT, WH/BLDG, M/BLDG

Requested By Linda Assigned To MAINTENANCE CREW Completed By

Start Date 5/15/17 Time : Completed Date 5/15/17 Time :

Make Size/Type Multiplier

Notes Tim Pitts (LC Recycling employee) called to say he had stepped on the meter and the lid gave, causing him to fall into pit. Meter is now leaking. Tim said other than some scratched, he was fine.

Inventory Item And Description	Quantity Ordered	Quantity Used

Replaced 3 gaskets, + S bar + meter bottom. Box is painted blue

Signature 

East Logan Water District
WORK ORDER 11643

Account # _____ Order Date 5/15/2017
 Name HENDRIX, CLIFFORD Status MEDIUM
 Address _____ Scheduled 05/15/17 09:15 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 52473697 07326625 9067 B14168308 9083
 Description _____
 Comment LF, BRK HSE, MYD T/A, GO STRA
 Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
 Start Date 5/15/17 Time _____ Completed Date 5/15/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes See whats going on Leaking at meter

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted meter bottom replaced bottom

WORK ORDER 11322

Account # _____ Order Date 1/13/2017
 Name THOMAS, JEFFREY C Status MEDIUM
 Address _____ Scheduled 01/13/17 08 18 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 50441846 ERT/INTERNAL ID# 72667226 READING 1615 LOCATOR TAG B14169093 READING IN / OUT _____

Description _____
 Comment RT WHSE RT CNR OF YD
 Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date 1/1/17 Time _____ Completed Date 1/1/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Tyler responded on 1-14-17 when a plumber hired by LTC to repair customer side of meter called Linda call to report gas side opening badly. Brandon was not because of emergency so Tyler went to stop the leak.		

Bud # 1701121468

~~Broken May Put back in ground?~~

ATT
LTC
LTRW
TX GAS
WRECC

Customer called on 1-20-17 He thought leak had not been repaired. Meter broken meter, buy was put back in ground according to the customer.

This is fixed 1-14-17

Signature BG/TM

WORK ORDER 11452

Account # _____ Order Date 2/24/2017
 Name FARLEY, ROBERT Status MEDIUM
 Address _____ Scheduled 02/24/17 09.12 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# WT 52473768 ERT/INTERNAL ID# 61287455 READING 5150 LOCATOR TAG B15280363 READING IN / OUT 5175
 Description _____
 Comment LF WH/BRK R/DR T/RT DOGS
 Requested By Linda Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/24/17 Time _____ Completed Date 2/24/17 Time _____
 Make _____ Size/Type _____ Multiplier _____
 Notes suppose to be a busted meter bottom

Inventory Item And Description	Quantity Ordered	Quantity Used

replaced meter bottom .5 gpm

Signature TPA

WORK ORDER 11436

Account # _____ Order Date 2/20/2017
 Name CHILES, ALLEN Status MEDIUM
 Address _____ Scheduled 02/20/17 08:33 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47502646	63183765	17298	B14170017	

Description _____
 Comment LF, WH HSE OFF RD, 20' RT DR
 Requested By Mr.Chiles Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Leak under road, changed out old CTS, Full pull from main...

Signature B.G.

WORK ORDER 11975

Account# _____ Order Date 8/21/2017
 Name FREEMAN, HAROLD Status MEDIUM
 Address _____ Scheduled 08/21/17 11:25 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43518909	09449821	6805	B14169905	

Description _____
 Comment LF GRAY TRLR, RT CNR, UP BANK
 Requested By Mr. Freeman Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/23/17 Time _____ Completed Date 8/23/17 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes We need to pull a service line under road where it is leaking BUD 1708210944 LTC & ATT by 8-23-17 at noon

Inventory Item And Description	Quantity Ordered	Quantity Used

*New line pulled
 just need to let
 dirt settle + put
 more down*

Signature 

East Logan Water District
WORK ORDER 13227

Account #
Name GARDNER, BOBBY & APRIL
Address
Telephone Job #

Order Date 8/14/2018
Status MEDIUM
Scheduled 08/14/18 12:10 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 000050056614 ERT/INTERNAL ID# 52260066 READING 4905 LOCATOR TAG B14169745 READING IN / OUT

Description
Comment LF,WH HSE,M/YD

Requested By Bobby Gardner Assigned To MAINTENANCE CREW Completed By *MTB*
Start Date / / Time : Completed Date 8/14/18 Time 12:00

Make _____ Size/Type _____ Multiplier _____

Notes Down from meter in tall grass is leaking.
LONG SIDE SERVICE LINE LEAK.

Inventory Item And Description	Quantity Ordered	Quantity Used

DUNCAN LN
~~*DUNCAN LN*~~
1508221318
LTC

U

Signature *MTB*

East Logan Water District
WORK ORDER 13169

Account #
Name GIDCUMB, JOSH B
Address
Telephone

Order Date 8/3/2018
Status MEDIUM
Scheduled 08/03/18 08 36 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81271620
ERT/INTERNAL ID# 74600692
READING 894
LOCATOR TAG B15368795
READING IN / OUT

Description
Comment LF OF DR, LF SD OF HSE

Requested By Josh Gidcumb
Assigned To MAINTENANCE CREW
Completed By *E.A.*

Start Date / / Time :
Completed Date 8/3/18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes He has marked with a stake where water is coming up Please check for leak

5:45 PM

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Daniel is checking</i>		

BB did Bud call to repair

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13121

Account # _____ Order Date 7/24/2018
 Name SMITH, KRISTA S Status MEDIUM
 Address _____ Scheduled 07/24/18 10 05 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473833	61950532	8001	B14172330	

Description _____
 Comment LF WOOD HS LYD 2 MTRS
 Requested by KRISTA Assigned to MAINTENANCE CREW Completed By _____
 Start Date 7/27/18 Time _____ Completed Date 7/27/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes CHECK TO SEE IF WE HAVE LEAK. INFRONT OF METER BOX CLOSEST TO RD

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 Y		
8- 3/4 ins-caps		
2ft 3/4 Tubing		

Bud ticket #
1807240974

LTC
WRECC

Signature 

East Logan Water District
WORK ORDER 13135

Account # _____ Order Date 7/27/2018
Name HUDNALL, MARTY Status MEDIUM
Address _____ Scheduled 07/27/18 09:36 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361398	63066010	6412	B14167162	64162

Description

Comment LF GRAY TRLR R/DR

Requested By Mrs Hudnall Assigned To MAINTENANCE CREW Completed By

Start Date / / Time : : Completed Date 7/27/18 Time 10:30

Make _____ Size/type _____ Multiplier _____

Notes Meter box in water, customer hears spewing. Please check

Leak on our side at meter box. Fixed leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature Mrs H

East Logan Water District
WORK ORDER 13123

Account #
Name KESSINGER, CARLA D
Address
Telephone Job #

Order Date 7/25/2018
Status HIGH
Scheduled 07/25/18 08:23 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 48979811 ERT/INTERNAL ID# 09785122 READING 7087 LOCATOR TAG B14167344 READING IN / OUT

Description

Comment LF, WOOD SIDE HSE, 20' RT DR

Requested By chris hughes Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Mr. Hughes called in stating that water is coming out of ground and standing in driveway

B.O.D ID # 18072508301

ATT PENN RILE ELL

Inventory Item And Description	Quantity Ordered	Quantity Used
2- 3/4 Shark Bit Couplings		
2- 2ft Tubing		

~~2- 3/4~~
1 1/2 a minute

Signature A. C.

East Logan Water District
WORK ORDER 13090

Account #
Name GROFF, BRAD K
Address
Telephone

Order Date 7/13/2018
Status MEDIUM
Scheduled 07/13/18 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66952468	60650148	3529	B14169131	

Description
Comment RT WHSE RT SIDE OF YD

Requested by Daniel Assigned To MAINTENANCE CREW Completed By
Start Date 7/17/18 Time . . . Completed Date 7/17/18 Time . . .

Make _____ Size/Type _____ Multiplier _____
Notes needs a new line pulled

Inventory Item And Description	Quantity Ordered	Quantity Used
Pulled New Tubing		
85ft 3/4 Tubing		
1- Flat head nut 3/4		
1- Cone head Nut 3/4		
2- 3/4 inserts		

by noon 7-13-18

ATT
LTC
W (con)
LTCWC
WREC - con

Signature A.C. M.H.

East Logan Water District
WORK ORDER 13061

Account # _____
 Name STOVALL, SARA
 Address _____
 Telephone _____ Job # _____
 Order Date 7/11/2018
 Status MEDIUM
 Scheduled 07/11/18 10:38 AM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69352006 ERT/INTERNAL ID# 63056288 READING 2820 LOCATOR TAG B14169834 READING IN / OUT _____

Description _____
 Comment LF, BRK HSE, MYD
 Requested By Sara Stovall Assigned To MAINTENANCE CREW Completed By _____
 Start Date 7/11/18 Time _____ Completed Date 7/11/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Mower noticed water around meter

Inventory Item And Description	Quantity Ordered	Quantity Used
8 ft 3/4 Tubing		
1 - 3/4 cone head		
1 - 3/4 Flange head		
2 - 3/4 INSERTS		

APT -
 WRECKER - clamp
 LTC -
 LTHW -
 Gir - clamp

2-Gallon
 Bermin



137 Hillcrest
 across from Sugarleaf.
 Check Daniel's clamp

Signature A.C. M.H.

East Logan Water District
WORK ORDER 13035

Account #
Name THOMPSON, LESLIE L
Address
Telephone Job #

Order Date 7/3/2018
Status MEDIUM
Scheduled 07/03/18 12 29 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418225	09725231	6414	B14167018	

Description
Comment LF,GRAY HSE,LF YD

Requested By Leslie Assigned To MAINTENANCE CREW Completed By DSB / M
Start Date 7/3/18 Time 12:00 PM Completed Date 7/3/18 Time 5:00 PM

Make _____ Size/Type _____ Multiplier _____

Notes cust adv. that meter is leaking on our side again

SERVICE LINE LEAK - REPLACED SL + CURT

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 13055

Account #		Order Date	7/5/2018
Name	McREYNOLDS, KENNAN D	Status	HIGH
Address		Scheduled	07/05/18 08 53 AM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG
WT 47747516	63097920	311	B14168913
Description			READING IN / OUT
Comment	RT BRK R/YD T/A T/RT 79		
Requested By	Gary Woodall	Assigned To	MAINTENANCE CREW
Completed By			
Start Date	___/___/___	Time	___:___
Completed Date	___/___/___	Time	___:___

Make _____ Size/Type _____ Multiplier _____
Notes main line water break

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 13142

Account # --
Name MARNEY, JAMES L
Address
Telephone

Order Date 7/27/2018
Status MEDIUM
Scheduled 07/27/18 04:38 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 65798120 ERT/INTERNAL ID# 58647038 READING 9847 LOCATOR TAG B14167701 READING IN / OUT

Description

Comment RT, BRK, L/CNR

Requested By Mrs. Marney

Assigned To MAINTENANCE CREW

Completed By

Start Date 7/27/18 Time ___:___

Completed Date 7/31/18 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 Couplings		
off Tubing 3/4		

BUD 180 727 1433
X Hwy 79 Call Andy 4-5 gallon per min.
ATF
Bluegrass Gas
LTRWC

Signature A.C.

East Logan Water District
WORK ORDER 13086

Account # _____ Order Date 7/12/2018
Name STUART, STEVEN R Status HIGH
Address _____ Scheduled 07/12/18 11 04 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45434925	63814715	3763	B14250513	

Description _____
Comment RT, WH/HS R/YD
Requested By STEVEN STUART Assigned To MAINTENANCE CREW Completed By _____
Start Date 7/12/18 Time _____ Completed Date 7/12/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes WATER IS FULL IN BOX.

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Pulled 1" tubing 100 ft</i>		
<i>2- 3/4-1" couplings</i>		
<i>6- 3/4 inserts</i>		

X Hwy 79 7-13-18 by 1 pm

LTC

1807121105

Signature AC M H

East Logan Water District
WORK ORDER 13089

Account # _____ Order Date 7/12/2018
Name DEARING, TABITHA A Status MEDIUM
Address _____ Scheduled 07/12/18 04:18 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 63869452 ERT/INTERNAL ID# 63183986 READING 3663 LOCATOR TAG B14169980 READING IN / OUT

Description
Comment LF,WH HSE,RT YD READ 2

Requested By Dennis Hafner Assigned To MAINTENANCE CREW Completed By _____
Start Date 7/12/18 Time _____ Completed Date 7/12/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Mike says water in ditchline, tests for chlorine

54211007

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>24 Tubings 4 ft</i>		
<i>3 3/4 inserts</i>		
<i>1- 3/4 coupling</i>		
<i>1- 3/4 connector</i>		
<i>1- 3/4 clamp</i>		

X Dennis Corinth
10. am
locate by Friday
front, area marked in white
both sides located

1807121674

ATT
LTC
LTRWC
TX Gas - clear
WRECC - clear

Signature AC-M.H

East Logan Water District
WORK ORDER 13050

Account # _____
Name FIELDS, MARY E
Address _____
Telephone _____ Job # _____
Order Date 7/3/2018
Status MEDIUM
Scheduled 07/03/18 03:00 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605864	07899039	4675	B15396071	

Description
Comment LT,WH/2-STORY HSE,LT/CNR
Requested by db Assigned To MAINTENANCE CREW Completed By _____
Start Date 7/16/18 Time _____ Completed Date 7/16/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes check for leak-db

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced Regulator		

X - AUBURN - RICHELIEU RD
1807061699
LTC WRECC

Signature AC

East Logan Water District
WORK ORDER 13029

Account #
Name FULCHER, ANTHONY
Address
Telephone Job #

Order Date 7/2/2018
Status MEDIUM
Scheduled 07/02/18 08:02 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 65798095 ERT/INTERNAL ID# 58647013 READING 73 LOCATOR TAG B15438752 READING IN / OUT

Description

Comment RT, HSE ON HILL 100' RT OF DR

Requested By Daniel

Assigned To MAINTENANCE CREW

Completed By

Start Date 7/2/18 Time

Completed Date 7/2/18 Time

Make _____ Size/Type _____ Multiplier _____

Notes

Replaced 180703345 LTC

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>Replaced Service Tubing</u>		
<u>1- 3/4 cone nut</u>		
<u>1- 3/4 Flat head nut</u>		

Signature

East Logan Water District
WORK ORDER 12908

Account #		Order Date	5/16/2018
Name	DULWORTH, SHANNON M	Status	MEDIUM
Address		Scheduled	05/16/18 02:39 PM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418185	63153561	4408	B14172363	

Description

Comment RT, 1/2 BRK HSE , LF DR - PASSE

Requested By Shannon Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 05/18/18 03:21 PM Completed Date 05/18/18 03:21 PM

Notes Check for standing water to the right of drive. Please check if our leak repaired 3/4 tubing 75ft
2 3/4 cone nuts
2 3/4 inserts

Signature _____

East Logan Water District
WORK ORDER 12548

Account #
Name MARR, STEVE A
Address
Telephone Job #
Order Date 2/9/2018
Status MEDIUM
Scheduled 02/09/18 12 29 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78786055	73607041	1141	B14168390	

Description
Comment LF, HSE, RT DR
Requested By Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 02/09/18 12 29 PM Completed Date 02/09/18 12 29 PM

Notes Customer leak Reading 1189 02/09/18 TM

Signature _____

East Logan Water District
WORK ORDER 12392

Account #
Name WATKINS, MAURICE
Address
Telephone

Order Date 1/2/2018
Status MEDIUM
Scheduled 01/02/18 08 23 AM
Order Type CHECK FOR LEAK ON OUR SIDE

Job #

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 9434292	9434292	1826		
Description	Water coming out of meter. no water at house			
Comment	RT, GRAY DBL WIDE. 10' RT DR T			
Requested By	Assigned To	MAINTENANCE CREW	Completed By	MAINTENANCE CREW
Start Date	01/02/18 09 48 AM		Completed Date	01/02/18 09 48 AM
Notes	CUSTOMER'S LEAK AC 01/02/18			

Signature _____

East Logan Water District
WORK ORDER 12398

Account #
Name THOMAS, DAVID L
Address
Telephone

Order Date 1/2/2018
Status MEDIUM
Scheduled 01/02/18 01:18 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50472313	10644886	4879	B14169841	

Description
Comment LF, WH TRLR, LF GR DR

Requested By David Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 01/02/18 01:42 PM Completed Date 01/02/18 01:42 PM

Notes Water/ice 10' from meter
Customer leak 01/02/17 TM

Signature _____

East Logan Water District
WORK ORDER 13091

Account #		Order Date	7/13/2018		
Name	CAMPBELL, GARY	Status	MEDIUM		
Address	-	Scheduled	07/13/18 08 31 AM		
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE		
	Job #				
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT	
WT 84900779	90118869	2867	B14250476		
Description					
Comment	LF HSE 1/2 UP HILL				
Requested By	Daniel	Assigned To	MAINTENANCE CREW	Completed By	MAINTENANCE CREW
Start Date	07/24/18 08 28 AM			Completed Date	07/24/18 08 28 AM

Notes BUD - 1567130041
marked by 7-17-18 at 8 00 am
ATT, LTC
WRECC, TX GAS
LTRWC

Signature _____

East Logan Water District
WORK ORDER 13092

Account #		Order Date	7/13/2018
Name	THOMAS, JEFFREY C	Status	MEDIUM
Address		Scheduled	07/13/18 08:36 AM
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 76352428	72434038	2611	B14169093	

Description
Comment RT WHSE RT CNR OF YD
Requested By Daniel Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 07/24/18 08:29 AM Completed Date 07/24/18 08:29 AM

Notes Patched in 2017, leaking again and needs new tubing pulled

BUD - 1807130043

marked by 07-17-18 at 8.00am

ATT, LTC
TX GAS, LRWC
WRECC

Signature _____

East Logan Water District
WORK ORDER 13137

Account #		Order Date	7/27/2018
Name	HINES, CHRIS L	Status	MEDIUM
Address		Scheduled	07/27/18 11:12 AM
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271736	74600808	1589	B14169985	

Description

Comment LF,WH HSE,LF YD

Requested By ROGER MARTIN Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 08/01/18 08:58 AM Completed Date 08/01/18 08:58 AM

Notes

LANLORD CALLED IN STATED THAT WATER IS STANDING BETWEEN LINES BETWEEN BARN LINE, METERS, AND STREET MR MARTIN STATED THAT HE IS PUTTING A FLAG IN THE AREA OF THE WATER AND THAT NO METERS ARE RUNNING IN THE DUPLEXES
leak has been fixed

Signature _____

East Logan Water District
WORK ORDER 13170

Account #
Name BOISSEAU, BOBBY
Address
Telephone

Order Date 8/3/2018
Status MEDIUM
Scheduled 08/03/18 08:38 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 21046375	08836943	7232	B14168007	

Description

Comment RT HSE LF DR #2

Requested By Mrs Boisseau Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 08/03/18 04:37 PM Completed Date 08/03/18 04:37 PM

Notes Meter box has water in it, please check for leak
Had to pull new line under road

Signature _____

East Logan Water District
WORK ORDER 13232

Account #
Name PRICE, MELVIN
Address
Telephone Job #
Order Date 8/15/2018
Status HIGH
Scheduled 08/15/18 01:32 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45221818	09537773	7558	B14168621	

Description
Comment RT, BRK. LT/YD END BRK WELL?
Requested By JUDY HALEY Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 08/16/18 08 43 AM Completed Date 08/16/18 08 43 AM

Notes WATER LEAK, CALLED IN BY JUDY HALEY. 2705427807

Signature _____

East Logan Water District
WORK ORDER 13454

Account # -
Name SOUTH UNION BRANDS LI C
Address
Telephone

Order Date 10/9/2018
Status MEDIUM
Scheduled 10/09/18 11:04 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271712	74600784	292	B15395673	

Description
Comment

Requested By greg gary Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 10/10/18 10 16 AM Completed Date 10/10/18 10 16 AM

Notes nipple was unscrewed, done leak adj

Signature _____

East Logan Water District
WORK ORDER 13464

Account #
Name HOCHSTETLER, MERVIN D
Address
Telephone Job #
Order Date 10/10/2018
Status MEDIUM
Scheduled 10/10/18 12:04 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979873	61287562	7043	B14170002	

Description
Comment LT, TRLR, R/YD
Requested By
Assigned To MAINTENANCE CREW
Completed By MAINTENANCE CREW
Start Date 10/12/18 09:20 AM
Completed Date 10/12/18 09:20 AM

Notes LEAK REPAIRED 5-10 GPM ,PG

Signature _____

East Logan Water District
WORK ORDER 13472

Account #
Name BAER, LEONARD L
Address
Telephone

Order Date 10/12/2018
Status MEDIUM
Scheduled 10/12/18 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 36583308	09968839	4349	B14166807	

Description
Comment LF, WH/HSE/1ST DR
Requested By MIKE Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 12/12/18 10:20 AM Completed Date 12/12/18 10:20 AM

Notes Someone called Mike to see if its leak
no leak

Signature _____

East Logan Water District
WORK ORDER 13512

Account #		Order Date	10/22/2018		
Name	ORDER, WORK	Status	MEDIUM		
Address		Scheduled	10/22/18 03 25 PM		
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE		
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT	
WT No Num					
Description					
Comment					
Requested By	MIKE HINES	Assigned To	MAINTENANCE CREW	Completed By	MAINTENANCE CREW
Start Date	11/28/18 09 47 AM			Completed Date	11/28/18 09 47 AM

Notes VALVE FOR SAMPLE STATION HAS SMALL LEAK, REPAIR WHEN HAVE EXTRA TIME AND OUT IN THAT AREA

Signature _____

East Logan Water District
WORK ORDER 13580

Account #		Order Date	11/6/2018		
Name	DuFRESNE, DALE D	Status	MEDIUM		
Address		Scheduled	11/06/18 10:55 AM		
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE		
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT	
WT 78641133	73488029	1008	B14168920		
Description					
Comment	LF,WH TRLR.LF@INTER 2 MTRS				
Requested By	MITCH	Assigned To	MAINTENANCE CREW	Completed By	MAINTENANCE CREW
Start Date	11/07/18 09:04 AM		Completed Date	11/07/18 09:04 AM	
Notes	REPAIRED SERVICE LINE-GP DB 2GPM LEAK				

Signature _____

East Logan Water District
WORK ORDER 13764

Account #
Name SWEET, STEVE K
Address
Telephone

Order Date 12/11/2018
Status MEDIUM
Scheduled 12/11/18 01 47 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78785977	73606963	1095	B15369290	

Description

Comment LF, RT OF DRV

Requested By

Assigned To MAINTENANCE CREW

Completed By MAINTENANCE CREW

Start Date 12/12/18 03:55 PM

Completed Date 12/12/18 03:55 PM

Notes cust stated that water meter is under water
just rain water, no leak or chlorine

Signature _____

East Logan Water District
WORK ORDER 13789

Account # ()
Name CAMPBELL, KENNY & MELISSA
Address
Telephone

Order Date 12/26/2018
Status MEDIUM
Scheduled 12/26/18 08 21 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 84304865	89866191	284	B14169699	

Description

Comment RT BRK HS L/CNR L/FIRE HYD

Requested By Chris Hughes Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 12/26/18 09 53 AM Completed Date 12/26/18 09 53 AM

Notes Mike checked, and talked with resident. No sign of a leak

Signature _____

East Logan Water District
WORK ORDER 13007

Account Name: BOBBETT, CLIFFORD G
Address
Telephone

Order Date: 6/14/2018
Status: HIGH
Scheduled: 06/14/18 08.09 AM
Order Type: CHECK METER

METER# WT 67242274 ERT/INTERNAL ID# 60912207 READING 4005 LOCATOR TAG B14167366 READING IN / OUT

Description: LF, WH TRLR, 15' LF 1ST DRIVE

Requested By: Clifford Bobbett Assigned To: MAINTENANCE CREW Completed By: [Signature]

Start Date: / / Time: : Completed Date: 6/24/18 Time: 12:57

Make _____ Size/Type _____ Multiplier _____

Notes: Cust called stated that had mobile home moved yesterday and they ran over meter, stated that he knew he would be responsible for charges

8 - UNION GROVE RD (20' Radius) Replace Meter Box (square) Reading 4186

Inventory Item And Description	Quantity Ordered	Quantity Used
Nov 14		
Dec 5 expense		
EL		
Logan Tele		
1811140780		
Replaced Meter Box		GP/RJ

* Duplicate Copy *

Has this been checked & fixed?

→ REPLACE METER BOX

Was meter fixed?

[Signature]

Signature

East Logan Water District
WORK ORDER 13517

Account # _____
Name ORDER, WORK
Address _____
Telephone _____ Job # _____
Order Date 10/24/2018
Status MEDIUM
Scheduled 10/24/18 11:17 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____

WT No Num _____
Description _____
Comment _____

Requested By _____ Assigned To MAINTENANCE CREW Completed By *LO/RS*

Start Date / / Time : : Completed Date 11/8/18 Time 12:21

Make _____ Size/Type _____ Multiplier _____

Notes
BUD # 1810241020
ATT, BLUEGRASS GAS, LTRW
LOCATED BY 2PM CTS

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>replaced sample station</i>		
<i>1 sample station</i>		

Signature  User1

East Logan Water District
WORK ORDER 13564

Account # 1
Name COLLINS, ERIC T
Address
Telephone Job #

Order Date 11/2/2018
Status MEDIUM
Scheduled 11/02/18 10:13 AM
Order Type RE-READ FOR BILLING

METER# WT 30081862 ERT/INTERNAL ID# 10101177 READING 362 LOCATOR TAG B14169849 READING IN / OUT 3620

Description

Comment RT WH/HS L/CNR

Requested By L

Assigned to MAINTENANCE CREW

Completed by R J G F

Start Date 1/1 Time :

Completed Date 11/2/18 Time 3:45

Make


Size/Type

Multiplier 11/8/18 12:00

Notes

Inventory Item And Description	Quantity Ordered	Quantity Used
Meter needs replaced won't elec. read & small leak		
Dug up & replaced service line & meter		
2 muller 3/4 nuts	2	
3/4 Blue per	5	

MTU: 14169849
LTC
Account # 1811071300



Manned
Todd's place -
meter & MTU

Signature

East Logan Water District
WORK ORDER 13298

Account #
Name MCGEE, RON
Address
Telephone Job #

Order Date 9/5/2018
Status MEDIUM
Scheduled 09/05/18 12:58 PM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 60628201	52913497	4080	B14652863	4080

Description
Comment LF, BRK HSE, 50' LFT DRIVE

Requested By RON MCGEE Assigned To MAINTENANCE CREW Completed By *MJH*

Start Date / / Time : Completed Date 9/13/18 Time 2:27
Fixed on 10-2-18

Make _____ Size/Type _____ Multiplier _____
Notes 2705426917-***2707255752****

CUSTOMER BROKE OFF SHUT OFF VALVE IN HIS HAND WHILE SHUTTING IT OFF HIMSELF

*CONTRACTOR'S Box must be dug up, not enough Room in side Box
to change shut off line*

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>1 shut off VALVE</i>		

*LTC
WRECC
ATMOS (CLEAR)*

Signature *Mike Hoo*

East Logan Water District
WORK ORDER 13464

Account #
Name HOCHSTETLER, MERVIN D
Address
Telephone Job #

Order Date 10/10/2018
Status MEDIUM
Scheduled 10/10/18 12:04 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979873	61287562	7043	B14170002	

Description
Comment LT, TRLR, RYD

Requested By _____ Assigned To MAINTENANCE CREW Completed By GP/RT
Start Date 1/1 Time _____ Completed Date 10/11/18 Time 3:51

Make _____ Size/Type _____ Multiplier _____
Notes Fixed Leak in tuber 5 to 10 pm

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>3/4 she-K bite</u>		<u>1</u>

X Sandy Gap Rd

~~ASD~~
LTC
WRECC

BUD:
1810101194

East Logan Water District
WORK ORDER 13285

Account # _____ Order Date 9/2/2018
 Name TANNER, MARANDA Status MEDIUM
 Address _____ Scheduled 09/02/18 10 11 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 63869446 56501955 7112 B14169551

Description _____
 Comment RT TAN HS L/DRIVE
 Requested By Karla Coles Assigned To MAINTENANCE CREW Completed By MAH CP
 Start Date / / Time : Completed Date 9/2/18 Time :

Make _____ Size/Type _____ Multiplier _____
 Notes Pavement buckling on side, check for leak
REPLIED SERVICE LINE

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>3/4" SERVICE LINE</u>		<u>30'</u>
<u>3/4" COMPRESSION SE COUPLINGS</u>		<u>2</u>

BUD 1809020049
 LTC
 WRECC

Signature 

East Logan Water District
WORK ORDER 13286

Account #		Order Date	9/3/2018
Name	ZIMMERMAN, DAVID	Status	MEDIUM
Address		Scheduled	09/03/18 08:55 PM
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 42033279	09159507	9815	B15042982	

Description

Comment LF GRAY HSE, IN FIELD ON RT OF

Requested by David Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 09/03/18 08:55 PM Completed Date 09/03/18 08:55 PM

Notes Noticed water gushing from side of road

Mike and Gary replaced a 2-3' section of 3" pipe. Rock had split the line. BUD called, DOW notified after hours. 9 customers under a BWA that Linda called in.

Signature _____

East Logan Water District
WORK ORDER 13297

Account # _____ Order Date 9/4/2018
Name MALLORY, GILBERT Status MEDIUM
Address _____ Scheduled 09/04/18 02:04 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 37668903	09193966	3004	B14166783	

Description _____
Comment RT, BRK HSE, 20FT RT OF DRIVE.
Requested By DORRIS SCARBROUGH Assigned to MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date 9/5/18 Time 2:30

Make _____ Size/Type _____ Multiplier _____

Notes SERVICE LINE LEAK, CALLED IN BY DORRIS SCARBROUGH 270-221-5155
DANIEL CHECK OUT CALLIN IN BUD

Repair service line 16PM

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4 Compression Caplin</i>		<i>1</i>
<i>3/4 Muller Nut</i>		<i>1</i>
<i>30FT Pipe</i>		

Signature *CP/UB D. P. P.*

East Logan Water District
WORK ORDER 13305

Account #
Name WRIGHT, CYNTHIA P
Address
Telephone Job #

Order Date 9/5/2018
Status MEDIUM
Scheduled 09/05/18 04 51 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 65798133 ERT/INTERNAL ID# 58647051 READING 5317 LOCATOR TAG B14167044 READING IN / OUT


Description
Comment LF BRK L/DR

Requested By Daniel Assigned To MAINTENANCE CREW Completed By DTS & GFP

Start Date ___/___/___ Time ___:___ Completed Date 9/7/18 Time 1:00

Make _____ Size/Type _____ Multiplier _____
Notes REPAIRED SERVICE LINE 45 GPM
(REPLACED)

Inventory Item And Description	Quantity Ordered	Quantity Used
10' 3/4" SERVICE LINE		10'

Signature 

East Logan Water District
WORK ORDER 13311

Account # _____ Order Date 9/10/2018
 Name REED, BARRY Status MEDIUM
 Address _____ Scheduled 09/10/18 08:56 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50180713	63717590	2027	B14169615	

Description _____
 Comment LF, WHSE, LF YD
 Requested By BARRY REED Assigned To MAINTENANCE CREW Completed By *MBH*
 Start Date / / Time : : Completed Date / / Time : :

Make _____ Size/Type _____ Multiplier _____

Notes CHECK FOR LEAK ACROSS RD, MAIN LINE

REQUIRED SERVICE LINE

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4" SERVICE LINE</i>		<i>5'</i>
<i>3/4" COMPRESSION COUPLING</i>		<i>1</i>

Bud Confirmation # 1809101047

ELW
LTC
WRECC

Signature *YMBH HS*

East Logan Water District
WORK ORDER 13310

Account #
Name STEELE, JAY E.
Address
Telephone

Order Date 9/10/2018
Status MEDIUM
Scheduled 09/10/18 08:38 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 22201478	63814719	4771	B14167373	

Description
Comment RT, TAN HSE, RT CNR IN FIELD

Requested By Jay Assigned To MAINTENANCE CREW Completed By DIS 9 GP
Start Date 9/11/18 Time 1:00 Completed Date 9/11/18 Time 1:00

Make _____ Size/Type _____ Multiplier _____

Notes BUD called
CLAMPED 3" BELL -- MAIN BREAK 1 GP

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>1-3" BELL CLAMP</u>		

Signature 

East Logan Water District
WORK ORDER 13525

Account #
Name MALLORY, GILBERT
Address
Telephone Job #

Order Date 10/29/2018
Status MEDIUM
Scheduled 10/29/18 09:33 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 37668903 ERT/INTERNAL ID# 09193966 READING 3028 LOCATOR TAG B14166783 READING IN / OUT

Description
Comment RT, BRK HSE, 20FT RT OF DRIVE,
Requested By phillip mallory Assigned To MAINTENANCE CREW Completed By GP/RD
Start Date 1/1 Time : Completed Date 10/30/18 Time 12:00

Make Size/Type Multiplier
Notes 1/2 between meter and ditch, Gary said that only pinhole leak, called in BUD

Inventory Item And Description	Quantity Ordered	Quantity Used
WRBCC - Cleared 1 to 2 gal min		
3/4 coupling		2
3/4 INSERTS		2

Oct 31 @ 9:45

4
18' - narrow
coreandmain.com

Knowledge
Experience
Service, Nationwide

✓ All
✓ LTC
LTL
wrecc

3173 Echo Valley Rd.

W. Mallory

1/2 between
meter & ditch

Phillip Mallory

772-0251

Signature

East Logan Water District
WORK ORDER 13660

Account #
Name SKIPWORTH, DJ & JENNIFER
Address
Telephone Job #

Order Date 11/29/2018
Status MEDIUM
Scheduled 11/29/18 01:33 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 34889951	63814717	6463	B14167120	

Description
Comment RT,WH/HSE LF/CIRCLE DR
Requested By ANN DROGE Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes ACROSS THE ROAD LEAK BUD CALLED IN EXCAVATION CLEARED, CALLED IN BY ANN DROGE ;

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 13453

Account #
Name PHILLIPS, MONTANA C
Address
Telephone Job #

Order Date 10/9/2018
Status MEDIUM
Scheduled 10/09/18 07:53 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81271633 ERT/INTERNAL ID# 74600705 READING 691 LOCATOR TAG B14969515 READING IN / OUT

Description

Comment LFT WHITE TRLR MID YD

Requested By neighbor

Assigned To MAINTENANCE CREW

Completed By GP/RT

Start Date 10/9/18 Time 9:30

Completed Date 10/9/18 Time 12:49

Make _____ Size/Type _____ Multiplier _____

Notes _____

neighbor's phone # 404-462-1111 (B. Green)

Inventory Item And Description	Quantity Ordered	Quantity Used
Long side leak Leaking by the Meter. 5 to 10 gpm		
Closest crossroad Friendship Rd		
3/4 coupling cone the still		1
3/4 pipe blue about 1 ft		1 ft
3/4 cone nut		1
3/4 clamp		1

front left in white
30' ft. both sides of Rd.

Out 30 /ale remark

Atmos
LTC
w/leak

1810090702
20 W (est)

Signature

[Handwritten Signature]

East Logan Water District
WORK ORDER 13504

Account #
Name GIBSON, JIMMY D
Address
Telephone

Order Date 10/19/2018
Status MEDIUM
Scheduled 10/19/18 09:07 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 42033331	09177363	1966	B14168642	

Description

Comment LF HSE, RT YD @ PP

Requested By MS CUNDIFF

Assigned To MAINTENANCE CREW

Completed By *MS / R.T*

Start Date / / Time :

Completed Date 10/19/18 Time 1:53

Make _____ Size/Type _____ Multiplier _____

Notes SERVICE LINE LEAK,
BUD: 1810190499
ATT. ATMOS, LOGAN TELE, RVILL SEWER

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4 Muller coupling</i>		<i>1</i>
<i>3/4 Clamp one bolt</i>		<i>1</i>
<i>Cup of grass seed</i>		<i>1</i>

Signature



East Logan Water District
WORK ORDER 13533

Account # _____ Name FUGATE, MARY Order Date 10/30/2018
Address _____ Status MEDIUM
Telephone _____ Job # _____ Scheduled 10/30/18 10:36 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 49616592 ERT/INTERNAL ID# 10271972 READING 686 LOCATOR TAG B14166211 READING IN / OUT _____

Description _____
Comment BRK HSE, 40'RT OF DR O/FENCE T

Requested By steve fugate Assigned to MAINTENANCE CREW Completed By GP/RJ
Start Date ___/___/___ Time ___:___ Completed Date 10/30/18 Time 2:30

Make _____ Size/Type _____ Multiplier _____
Notes cust states that it's a main water leak, not in front of house, kinda fieldy area, can contact steve a

Inventory Item And Description	Quantity Ordered	Quantity Used
10 to 20 gpm		3
3/4 inserts		1
3/4 coupling		1
3/4 muller Nut		

820

16th ext
Logan Tele
Wheeler
181 030 0916

Signature 

East Logan Water District
WORK ORDER 13316

Account #
Name COSTELLOW, JAMES T
Address
Telephone Job #

Order Date 9/11/2018
Status MEDIUM
Scheduled 09/11/18 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 63869517 ERT/INTERNAL ID# 63183737 READING 4030 LOCATOR TAG B14169387 READING IN / OUT 4049

Description

Comment LF, BRK HSE, RT DR

Requested By TAMMY COSTELLOW

Assigned To MAINTENANCE CREW

Completed By *MN* 09/11/18

Start Date *9/11/18* Time *12:30*

Completed Date *9/11/18* Time *11:48*

Make _____ Size/Type _____ Multiplier *9/25/18 10:15*

Notes LEWISBURG SIDE, DOWN BELOW WHERE THEIR METER IS AROUND WHERE THEY QUIT MOWING
THERE IS WATER STANDING

TAMMY COSTELLOW-2708891561

*Leak is service line for 5127 Ties
in to main line
not at cust meter, they replaced
their meter leak @ their meter couple
months ago.*

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>2-3/4 coupling and about 2 to 2.5 foot of 3/4 blue pipe</i>		<i>2</i>

Signature

[Signature] GP/DB
M. P. [Signature]

East Logan Water District
WORK ORDER 13145

Account # _____
Name DEWEESE, DANIEL T
Address _____
Telephone _____ Job # _____

Order Date 7/31/2018
Status HIGH
Scheduled 07/31/18 08 04 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78786020	73607006	705	B14168805	

Description

Comment RT, TAN D/WIDE MIDDLE YARD

Requested By daniel Assigned to MAINTENANCE CREW Completed By *[Signature]*

Start Date / / Time : Completed Date 7/31/18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes

LEAK 8 GPM

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>30' - 1" SERVICE TUBING</i>		
<i>2 - 1" x 3/4" COMP. COUPLINGS</i>		

Signature *[Signature]*

East Logan Water District
WORK ORDER 13251

Account # _____ Order Date 8/21/2018
 Name NISSLEY, AMOS Status MEDIUM
 Address _____ Scheduled 08/21/18 03:27 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 28577168	39220350	4078	B14168749	

Description _____

Comment RT, METAL BLD, ACROSS/L YD 10'

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____

Start Date ___/___/___ Time ___:___ Completed Date 8/23/18 Time ___:___

Make _____ Size/Type _____ Multiplier DC MH

Notes CHECK FOR LEAK ON OUR SIDE, MAN CALLED IN STATED THAT CLOSE TO DITCH AND ON OUR SIDE OF METER THAT WATER IS RUNNING IN PRETTY GOOD-CS

REPLACE SERVICE LINE

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>3/4" SERVICE LINE</u>		<u>20'</u>

X - GOODMAN RD.

LTC 1808211692

Signature Mike H

East Logan Water District
WORK ORDER 13134

Account # _____
Name JENKINS, LINDELL
Address _____
Telephone _____

Order Date 7/27/2018
Status MEDIUM
Scheduled 07/27/18 08:15 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 63869482 ERT/INTERNAL ID# 56501991 READING 8206 LOCATOR TAG B14167369 READING IN / OUT _____

Description _____
Comment RT BRK MYD

Requested By _____ Assigned To MAINTENANCE CREW Completed By MH DB
Start Date 7/27/18 Time _____ Completed Date 7/27/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes fix leak
Air Relief valve 8/31/18 Andy completed

Inventory Item And Description	Quantity Ordered	Quantity Used

Air Relief Valve Damaged

It is turned off

before
Intersection of
X Sharp Jordan + Anderson Street

1807270557



1 July 31st 10 am

LTC
Mid Valley Pipeline
WRECC

Signature [Handwritten Signature]

East Logan Water District
WORK ORDER 13210

Account #
Name TAYLOR -- TP, CAROLYN
Address
Telephone Job #

Order Date 8/9/2018
Status MEDIUM
Scheduled 08/09/18 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170325	09133430	7377	B14167454	

Description:
Comment LF TRLR LYD
Requested By Carolyn Assigned to MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 08/09/18 02:49 PM Completed Date 08/09/18 02:49 PM

Notes leak is on our side of the line, bud callhas been made-cs

2 $\frac{3}{4}$ Flat Nuts

2- $\frac{3}{4}$ Flat Nuts

2- $\frac{3}{4}$ inserts

3.0 gallons per minute

Signature



East Logan Water District
WORK ORDER 13227

Account #
Name GARDNER, BOBBY & APRIL
Address
Telephone Job #

Order Date 8/14/2018
Status MEDIUM
Scheduled 08/14/18 12 10 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 000050056614	52260066	4905	B14169745	

Description

Comment LF,WH HSE,M/YD

Requested By Bobby Gardner

Assigned To MAINTENANCE CREW

Completed By *WH*

Start Date ___/___/___ Time ___:___

Completed Date 8/14/18 Time 10:00

Make _____ Size/Type _____ Multiplier _____

Notes Down from meter in tall grass is leaking

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>8" Service Line 2 nuts</i>		

Signature *W. H. Gardner*

East Logan Water District
WORK ORDER 13268

Account # _____
 Name STRATTON, WALLACE D
 Address _____
 Telephone _____ Job # _____
 Order Date 8/28/2018
 Status MEDIUM
 Scheduled 08/28/18 12:38 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 39340882 ERT/INTERNAL ID# 73543854 READING 732 LOCATOR TAG B14169005 READING IN / OUT _____

Description _____
 Comment LF, TAN HSE, RT DR
 Requested By BUD Assigned To MAINTENANCE CREW Completed By _____

Start Date ___/___/___ Time ___:___:___ Completed Date ___/___/___ Time ___:___:___

Make _____ Size/Type _____ Multiplier _____

Notes LEAK ON OUR SIDE, LEAK ON CUST SIDE IN APRIL
 BUD#1808271789

Inventory Item And Description	Quantity Ordered	Quantity Used
1 3/4 coupling		
2 3/4 inserts		
2 gal per min		

Signature GPaid AC

East Logan Water District
WORK ORDER 13275

Account#
Name BASSHAM, CHRIS & GLENDA
Address
Telephone Job #

Order Date 8/30/2018
Status HIGH
Scheduled 08/30/18 09:44 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 26126750 ERT/INTERNAL ID# 39202622 READING 4310 LOCATOR TAG B14169971 READING IN / OUT

Description

Comment RT, WH HSE, LF CNR

Requested By Steve Hunt Assigned to MAINTENANCE CREW Completed By GPO / D E

Start Date / / Time : Completed Date 8/31/18 Time 4:00

Make _____ Size/Type _____ Multiplier _____

Notes X Old Quality Rd (2377)
across from red barn, in front of gates, watch for electric fence and don't let bulls out of field

REPLACED SERVICE LINE

Inventory Item And Description	Quantity Ordered	Quantity Used
3/4" PE SERVICE LINE		80'
@ 3/4" COMPRESSION NUTS		2

across from red barn
in front of gates
marked in white

1800300580

LTC

Signature 

East Logan Water District
WORK ORDER 13278

Account # ---
 Name ORDER, WORK
 Address
 Telephone Job #
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT No Num
 Description
 Comment
 Requested By Danny Haley Assigned To MAINTENANCE CREW Completed By *CP Dineal*
 Start Date / / Time : Completed Date / / Time :

Make _____ Size/Type _____ Multiplier _____
 Notes On Cave Springs Rd, 1/4 mile past Browning Rd away from 68/80, wet spot on/by road in front of trailer. Danny Haley (...99 Bucksv Rd)
Replace service line 11:30

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>1 Compress 3/4</i>		<i>5</i>
<i>1 Compress Nut 3/4</i>		<i>1</i>
<i>1 Muller Nut 3/4</i>		<i>1</i>
<i>60 FT PE</i>		

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13281

Account #
Name BELCHER, WAYNE
Address
Telephone

Order Date 8/30/2018
Status MEDIUM
Scheduled 08/30/18 02:20 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 81568829 74698200 1270 B14168537

Description
Comment LF, BRK HSE, LF IN FIELD, O/FE

Requested by WAYNE BELCHER Assigned To MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes CUST CALLED STATED THTA END OF MARSHALL RD THAT THERE IS WATER RUNNING INTO FIELD AND HAS BEEN RUNNING FOR A WHILE

Inventory Item And Description	Quantity Ordered	Quantity Used
Inserts 3/4		2
Caplin 3/4		1
Bolt Clamp 3/4 x 3		1

179
end of Marshall
left hand side
TIC # 180 831 1175

ELWD
LTC

3104 GPM

Signature AC/GB

East Logan Water District
WORK ORDER 13254

Account #
Name SUAREZ, ELAINE
Address
Telephone

Order Date 8/22/2018
Status HIGH
Scheduled 08/22/18 10:33 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 78786040
ERT/INTERNAL ID# 73607026
READING 747
LOCATOR TAG B15347551
READING IN / OUT

Description
Comment RT, GRAY TRLR. LF DR


Requested By COURTNEY
Assigned To MAINTENANCE CREW
Completed By DB GP

Start Date 8/22/18 Time 10:33
Completed Date 9/11/18 Time

Make _____ Size/Type _____ Multiplier _____
Notes BUD-1808220931

Inventory Item And Description	Quantity Ordered	Quantity Used
7' 3" PIPE		7'
1- 3" KNOCK-ON		1

Boil Water Samples Pulled
10 Customers

Signature 

East Logan Water District
WORK ORDER 13262

Account # -----
Name TAYLOR, JOSEPH R
Address -----
Telephone ----- Job # -----

Order Date 8/24/2018
Status MEDIUM
Scheduled 08/24/18 09:11 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 54179256	63803449	3564	B14169938	3594

Description
Comment LF ACROSS FROM LAST MTR 2ND MT
Requested By NOLA TAYLOR Assigned To MAINTENANCE CREW Completed By MH/GP
Start Date 8/25/18 Time 10:30 Completed Date 8/25/18 Time 10:30

Make _____ Size/Type _____ Multiplier _____

Notes
CHECK FOR LEAK NEXT TO ROAD. LEAKING BETWEEN ROAD AND METER
Leak on our side, ~~seen~~ MARKED in white paint

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>6" 3/4" SERVICE Line 2 nuts 2 inserts</u>		

X James
MATLOCK
1808241700
LTC

Replaced Service line
FROM MAIN to meter
~~8-28-18~~ 8-28-18
MH/GP

Signature Mikolb

East Logan Water District
WORK ORDER 13253

Account #
Name BRAY, TIM
Address
Telephone

Order Date 8/22/2018
Status HIGH
Scheduled 08/22/18 10:29 AM
Order Type CHECK FOR LEAK ON OUR SIDE

Job #

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 33123408	09141087	6319	B14166010	

Description

Comment RT,GRAY/HSE M/YD

Requested By COURNTEY

Assigned To MAINTENANCE CREW

Completed By *MJD*

Start Date ___/___/___ Time ___:___

Completed Date 8/23/18 Time 4:00

Make _____ Size/Type _____ Multiplier: _____
Notes BUD 1808220922

Inventory Item And Description	Quantity Ordered	Quantity Used

MJD

Signature

East Logan Water District
WORK ORDER 13240

Account #
Name WILLIAMS, ALEIGHA R
Address
Telephone

Job #

Order Date 8/19/2018
Status MEDIUM
Scheduled 08/19/18 10.56 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979887	63340008	1631	B14168209	

Description

Comment RT, WH/HSE, L/1st DR

Requested By DANIEL

Assigned To MAINTENANCE CREW

Completed By *MH*

Start Date / / Time :

Completed Date 8/29/18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes BUD: 1808171226
REPAIR WATER LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used

[Handwritten Signature]

Signature _____

East Logan Water District
WORK ORDER 13241

Account #
Name **ARNOLD SCOTT**
Address
Telephone

Order Date 8/19/2018
Status MEDIUM
Scheduled 08/19/18 10 57 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 26077940 ERT/INTERNAL ID# 08710990 READING 4638 LOCATOR TAG Finaled 4/10/20 READING IN / OUT

Description
Comment Finaled 4/10/2006
Requested By DANIEL Assigned To MAINTENANCE CREW Completed By *M-H*
Start Date / / Time : Completed Date 8/19/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes REPAIR WATER LEAK
BUD 1808171239
Potholes

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13343

Account # _____ Order Date 9/12/2018
 Name BOISSEAU, BOBBY Status MEDIUM
 Address _____ Scheduled 09/12/18 04:37 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 21046375	08836943	7273	B14168007	

Description

Comment RT HSE LF DR #2

Requested By Linda Assigned to MAINTENANCE CREW Completed By *MH*
 Start Date ____/____/____ Time ____:____ Completed Date *9/13/18* Time *2:29*

Make _____ Size/Type _____ Multiplier _____

Notes Mrs. Boisseau thinks we are still leaking where we pulled a new line under the road. Please check water in box for chlorine

Chlorine & Sound shows A Leak

Inventory Item And Description	Quantity Ordered	Quantity Used

*LTC
WRCC*

Signature *YM use [Signature]*

East Logan Water District
WORK ORDER 13352

Account # 0
Name FERGUSON, WILLIAM S
Address
Telephone Job #

Order Date 9/17/2018
Status MEDIUM
Scheduled 09/17/18 03 53 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 52473784 ERT/INTERNAL ID# 07306105 READING 7719 LOCATOR TAG B14168909 READING IN / OUT

Description
Comment LFT, WHITE HSE L/DR

Requested By DANIEL Assigned To MAINTENANCE CREW Completed By *mtt/ep*
Start Date / / Time : Completed Date 9/12/18 Time 1:00

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>2' 3/4" water line</i>		
<i>1 3/4" coupling</i>		
<i>1 3/4" nut</i>		

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13355

Account #
Name MOORE, BETTY J
Address
Telephone

Order Date 9/18/2018
Status HIGH
Scheduled 09/18/18 02:32 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 23195735 ERT/INTERNAL ID# 08684782 READING 5546 LOCATOR TAG B14167125 READING IN / OUT

Description
Comment LF, BRK HSE, RT CNR

Requested By Linda Assigned To MAINTENANCE CREW Completed By *MA*
Start Date / / Time : Completed Date 9/19/18 Time 9:00


Make _____ Size/Type _____ Multiplier _____

Notes Water in ditch, please see if we or she has a leak.
Definitive Leak - SERVICE LINE LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4" SERVICE LINE</i>		<i>3'</i>
<i>2 1/2" x 6" FULL CIRCLE CLAMP</i>		<i>1</i>

ATT (CLEAR)
LTC
LTRW
WRECC
TGT
conf.#
1809192025

Mike is checking



Signature *Mike H*

East Logan Water District
WORK ORDER 13355

Account # ()
Name COLEMAN, CLARENCE R
Address
Telephone Job #

Order Date 9/18/2018
Status MEDIUM
Scheduled 09/18/18 08:38 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78461108	73488004	212	B14168795	

Description

Comment RT BRK RT OF 1st DR

Requested By MIKE HINES

Assigned To MAINTENANCE CREW

Completed By GP

Start Date ___/___/___ Time ___:___

Completed Date 9/18/18 Time 2:51

Make _____ Size/Type _____ Multiplier _____

Notes BUD 1809171976

Inventory Item And Description	Quantity Ordered	Quantity Used
90' 3/4 WATER line		
2 3/4 NUTS		

LTC
wRecc

Signature 

East Logan Water District
WORK ORDER 13356

Account # 0
Name DELANEY, PAMELA L
Address
Telephone Job #

Order Date 9/18/2018
Status MEDIUM
Scheduled 09/18/18 03:39 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 50056582 10036442 253 B14169592

Description
Comment LFT BRK IN CURVE RT OF 1st DR

Requested By Daniel Brown Assigned To MAINTENANCE CREW Completed By *MH/GF*
Start Date / / Time : Completed Date 9/18/18 Time 4:00

Make _____ Size/Type _____ Multiplier _____

Notes Leak at property, BUD called

Inventory Item And Description	Quantity Ordered	Quantity Used
30' 3/4 WATER LINE		
1 3/4 COUPLING		
1 3/4 NUT		
1 3/4 CLAMP		

MH/GF

Signature

Water District
WORK ORDER 13359

Name: WOODWARD, STEVEN S

Address

Telephone

Job #

Order Date 9/20/2018

Status MEDIUM

Scheduled 09/20/18 09:26 AM

Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 49846584	63097887	3791	B14166676	

Description

Comment LF, WH/HS L/DR READ 2

Requested By mr woodward

Assigned To MAINTENANCE CREW

Completed By *M D*

Start Date / / Time :


Completed Date 9/20/18 Time 12:00

Make _____ Size/Type _____ Multiplier _____

Notes meter box is full of water cust said that meter is leaking in box

Inventory Item And Description	Quantity Ordered	Quantity Used
12' Line		
1 3/4 nut		

Signature



East Logan Water District
WORK ORDER 13363

Account #
Name JACKSON JAMES
Address
Telephone Job #

Order Date 9/24/2018
Status MEDIUM
Scheduled 09/24/18 07:52 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 31152888 ERT/INTERNAL ID# 09964879 READING 2109 LOCATOR TAG B14166435 READING IN / OUT

Description
Comment RT, WH HSE, LF CNR YD

Requested By James Jackson Assigned To MAINTENANCE CREW Completed By

Start Date / / Time : Completed Date 9/28/18 Time 3:30

Make _____ Size/Type _____ Multiplier _____

Notes left letter, east of address in field, west of brick house

Inventory Item And Description	Quantity Ordered	Quantity Used
Repair 6 in main one knock on and about 10ft of pipe.		1

Signature

[Handwritten Signature] 6/1/DB

East Logan Water District
WORK ORDER 13364

Account # C
Name MANNING, DARLENE
Address
Telephone

Order Date 9/24/2018
Status MEDIUM
Scheduled 09/24/18 08:56 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 33973712 ERT/INTERNAL ID# 08821599 READING 551 LOCATOR TAG B14167737 READING IN / OUT

Description

Comment LT,GRAY TRLR,LT/DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By *MH*

Start Date / / Time : : Completed Date 9/23/18 Time 11:30

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
1 6x15 C/amp		

Signature *Wmiko*

East Logan Water District
WORK ORDER 12974

Account #
Name SKIPWORTH, BILLY W
Address
Telephone

Order Date 6/7/2018
Status HIGH
Scheduled 06/07/18 10:25 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 41855160 ERT/INTERNAL ID# 09881718 READING 8714 LOCATOR TAG B14166232 READING IN / OUT

Description
Comment LF, WH HSE OFF RD, RT FLD

Requested By Billy Skipworth Assigned To MAINTENANCE CREW Completed By

Start Date 6/8/18 Time : : Completed Date 6/8/18 Time : :

Make _____ Size/Type _____ Multiplier _____

Notes cust called stating that water leak on our side meter not turning but water is spilling

Inventory Item And Description	Quantity Ordered	Quantity Used

BUD across from 1418 Merton

ATT
Bluegrass Gas
TX Gay
LTRWC

1806070939

request located by 8 am 6-8-18 Friday

*busted metal
bottom*

Signature

AC

East Logan Water District
WORK ORDER 12810


Account # ()
Name BIVENS, CLARENCE A
Address
Telephone Job #

Order Date 4/20/2018
Status MEDIUM
Scheduled 04/20/18 09.50 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50055734	61512460	4345	B14169933	
Description		4384		
Comment	LF,WH HSE,RT CNR			
Requested By	clarence	Assigned To	MAINTENANCE CREW	Completed By
Start Date	4/20/18	Time		Completed Date 4/20/18 Time

Make _____ Size/Type _____ Multiplier _____
Notes check for leak

Inventory Item And Description	Quantity Ordered	Quantity Used
Leak on are side		

 Home sid left on water cr... left at stop sign
3 way stop go right

Bud # 1802451016
Notified - Logan Tele

No leak

Signature A.C

East Logan Water District
WORK ORDER 12498

Account #
Name HARDIN, KAREN S
Address
Telephone

Order Date 1/31/2018
Status MEDIUM
Scheduled 01/31/18 04:00 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 52473801 ERT/INTERNAL ID# 61287517 READING 3875 LOCATOR TAG B14172336 READING IN / OUT

Description
Comment RT, ROCK HSE, LF CNR

Requested By Andy Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date 1/31/18 Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

DKL Leak!

Order: 00470497 Line: 004	Order: 00470497 Line: 004
Date: 0118 	Date: 0118 
Part No: A2PXX38GGXXX1XX	Part No: A2PXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL 100GLPK DP/P 5WHL 4A 6'SEN L/HSG PK	Desc: MTR 5/8-3/4 AS ER-TRPL 100GLPK DP/P 5WHL 4A 6'SEN L/HSG PK
Sensus 	Sensus 
Meter SN: 84200071	Meter SN: 84200071
Flow: 	Flow: 
Low: 099.4 Mid: 101.0 Hi: 099.7	Low: 099.4 Mid: 101.0 Hi: 099.7
Register 	Register 
Cust ID: 89837134	Cust ID: 89837134
Register Fact ID: 89837134	Register Fact ID: 89837134
Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature AC

East Logan Water District
WORK ORDER 12571

Account # _____ Order Date 2/21/2018
 Name MILLER, DAVID Status MEDIUM
 Address _____ Scheduled 02/21/18 02 15 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 35188817 09726482 6595 B14170065 _____

Description _____
 Comment LF WH HSE. (OLD STORE) LF PRK
 Requested By Laura Miller Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes water around gazebo at market check for leak

Inventory Item And Description	Quantity Ordered	Quantity Used
	40 Ft 3/4 Tubeins	
	2- 3/4 inserts	
	2- 3/4 Serror	
	1- 12"-3/4 nipple	
	1- new meter	
	1- Standard BOX and Lid	
<i>WATER # 14170065</i>		

BUD -
ATT
Service to

6596 - old
0 - new R



Order: 00452685 Line: 002 Order: 00452685 Line: 002
 Date: 0817 Date: 0817
 Part No: A2DXX38GGXXX1XX Part No: A2DXX38GGXXX1XX
 Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK
 DP/R 5WHL4A 100G 6'SEN L/HSGPK DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 83545688 Sensus Meter SN: 83545688
 EID: _____ EID: _____
 Len: 097.9 Wid: 100.7 Ht: 100.0 Len: 097.9 Wid: 100.7 Ht: 100.0
 Registered Cust ID: 89536800 Registered Cust ID: 89536800
 Registered Part ID: 89536800 Registered Part ID: 89536800
 Barcode: [X][X][X][X][] [] [] [] [] [] [] [] [] [] Barcode: [X][X][X][X][] [] [] [] [] [] [] [] [] []

Signature *AC 1711*

East Logan Water District
WORK ORDER 12882

Account # 1
Name GOODALL, JAYME
Address
Telephone

Order Date 5/9/2018
Status MEDIUM
Scheduled 05/09/18 02.30 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 32089179 ERT/INTERNAL ID# 63238017 READING 5919 LOCATOR TAG B14170205 READING IN / OUT 6000 5924

Description
Comment LF, WH HSE OFF RD, LF DR, AT H

Requested By Daniel Assigned To MAINTENANCE CREW Completed By **DB TM**

Start Date 1/1/ Time : Completed Date 5/10/18 Time 10:23

Make _____ Size/Type _____ Multiplier _____
Notes service tube leak BUD called

Inventory Item And Description	Quantity Ordered	Quantity Used
6' 3/4" SERVICE LINE		
1- 5/8" WM		
LEAK = 4 GPM		
NEW ID# 89866172		



Order: 00473309 Line: 003
Date: 0118
Part No: A2PXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL 100GLPK
DP/P 5WHL 4A 6'SEN L/HSG PK

Order: 00473309 Line: 003
Date: 0118
Part No: A2PXX38GGXXX1XX
Desc: MTR 5/8-3/4 AS ER-TRPL 100GLPK
DP/P 5WHL 4A 6'SEN L/HSG PK

Sensus
Meter SN: 84304846
Flow:
Low: 100.1 Mid: 100.9 Hi: 099.5
Register
Cust ID: 89866172
Register
Fact ID: 89866172
Config:

Sensus
Meter SN: 84304846
Flow:
Low: 100.1 Mid: 100.9 Hi: 099.5
Register
Cust ID: 89866172
Register
Fact ID: 89866172
Config:

Signature

East Logan Water District
WORK ORDER 12936

Account #
Name COOPER, MARION
Address
Telephone

Order Date 5/25/2018
Status MEDIUM
Scheduled 05/25/18 05:43 PM
Order Type READ OUT, LOCK, FINAL OUT

METER# WT 25547327 ERT/INTERNAL ID# 10649916 READING 8724 LOCATOR TAG B14166215 READING IN / OUT

Description
Comment LFT WHSE RT CENTER YD

Requested By Marion Assigned To MAINTENANCE CREW Completed By

Start Date / / Time : Completed Date 5/29/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
7ft 3/4 Tubing		
1- 3/4-12" Nipple		
1- new 3/4 meter		
1- 3/4 Setter		
1- 3/4 connector Brass Stub		
1- 3/4 Regulator		
1- Standard box and lid		
2- 3/4 inserts		
1- 3/4 Schedule 80 PVC Fitting		

Sensus
www.sensus.com
1-800-METERIT



Order: 00483082 Line: 002
Part: Date: 0418

AX2XX38P1GGXSXD
MTR 5/8-3/4 AS ER+ TRPL 6'
5WHL4A 100G LHP
SMART DP/P

Config: H8A2BAAA

Sensus
Meter SN: 84708337

Flow:
Low 100.5 Mid:101.3 H1:099.5

Register
Cust ID: 90041834

Register
Fact ID: 90041834

Order: 00483082 Line: 002
Part: Date: 0418

AX2XX38P1GGXSXD
MTR 5/8-3/4 AS ER+ TRPL 6'
5WHL4A 100G LHP
SMART DP/P

Config: H8A2BAAA

Sensus
Meter SN: 84708337

Flow:
Low 100.5 Mid:101.3 H1:099.5

Register
Cust ID: 90041834

Register
Fact ID: 90041834

old m
10649
3702

Signature AC

East Logan Water District
WORK ORDER 12966

Account # 00000001
Name SCOTT, JERRY
Address
Telephone

Order Date 6/6/2018
Status HIGH
Scheduled 06/06/18 08.03 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48431584	09512499	1593	B14167877	11803

Description
Comment RT, BRK L/DR T/LF
Requested By Jerry Scott Assigned To MAINTENANCE CREW Completed By
Start Date 6/16/18 Time : Completed Date / / Time :

Make _____ Size/Type _____ Multiplier _____
Notes Cust called in stated that appears to be a leak between meter and main line

Inventory Item And Description	Quantity Ordered	Quantity Used

Short side

new marked in white

X- J will

Replaced Service
Main & part new

Also put a new

Old - 11803

New - 0

Sensus www.sensus.com

Order: 00473309 Line: 003 Order: 00473309 Line: 003

Date: 0118 Date: 0118

Part No: A2PXX38GGXXX1XX No: A2PXX38GGXXX1XX

Desc: MTR 5/8-3/4 AS ER-TRPL 100GLPK MTR 5/8-3/4 AS ER-TRPL 100GLPK

DP/P 5WHL 4A 6'SEN L/HSG PK DP/P 5WHL 4A 6'SEN L/HSG PK

Sensus Meter SN: 84304847 Sensus Meter SN: 84304847

Flow: Flow:

Low: 099.3 Mid: 100.9 H1: 099.4 Low: 099.3 Mid: 100.9 H1: 099.4

Register Cust ID: 89866173 Register Cust ID: 89866173

Register Fact ID: 89866173 Register Fact ID: 89866173

Config: Config:



Signature *Tom [unclear]*

East Logan Water District
WORK ORDER 13018

Account # _____ Order Date 6/19/2018
Name DENNING, DAVID L Status HIGH
Address _____ Scheduled 06/19/18 03.09 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 52473844 07294500 5716 B14172311
Description _____
Comment LT,WH/HSE.LT/CNR
Requested By Ron Denning Assigned To MAINTENANCE CREW Completed By _____
Start Date 6/19/18 Time _____ Completed Date 6/19/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

*Customer name is Ron (270) 847-9152
Starts w/ pressure then has none or very little*

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Changed meter & checked pressure. Had around 10 psi coming out.</i>		
<i>Cust. stated its really only in shower. So suggested to clean shower head or change it out.</i>		

*old - 5
new - 0*

Sensus
www.sensus.com
1-800-METERIT



Certified to NSF/ANSI 61-G

Order: 00488049 Line: 002

Part: _____ Date: 0518



AX2XX38P1GGXSXD

MTR 5/8-3/4 AS ER+ TRPL 6'


5WHL4A 100G LHP

SMART DP/P

Config: H8A2BAAA

Order: 00488049 Line: 002

Part: _____ Date: 0518



AX2XX38P1GGXSXD

MTR 5/8-3/4 AS ER+ TRPL 6'

5WHL4A 100G LHP

SMART DP/P

Config: H8A2BAAA

Sensus
Meter SN: 84900780

Flow:
Low:100.2 Mid:101.4 Hi:099.6

Register
Cust ID: 90118870
Register
Fact ID: 90118870

Sensus
Meter SN: 84900780

Flow:
Low:100.2 Mid:101.4 Hi:099.6

Register
Cust ID: 90118870
Register
Fact ID: 90118870

Signature

East Logan Water District
WORK ORDER 12394

Account # _____ Name LEE, CAROL T Address _____ Telephone _____ Job # _____ Order Date 1/2/2018 Status MEDIUM Scheduled 01/02/18 09:49 AM Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 46202702 ERT/INTERNAL ID# 63097941 READING 4210 LOCATOR TAG B14168250 READING IN / OUT 2 / 4249
Description Water freezing around/in meter box
Comment LT, 100 YDS PAST OLD BRN T/A T
Requested By Linda Assigned To MAINTENANCE CREW Completed By D B A C
Start Date 01 / 02 / 18 Time 9 : 00 Completed Date 01 / 02 / 18 Time 10 : 00

Make _____ Size/Type _____ Multiplier _____
Notes BUSTED METER BOTTOM - REPLACED METER

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>5/8 x 3/4 METER</u>		
<u>SEE ATTACHED TAG</u>		

Order: 00452685 Line: 002	Order: 00452685 Line: 002
Date: 0817 	Date: 0817 
Part No: <u>A2DXX38GGXXX1XX</u>	Part No: <u>A2DXX38GGXXX1XX</u>
Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK	Desc: MTR 5/8-3/4 AS ER-TRPL G 6'LPK DP/R 5WHL4A 100G 6'SEN L/HSGPK
Serials:  Meter SN: <u>83545709</u>	Serials:  Meter SN: <u>83545709</u>
Flow: 	Flow: 
Flow: 099.3 M3: 100.6 H1: 099.4	Flow: 099.3 M3: 100.6 H1: 099.4
Reg. Meter:  Part ID: <u>89536821</u>	Reg. Meter:  Part ID: <u>89536821</u>
Reg. Meter:  Part ID: <u>89536821</u>	Reg. Meter:  Part ID: <u>89536821</u>
Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Config: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Signature _____

East Logan Water District
WORK ORDER 12404

Account # _____
Name HARPER, KENNETH W
Address _____
Telephone _____

Order Date 1/2/2018
Status MEDIUM
Scheduled 01/02/18 04:07 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT	39220372	6491	B14169451	

Description Customer thinks either busted meter or bottom

Comment LF, W/TRLR LF CORNER TRLR

Requested By Kenneth

Assigned To MAINTENANCE CREW

Completed By _____

Start Date 1/2/18 Time _____

Completed Date 1/2/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Changed due to busted
SR I meter bottom

Sensus
www.sensus.com



Certified to
NSF/ANSI 61-G

Order: 00326011 Line: 001

Date: 1114

Part No: A2DXX38GGXXX1XX

Desc:
MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus
Meter SN: 78461033

Flow:

Low: 096.7 Mid: 100.6 Hi: 099.8

Register
Cust ID: 73487929

Register
Fact ID: 73487929

Config:

Signature

East Logan Water District
WORK ORDER 12441

Account #
Name GIVENS, JOSEPH D
Address
Telephone Job #

Order Date 1/7/2018
Status MEDIUM
Scheduled 01/08/18 08:36 AM
Order Type CHECK METER

METER# WT 2993W ERT/INTERNAL ID# 39220365 READING 4215 LOCATOR TAG B14172378 READING IN / OUT

Description
Comment RT WH/HS R/YD

Requested By Linda Assigned To MAINTENANCE CREW Completed By
Start Date / / Time : Completed Date 1 / 8 / 18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes Customer called Sunday to say he had water blowing out of box
Andy changed out meter as it had frozen and burst

Inventory Item And Description	Quantity Ordered	Quantity Used

Order: 00452685 Line: 002	Order: 00452685 Line: 002
Date: 0817 	Date: 0817 
Part No: A2DXX38GGXXX1XX	Part No: A2DXX38GGXXX1XX
Desc:	Desc:
MTR 5/8-3/4 AS ER-TRPL G 6'LPK	MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK	DP/R 5WHL4A 100G 6'SEN L/HSGPK
Revenue 	Revenue 
Water S/N: 83545702	Meter S/N: 83545702
Flow: 	Flow: 
Len: 097.9 Wdg: 100.8 Ht: 099.9	Len: 097.9 Wdg: 100.8 Ht: 099.9
Reg. Meter: 	Reg. Meter: 
Reg. ID: 89536814	Reg. ID: 89536814
Reg. Meter: 89536814	Reg. Meter: 89536814
Reg. ID: 89536814	Reg. ID: 89536814

Signature _____

East Logan Water District
WORK ORDER 12411

Account #
Name TIMBERLAKE, STEVEN K
Address
Telephone Job #

Order Date 1/3/2018
Status MEDIUM
Scheduled 01/03/18 08.41 AM
Order Type ZERO USAGE/CHECK OUT

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 31604190	64952918	2101	B14820761	2101

Description

Comment RT HSE LF PROPERTY

Requested By

Assigned To MAINTENANCE CREW

Completed By DB

Start Date 1/1 Time 0


Completed Date 1/5/18 Time 3:45

Make _____ Size/Type _____ Multiplier _____
Notes ROTTED REG. & METER - REPLACED BOTH LEFT OFF PIPES FROZEN

Inventory Item And Description	Quantity Ordered	Quantity Used

Order: 00436047 Line: 003

Order: 00436047 Line: 003

Date: 0417 

Date: 0417 

Part No: ~~A2DXX38G, XXX1XX~~

Part No: ~~A2DXX38GGXXX1XX~~

Desc:

Desc:

MTR 5/8-3/4 AS ER-TRPL G 6'LP:
DP/R 5WHL4A 100G 6'SEN L/HSGPK

MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus 
Meter SN: 82995070

Sensus 
Meter SN: 82995070

Flow: 

Flow: 

Low: 096.8 Mid: 101.3 Hi: 100.4

Low: 096.8 Mid: 101.3 Hi: 100.4

Register 
Cust ID: 89283279

Register 
Cust ID: 89283279

Register
Fact ID: 89283279

Register
Fact ID: 89283279

Config:

Config:

Signature _____

East Logan Water District
WORK ORDER 12443

Account #
Name CHURCH OF GOD PROPHECY %
Address
Telephone Job #

Order Date 1/8/2018
Status MEDIUM
Scheduled 01/08/18 09:20 AM
Order Type CLEAN UP PROPERTY

METER# WT 19803793 ERT/INTERNAL ID# 39202741 READING 1896 LOCATOR TAG B14166156 READING IN / OUT

Description Hole at meter needs filling in
Comment RT, WHITE CHURCH, LF DRIVE

Requested By Assigned To MAINTENANCE CREW Completed By

Start Date 1/11/18 Time : : Completed Date 1/11/18 Time : :

Make Size/Type Multiplier

Notes

Inventory Item And Description	Quantity Ordered	Quantity Used

3 gallons per min

filled hole in & also replaced meter due to it being busted

NEW - U

id-2059

Order: 00452685 Line: 002

Order: 00452685 Line: 002

Date: 0817

Date: 0817

Part No: A2DXX38GGXXX1XX

Part No: A2DXX38GGXXX1XX

Desc:

Desc:

MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

MTR 5/8-3/4 AS ER-TRPL G 6'LPK
DP/R 5WHL4A 100G 6'SEN L/HSGPK

Sensus Meter SN: 83545720

Sensus Meter SN: 83545720

Flow:

Flow:

Low 098.5 High 100.8 Hi-099.8

Low 098.5 High 100.8 Hi-099.8

Register Part ID: 89536832

Register Part ID: 89536832

Register Part ID: 89536832

Register Part ID: 89536832

Unit:

Unit:

Signature [Signature]

East Logan Water District
WORK ORDER 13631

Account #
Name PRUITT, JUSTUS C
Address
Telephone Job #

Order Date 11/19/2018
Status MEDIUM
Scheduled 11/19/18 10 22 AM
Order Type ABNORMAL SMELL/COLOR

METER# WT 84900769 ERT/INTERNAL ID# 90118859 READING 26 LOCATOR TAG B15450945 READING IN / OUT

Description
Comment LFT. LFT OF DR 35FT

Requested By _____ Assigned to MAINTENANCE CREW Completed By Capit
Start Date 11/19/18 Time _____ Completed Date 11/19/18 Time 2:50

Make _____ Size/Type _____ Multiplier _____
Notes Flushed Approx 4000

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 13643

Account Name GALBRAITH, BRETT G Order Date 11/21/2018
Address Job # 17 Status MEDIUM
Telephone Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605914	63671860	2709	B14462954	

Description

Comment

Requested By Linda Assigned To MAINTENANCE CREW Completed By *[Signature]*
Start Date 11/21/18 Time 10:59 Completed Date 11/21/18 Time 2:00

Make _____ Size/Type _____ Multiplier _____
Notes Customer says leak is in box *3467*

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Nut was loose on meter</i>		

Iron Mt
3987
00138

Signature *[Signature]*

East Logan Water District
WORK ORDER 13651

Account # _____ Order Date 11/28/2018
 Name BARROW, MARK Status MEDIUM
 Address _____ Scheduled 11/28/18 08:30 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056530	09961419	449	B14169784	

Description _____
 Comment RT, WH HSE, RT 1ST DR
 Requested By MR BARROW Assigned To _____ Completed By *[Signature]*
 Start Date 11/28 Time 8:30 Completed Date 11/28/18 Time 9:25

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Leak on his side</i>		

[Handwritten Signature]

Signature

East Logan Water District
WORK ORDER 13650

Account #
Name SLAUGHTER, MIKE L
Address
Telephone Job #

Order Date 11/26/2018
Status MEDIUM
Scheduled 11/26/18 03 39 PM
Order Type CHECK METER

METER# WT 83431876 ERT/INTERNAL ID# 89480624 READING 491 LOCATOR TAG B15438785 READING IN / OUT

Description
Comment RT OF DR/ RT CORNER OF TRAILER

Requested By MICHAEL Assigned To MAINTENANCE CREW Completed By *[Signature]*
Start Date 1/1 Time Completed Date 11/15/18 Time 12:42

Make Size/Type Multiplier
Notes PRESSURE REGULATOR, IS RUSTED

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Replaced the reg. bolt on to rusted off.</i>		
<i>1 3/4 Reg</i>		<i>1</i>

Signature *[Signature]*

East Logan Water District
WORK ORDER 12966

Account # _____ Name SCOTT, JERRY Order Date 6/6/2018
Address _____ Status HIGH
Telephone _____ Job # _____ Scheduled 06/06/18 08:03 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 48431584 ERT/INTERNAL ID# 09512499 READING 1593 LOCATOR TAG B14167877 READING IN / OUT _____

Description _____
Comment RT, BRK L/DR T/LF
Requested By Jerry Scott Assigned To MAINTENANCE CREW Completed By _____
Start Date 6/1/18 Time _____ Completed Date 6/1/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Cust called in stated that appears to be a leak between meter and main line

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 24 metal		
1- 3/4 Settes		
1- 3/4 Stube		
2- 3/4 inserts		
1- 3/4 Regulator		
10ft of tubing		
1- Standard metal box and Lid		

Signature A. C. T. M.

East Logan Water District
WORK ORDER 13205

Account #
Name BAER, LEONARD I
Address
Telephone Job #

Order Date 8/8/2018
Status MEDIUM
Scheduled 08/08/18 08 30 AM
Order Type MISCELLANEOUS

METER# WT 36583308 ERT/INTERNAL ID# 09968839 READING 4164 LOCATOR TAG B14166807 READING IN / OUT

Description
Comment LF, WH/HSE/1ST DR

Requested By Daniel Assigned to MAINTENANCE CREW Completed By

Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes please call in locate, so we can dig and fix ditch line, let dry and check for leak again-thx

Inventory Item And Description	Quantity Ordered	Quantity Used

East Logan Water District
WORK ORDER 12924

Account # _____
Name *813* RIGGS, BILL
Address _____
Telephone _____ Job # _____

Order Date 5/23/2018
Status MEDIUM
Scheduled 05/23/18 01:32 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 68434114 ERT/INTERNAL ID# 62202138 READING 3651 LOCATOR TAG B14166659 READING IN / OUT _____

Description _____
Comment LF, YELLOW HSE. SIDE OF HSE. R


Requested By Tyler Assigned To MAINTENANCE CREW Completed By *TJB*
Start Date / / Time : Completed Date 5/23/18 Time 3:01

Make _____ Size/Type _____ Multiplier _____

Notes
Checked 5/23/18 - Done, No Water For 4 Hr. Dues

Inventory Item And Description	Quantity Ordered	Quantity Used

DRY, NO SOUND, NO LEAK

Signature 

East Logan Water District
WORK ORDER 13150

Account #
Name BAER, LEONARD L
Address
Telephone Job #

Order Date 8/1/2018
Status MEDIUM
Scheduled 08/01/18 12:11 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 36583308 ERT/INTERNAL ID# 09968839 READING 4164 LOCATOR TAG B14166807 READING IN / OUT ~~4164~~ 4183

Description
Comment LF, WH/HSE/1ST DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By MTT
Start Date 8/1/18 Time 1:00 Completed Date 8/1/18 Time 3:50

Make _____ Size/Type _____ Multiplier _____

Notes around where the meter is is full of water, replaced a line on 5/18. check to make sure plz

Meters was full of water, pumped out, no sign of visible leak
need to be sounded, area around meter very wet (no leak on customer)

Inventory Item And Description	Quantity Ordered	Quantity Used

Daniel has already sounded. Need to call in a locate on this address so we can dig and dress up ditch line let it dry then check it again

Signature *Y. M. H.*

East Logan Water District
WORK ORDER 13196

Account # _____ Order Date 8/6/2018
Name FARMER, MICHAEL Status MEDIUM
Address _____ Scheduled 08/06/18 08:04 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 67163195 60838656 6495 B14250495 _____ 4505
Description _____
Comment LF IN FIELD 100' PAST LAST MTR
Requested By Sarah Moore Assigned To MAINTENANCE CREW Completed By *MAJ*
Start Date ____/____/____ Time ____:____ Completed Date *8-16-18* Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes Water standing in driveway, please check for a leak
Sub to issue of visible leak (tested no chlorine)

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *Michael H.*

Callaghan Water District
WORK ORDER 13185

Account # _____ Order Date 8/1/2018
Name CALLAHAN TP REBECCA A Status MEDIUM
Address _____ Scheduled 08/01/18 02:16 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 81568772 74698143 479 B14168947 _____ 0479

Description _____
Comment RT, BRN TRLR, M/YD 2ND

Requested By _____ Assigned To MAINTENANCE CREW Completed By (V11)
Start Date 8/1/18 Time _____ Completed Date 8/17/18 Time 12:30

Make _____ Size/Type _____ Multiplier _____

Notes where trailer use to be water is leaking, LOCK!!!!

Water on top of ground where trailer previously set, meter is off and locked

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 13211

Account #
Name LEACH, DAVID
Address
Telephone Job #

Order Date 8/9/2018
Status MEDIUM
Scheduled 08/09/18 08 34 AM
Order Type MISCELLANEOUS

METER# WT 51170355 ERT/INTERNAL ID# 09441660 READING 9224 LOCATOR TAG B14167803 READING IN / OUT 9238

Description
Comment RT, HSE OFF RD, LF GR DR, O/FE

Requested By DAVID LEACH Assigned To MAINTENANCE CREW Completed By *DL*

Start Date 8/9/18 Time 8:34 Completed Date 8/13/18 Time 1:27

Make _____ Size/Type _____ Multiplier _____

Notes REPLACE METER LID, ALSO MAKE SURE THAT THERE IS NO LEAK, CUSTOMER SAYS THAT PENNYRILE IS THE CULPRIT FOR IT WITH THEIR TREE TRIMMING! LOL
placed lid no leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *David Leach*

East Logan Water District
WORK ORDER 13219

Account Name: BARROW, MACIE Order Date: 8/10/2018
 Address: ----- Status: MEDIUM
 Telephone: Job #: Scheduled: 08/10/18 04:45 PM
 Order Type: CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51400583	64887922	3857	B14168786	3896

Description: RT WH/HS L/CNR HS

Requested by: Linde Assigned To: MAINTENANCE CREW Completed By: [Signature]

Start Date: 8/10/18 Time: Completed Date: 8/10/18 Time: 12:14

Make: Size/Type: Multiplier:

Notes: Sometime this week in passing, please pump out box and see if meter is turning, or if we have a leak
 We can call customer to let them know Diane Barrow

BOX WAS DRY, METER NOT TURNING, NO LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used

Trailer left side

Signature: [Signature]

East Logan Water District
WORK ORDER 13079

Account # -
Name CASH, JAMES G
Address
Telephone

Order Date 7/10/2018
Status MEDIUM
Scheduled 07/10/18 11:28 AM
Order Type CHECK METER

METER# WT 48431518 IRT/INTERNAL ID# 09204973 READING 6833 LOCATOR TAG B14167231 READING IN / OUT 5922

Description

Comment LF BRK L/DR

Requested By JOYCE CASH

Assigned To MAINTENANCE CREW

Completed By *[Signature]*

Start Date *7/10/18* Time *11:28*

Completed Date *7/10/18* Time *11:28*

Make _____ Size/Type _____ Multiplier _____

Notes Please check meter for leak on either side and we will notify customer

Found no leaks & small depression while damp did not appear to

Inventory Item And Description	Quantity Ordered	Quantity Used

SOUNDING METER 7-18-18 @ 11:56. NO LEAK

Signature *[Signature]*

East Logan Water District
WORK ORDER 13506

Account # 100001
Name THOMAS, GARY D
Address
Telephone
Job #
Order Date 7/18/2018
Status MEDIUM
Scheduled 07/18/18 12:36 PM
Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 63869448	56501957	7673	B14169611	

Description
Comment LF,HSE OFF RD, RT DR O/FENCE
Requested By Ms. Thomas Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW
Start Date 07/18/18 02 18 PM Completed Date 07/18/18 02 18 PM

Notes -busted pressure regulator-db

Signature



WORK ORDER 13118

Account #
Name DURHAM, SARAH J
Address
Telephone Job #

Order Date 7/24/2018
Status MEDIUM
Scheduled 07/24/18 08 32 AM
Order Type MISCELLANEOUS

METER# WT 000065798051
ERT/INTERNAL ID# 58646969
READING 6955
LOCATOR TAG B14167002
READING IN / OUT 6955

Description
Comment RT,BEIGE 2 STORY, LF CNR

Requested By _____ Assigned To MAINTENANCE CREW Completed By DB
Start Date 7/24/18 Time 9:59 Completed Date 7/24/18 Time 9:59

Make _____ Size/Type _____ Multiplier _____

Notes bank has requested that the meter be removed due to water still leaking inside the home, also would like us to mark the with a flag where the meter is located

REPLACED CUT OFF & PULLED METER

Inventory Item And Description	Quantity Ordered	Quantity Used
1 - 3/4" CUT OFF		1

Signature _____

WORK ORDER 1334A

Account #
Name COBLENTZ, LEON A
Address
Telephone

Order Date 9/13/2018
Status MEDIUM
Scheduled 09/13/18 01 02 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473710	61750532	877	B14167336	

Description
Comment LF, RT SUMMERS RD 5TH METER

Requested By LEON Assigned To MAINTENANCE CREW Completed By
Start Date ___/___/___ Time ___:___ Completed Date 9/13/18 Time 1:15

Make _____ Size/Type _____ Multiplier _____
Notes HE SAYS THE LEAK IS BETWEEN METER AND HIS CUT-OFF PLEASE SEE WHERE IT IS LEAKING, AND IF WE NEED TO REPAIR

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature

East Logan Water District
WORK ORDER 13513

Account # _____ Order Date 9/10/2018
 Name PORTER, SUSAN L Status MEDIUM
 Address _____ Scheduled 09/10/18 11:14 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 37363854 39215147 4411 B15402190
 Description _____
 Comment RT GREY/HSE LFT OF SAME DR NO
 Requested By LINDA Assigned To MAINTENANCE CREW Completed By *[Signature]*
 Start Date / / Time : Completed Date 9/15/18 Time 2:16

Make _____ Size/Type _____ Multiplier _____
 Notes
No chlorine, no sound pumped out Box. Check again in a few days

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *[Signature]*

WORK ORDER 13347

Account # _____ Order Date 9/14/2018
 Name BFI _____ Status MEDIUM
 Address _____ Scheduled 09/14/18 08 01 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 40966798	08581464	8072	B14172457	

Description _____
 Comment RT, BEIGE HSE, LF YD
 Requested By carroll Assigned To MAINTENANCE CREW Completed By *MH*
 Start Date / / Time : Completed Date 9/17/18 Time 2:25

Make _____ Size/Type _____ Multiplier _____

Notes sound meter for leak under rd
No Sound or Signs of Leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *MH*

East Logan Water District
WORK ORDER 13346

Account # _____ Order Date 9/13/2018
 Name SCARBROUGH, M.E. Status MEDIUM
 Address _____ Scheduled 09/13/18 03:28 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 36518898	08769277	4901	B14168648	

Description _____
 Comment LT, WH/HSE, RT/DR
 Requested By Mr Rogers Assigned To MAINTENANCE CREW Completed By *MH*
 Start Date ___/___/___ Time ___:___ Completed Date *9/13/18* Time *3:15*

Make _____ Size/Type _____ Multiplier _____

Notes See if there is a leak in this area He said it looks like a leak was fixed recently but may still be leaking because of the wetness

No sound, or signs of any leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *Mike H*

East Logan Water District
WORK ORDER 13098

Account # _____ Order Date 7/16/2018
 Name WHITING, KIMBERLY Status MEDIUM
 Address _____ Scheduled 07/16/18 11:05 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684169	59596257	2875	B14164563	

Description _____
 Comment RT, TRLR, LT/DR
 Requested By Rob Whiting Assigned to MAINTENANCE CREW Completed by _____
 Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____
 Notes Mark Cole backed over our meter, breaking the line. Andy called in on Saturday 7/14/18 to repair

Inventory Item And Description	Quantity Ordered	Quantity Used

1 hr Andy repaired
~~#~~ tubing
 3/4 female threaded coupling
 no water lost ELWD

East Logan Water District
WORK ORDER 13461

Account # _____ Order Date 10/10/2018
Name HOSTETLER, EUGENE Status MEDIUM
Address _____ Scheduled 10/10/18 09 16 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473756	63097877	1402	B14170092	

Description _____
Comment RT,WH HSE,20' RT DR
Requested By REBECCA STAMPS Assigned To MAINTENANCE CREW Completed By *GP/RJ*
Start Date *10/10/18* Time _____ Completed Date *10/10/18* Time *10:50*

Make _____ Size/Type _____ Multiplier _____
Notes YELLOW HOUSE, AT MAILBOXES,
No Leak

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Sounded it No Leak</i>		

Signature 

WORK ORDER 13515

Account # _____
 Name GILBERT, CHRISTOPHER C
 Address _____
 Telephone _____
 Order Date 10/23/2018
 Status MEDIUM
 Scheduled 10/23/18 01:44 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81568833
 ERT/INTERNAL ID# 74698204
 READING _____
 LOCATOR TAG B15401636
 READING IN / OUT _____

Description _____
 Comment LF OF DR
 Requested By _____
 Assigned To MAINTENANCE CREW
 Completed By *RT GP*

Start Date / / Time :
 Completed Date 10/23/18 Time 2:30

Make _____ Size/Type _____ Multiplier _____
 Notes chris gilbert

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Was not a Leak</i>		
<i>ground water I guess</i>		
<i>Sounded Meter w/ sound</i>		

Signature *[Handwritten Signature]*

EAST LOGAN WATER DISTRICT
WORK ORDER 13420

Account # _____
Name HALL STEVE
Address _____
Telephone _____

Order Date 10/4/2018
Status MEDIUM
Scheduled 10/04/18 02:31 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 52473877 ERT/INTERNAL ID# 07229376 READING 6593 LOCATOR TAG B15415792 READING IN / OUT _____

Description
Comment RT,IN CURVE 25FT RT/GATE

Requested By mike Assigned To MAINTENANCE CREW Completed By _____
Start Date 10/4/18 Time 2:31 Completed Date 10/4/18 Time 2:58

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
No leak		

Signature 

East Logan Water District
WORK ORDER 13530

Account #
Name DUNCAN, KEVIN I
Address
Telephone

Order Date 10/29/2018
Status MEDIUM
Scheduled 10/29/18 03:47 PM
Order Type

METER# WT 65798112 ERT/INTERNAL ID# 58647030 READING 54 LOCATOR TAG B14167378 READING IN / OUT

Description
Comment

Requested By MR DUNCAN Assigned To MAINTENANCE CREW Completed By *RT 68*
Start Date *10/29/18* Time *1:00* Completed Date *10/29/18* Time *2:00*

Make _____ Size/Type _____ Multiplier _____

Notes SMELLS AND TESTS NASTY CHECK, CHLORINE & FLORIDE IN THE WATER

Flushed line

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13572

Account #
Name JUDD-MCCORMICK, CARRIE J
Address
Telephone Job #

Order Date 11/4/2018
Status MEDIUM
Scheduled 11/04/18 02:40 PM
Order Type CHECK METER

METER# WT 9135988 ERT/INTERNAL ID# 9135988 READING LOCATOR TAG READING IN / OUT 21

Description
Comment LF OF DR, MID OF YRD

Requested By courtney Assigned To MAINTENANCE CREW Completed By RT/62
Start Date 1/1 Time Completed Date 11/6/18 Time 1:24

Make Size/Type Multiplier

Notes thursday when mike shut off it was at 17 7, friday at 5 18 4, saturday at lunch 18 9, check to see why meter is seeping water please!

Inventory Item And Description	Quantity Ordered	Quantity Used
Switch out setter		
3/4 shark bite cut off		1
3/4 shark bites to 3/4 pipe fittings		2

GARY
Change (setter)
to the yoke setup

Signature

WORK ORDER 13576

Account # _____ Order Date 11/5/2018
 Name WALTON, BELMARIE O Status MEDIUM
 Address _____ Job # 56-8718 Scheduled 11/05/18 11:18 AM
 Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 25976047 59495724 421 B14169573

Description _____
 Comment RT,TRLR,RT GR DR O/FENCE T/LF
 Requested By MR WALTON Assigned To MAINTENANCE CREW Completed By RJ CP
 Start Date 11/1 Time _____ Completed Date 11/5/18 Time 10:55

Make _____ Size/Type _____ Multiplier _____

Notes CHECK FOR LEAK ON OUR SIDE, METER BOX WAS FULL OF WATER, AND WATER RUNNING DOWN DRIVE

Inventory Item And Description	Quantity Ordered	Quantity Used
Small leak for 2 gallons a minute already marked in white		
across from 1645 Lester Meadows		
74 Inserts		2
3/4 Cone Nut		1
3/4 Muller Nut		1
3/4 blue Pipe About 5 feet		
5 to 10 gpm		

lat 37.02704
 long - 84.89292

Signature



East Logan Water District
WORK ORDER 13560

Account #
Name PARKER, TODD C
Address
Telephones

Order Date 11/2/2018
Status HIGH
Scheduled 11/02/18 09:58 AM
Order Type RE-READ FOR BILLING

METER# WT 29899007 IRT/INTERNAL ID# 63719217 READING 3160 LOCATOR TAG B14169014 READING IN / OUT 3212

Description
Comment RT TRLR OFF RD L/1ST POLE ON R

Requested By Linda Assigned to MAINTENANCE CREW Completed By
Start Date 1/1 Time : Completed Date 1/1/1 Time 2:36

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
NEED MORE info		

There is a leak in meter box @ anderson store rd d T Merenda
S-pipe from press. reg. to meter prob just needs washer

37.03494
- 86.79714

Signature _____

East Logan Water District
WORK ORDER 13604

Account #
Name PRUITT, JUSTUS C
Address
Telephone

Order Date 11/13/2018
Status MEDIUM
Scheduled 11/13/18 09:01 AM
Order Type ABNORMAL SMELL/COLOR

METER# WT 84900769 ERT/INTERNAL ID# 90118859 READING 26 LOCATOR TAG B15450945 READING IN / OUT

Description
Comment LFT. LFT OF DR 35FT

Requested By JUSTUS Assigned To MAINTENANCE CREW Completed By *RJ*

Start Date / / Time : Completed Date / / Time :


Make _____ Size/Type _____ Multiplier _____

Notes CUST STATED THAT COLOR OF WATER IS BROWN/RUSTIC
EXT WHEN HEADING THAT WAY, SO CAN UNLOCK GATE

Customer Stated mainly Brown Rusty Water in Mornings

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>We Flushed End of Line</i>		
<i>For 11 minutes flushed approx. 2,000</i>		
<i>gallons</i>		

Signature



East Logan Water District
WORK ORDER 13620

Account # _____
 Name BRITT, DANNY
 Address _____
 Telephone _____ Job # _____
 Order Date 11/15/2018
 Status MEDIUM
 Scheduled 11/15/18 01:41 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473766	69468376	3435	B14166615	

Description _____
 Comment LF 100' PAST DR ---> ON RD T/RT
 Requested By Mrs. Britt Assigned To MAINTENANCE CREW Completed By P.J.
 Start Date ___/___/___ Time ___:___ Completed Date 11/15/18 Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Meter box is full of water and meter is turning according to customer. Please make sure this is not on us

Inventory Item And Description	Quantity Ordered	Quantity Used
Sounded meter small leak on customer west side		

03473

Signature _____

East Logan Water District
WORK ORDER 13656

Account #
Name NICHOLS, TONIA M
Address
Telephone Job #

Order Date 11/28/2018
Status MEDIUM
Scheduled 11/28/18 03:05 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 40735824 ERT/INTERNAL ID# 10281553 READING 6164 LOCATOR TAG B14169514 READING IN / OUT

Description
Comment WH BRK, BARN LF OF HSE, CEM

Requested By Tonia Assigned To MAINTENANCE CREW Completed By *GP RIT*
Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____

Notes Tonia says we fixed a leak at the end of her drive a few months ago, but she thinks it is leaking again. Water is puddled there for a couple of weeks

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Tighten up the stainless pipe clamp!</i>		

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13459


Account # _____ Order Date 10/10/2018
 Name STINSON, JOY Status MEDIUM
 Address _____ Scheduled 10/10/18 08:11 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170353	10290168	5876	B14168210	

Description _____
 Comment RT, BRK LT/YD
 Requested By JOY Assigned To MAINTENANCE CREW Completed By *GP/RS*
 Start Date 10/10/18 Time 8:15 Completed Date 10/10/18 Time 8:57

Make _____ Size/Type _____ Multiplier _____
 Notes CUST NOT SURE IF ON HER SIDE OR OUR SIDE OF METER

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Crusted Meter bottom Replaced</i>		<i>1</i>

Signature 

ELWD Water District
WORK ORDER 13475

Account #
Name TURNER, JAMES
Address
Telephone

Order Date 10/12/2018
Status MEDIUM
Scheduled 10/12/18 01:27 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 40735822	69468369	2916	B14166386	

Description
Comment LF. WH HSE, LF YD, 2 METERS

Requested By _____ Assigned To MAINTENANCE CREW Completed By *YJL*
Start Date 10/12/18 Time 1:00 Completed Date 10/12/18 Time 2:00

Make _____ Size/Type _____ Multiplier _____

Notes Meter bottom blew out. Not going through meter. Mike repaired. Reading on 10/12/18 was 2924. Probably 25gpm.

Changed meter bottom

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *YJL*

East Logan Water District
WORK ORDER 13404

Account #
Name JACKSON, JAMES
Address
Telephone

Order Date 10/1/2018
Status MEDIUM
Scheduled 10/01/18 03:02 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 31152888	09964879	2141	B14166435	

Description

Comment RT, WH HSE, LF CNR YD

Requested By Mr. Jackson (son) Assigned To MAINTENANCE CREW Completed By *[Signature]*

Start Date / / Time : : Completed Date 10-1/18 Time 3:57

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
1 WATERLINE 3/4		
2 3/4 NUTS		

Signature *[Signature]*

East Logan Water District
WORK ORDER 13661

Account # _____ Order Date 11/29/2018
Name LARSON, ERIC & NANCY A Status MEDIUM
Address _____ Scheduled 11/29/18 02:31 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 51780794 63183750 15216 B14169815

Description _____
Comment RT,MTL BLD OFF RD, RT 1ST DR T
Requested By DANIEL MAST Assigned To MAINTENANCE CREW Completed By *LP*
Start Date ____/____/____ Time ____ Completed Date *11/26/18* Time *2:50*

Make _____ Size/Type _____ Multiplier _____

Notes DANIEL CALLED TO SAY THAT THERE IS NORMALLY A SMALL AMOUNT OF WATER RUNNING OVER RD, BUT NOW THER IS QUITE A BIT OF WATER, CALLED IN BY DANIEL MAST 270-755-4824

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Repaired Main Line</i>		
<i>Two foot pte of pipe 4 inch</i>		<i>1</i>
<i>Knock dow 4 inch</i>		<i>1</i>
<i>1 rubber packing Merb Joint 4 in</i>		<i>1</i>

5177

Signature 

East Logan Water District
WORK ORDER 13531

Account # _____ Order Date 10/30/2018
 Name BOYD TP, DENISE R Status MEDIUM
 Address _____ 6-8579 Scheduled 10/30/18 10.08 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 69361571	63066183	4697	B14167806	

Description _____
 Comment LT, TAN HSE, LT/DR
 Requested By ms boyd Assigned To MAINTENANCE CREW Completed By *C.P. RJ*
 Start Date 10/30/18 Time _____ Completed Date 10/30/18 Time 1:15

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced washer		1

Signature 

East Logan Water District
WORK ORDER 13402

Account # _____
 Name SWEATT, ROY
 Address _____ Job # 197
 Telephone _____
 Order Date 10/1/2018
 Status MEDIUM
 Scheduled 10/01/18 12:02 PM
 Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50236746	73543859	1564	B14170128	

Description _____
 Comment LF, WH HSE, LF CNR AT WH FENCE
 Requested By MR SWEATT Assigned To MAINTENANCE CREW Completed By *YMH*
 Start Date ____/____/____ Time ____:____ Completed Date *10/1/18* Time *1:55*

Make _____ Size/Type _____ Multiplier _____

Notes CUSTOMER SAYS THAT THE BOTTOM OF THE METER IS POURING OUT WATER, CUST HAS METER TURNED OFF AT THIS MOMENT

changed meter Bottom

Inventory Item And Description	Quantity Ordered	Quantity Used



Signature *YMH*

East Logan Water District
WORK ORDER 13460

Account #
Name BOYD TP, DENISE R
Address
Telephone

Order Date 10/10/2018
Status MEDIUM
Scheduled 10/10/18 09:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69361571 ERT/INTERNAL ID# 63066183 READING 4697 LOCATOR TAG B14167806 READING IN / OUT

Description
Comment LT, TAN HSE, LT/DR

Requested By Denise Assigned To MAINTENANCE CREW Completed By *GP/KS*
Start Date *10/10/18* Time *10:41* Completed Date *10/10/18* Time *10:02*

Make _____ Size/Type _____ Multiplier _____
Notes Water around meter, running down road

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Nut loose on S pipe!!</i>		

[Handwritten Signature]

Signature

East Logan Water District
WORK ORDER 13519

Account #
Name MORGAN, DOYLE
Address
Telephone Job #

Order Date 10/25/2018
Status MEDIUM
Scheduled 10/25/18 08:13 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 68434133	62202157	521	B14168476	

Description
Comment LF RT/CNR BARN AT HYD

Requested By Mr Morgan Assigned To MAINTENANCE CREW Completed By *RJLP MH RK*

Start Date 1/1 Time _____ Completed Date 10/25/18 Time 2:00

Make _____ Size/Type _____ Multiplier _____
Notes There is a leak here; please see if it is our leak or customer's leak Meter is by green gates

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>2 x 3/4 plastic inserts</i>		
<i>2 x 3/4 muller nuts</i>		
<i>80ft x 3/4 Blue pax</i>		

Signature



East Logan Water District
WORK ORDER 13516

Account # _____ Order Date 10/24/2018
Name AUSTIN, FRED Status MEDIUM
Address _____ Scheduled 10/24/18 08:44 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66964685	61750521	1723	B14166451	

Description _____
Comment RT, GREEN TRLR, R/DR
Requested By WILLIAM JOHNSON Assigned To MAINTENANCE CREW Completed By RJ GP
Start Date 10/24/18 Time 10:30 Completed Date 10/24/18 Time 10:30

Make _____ Size/Type _____ Multiplier _____
Notes CALL WILLIAM JOHNSON AT _____ WE WOULD LIKE TO MEET YOU AND LOOK AT THE LEAK!

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>3/4 coupling</u>		<u>1</u>
<u>3/4 inserts</u>		<u>2</u>
<u>Leak service line</u>		
<u>Repaired</u>		
<u>S-10 gpm</u>		

Signature 

East Logan Water District
WORK ORDER 13450

Account #		Order Date	10/8/2018
Name	GREATER LIFE APOSTOLIC CHURCH	Status	MEDIUM
Address		Scheduled	10/08/18 11:11 AM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG
WT 67163189	60838650	810	B14168760
Description		READING IN / OUT	

Comment

Requested By Marty Marshall Assigned To MAINTENANCE CREW Completed By *B. P. [Signature]*

Start Date / / Time : Completed Date / / Time :

Make _____ Size/Type _____ Multiplier _____

Notes Please check for leak
also see log for meter

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4 coupling</i>		<i>1</i>

Signature *[Handwritten Signature]*

WORK ORDER 13452

Account # 100001
Name FERGUSON, ECHO L
Address 1
Telephone 7

Order Date 10/8/2018
Status MEDIUM
Scheduled 10/08/18 05:05 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATION TAG	READING IN / OUT
WT 35188814	09974664	6380	B14169883	

Description

Comment RT, BRK HSE, OFF RD, 10' LF GR

Requested By Echo Ferguson

Assigned To MAINTENANCE CREW

Completed By *GARY*

Start Date 10/1/18 Time

Completed Date 10/8/18 Time

Make _____ Size/Type _____ Multiplier _____

Notes Box full of water

Gary checked, leak on our side of meter

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4 Shark bite !!! 51010gpm</i>		<i>1</i>

*11:00 AM estimate
20' L of drive both sides of road*

ATT
WRCC

1810090328

Signature *D. J. [Signature]*

East Logan Water District
WORK ORDER 13133

Account # _____
Name STAMPS, ROBERT J
Address _____
Telephone _____

Order Date 7/26/2018
Status MEDIUM
Scheduled 07/26/18 01:45 PM
Order Type CHECK FOR LEAK ON OUR SIDE

Job # _____
METER# WT 81004659 ERT/INTERNAL ID# 74516495 READING 880 LOCATOR TAG B14167452 READING IN / OUT _____

Description
Comment LF GRAY HS LYD

Requested By Mr. Stamps Assigned To MAINTENANCE CREW Completed By _____
Start Date 7/24/18 Time _____ Completed Date 7/24/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Andy fixed a main line leak in January 2018. Customer thinks it leaking again. He got stuck mowing because it was so wet. Please check.

Inventory Item And Description	Quantity Ordered	Quantity Used
12" 3/4 Tubing		
2 3/4 Couplings	05	

X Summers (Emergency locate)

LTC
WRLLC
1807270490

Signature 

ACCOUNT #
Name CALLAHAN TP. REBECCA A
Address
Telephone Job #

Order Date 3/16/2018
Status MEDIUM
Scheduled 03/16/18 10 16 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81568772	74698143	479	B14168947	479

Description
Comment RT, BRN TRLR. MYD 2ND

Requested By Callahan Assigned To MAINTENANCE CREW Completed By
Start Date 3/16/18 Time : : Completed Date 3/16/18 Time : :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Meter was not furning
looked for water but
only found rain water
puddles
Tyler has this

Signature TM

Water District
WORK ORDER 12605

Account # _____ Order Date 3/12/2018
Name GILLIS, AMY M Status MEDIUM
Address _____ Scheduled 03/12/18 10:50 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 36140720 ERT/INTERNAL ID# 10413228 READING 5235 LOCATOR TAG B14166690 READING IN / OUT _____

Description _____
Comment LFT W/HSE RT OF DR *5271*

Requested By Linda Assigned To MAINTENANCE CREW Completed By _____

Start Date *3/12/18* Time _____ Completed Date *3/12/18* Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Meter box full of water, please see if meter is turning She says we told her leak on her side, landlord say leak on our side. ???

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>The meter is steadily turning</i>		
<i>That tells me leak is on their side</i>		

Signature *AC*

EAST LOGAN WATER DISTRICT
WORK ORDER 12694

Account # _____ Order Date 3/19/2018
Name BRADY, JAMES J Status MEDIUM
Address _____ Scheduled 03/19/18 03 41 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 51780814 71949262 4624 B14168910

Description

Comment RT, BRK HSE, LF CNR

Requested By James Assigned To MAINTENANCE CREW Completed By _____

Start Date 3/20/18 Time _____ Completed Date 3/20/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes See if his leak is on us, says when he turns his cutoff valve off, the meter still turns

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>1 - NEW GASKET</i>		

About 1/2 gallon minute

Signature *A.C*

EAST LOUISVILLE WATER DISTRICT
WORK ORDER 12655

Account #
Name WILSON, LESLIE D
Address
Telephone

Order Date 3/7/2018
Status MEDIUM
Scheduled 03/07/18 02:30 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 69361506 63066118 7959 B14168279

Description
Comment LF,WH/HSE RT/YD

Requested By Daniel Assigned To MAINTENANCE CREW Completed By
Start Date 3/8/18 Time : Completed Date 3/8/18 Time :

Make Size/Type Multiplier
Notes Daniel called BUD

Inventory Item And Description	Quantity Ordered	Quantity Used
We fixed it		

Signature A.C. D.B.

East Logan Water District
WORK ORDER 42662

Account # _____ Order Date 3/9/2018
Name HARWOOD, BILL Status MEDIUM
Address _____ Scheduled 03/09/18 03:56 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / CUT
WT 50180689	61512457	5941	B14166546	

Description _____
Comment LFT WHITE DBL WIDE MID YD
Requested By Bill Harwood Assigned To MAINTENANCE CREW Completed By _____
Start Date 3/13/18 Time _____ Completed Date 3/13/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Called to report possible leak Linda saw there is water in front of meter, tested for chlorine. BUD needs to be called to repair service tube neares cross road is Reclor



Inventory Item And Description	Quantity Ordered	Quantity Used
6' of service tubing 3/4		
2- 3/4 nuts		
2- 3/4 inserts		

BUD # 1803120536

x-RELTOW RID.

LTC WRECC

1/2 Gal Per minute



Signature AC

LESLIE COUNTY WATER DISTRICT
WORK ORDER 12656

Account #
Name SHOEMAKE, CHARLES
Address
Telephone Job #

Order Date 3/7/2018
Status MEDIUM
Scheduled 03/07/18 02:36 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50236748	09810632	5490	B14169622	

Description
Comment RT BRK,LFT OF DR BY TREES
Requested By Daniel Assigned To MAINTENANCE CREW Completed By
Start Date 3/8/18 Time : : Completed Date 3/8/18 Time : :

Make _____ Size/Type _____ Multiplier _____
Notes Daniel called BUD so we can repair/replace tubing

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>1 3/4 Quick coupling</i>		

3 to 4 Gals

Signature *A.C.*

WEST LUGER WATER DISTRICT
WORK ORDER 12584

Account # _____ Order Date 2/27/2018
 Name BALDWIN, RONALD R Status MEDIUM
 Address _____ Scheduled 02/27/18 08:38 AM
 Telephone _____ b# _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056531	09720861	1671	B14167459	

Description _____
 Comment LF YELLOW HSE, LF DR
 Requested By Mr Baldwin Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/27/18 Time _____ Completed Date 2/27/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>NO Leak</i>		

Signature AC

East Logan Water District
WORK ORDER 12576

Account # _____ Order Date 2/23/2018
 Name *Cartwright* JAMES F Status MEDIUM
 Address _____ Scheduled 02/23/18 11:20 AM
 Telephone _____ Job # _____ Order Type CHECK METER

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 57551155	63803451	4410	B14170013	<u>4447</u>

Description _____
 Comment RT, BLUE HSE, RT CNR
 Requested By Pennyrite Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/23/18 Time _____ Completed Date 2/23/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes A & G Tree Service is contracted thru Pennyrite. Cutting limbs, and a limb fell on meter lid and busted it. Please see what damage was done, make sure nothing is leaking

Inventory Item And Description	Quantity Ordered	Quantity Used

*New lid + Complete MVU housing + a 4' inch riser.
 Will need to replace box
 X - 68/80
 area marked in white paint.*

Signature *fm*

EAST LOGAN WATER DISTRICT
WORK ORDER 12551

Account #
Name STRATTON, PENNY D
Address
Telephone

Order Date 2/12/2018
Status MEDIUM
Scheduled 02/12/18 12:43 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 34116526	09946296	3247	B14167522	35-31

Description
Comment LF,WH TRLR,RT DR

Requested By Linda Assigned To MAINTENANCE CREW Completed By
Start Date 2/17/18 Time : Completed Date 2/17/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature TM

WEST VIRGINIA WATER DISTRICT
WORK ORDER 12536

Account #
Name HENSLEY, MARK D
Address
Telephone "

Order Date 2/6/2018
Status MEDIUM
Scheduled 02/06/18 10:54 AM
Order Type CHECK METER

Job #

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 21337546	13200929	3928	B14168135	3932

Description Cut back on & meter leaking

Comment RT,WH/BRN TRLR,LF CNR

Requested By Customer Assigned To MAINTENANCE CREW Completed By

Start Date 2/11/18 Time : Completed Date 2/16/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

back on & there is no leak. just had ground water in box

Sept Hyles

Signature *FM*

East Logan Water District
WORK ORDER 12535

Account # _____ Order Date 2/5/2018
Name FLEWALLEN, RITCHIE H Status MEDIUM
Address _____ Scheduled 02/05/18 04:10 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271691	74600763	436	B14892525	436

Description _____
Comment LF, BRK HSE, 15' RT DR
Requested By Contractor _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 2/16/18 Time _____ Completed Date 2/16/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Workers called and said our PRV was leaking at the meter. They turned meter off until we can replace the regulator. Please check

Inventory Item And Description	Quantity Ordered	Quantity Used

Replaced PRV

Signature 

West Logan Water District
WORK ORDER 12816

Account # _____ Order Date 4/24/2018
 Name BARROW, MARK Status MEDIUM
 Address _____ Scheduled 04/24/18 04 11 PM
 Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 50056530 ERT/INTERNAL ID# 09961419 READING 4 LOCATOR TAG B14169784 READING IN / OUT _____

Description _____
 Comment RT, WH HSE, RT 1ST DR
 Requested By Mark Assigned To MAINTENANCE CREW Completed By DB
 Start Date ____/____/____ Time _____ Completed Date 4/26/18 Time 8:00

Make _____ Size/Type _____ Multiplier _____

Notes Standing water is highly unusual See if we have a leak Check his meter, he thinks he might also have a leak
No LEAK IN YARD -- RAIN WATER

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 12801

Account # 1
Name HALL, RICKY
Address
Telephone

Order Date 4/13/2018
Status MEDIUM
Scheduled 04/13/18 09:37 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 81271710 ERT/INTERNAL ID# 74600782 READING 1732 LOCATOR TAG B14168622 READING IN / OUT

Description
Comment RT, 2 STORY WH/HS R/DR

Requested By Ricky Hall Assigned To MAINTENANCE CREW Completed By *DB*

Start Date / / Time : Completed Date 4/16/18 Time 9:29

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

*SOUNDING METER NO NOISE
METER NOT TURNING
ANDY FOUND SMALL LEAK ON PRESSURE REG. FIXED 4-26-18*

Signature *DB*

East Logan Water District
WORK ORDER 12738

Account # _____ Order Date 4/12/2018
 Name SCHWARTZ, SUZANNA Status MEDIUM
 Address _____ Scheduled 04/12/18 08:10 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 33973729	08837340	2411	B14148039	2428

Description _____
 Comment RT,WH/HSE M/YD
 Requested By Suzanna Assigned To MAINTENANCE CREW Completed By _____
 Start Date 4/12/18 Time _____ Completed Date 4/12/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Customer says possible leak

Inventory Item And Description	Quantity Ordered	Quantity Used

Did not see any indication of leak.

Signature *[Signature]*

WORK ORDER 12728

Account #
Name KEMP, RUSSELL S
Address
Telephone

Order Date 4/6/2018
Status MEDIUM
Scheduled 04/06/18 09:08 AM
Order Type CHECK METER

METER# WT 42088278 ERT/INTERNAL ID# 09727127 READING 508 LOCATOR TAG B14166968 READING IN / OUT

Description
Comment RT, BRK HSE, 15' LF OF LF CNR

Requested By Janel Kemp Assigned To MAINTENANCE CREW Completed By

Start Date 4/16/18 Time : Completed Date 4/16/18 Time :

Make Size/Type Multiplier

Notes Customer reports Semi-Truck ran off road and ground around meter is disturbed. Check to see if meter is ok.

Inventory Item And Description	Quantity Ordered	Quantity Used
Meter and Meter Box is good		
No Leaks		

Signature A.C.

East Logan Water District
WORK ORDER 12723

Account # -
Name STEPHENS MELANIE
Address
Telephone

Order Date 4/3/2018
Status MEDIUM
Scheduled 04/03/18 10.30 AM
Order Type CHECK METER



METER# WT 51780823 ERT/INTERNAL ID# 09624330 READING 5615 LOCATOR TAG B14172297 READING IN / OUT

Description
Comment RT, BRK, L OF HSE behind bldg *5637*

Requested By Linda Assigned To MAINTENANCE CREW Completed By
Start Date *4/3/18* Time : Completed Date *4/3/18* Time :

Make _____ Size/Type _____ Multiplier _____
Notes Check for leak may want to change out the meter

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Meter is Good</i>		
<i>No leaks</i>		

A. C.

Signature

EAST LOGAN WATER DISTRICT
WORK ORDER 13032

Account # _____ Order Date 7/2/2018
Name CUNNINGHAM, CHANDA L Status MEDIUM
Address _____ Scheduled 07/02/18 02:50 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82994989	89283198	650	B15438801	0699

Description

Comment RT/ RT NCR PF HSE/ 4' OFF RD

Requested By CHANDA

Assigned To MAINTENANCE CREW

Completed By *DB*

Start Date / / Time :

Completed Date 7/2/18 Time 3:55

Make _____ Size/Type _____ Multiplier _____

Notes CUST CALLED TO CHECK 7/20/18 BILL AMT ADV. HER OF HER USAGE, STATES THAT METER BOX IS BROKE

BROKEN ON CURB SIDE SHOWS OFF FOR CUST.

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature

East Logan Water District
WORK ORDER 13076

Account # _____
Name THOMASON, LESLIE
Address _____
Telephone _____ Job # _____

Order Date 7/9/2018
Status MEDIUM
Scheduled 07/09/18 02 29 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 78461136	73488032	836	B14169266	

Description _____
Comment RT, LT/LOT, PAST B FARMS RD-R

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
Notes STATES THAT METER IS FULL OF WATER ADV THAT MORE THAN LIKELY LEAK IS ON HER SIDE BUT WILL HAVE SOMEONE CHECK TO MAKE SURE

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 13319

Account #
Name H&H SHEETMETAL
Address
Telephone

Order Date 9/11/2018
Status MEDIUM
Scheduled 09/11/18 12.06 PM
Order Type ZERO USAGE/CHECK OUT

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684160	59596248	1213	B14167948	

Description

Comment LF, SHOP, LF CNR RED BLD

Requested By COURTNEY Assigned to MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 09/11/18 09 07 AM Completed Date 09/11/18 09 07 AM

Notes

SHOWING NO USAGE IN LAST YEAR. PLEASE CHECK OUT TO MAKE SURE EVERYTHING IS WORKING PROPERLY
METER IS TURNED OFF. BOTOM OF METER IS BUSTED.

Make bottom

New Met# 9135921 Kam Met l.d needs replaced

Signature _____

East Logan Water District
WORK ORDER 13447

Account #	00	Order Date	10/5/2018
Name	EIGSTI, DEION R	Status	MEDIUM
Address		Scheduled	10/05/18 03.32 PM
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056581	55345465	5313	B14169802	

Description

Comment RT, TAN TRLR, RT CNR

Requested By Loyd Houchens Assigned To MAINTENANCE CREW Completed By GP/MLH

Start Date 10/1/18 Time : Completed Date 10/6/18 Time 2:00

Make _____ Size/Type _____ Multiplier _____

Notes Water here and across the road. It is a leak. Area marked and LTC notified.

Leak fixed

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>2 Muller Nwts</i>		<i>2</i>
<i>50ft of blue tubing 3/4</i>		<i>50ft</i>
<i>1 New Meter S/N 9135986 /LW/18</i>		<i>1</i>

tubing *Reading 531573.4*
Cracked meter bottom
replaced meter
9135986 Kamstrup

Signature *GP*

East Logan Water District
WORK ORDER 13234

Account # _____
Name **LOOPER, CURTIS J**
Address _____
Telephone _____

Order Date **8/16/2018**
Status **MEDIUM**
Scheduled **08/16/18 11:47 AM**
Order Type **CHECK FOR LEAK ON OUR SIDE**

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473837	07303076	8902	B14167000	<u>8902</u> <u>0000</u>

Description

Comment **RT, BARN ACROSS/H CHAP RD**

Requested By **LINDA** Assigned To **MAINTENANCE CREW** Completed By **MMH**

Start Date / / Time : Completed Date 8/16/18 Time 12:51

Make _____ Size/Type _____ Multiplier _____

Notes Daniel says leaking on customer side, but meter was not turning Please change out meter, turn on, and see if it registers If so, then turn off and call us or customer to tell him it is def a leak on his side

Changed Meter Leak is Visible coming out of Ground on customer side

Inventory Item And Description	Quantity Ordered	Quantity Used

Sensus

www.sensus.com
1-800-METERIT



Certified to NSF/ANSI 61-G

Order: 00488049 Line: 002

Part: _____ Date: 0518



AX2XX38P1GGXSXD
MTR 5/8-3/4 AS ER+ TRPL 6'
5WHL4A 100G LHP
SMART DP/P

Config: _____
H8A2BAAA

Sensus _____
Meter SN: 84900770

Flow: _____
Low:100.1 Mid:101.5 H1:099.6

Register _____
Cust ID: 90118860

Register _____
Fact ID: 90118860

Order: 00488049 Line: 002

Part: _____ Date: 0518



AX2XX38P1GGXSXD
MTR 5/8-3/4 AS ER+ TRPL 6'
5WHL4A 100G LHP
SMART DP/P

Config: _____
H8A2BAAA

Sensus _____
Meter SN: 84900770

Flow: _____
Low:100.1 Mid:101.5 H1:099.6

Register _____
Cust ID: 90118860

Register _____
Fact ID: 90118860

Signature

MMH

East Logan Water District
WORK ORDER 12910

Account # -----
Name LASTER, SARA D
Address -----
Telephone -----

Order Date 5/17/2018
Status MEDIUM
Scheduled 05/17/18 09:31 AM
Order Type CHECK FOR LEAK ON OUR SIDE

Job # -----

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 31419086	09891360	4663	B14891980	RT HSE

Description
Comment RT HSE, RT YARD

Requested By Brandon Sawyers Assigned To MAINTENANCE CREW Completed By

Start Date 5/17/18 Time : Completed Date 5/17/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

nothing leaking Just ran over his cut off cap

Signature 

East Logan Water District
WORK ORDER 12905

Account #
Name HEAD, WALTER B
Address
Telephone Job #

Order Date 5/15/2018
Status LOW
Scheduled 05/15/18 08:58 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 34889445 ERT/INTERNAL ID# 09366541 READING 7519 LOCATOR TAG B14167622 READING IN / OUT

Description
Comment RT BRK L/DR

Requested By Linda Assigned To MAINTENANCE CREW Completed By LD

Start Date / / Time : Completed Date 5/15/18 Time 11:40

Make _____ Size/Type _____ Multiplier _____

Notes Leak fixed in July 2015 Area has sunk See if it is leaking again, or if we need to repair Talk to customer while there
772-0559

Inventory Item And Description	Quantity Ordered	Quantity Used

DRIVE IS SUNK WHERE 10" MAIN IS INSTALLED. TOOK PICTURES. DRIVE NEEDS TO BE REPAIRED.

Signature *LD*

East Logan Water District
WORK ORDER 12903

Account # _____
Name LESTER, CAROLYN E
Address _____
Telephone _____ Job # _____

Order Date 5/15/2018
Status MEDIUM
Scheduled 05/15/18 07:51 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 20235134	39202683	3032	B14169201	3037

Description
Comment LF, GRAY TRLR, LF DR

Requested By customer Assigned To MAINTENANCE CREW Completed By DB
Start Date 5/15/18 Time 7:05 Completed Date 5/15/18 Time 11:05

Make _____ Size/Type _____ Multiplier _____

Notes Left message on machine, says leak behind mailbox

NO LEAK IN SERVICE, SCHEDULED ON 5 OFF, NO WATER PRESENT.
HOLE IN DRY DIRT

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 12909

Account # _____ Order Date 5/16/2018
 Name SHOEMAKE, DANNY D Status MEDIUM
 Address _____ Scheduled 05/16/18 03.33 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82995072	89283281	212	B15440706	

Description _____
 Comment RT WH HSE LON GR DR M/FR YD
 Requested By Danny Shoemake Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Danny thinks we have a leak around the blow off we set a few months back.

No leak EC shut off. Meter not turning.

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 12896

Account #
Name ELAMON, RUTH ANN & DANNY
Address
Telephone Job #

Order Date 5/14/2018
Status MEDIUM
Scheduled 05/14/18 08 50 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51170333	61750522	9346	B14168637	9388

Description
Comment
Requested by mrs. ruth Assigned To MAINTENANCE CREW Completed By DE
Start Date / / Time : Completed Date 5/14/18 Time 9:40

Make _____ Size/Type _____ Multiplier _____
Notes customer says alot of water still around box
No Service on Meter. No leak in service

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 12884

Account #
Name APPLING, BUCK
Address
Telephones

Order Date 5/9/2018
Status MEDIUM
Scheduled 05/09/18 03.09 PM
Order Type MISCELLANEOUS

Job #

METER# WT 65798129 ERT/INTERNAL ID# 58647047 READING 2096 LOCATOR TAG B14167768 READING IN / OUT 2.1x

Description

Comment LT, WH/HSE, RT/YD

Requested By Linda

Assigned To MAINTENANCE CREW

Completed By

Start Date 5/10/18 Time ___:___

Completed Date 5/10/18 Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Please call Mrs. Appling and show her the meter, clean it off, and see if there is a leak

Inventory Item And Description	Quantity Ordered	Quantity Used

maybe Friday if not too busy?

NO leak & showed her how to check for leak

Signature



East Logan Water District
WORK ORDER 12832

Account # _____ Name LOOPER, CURTIS Order Date 5/2/2018
Address _____ Status MEDIUM
Telephone _____ Job # _____ Scheduled 05/02/18 08:48 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47747447	63097826	6202	B14167361	

Description _____
Comment LF WH/HS R/YD BY LP TANK T/LF
Requested By daniel brown Assigned To MAINTENANCE CREW Completed By _____
Start Date 5/4/18 Time ____:____ Completed Date 5/4/18 Time ____:____

Make _____ Size/Type _____ Multiplier _____
Notes check for leak on main an d/b did bud call an the number for bud # 1805020424

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>NO LEAK</i>		

Signature *A.C. T.M.*

East Logan Water District
WORK ORDER 12867

Account #
Name **BROWN, MICHAEL**
Address
Telephone

Order Date 5/3/2018
Status MEDIUM
Scheduled 05/03/18 05:43 PM
Order Type CHECK FOR LEAK ON OUR SIDE

Job #

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473770	70978961	1577	B14250481	

Description
Comment RT BRK R/DR

Requested By Michael Brown Assigned To MAINTENANCE CREW Completed By
Start Date 5/14/18 Time : Completed Date 5/14/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes Found wet spot that left tracks as they mowed Please see whats leaking

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 Sitter		
1- 3/4-12" nipple		
2- 3/4 inserts		
1- 3/4 PVC coupling		
1- Standard meter Box		
1- Standard Lid		
1- 3/4 nut		

WRECC

LTC

1805040221

Signature A. V. T. M.

East Logan Water District
WORK ORDER 12883

Account # _____ Order Date 5/9/2018
Name HESTER, WALTER M III Status MEDIUM
Address _____ Scheduled 05/09/18 02:57 PM
Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 54111895	63097855	7585	B14169205	

Description _____
Comment LF WH/HS ON CNR L/CNR
Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____
Start Date 5/11/18 Time _____ Completed Date 5/11/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Service tube leak

Inventory Item And Description	Quantity Ordered	Quantity Used
2- 3/4 inch pipe		
2- Tee		
Replaced Service Tubing		

O.B. d d Bud call

Signature Ali

East Logan Water District
WORK ORDER 12697

Account #
Name CROCKER, DAVID
Address
Telephone

Order Date 3/20/2018
Status MEDIUM
Scheduled 03/20/18 10 26 AM
Order Type MISCELLANEOUS

METER# WT 47704823 ERT/INTERNAL ID# 63056378 READING 4814 LOCATOR TAG B14170250 READING IN / OUT

Description
Comment LF, BRK HSE, 20' RT GR DR

Requested By ELWD Assigned To MAINTENANCE CREW Completed By
Start Date 4/21/18 Time Completed Date 4/21/18 Time

Make Size/Type Multiplier
Notes Pulling a new service line under road

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced service Tubing		
3/4 Tubing 90 FT 2-3/4 inserts		
2-3/4 NUTS		

Bud 1803161151

ATT

1804091310

~~1218~~

Signature

A.L. J.M.

East Logan Water District
WORK ORDER 12737

Account # _____ Name CROPPER, CHARLES Order Date 4/11/2018
 Address _____ Status HIGH
 Telephone _____ Job # _____ Scheduled 04/11/18 02:26 PM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684152	59596240	7344	B14167057	

Description
 Comment LT, BRK, FAR LT/YD
 Requested By kathy cropper Assigned To MAINTENANCE CREW Completed By _____
 Start Date ___/___/___ Time ___:___ Completed Date ___/___/___ Time ___:___

Make _____ Size/Type _____ Multiplier _____
 Notes long side service tube

Inventory Item And Description	Quantity Ordered	Quantity Used
Relocated tubing 80 FT 3/4 1-Row		
Note 2- 3/4 insert Roadbore was 35 FT		
3/4 - 4" saddle		
Not even a 1/4 of a gallon a minute		
Cut old corp OFF		

Ticket / Bud # 1804111592
 New Bud # 1804110678

Notify

Att, BU Gas

~~5:16 - 5:45 PM at site~~

Signature

A. C.

East Logan Water District
WORK ORDER 12812

Account #
Name HALL, RICKY
Address
Telephone

Order Date 4/23/2018
Status MEDIUM
Scheduled 04/23/18 02:47 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 81271710 74600782 1732 B14168622

Description
Comment RT, 2 STORY WH/HS R/DR

Requested By Assigned To MAINTENANCE CREW Completed By

Start Date / / Time : Completed Date / / Time :

Make Size/Type Multiplier

Notes replace box an setter bud #1804231543

Notify Logan Tele

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Leak on air side</i>		
<i>We found that on Saturday</i>		

*Put in Dual setter w. + Regulator 3/4
Replaced meter h.*

Signature _____

East Logan Water District
WORK ORDER 12424

Account #
Name MCINTOSH GARY F
Address
Telephone Job #

Order Date 1/3/2018
Status MEDIUM
Scheduled 01/03/18 03:40 PM
Order Type MISCELLANEOUS

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979880	09811264	2016	B14166697	
Description	LF, 7360.6.961	coll		
Comment				
Requested By Tyler		Assigned To MAINTENANCE CREW		Completed By
Start Date 1/16/18	Time		Completed Date 1/16/18	Time

Make _____ Size/Type _____ Multiplier _____
Notes Cutoff needs to be replaced when it gets a little warmer

Inventory Item And Description	Quantity Ordered	Quantity Used
1 - 3/4 Cutoff Replaced		

AL-TM

Signature _____

East Logan Water District
WORK ORDER 12701

Account # _____
 Name FOX, TIMOTHY P
 Address _____
 Telephone _____ Job # _____
 Order Date 3/22/2018
 Status MEDIUM
 Scheduled 03/22/18 09:14 AM
 Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 78786048 ERT/INTERNAL ID# 73607034 READING 14 LOCATOR TAG B14168821 READING IN / OUT 16

Description
 Comment RT, TRLR IN WOODS, RT CNR
 Requested By Timothy Assigned To MAINTENANCE CREW Completed By _____
 Start Date 3/22/18 Time _____ Completed Date 3/22/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Water comes up around meter there Make sure meter is in same on/off position when you leave as when you got there

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted PRV, Dont have everything to fix it today on
 3-22-18. will return 3-23-18 to fix

3-23-18
 Leaked PRV
 & same readings (16)

Signature TM

East Logan Water District
WORK ORDER 12881

Account #
Name FREEMAN, HAROLD
Address
Telephone Job #

Order Date 5/9/2018
Status MEDIUM
Scheduled 05/09/18 02:08 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 43518909
ERT/INTERNAL ID# 09449821
READING 7133
LOCATOR TAG B14169905
READING IN / OUT

Description
Comment LF GRAY TRLR, RT CNR, UP BANK

Requested By d/b _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 5/11/18 Time _____ Completed Date 5/21/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced 3 FT $3/4$ Tubing		
Tubing was not all the way in the setter.		
A.C. T.M. Seeded and Stawed He's done		

Signature A.C.

West Eugene Water District
WORK ORDER 12565

Account #
Name ROGERS, JAMES D
Address
Telephone Job #

Order Date 2/20/2018
Status MEDIUM
Scheduled 02/20/18 01:36 PM
Order Type CHECK METER

METER# WT 52473884 ERT/INTERNAL ID# 07302667 READING 8684 LOCATOR TAG B14168830 READING IN / OUT

Description Change out meter box
Comment LT, BRK, LTYD

Requested By Andy Assigned To MAINTENANCE CREW Completed By

Start Date 3/12/18 Time Completed Date 3/1/18 Time

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
1 - Standard meter box Lid		
1 - 3/4 setter		
3 - 3/4 inserts		
1 - 3/4 coupling		

Bud# 1802200939 X by 02/22/18
LTC, WRECC

Signature AC

East Logan Water District
WORK ORDER 12892

Account #
Name COLES, PAUL
Address
Telephone Job #

Order Date 5/11/2018
Status MEDIUM
Scheduled 05/11/18 01:29 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82994988	89283197	16	B15438672	

Description

Comment RT/ RT OF DR/ 6' OFF RD

Requested By customer

Assigned To MAINTENANCE CREW

Completed By *DB*

Start Date ___/___/___ Time ___:___

Completed Date 5/11/18 Time 3:00

Make _____ Size/Type _____ Multiplier _____

Notes leaking in box

Inventory Item And Description	Quantity Ordered	Quantity Used
1-7" SETTER		
1.5 HR TIME		

*Damage repaired
Bulldozer marks to be filled*

DOZER RAN OVER METER BOX. BROKE SETTER ON BACK SIDE.

Signature 

East Logan Water District
WORK ORDER 12435

Account #
Name AUSBROOKS, JAMES D
Address
Telephone Job #

Order Date 1/5/2018
Status MEDIUM
Scheduled 01/05/18 08 10 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 35189021 ERT/INTERNAL ID# 09371096 READING 1739 LOCATOR TAG B14167431 READING IN / OUT

Description
Comment RT,RED BLD,LF 2ND DR

Requested By Daniel Assigned To MAINTENANCE CREW Completed By DB9 A.C
Start Date 1/1/18 Time Completed Date 1/5/18 Time 9:00

Make Size/Type Multiplier

Notes Main line leak on Cartmill

REDAILED MAIN

Inventory Item And Description	Quantity Ordered	Quantity Used
6x15 CLAMP		

BWD# 1801040973 ATT LTC LTRW WRECC
X-ECO VALLEY RD.

Signature _____

WORK ORDER 12447

Account #
Name FUGATE, STEVE W
Address
Telephone Job #

Order Date 1/8/2018
Status MEDIUM
Scheduled 01/08/18 11:38 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81004655	74516491	489	B15368334	

Description Water coming up out of ground

Comment

Requested By Steve Fugate Assigned To MAINTENANCE CREW Completed By DB + AC

Start Date 1/8/18 Time 12:00 Completed Date 1/8/18 Time 12:00

Make Size/Type Multiplier
Notes No LEAK CURRENT WATER - WILL CONTINUE TO MONITOR

Inventory Item And Description	Quantity Ordered	Quantity Used

*Called
Daniel*

Signature _____

East Logan Water District
WORK ORDER 12449

Account # _____ Order Date 1/8/2018
 Name HOSTETLER, MORRIS Status MEDIUM
 Address _____ Scheduled 01/08/18 11:42 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 44025967	62202132	2812	B14167897	2837

Description: Water coming out of meter
 Comment: RT, STONE-GRAY HS 50'BEFORE DR
 Requested By Mr. Hosteller Assigned To MAINTENANCE CREW Completed By _____
 Start Date 1/8/18 Time _____ Completed Date 1/8/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted bottom replaced bottom (around 1/2 gal/hr min)
 Meter is still turning slowly

Signature TM

East Logan Water District
WORK ORDER 12427

Account # _____ Order Date 1/4/2018
Name GILLIS, AMY M Status MEDIUM
Address _____ Scheduled 01/04/18 08:22 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 36140720 ERT/INTERNAL ID# 10413228 READING 5006 LOCATOR TAG B14166690 READING IN / OUT _____

Description
Comment LFT WHSE RT OF DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 1/15/18 Time _____ Completed Date 1/15/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes Main line leak

Inventory Item And Description	Quantity Ordered	Quantity Used
NO leak found		

1801040327

Marked in white

AFT
LTC

Signature 

East Logan Water District
WORK ORDER 12426

Account # _____
Name FERGUSON, ECHO L
Address _____
Telephone _____ Job # R 774 1338
Order Date 1/3/2018
Status MEDIUM
Scheduled 01/03/18 04:48 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 83545697 89536809 B14170083

Description _____
Comment RT,WH HSE RT CNR
Requested By Linda Assigned To MAINTENANCE CREW Completed By AC
Start Date ___/___/___ Time ___:___ Completed Date 1/3/18 Time 12:00

Make _____ Size/Type _____ Multiplier _____

Notes Water flowing up at meter
REPAIRED SERVICE LINE 15 GPM 5400 GAL LOST

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature DB

East Logan Water District
WORK ORDER 12403

Account # _____ Order Date 1/2/2018
Name WHITE, BARRY L Status MEDIUM
Address _____ Scheduled 01/02/18 02:08 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 69361540 ERT/INTERNAL ID# 63066152 READING 2265 LOCATOR TAG B14167788 READING IN / OUT _____

Description
Comment LF, WH-BLUE TRLR, RT/YD

Requested By Barry White Assigned To MAINTENANCE CREW Completed By _____
Start Date 1/1/18 Time _____ Completed Date 1/1/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes BUD # 18010210AC
AST, ITC

Inventory Item And Description	Quantity Ordered	Quantity Used
4 FT Pile of Tubing 3/4		
3 - 3/4 inserts		
1 - 3/4 Couplings		
1 - 3/4 nut		

3 - gal per minute

Signature AC. T.M

East Logan Water District
WORK ORDER 12402

Account # _____ Order Date 1/2/2018
Name STAMPS ROBERT J Status MEDIUM
Address _____ Scheduled 01/02/18 01:56 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81004659	74516495	712	B14167452	

Description POSSIBLE MAIN LINE LEAK

Comment LF GRAY HS LYD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____

Start Date 1/4/18 Time _____ Completed Date 1/4/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes BND # 1801070878 LTC WRECC

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>10 ft roll of Tubing</u>		
<u>2 - 3/4 Couplings</u>		
<u>4 - 3/4 inserts</u>		

4 gal per minute

Signature A.C

EAST LUGAN TOWNSHIP DISTRICT
WORK ORDER 12434

Account # _____ Order Date 1/5/2018
 Name BARNETT, NANCY TP Status MEDIUM
 Address _____ Scheduled 01/05/18 08:24 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 45221795	62208767	2144	B14169584	2264

Description _____
 Comment LF, WH HSE, 50' RT, RT CNR
 Requested By Nancy Assigned To MAINTENANCE CREW Completed By _____
 Start Date ____/____/____ Time ____:____ Completed Date 1/5/18 Time 9:57

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Customer Leak

EAST LOGAN WATER DISTRICT
WORK ORDER 12405

Account # _____ Order Date 1/3/2018
 Name DOTSON, DARLENE Status MEDIUM
 Address _____ Scheduled 01/03/18 07:13 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
 WT 51780787 10289537 337 B14169637 _____
 Description _____
 Comment LF, BRK HSE, LF YD O/FENCE
 Requested By Darlene Assigned To MAINTENANCE CREW Completed By DB & AC
 Start Date ___/___/___ Time ___:___:___ Completed Date 1/3/18 Time 8:48 AM

Make _____ Size/type _____ Multiplier _____
 Notes Emergency BUD call
 Not work LEAK SHOW OFF METER

Inventory Item And Description	Quantity Ordered	Quantity Used

LTC

X

1501030180

Signature _____

East Logan Water District
WORK ORDER 12429

Account #
Name ANDERSON, NATASHA D
Address
Telephone

Order Date 1/4/2018
Status MEDIUM
Scheduled 01/04/18 11:56 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 78786000 ERT/INTERNAL ID# 73606986 READING 2216 LOCATOR TAG B14169884 READING IN / OUT

Description

Comment LF, BARN LOT, 30' RT BARN AT F O

Requested By Tyler Assigned To MAINTENANCE CREW Completed By AC & DIS

Start Date 1/1/18 Time : Completed Date 1/4/18 Time 3:30

Make _____ Size/Type _____ Multiplier _____

Notes BUD# 18010408
LTC, WRECC

ROUTED METER BOTTOM, REGULATOR, & CUTOFF 15 GPM @ 10 HRS 7000 GALL LOSS

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____

East Logan Water District
WORK ORDER 12401

Account #		Order Date	1/2/2018
Name	CARDWELL, NORINE	Status	MEDIUM
Address		Scheduled	01/02/18 01:55 PM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 82995118	89283327	83	B14169023	
Description	POSSIBLE MAIN LINE LEAK			
Comment	RT, TAN HSE. LT/DR			
Requested By	DANIEL	Assigned To	MAINTENANCE CREW	Completed By
				DB
Start Date	1 / 1	Time	:	
		Completed Date	1 / 3 / 18	Time 12: 0

Make _____ Size/Type _____ Multiplier _____
 Notes SID # 180,020821 LTC MID GAS WIRECL

Inventory Item And Description	Quantity Ordered	Quantity Used

No LEAK FOUND

WORK ORDER 12400

Account # _____ Order Date 1/2/2018
 Name HEAD, BOBBIE Status MEDIUM
 Address _____ Scheduled 01/02/18 01 54 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48485205	13210058	4443	B14170242	

Description SERVICE LINE

Comment LF, BRK HSE, RT DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By AC

Start Date 1/1/18 Time _____ Completed Date 1/13/18 Time 12:00

Make _____ Size/Type _____ Multiplier _____

Notes BUD # 1801020553

LTC ATT

Inventory Item And Description	Quantity Ordered	Quantity Used

Service line replaced

Signature _____

East Logan Water District
WORK ORDER 12412

Account #
Name CLINARD, JONATHAN P
Address
Telephone Job #

Order Date 1/3/2018
Status MEDIUM
Scheduled 01/03/18 10:35 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 48431491 63097869 5705 B14167284

Description
Comment RT YELLOW D-WIDE L/DR T/LF

Requested By Daniel Assigned To MAINTENANCE CREW Completed By

Start Date 1/3/18 Time _____ Completed Date 1/3/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
3" pipe		
1 - 3/4 coupling		
3 - 3/4 inserts		
1 - 3/4 nut		

Box # 1801030624 LTC WRELL
x-CHANDLER RD

Signature A.C. T.M

East Logan Water District
WORK ORDER 12432

Account # _____ Order Date 1/4/2018
 Name AUSTIN, FRED Status MEDIUM
 Address _____ Scheduled 01/04/18 01:11 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66964685	61750521	1669	B14166451	1678

Description WATER RUNNING OUT OF METER

Comment RT. GREEN TRLR, R/DR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____


Start Date 1/4/18 Time _____ Completed Date 1/4/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

water is coming in from behind meter & meter is turning slowly

Signature 

East Logan Water District
WORK ORDER 12413

Account #
Name GLOSTER, DANA L
Address
Telephone

Order Date 1/3/2018
Status MEDIUM
Scheduled 01/03/18 10:50 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 35507373 ERT/INTERNAL ID# 63524772 READING 1263 LOCATOR TAG B15089779 READING IN / OUT _____
Description Possible main line leak
Comment RT HSE RT CNR
Requested By _____ Assigned To MAINTENANCE CREW Completed By DJB
Start Date 1/1/18 Time _____ Completed Date 2/16/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes CLOSE WORK ORDER NO LEAK

Inventory Item And Description	Quantity Ordered	Quantity Used

BUD # 1801030477 LTC
X-DAVENPORT LN

Signature _____

East Logan Water District
WORK ORDER 12484

Account # _____ Order Date 1/24/2018
Name EVANS, DEMETRIA & ANTHONY V Status MEDIUM
Address _____ Scheduled 01/24/18 08:35 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
WT 39340867 10301848 3077 B14700937

Description Main line leak
Comment RT, 1/2 BRK HSE, LF CNR

Requested By Daniel Assigned To MAINTENANCE CREW Completed By DB/AC/TM

Start Date 1/1/18 Time _____ Completed Date 1/24/18 Time 4:30

Inake _____ Size/Type _____ Multiplier _____

Notes 90° BRASS ELBOW MAIN REPAIRED & NEW KICKER POURED

35 GAL/MIN

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 4" 90° BEND		
2- ROMAC GRIP RINGS 4"		
10'-4" SDR-21		
1- 4" SPLIT FACE BOLL RESTRAINT		
2- 4" PVC KICKER ON		

Signature _____

East Logan Water District
WORK ORDER 12490

Account # _____ Order Date 1/29/2018
Name LOGAN, CARLA Status MEDIUM
Address _____ Scheduled 01/29/18 02:15 PM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684139	61287401	2411	B14167865	2431

Description _____

Comment RT,TRLR,MYD

Requested By Walt Shifflett

Assigned To MAINTENANCE CREW

Completed By DJS

Start Date 1/1/ Time :

Completed Date 1/29/18 Time 2:43

Make _____ Size/Type _____ Multiplier _____

Notes _____

CNT OFF ON CUSTOMER SIDE IS BROKEN NO ISSUE ON OUR SIDE

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature _____



WEST LUGER WATER DISTRICT
WORK ORDER 12499

Account # _____ Name HOSTETLER, EUGENE Order Date 2/1/2018
 Address _____ Status MEDIUM
 Telephone _____ Job # _____ Scheduled 02/01/18 08:13 AM
 Order Type CHECK FOR LEAK ON OUR SIDE


METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 52473756 63097877 1175 B14170092

Description _____
 Comment RT,WH HSE.20' RT DR
 Requested By Tyler Assigned To MAINTENANCE CREW Completed By _____
 Start Date 2/1/18 Time _____ Completed Date 2/1/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes tyler found a probable leak at this address. Please check

Inventory Item And Description	Quantity Ordered	Quantity Used
12' 3/4 PIPE		
2- 3/4 NUTS		
2- 3/4 INSERTS		

3-4 gallons
Per minute

Signature 

East Logan Water District
WORK ORDER 12488

Account #
Name BRAY, OTIS
Address
Telephone Job #

Order Date 1/29/2018
Status MEDIUM
Scheduled 01/29/18 12:09 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 21337408	63814709	2433	B13480791	

Description
Comment LT 1/2 BRICK RT 2ND DR

Requested By Bray Assigned To MAINTENANCE CREW Completed By
Start Date 1/29/18 Time _____ Completed Date 1/29/18 Time _____

iflake _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
2 ^{ft} piece of 1" pipe		
4 1" inserts		
2 1" couplings		

7-8 Gals Per minute

Signature A. W. C.

East Logan Water District
WORK ORDER 12476

Account #
Name BRADLEY TP. MICHAEL A
Address
Telephone

Order Date 1/22/2018
Status MEDIUM
Scheduled 01/22/18 08:18 AM
Order Type CHECK METER

METER# WT 51170326 ERT/INTERNAL ID# 09205865 READING 942 LOCATOR TAG B14169503 READING IN / OUT

Description
Comment LF, BRN TRLR, M/YD

1020

Requested By customer Assigned To MAINTENANCE CREW Completed By

Start Date *1/22/18* Time : Completed Date *1/22/18* Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Changed out Plastic Reg</i>		
<i>They have a leak</i>		
<i>on their side and I</i>		
<i>let them know</i>		

Signature

[Handwritten Signature]

WORK ORDER 12479

Account #
Name GORMLEY, MILDRED
Address
Telephone

Order Date 1/22/2018
Status MEDIUM
Scheduled 01/22/18 10:45 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 50056603	08850106	2233	B14168860	

Description Air bubbling up where main line is

Comment LF, BRK HSE, RT CNR

Requested By Mr. Gormley Assigned To MAINTENANCE CREW Completed By

Start Date 1/23/18 Time : Completed Date 1/23/18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Checked main for leak		
NO LEAK		

Signature A.C

East Logan Water District
WORK ORDER 12865

Account #
Name **WRIGHT, J**
Address
Telephone

Order Date 5/4/2018
Status MEDIUM
Scheduled 05/04/18 10.08 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 68434129 ERT/INTERNAL ID# 62202153 READING 5108 LOCATOR TAG B14169645 READING IN / OUT 5117

Description
Comment LF, WH HSE, FAR RT YD

Requested By Connie Shoemake Assigned To MAINTENANCE CREW Completed By DE

Start Date 5/1/18 Time 9:50 Completed Date 5/1/18 Time 5:50

Make _____ Size/Type _____ Multiplier _____

Notes Wet spot between meter and road Found while mowing

*No service provided as small hole can't find
BUD # 1805091212 ATT LTRWC TEX GAS WRECK*

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Replaced Tubing</i>		
<i>Fixed Main Line</i>		

SERVICE LINE LEAK

Signature *AC*

East Logan Water District
WORK ORDER 12898

Account # _____
Name STAMPS, REBECCA J
Address _____
Telephone _____

Order Date 5/14/2018
Status MEDIUM
Scheduled 05/14/18 11 12 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 66553081 ERT/INTERNAL ID# 62326768 READING 3403 LOCATOR TAG B13303832 READING IN / OUT _____

Description _____

Comment RT TRL LF YD

Requested By Rebecca Stamps Assigned To MAINTENANCE CREW Completed By _____

Start Date ____/____/____ Time ____:____ Completed Date ____/____/____ Time ____:____

Make _____ Size/Type _____ Multiplier _____

Notes says water in box along with muddy ground

3.005 1805 141336 LTC WREU

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced Service Tubing		
1-3/4" x 6" Saddle		
1-3/4" Corp.		
2-3/4" Inserts		

4 gallons per min.

Signature A.C.

East Logan Water District
WORK ORDER 12891

Account #
Name **EZELL, STEVE**
Address
Telephone Job #

Order Date 5/1/2018
Status MEDIUM
Scheduled 05/01/18 12:38 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 47418244	07898335	231	B14169471	

Description

Comment LF, WH/HSE, L/CNR

Requested By Steve

Assigned To MAINTENANCE CREW

Completed By

Start Date 5/1/18 Time :__

Completed Date 5/1/18 Time :__

Make _____ Size/Type _____ Multiplier _____

Notes

Box # 1805 111 093 LTR WRECC

Inventory Item And Description	Quantity Ordered	Quantity Used
1- $\frac{3}{4}$ Tandem Setter		
1- $\frac{3}{4}$ Regulator		
1- $\frac{3}{4}$ S Pipe		
1- Standard meter Box and Lid		
7Ft $\frac{3}{4}$ Tubing		
1- $\frac{3}{4}$ 1/2" nipple		
2- $\frac{3}{4}$ inserts		
1- $\frac{3}{4}$ CONC. NUT		

Signature

WORK ORDER 12937

Account # _____
Name COOPER, MARION
Address _____
Telephone _____ Job # _____

Order Date 5/29/2018
Status MEDIUM
Scheduled 05/29/18 07:46 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 25547327	10649916	8724	B14166215	

Description _____
Comment LFT WHSE RT CENTER YD
Requested By Mary Davis/MCooper Assigned To MAINTENANCE CREW Completed By _____
Start Date ____/____/____ Time _____ Completed Date 5/10/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes We have a leak, and customer has terrible leak

Inventory Item And Description	Quantity Ordered	Quantity Used

East Logan Water District
WORK ORDER 12818

Account # _____ Order Date 4/26/2018
 Name TURLEY, DALE Status MEDIUM
 Address _____ Scheduled 04/26/18 10:49 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 49616583 62351421 4144 B14169652

Description _____
 Comment RT, BRK HSE, RT CNR
 Requested By Jonathan Hughes Assigned To MAINTENANCE CREW Completed By _____
 Start Date 4/13/18 Time _____ Completed Date 4/12/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes Check for service leak Water coming up in road, so check all around
 SERVICE LINE LEAK Sid# 1804270759 LTC WTRCC.

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>New Service Tubing</i>		
<i>80 ft</i>		

Signature A.C.

East Logan Water District
WORK ORDER 12825

Account #
Name WHITE, HARRIET
Address
Telephone

Order Date 4/30/2018
Status MEDIUM
Scheduled 04/30/18 08:08 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979850	72752293	613	B14169214	626

Description
Comment RT, BRK HSE, RT YD

Requested By Harriet Assigned To MAINTENANCE CREW Completed By
Start Date 4/30/18 Time : Completed Date 4/30/18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used

Busted S&L II bottom replaced bottom around 1 gpm

Signature *[Signature]*

East Logan Water District
WORK ORDER 12823

Account #
Name KNUCKLES, TRACY
Address
Telephone

Order Date 4/27/2018
Status MEDIUM
Scheduled 04/27/18 12:42 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 22201563 09245276 545 B14652678

Description
Comment RT, GRAY HS R/CNR

Requested By Tracy Assigned To MAINTENANCE CREW Completed By

Start Date 4/27/18 Time : Completed Date 4/27/18 Time

Make Size/Type Multiplier
Notes Water running between meter and road in ditch line. Please check

Inventory Item And Description	Quantity Ordered	Quantity Used
107 Ft Replaced $\frac{3}{4}$		
4 $\frac{3}{4}$ INSERTS		
1- $\frac{3}{4}$ COUPLING		
2- $\frac{3}{4}$ NUTS		

Long Side Service leak.
Area marked in white both sides of road
X-street - W. Brown Rd

1804271482

Logan tele

Repaired by
AC
Assist by TM

Signature *TM - AC - TM*

East Logan Water District
WORK ORDER 12831

Account # _____ Name OVERHOLT, ARLAND RAY Order Date 5/2/2018
Address _____ Status MEDIUM
Telephone _____ Job # _____ Scheduled 05/02/18 08:15 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 52473725 ERT/INTERNAL ID# 07132536 READING 713 LOCATOR TAG B14168526 READING IN / OUT _____

Description _____
Comment RT,WH/HSE L/DR

Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____

Start Date 5/2/18 Time _____ Completed Date 5/2/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Leak and contractors box

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 SETTER		
2- 3/4 INSERTS		
1- 3/4 RISER		
1- Standard meter box		
1- Standard Lid		
1- 80 gauge coupling		
7ft of 3/4 Tubing		
1- 3/4 - 12" Nipple		

LTC
WPECC - check

1805011020

replace box + repair a leak

Signature A. C

East Logan Water District
WORK ORDER 12859

Account # _____ Order Date 5/2/2018
 Name LEACH, DAVID Status MEDIUM
 Address _____ Scheduled 05/02/18 02:45 PM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 48979843	61287447	5264	B14167709	

Description _____
 Comment RT, WH/HSE, LF/DR
 Requested By Mr Leach Assigned to MAINTENANCE CREW Completed By _____
 Start Date 5/3/18 Time _____ Completed Date 5/3/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes check for leak

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 3/4 Brass Coupling		
2- 3/4 inserts		
1 4" - 3/4 clamp		
4- scoops gravel		

2- Gal Per minute

Y Longville Laver
LTC

1805 021 681

Signature A.C. T.M.

INBOX Compose Addresses Folders Options
Current folder: INBOX Calendar Help Search
Logged in as: eastlogan@logantele.com Sign Out

Image Delete 1/29/18 Forward Reply Reply All

Subject: KUPI 0565 2018/11/29 #00007 1811291392-00A EMER NEW
From: tickets@kentucky811.org
Date: Thu, November 29, 2018 3:43 pm
To: eastlogan@logantele.com
Priority: High

Options: View Full Header View Printable Version Download this as a file Add to Addressbook View

0565 00007 KUPIa 11/29/2018 16:43:56 1811291392-00A EMER NEW STRT
EMERGENCY SEE REMARKS

Ticket : 1811291392 Date: 11/29/2018 Time: 16:39 Oper: ACRENSHAW Chan:000

State: KY Cnty: LOGAN City: LEWISBURG
Subdivision:

Address :
Street :
Cross 1 :
Location: LOCATE THE FRONT OF THE PROPERTY - AREA IS MARKED WITH WHITE PAINT
Boundary: n 37.037818 s 37.028823 w -86.899464 e -86.887887

Work type : WATER LINE REPAIR
Done for : EAST LOGAN WATER DISTRICT INC
Start date: 11/29/2018 Time: 16:40 Hours notice: 0/0 Priority: EMER
Ug/Oh/Both: U Blasting: NO Emergency: Y
Duration : N/A Depth: 3 FEET

Company : EAST LOGAN WATER DISTRICT INC Type: MEMB
Co addr : 333 FRANKLIN ST
City : RUSSELLVILLE State: KY Zip: 42276
Caller : COURTNEY SAUNDERS Phone: (270)717-0991
Contact : GARY PRICE - CELL Phone:
Mobile : (270)938-3727
Fax : (270)717-0958
Email : EASTLOGAN@LOGANTELE.COM

Remarks : CREW ON SITE
:

Submitted date: 11/29/2018 Time: 16:39
Members: 0196 0565

Take Address
Delete & Prev | Delete & Next
Move to: INBOX Move

[INBOX](#) [Compose](#) [Addresses](#) [Folders](#) [Options](#)

Current Folder: INBOX

[Calendar](#) [Help](#) [Search](#)

Logged in as: eastlogan@logantele.com

[Sign Out](#)

[All Folders](#)

[Delete](#)

Subject: KUPI 0565 2018/11/29 #00001 1811290326-00A EMER NEW

From: tickets@kentucky811.org

Date: Thu, November 29, 2018 8:17 am

To: eastlogan@logantele.com

Priority: High

Options: [View Full Header](#) [View Printable Version](#) [Download this as a file](#) [Add to Addressbook](#) [View](#)

0565 00001 KUPIa 11/29/2018 09:17:01 1811290326-00A EMER NEW STRT

EMERGENCY SEE REMARKS

Ticket : 1811290326 Date: 11/29/2018 Time: 09:13 Oper: MEVENER Chan:000

State: KY Cnty: LOGAN City: AUBURN

Subdivision:

Address :

Street :

Cross 1 :

Location: LOCATE A 20 FOOT RADIUS OF THE WHITE LINED AREA ON THE NORTH SIDE OF THE INTERSECTION

Boundary: n 36.860230 s 36.859130 w -86.755824 e -86.754456

Work type : REPAIR WATER LINE

Done for : EAST LOGAN WATER DISTRICT INC

Start date: 11/29/2018 Time: 09:14 Hours notice: 0/0 Priority: EMER

Ug/Oh/Both: U Blasting: NO Emergency: Y

Duration : N/A Depth: 3 FEET

Company : EAST LOGAN WATER DISTRICT INC Type: MEMB

Co addr : 333 FRANKLIN ST

City : RUSSELLVILLE State: KY Zip: 42276

Caller : LINDA ALEXANDER Phone: (270)717-0991

Contact : GARY PRICE - CELL Phone:

Mobile : (270)938-3727

Fax : (270)717-0958

Email : LINDA@EASTLOGANWATER.COM

Remarks : CREW IN ROUTE

Submitted date: 11/29/2018 Time: 09:13

Members: 0196 0340 0423 0565

[Take Address](#)

[Delete & Prev](#) | [Delete & Next](#)

Move to:

[Move](#)

East Logan Water District WORK ORDER 12975

Account # 71
Name LOGAN COUNTY BOARD OF EDUCATION
Address
Telephone Job #

Order Date 6/7/2018
Status MEDIUM
Scheduled 06/07/18 10:29 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 000065445937	73631524	26946	B14250073	

Description

Comment LT SCHOOL IN METER PIT

Requested By Dorris Blick Assigned To MAINTENANCE CREW Completed By

Start Date 6/13/18 Time : Completed Date 6/18/18 Time :

Make _____ Size/Type _____ Multiplier _____

Notes check for leak, corner of yard there is a green pedestal There is always water running thru here and in ditch line

Inventory Item And Description	Quantity Ordered	Quantity Used

Area marked in white both sides of road
X- Shrum or J. Will Stewart

Signature 

East Logan Water District
WORK ORDER 12971

Account #
Name WELLS, DANIEL A
Address
Telephone

Order Date 6/6/2018
Status MEDIUM
Scheduled 06/06/18 11.28 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 81271712	74600784	26	B15395673	27

Description
Comment

Requested By Greg Gary Assigned To MAINTENANCE CREW Completed By
Start Date 6/6/18 Time Completed Date 6/6/18 Time

Make Size/Type Multiplier
Notes After they repaired their leak on their side they still see water around the meter

Inventory Item And Description	Quantity Ordered	Quantity Used

Did not see any water around meter

Signature 

East Logan Water District
WORK ORDER 13015

Account # _____ Order Date 6/19/2018
 Name BRAY TIM Status HIGH
 Address _____ Scheduled 06/19/18 08:55 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 33123408 09141087 6178 B14166010

Description _____
 Comment RT, GRAY/HSE M/YD

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
 Start Date 6/19/18 Time _____ Completed Date 6/19/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes there is a leak, chlorine in ditch across rd from main, may need new tubing

Inventory Item And Description	Quantity Ordered	Quantity Used
2- 75ft of 3/4 tubing		
2 3/4		
6- 3/4 nuts		
12- 3/4 inserts		
4 short pieces of 3/4 tubing 5ft long		

6-7 Gallons per minute

Signature A.L. T.M.

East Logan Water District
WORK ORDER 13019

Account # _____ Order Date 6/20/2018
Name JOHNSON JANET Status HIGH
Address _____ Scheduled 06/20/18 10:50 AM
Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 49616590 10288996 7984 B14167443

Description
Comment

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 6/20/18 Time _____ Completed Date 6/20/18 Time _____

Make _____ Size/Type _____ Multiplier _____
Notes SHORT SIDE SERVICE. MARKED IN WHITE ~~PLAINVIEW CHURCH~~ PLAINVIEW CHURCH

Inventory Item And Description	Quantity Ordered	Quantity Used
4ft 3/4 Tubing		
2- 3/4 nuts		
2- 3/4 inserts		

py 6-22-18 @ 11:00 Am

1 Gallon per minute

LTC

1806200880

Signature

A.C.

East Logan Water District
WORK ORDER 12967

Account #
Name LOWHORN, ASHLEY M
Address
Telephone

Order Date 6/5/2018
Status HIGH
Scheduled 06/06/18 09:26 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473815	59637883	4214	B14166345	

Description:

Comment RT BRK L/DR 2ND MTR

Requested By Customer Assigned To MAINTENANCE CREW Completed By MAINTENANCE CREW

Start Date 06/05/18 09:27 AM Completed Date 06/05/18 09:27 AM

Notes There is a leak, spoke with Bud, will repair on 6/6/18

*7.5" 3/4 tubing
2 - 3/4 inserts
1 - 3/4 cone nut
1 - 3/4 flat nut*

1/2 gallon per minute

Signature: A.C. 6-6-18

East Logan Water District
WORK ORDER 13010

Account #		Order Date	6/15/2018
Name	MAJORS -- TP FLOSSIE	Status	MEDIUM
Address		Scheduled	06/15/18 10:23 AM
Telephone		Order Type	CHECK FOR LEAK ON OUR SIDE
	Job #		
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG
WT 32789103	10378841	5183	B14167565
Description			READING IN / OUT
Comment	RT,WH/HSE LF/DR		
Requested By	Mrs. Majors	Assigned To	MAINTENANCE CREW
Completed By			
Start Date	6/15/18	Time	
Completed Date	6/15/18	Time	

Make _____ Size/Type _____ Multiplier _____
Notes Check for leak 1/2 between her drive and the lot next door

Inventory Item And Description	Quantity Ordered	Quantity Used
She is going to call me		
When she has water standing		
and we will go from there.		

Area marked in white

X- Warmer chick

Short side maybe main.

Handwritten note:
X marked to Tyler

Handwritten note in a large oval:
Tuesday 6-14-18
LTC
1806151200

Signature TM A.L.

East Logan Water District
WORK ORDER 12979

Account #
Name BAKIE, JAMES & ISACA R
Address
Telephone Job #

Order Date 6/8/2018
Status MEDIUM
Scheduled 06/25/18 03:40 PM
Order Type READ OUT ONLY

METER#	ERY/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684142	59596230	3259	B14168082	3300

Description
Comment RT, GRAY HSE, MYD, T/A

Requested By Isaca Assigned to MAINTENANCE CREW Completed By DB
Start Date / / Time : Completed Date 06/25/18 Time 10:34

Make _____ Size/Type _____ Multiplier _____

Notes House is changing owners, current owner wants water shut off on the 25th. Check with me to make sure that new owner has not come in to make deposit and have transferred into their name and we will just do a read out!

FIXED LEAK ON TRV IN BOX 0.25 GAL/MIN

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 13021

Account # 1
Name THOMAS, GREGORY
Address
Telephone Job #

Order Date 6/21/2018
Status MEDIUM
Scheduled 06/21/18 12.48 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473795	07305792	6997	B14169686	

Description
Comment RT GRAY HS LYARD

Requested By Daniel Assigned To MAINTENANCE CREW Completed By AC & DIS & TM

Start Date 6/21/18 Time 12:48 PM Completed Date 6/21/18 Time 5:50 PM

Make _____ Size/Type _____ Multiplier _____

Notes Daniel found a leak here Long side needs replacing

20 GPM REPLACED SERVICE LINE

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature 

East Logan Water District
WORK ORDER 12475

Account #
Name KUHNS, ELMER B
Address
Telephone

Order Date 1/19/2018
Status MEDIUM
Scheduled 01/19/18 03:13 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 51170351 ERT/INTERNAL ID# 72667221 READING 1917 LOCATOR TAG B15090691 READING IN / OUT

Description
Comment RT, BRK HSE LYD @ FENCE

Requested By tyler Assigned To MAINTENANCE CREW Completed By

Start Date ~~6-14-18~~ 6-14-18 Time : Completed Date ~~6-14-18~~ 6-14-18 Time

Make Size/Type Multiplier

Notes Service tube leak to be repaired Monday 1-22-18

~~BUE~~
XThornton LTC, WRECC

Inventory Item And Description	Quantity Ordered	Quantity Used
100 FT 3/4 Tubeing		
2- 3/4 inserts		
2- 3/4 nuts		
Pulled New tubing		

Andy patched over weekend
Going to pull New Tubing

X Thornton

LTC
WRECC

1806081419

180 409 1301

Signature _____

East Logan Water District
WORK ORDER 12793

Account # _____
Name CLARK, JOHN
Address _____
Telephone _____ Job # _____
Order Date 4/12/2018
Status MEDIUM
Scheduled 04/12/18 03:40 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 43605839 ERT/INTERNAL ID# 09206136 READING 3974 LOCATOR TAG B14169493 READING IN / OUT _____

Description _____

Comment LF WH/HS LDR

Requested By DB Assigned To MAINTENANCE CREW Completed By _____

Start Date 4/12/18 Time _____ Completed Date 4/13/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes Daniel found a service line leak to be repaired

3.5" 1804121685 LTC WRECC

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced Service Tubing		
from Metal to Meia		

5 to 6 gallons per minute

Signature A. C.

East Logan Water District
WORK ORDER 12939

Account # _____ Order Date 5/29/2018
 Name THOMAS, DAVID L Status MEDIUM
 Address _____ Job # 9636 Scheduled 05/29/18 09:35 AM
 Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 50472313 10644886 6758 B14169841

Description _____
 Comment LF, WH TRLR, LF GR DR
 Requested By kenny Assigned To MAINTENANCE CREW Completed By _____
 Start Date 6/1/18 Time _____ Completed Date 6/1/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes says hes repaired his leak an while back filling got our service tube but has is repaired an water is still coming out from another spot if need to call kenny a.

Emp # 1805291348

By DUNCAN CA. LTC WRECC

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 8" - 20" CLAMP		
1- 8" SADDLE and COP.		
12ft 3/4 P.P.C		
2- 3/4 INSERTS		

METER IS REVERSE TAPPED
 REPLACE SERVICE LINE - SHORT SIDE

Signature A.C. T.M.

East Logan Water District
WORK ORDER 12919

Account # _____ Order Date 5/21/2018
Name MCKINNEY, KRISTIAN L Status MEDIUM
Address _____ Job # 9 Scheduled 05/21/18 04:39 PM
Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 51780786	09170943	8488	B14167675	

Description _____
Comment LF, BRK/HSE RT/CNR
Requested By Daniel Assigned To MAINTENANCE CREW Completed By _____
Start Date 5/18/18 Time _____ Completed Date 5/18/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes
BUD # 1805211357 LTC

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Platched for NOID</i>		
<i>85ft 3/4 Tubing</i>		
<i>1- Standard Meter box and Lid</i>		
<i>1- 3/4" x 1" Coupling 4- 3/4 inserts</i>		
<i>1- 3/4 Setter</i>		
<i>1- 3/4-12" Nipple</i>		

Daniel found leak

around 7-gallons per minute

Signature



East Logan Water District
WORK ORDER 12932

Account #
Name BAER, LEONARD L
Address
Telephone Job #

Order Date 5/25/2018
Status MEDIUM
Scheduled 05/25/18 04 14 PM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 36583308	09968839	3901	B14166807	

Description
Comment LF, WH/HSE/1ST DR

Requested By Leonard Assigned To MAINTENANCE CREW Completed By *DB*
Start Date *5/1/18* Time : : Completed Date *5/25/18* Time *4:30*

Make _____ Size/Type _____ Multiplier _____
Notes wet around meter area

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>1- 3/4 Coupling BRASS</i>		
<i>2- 3/4 INSERTS</i>		

Small leak
long side service line replace
1-gallon Pet mineral

DB *A.C.*

East Logan Water District
WORK ORDER 12904

Account # C
Name NOFFSINGER, TERRELL
Address
Telephone Job #

Order Date 5/15/2018
Status MEDIUM
Scheduled 05/15/18 07:55 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 30318337	70153732	3435	B14169634	

Description
Comment LF, TAN HSE, RT YD AT FENCE T/

Requested By Mr. Noffsinger Assigned To MAINTENANCE CREW Completed By

Start Date 5/16/18 Time ___:___ Completed Date 5/16/18 Time ___:___

Make _____ Size/Type _____ Multiplier _____

Notes Corner of Echo Valley & Dennis Cornth. Possible main leak at hydrant or close to it. Please check

SL LEAK BUD# 1805150184 ATT LHC LTRIC TERRELL

Inventory Item And Description	Quantity Ordered	Quantity Used
1- $\frac{3}{4}$ Couplings		
1- $\frac{3}{4}$ Clamp		
2- Inserts		

6 gallons per Minute

Signature A.C.

East Logan Water District
WORK ORDER 13011

Account # _____ Order Date 6/18/2018
 Name HAM MICHELLE R Status HIGH
 Address _____ Scheduled 06/18/18 08 05 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 43605860	09205209	3288	B14166474	

Description _____
 Comment LF
 Requested By Mr Ham Assigned To MAINTENANCE CREW Completed By _____
 Start Date 6/18/18 Time _____ Completed Date 6/18/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes cust came in and stated that meter and surrounding meter is covered in water

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Leak on the side</i>		

Signature *A.C.*
 User1

East Logan Water District
WORK ORDER 13008

Account # _____ Order Date 6/14/2018
 Name MOORE, JAMES R Status MEDIUM
 Address _____ Scheduled 06/14/18 11:55 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 52473829	61287448	3229	B14166579	3252

Description
 Comment LF R/CNR LOT AT FEN TA

Requested By Therice Moore Assigned To MAINTENANCE CREW Completed By _____
 Start Date 6/14/18 Time _____ Completed Date 6/14/18 Time _____

Plate _____ Size/Type _____ Multiplier _____

Notes Older woman her usage has increased over the last 6 months See if meter is turning and talk with the customer

Inventory Item And Description	Quantity Ordered	Quantity Used

meter was turning really slowly spoke to her & gave her ideas about trying to find it.

Signature 

East Logan Water District
WORK ORDER 13216

Account #
Name PRUNTY, BROOKS W
Address
Telephone Job #

Order Date 8/10/2018
Status MEDIUM
Scheduled 08/10/18 10:00 AM
Order Type CHECK METER

METER# WT 69361527 ERT/INTERNAL ID# 63066139 READING 4390 LOCATOR TAG B14167405 READING IN / OUT 4409

Description
Comment LF, TAN TRLR, LF DR 2ND

Requested By Victoria Assigned To MAINTENANCE CREW Completed By *MJD*
Start Date ___/___/___ Time ___:___ Completed Date 8/13/18 Time 1:00

Make _____ Size/Type _____ Multiplier _____

Notes logan tele ran over meter, please check replace and fix
Meter Box that is damaged has no meter Replaced lid

Inventory Item And Description	Quantity Ordered	Quantity Used

Signature *[Handwritten Signature]*

East Logan Water District
WORK ORDER 13165

Account #		Order Date	8/3/2018
Name	MCCOY, CHARITY L	Status	MEDIUM
Address		Scheduled	08/03/18 08:16 AM
Telephone	Job #	Order Type	CHECK FOR LEAK ON OUR SIDE
METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG
WT 52473821	07132107	4718	B14652849
READING IN / OUT			

Description
Comment LT,WH/HSE,ON CNR,RT DR
Requested By Mrs. McCoy Assigned To MAINTENANCE CREW Completed By
Start Date 7-2-18 Time : Completed Date 7-2-18 Time :

Make _____ Size/Type _____ Multiplier _____
Notes Contractors box is leaking on our side

Inventory Item And Description	Quantity Ordered	Quantity Used
1- Standard box 1- Tandem jetter		
1- 3/4-12" nipple 3/4-12 ft tubing		

1808030183
LTC
WRELL

Signature AL MH

East Logan Water District
WORK ORDER 13197

Account #
Name BRAY, OTIS
Address
Telephone

Order Date 8/6/2018
Status MEDIUM
Scheduled 08/04/18 08:06 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# WT 21337408 ERT/INTERNAL ID# 63814709 READING 2669 LOCATOR TAG B13480791 READING IN / OUT

Description
Comment LT 1/2 BRICK RT 2ND DR

Requested By Mrs Bray Assigned to MAINTENANCE CREW Completed By
Start Date 8/4/18 Time : Completed Date 8/4/18 Time :

Make Size/Type Multiplier
Notes Got a call on Saturday 8/4/18, water bubbling up by fence, running down road. Please check for leak

Inventory Item And Description	Quantity Ordered	Quantity Used
1- 1" Coupling		
2- 1" inserts		

S. Ballou
Per-minute

Signature A.C. M.H.

East Logan Water District
WORK ORDER 13229

Account # _____ Order Date 8/15/2018
 Name VOWELL, DALE Status MEDIUM
 Address _____ Scheduled 08/15/18 08:03 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER#	ERT/INTERNAL ID#	READING	LOCATOR TAG	READING IN / OUT
WT 66684142	59596230	3322	B14168082	

Description _____
 Comment RT, GRAY HSE, MYD, T/A
 Requested By dale vowell Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/15/18 Time _____ Completed Date 8/15/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes _____

Inventory Item And Description	Quantity Ordered	Quantity Used
Replaced Rubber Washer		

$\frac{1}{2}$ Gallon
minute

Signature AC

East Logan Water District
WORK ORDER 13199

Account #
Name DURHAM, SARAH J
Address
Telephone Job #

Order Date 8/6/2018
Status MEDIUM
Scheduled 08/06/18 09:53 AM
Order Type MISCELLANEOUS

METER# WT 000065798051 ERT/INTERNAL ID# 58646969 READING 6955 LOCATOR TAG B14167002 READING IN / OUT

Description
Comment RT,BEIGE 2 STORY, LF CNR

Requested By _____ Assigned To MAINTENANCE CREW Completed By _____
Start Date 8/5/18 Time _____ Completed Date 8/5/18 Time _____

Make _____ Size/Type _____ Multiplier _____

Notes pul the meter back into the box, make sure that it is locked and turned off plz
cut off valve was replaced so shouldn't leak any more

Inventory Item And Description	Quantity Ordered	Quantity Used
60' 1" Service Tubing		
2- 1/4" Couplings		
2- 1" inserts		
2- 3/4" inserts		

Signature A.C. M.H.

East Logan Water District
WORK ORDER 13223

Account #
Name POWELL, STAN
Address
Telephone Job #

Order Date 8/13/2018
Status MEDIUM
Scheduled 08/13/18 10:24 AM
Order Type CHECK FOR LEAK ON OUR SIDE

METER# ERT/INTERNAL ID# READING LOCATOR TAG READING IN / OUT
WT 45221361 61287529 7667 B14169188

Description
Comment RT, ACROSS RD BEHIND POLE

Requested By STAN POWELL Assigned To MAINTENANCE CREW Completed By *MH* *8/13/18*
Start Date *8/13/18* Time *12:30* Completed Date *8/13/18* Time *12:30*

Make _____ Size/Type _____ Multiplier _____

Notes CHECK METER, PENNYRILE RURAL MAY HAVE RAN OVER LINE OR METER, METER IS FULL OF WATER
-STAN POWELL, CALL AND LET HIM KNOW WHAT WE FIND OUT PLEASE

811 Bld CONF # 1808131185 Logan Tele and WRECC notified to locate

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>3/4 Coupling</i>		<i>1</i>
<i>3/4 piece of P. Pe about 2 foot long blue</i>		<i>1</i>
<i>3/4 Cone Nut</i>		<i>1</i>

Signature *Mike H. Powell*

East Logan Water District
WORK ORDER 13366

Account # _____ Order Date 9/24/2018
 Name DuFRESNE, DALE D Status MEDIUM
 Address _____ Job # 61 Scheduled 09/24/18 09:44 AM
 Telephone _____ Order Type CHECK FOR LEAK ON OUR SIDE
 METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 78641133 73488029 909 B14168920
 Description _____
 Comment LF,WH TRLR,LF@INTER 2 MTRS
 Requested By _____ Assigned To MAINTENANCE CREW Completed By DB GP
 Start Date 1 / 1 Time _____ Completed Date 9/21/18 Time 4:15

Make _____ Size/Type _____ Multiplier _____
 Notes REPAIRS SERVICE LINE
2 A.M.

Inventory Item And Description	Quantity Ordered	Quantity Used
<u>3/4" COMPRESSION CLAMPING</u>		<u>1</u>
<u>3/4" FULL CIRCLE CLAMP</u>		<u>1</u>

Signature 

East Logan Water District
WORK ORDER 13233

Account # _____ Order Date 8/16/2018
 Name DURHAM, SARAH J Status MEDIUM
 Address _____ Scheduled 08/16/18 10 00 AM
 Telephone _____ Job # _____ Order Type CHECK FOR LEAK ON OUR SIDE

METER# _____ ERT/INTERNAL ID# _____ READING _____ LOCATOR TAG _____ READING IN / OUT _____
 WT 84900760 90118850 B14167002

Description _____
 Comment RT,BEIGE 2 STORY, LF CNR
 Requested By DANIEL Assigned To MAINTENANCE CREW Completed By _____
 Start Date 8/17/18 Time _____ Completed Date 8/17/18 Time _____

Make _____ Size/Type _____ Multiplier _____
 Notes SERVICE LINE LEAK,
 BUD#1808130958
 X-MELODY RIDGE
 ATT & ATMOS

Inventory Item And Description	Quantity Ordered	Quantity Used
<i>Pulled new service tubing</i>		
<i>50ft 1" tubing</i>		
<i>2- 1" 3/4 couplings</i>		
<i>2- 1" inserts 4- 3/4 inserts</i>		

Signature A.C. M.H.