

Delaplain Discharge Quality

Sample Date	CBOD 10/15 mg/L	TSS 30/45 mg/L	pH 6-9	E Coli 130/240	NH3 May- Oct 2/3 mg/L	DO >7	TPhos Rpt	TNit Rpt	TRC .011/.019
2/24/2021	14	78	7.04	727	0.11	9.52			<.01
3/5/2021	<4	<6	6.92	10	0.2	7.3	12.5	1.52	<.01
3/11/2021	7	<6	6.53	2	0.3	8.1			<.01
3/19/2021	<4	<6	6.85	12	0.3	7.75			<.01
3/27/2021	6	<6	6.7	1	<.2	7.5			<.01
4/1/2021	<4	<6	6.7	13	<.2	7.45			<.01
4/9/2021	8	10	7.13	28	<.2	8.25	19.1	2.96	<.01
4/16/2021	<4	<6	6.9	7	<.2	7.05			<.01
4/23/2021	6	<6	6.65	58	<.2	6.65			<.01
5/7/2021	9	142	6.9	2420	<.2	7.8	10.9	1.95	<.01
5/14/2021	6	13	6.66	12	0.2	7.5			<.01
5/21/2021	6	17	6.67	49.4	<.2	7.8			<.01
5/27/2021	<4	16	6.63	88	1.1	7.05			<.01
6/4/2021	69	471	6.3	3	0.9	7.5	8.35	36.3	<.01
6/11/2021	14	8	6.52	*92	0.4	7.15			<.01
6/16/2021	7	<6	6.7	13	0.6	7.25			
6/22/2021	<4	<6	7.38	29	0.4	7.46			<.01
7/7/2021	<4	<6	6.7	42	1.3	7.75	1.81	13.4	<.01
7/13/2021	<4	<6	6.75	32	0.4	7.55			<.01
7/20/2021	<4	<6	6.6	32	0.4	6.6			<.01
7/27/2021	<4	<6	6.4	9	0.5	7.5			<.01
8/3/2021	<4	<6	6.7	6	0.6	7.55	1.86	6.7	<.01
8/10/2021	18	<6	7.06	2	0.4	7.06			<.01
8/19/2021	<4	<6	7.1	154	0.5	7.4			<.01
8/24/2021	7	<6	6.95	16	0.4	7.9			<.01
9/3/2021	<4	<6	7.16	96	1	7	0.92	6.4	<.01
9/8/2021	<4	<6	7.25	9	<.2	7.65			<.01
9/13/2021	4	<6	7	2	0.6	8			<.01
9/21/2021	<4	<6	6.95	23	0.4	9.25			<.01
10/7/2021	3	6	7.74	980	0.78	8.2	1.1	6.05	0
10/14/2021	3	1	7.61	1	0.6	8.7	1.25	5.16	0
10/21/2021	2	0	7.08	27	1.03	8.1	1.1	5.98	0
10/27/2021	2	1	7.2	84	0.5	8.1	0.8	6.45	0
11/5/2021	0	0	7.28	167	0.3	8.3	0.9	7.34	0
11/11/2021	0	2	7.2	6	0.32	8.1	1	10.3	0
11/18/2021	2	0	7.63	26	0.47	9.2	1.7	9	0
11/22/2021	2	27	7.64	1300	0.4	9.3	0.35	8.22	0
12/1/2021	2	0	6.93	0	0.81	9.3	1.2	6.62	0
12/8/2021	2	4	6.94	2	0.27	10	1.66	3.8	0
12/15/2021	2	4	6.86	0	0.47	9.3	0.9	4.46	0
12/22/2021	2	4	6.89	0	1.46	9.2	1.15	3.97	0
1/5/2022	2	6	6.88	0	0.3	9.9	0.63	4.68	0
1/12/2022	2	4	6.74	0	0.3	9.2	0	4.54	0
1/19/2022	2	3	6.84	0	1.04	9	0.79	5.02	0
1/26/2022	3	4	6.83	0	0.17	10.2	1.4	7.74	0
2/2/2022	2	2	6.72	0	0.93	9.4	3.3	8.66	0
2/9/2022	2	3	6.71	14	0.64	9.8	0.27	7.01	0
2/16/2022	2	2	6.62	0	1.08	9.8	1.2	7.35	0
2/23/2022	2	8	6.72	0	0.24	10	0.6	4.41	0
3/2/2022	2	2	6.9	0	0.56	9.6	1.18	5.4	0

Herrington Haven Discharge Quality

Sample Date	BOD 30/45 mg/L	TSS 30/45 mg/L	pH 6-9	E Coli 130/240	NH3 20/30 mg/L	DO >2	T Phos Rpt	T Nit Rpt	TRC .011/.019
3/31/2021	<4	<6	8.77	<1	<.2	5.65	22.8	7.83	
6/2/2021	<4	<6	7.62	6	<.2	9.6	6.19	9.8	<.01
8/20/2021	7	7	7.45	1	<.02	7.6	9.27	21.4	
10/29/2021	2	6	7.24	0	0	6.2	1.5	33.2	0
1/28/2022	4	26	6.73	0	0	9.2	7.7	45	0

Woodland Acres Discharge Quality

Sample Date	CBOD 10/15 mg/L	TSS 30/45 mg/L	pH 6-9	E Coli 130/240	NH3 M-O 2/3 mg/L	DO >7	TRC .011/.019
3/10/2021	5	8	7.08	49/2420	<.2	8.2	0.01
6/29/2021	<4	15	7.35	<1	11.1	9.5	0.01
9/14/2021	<4	91	6.95	<1	0.3	7.42	<.01
12/14/2021	16	21.8	6.79	0	16.5	12.1	0
3/15/2022	22	72	7.23	2420	18.6	8.8	1.91