

AssetDescription	WorkflowTitle	WorkOrderDescription	WorkOrderPriority	WorkOrderStatus	DateCreated
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	██████████ at ██████████ (Delaplain) called in to let us know that the sewage manhole cover near her property had been unbolted and uncovered and then left that way. She covered it back up and placed the bolt back into position but thought we may need to have someone go out there and take care of it. She was also wondering what we(if it was us) were doing there that caused it to be left off; looked at station with the customer and tightened cap to customers satisfaction	Critical	Closed	11/19/2021 1:21:08 PM
Wastewater Treatment Plant - Delaplain - WWTP	Corrective Work Order	Broken line connecting to sewer main ██████████	Critical	Complete	11/27/2021 6:24:32 AM
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	██████████ at ██████████ Georgetown, LA 40324 (Delaplain) has a sewer pipe that is busted up above the ground. She would like something to be done about it before she has sewer problems. Pic attached; was not a sewer pipe but access to a valve and customer satisfied with explanation	Critical	Closed	12/23/2021 11:08:31 AM
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	██████████ at ██████████ Georgetown, KY 40324 (Delaplain) called saying that there is a break in the sewer line, he stated that the plumber came and said that there is a block where the mainline and the customer's line connect; repaired	Emergency	Closed	1/18/2022 1:09:21 PM
Wastewater Treatment Plant - Delaplain - WWTP	Corrective Work Order	Clean main sewer line and cut customer later protruding into line	Minor	Complete	1/23/2022 6:55:09 PM
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	██████████ at ██████████ Georgetown, KY 40324 (Delaplain) says we dug his yard around the manhole to find a problem with the sewer that his neighbor was having. He says he has an 8" deep hole around his sewer cap and is requesting we come out to make it flush with the ground; arranged with contractor to install riser ring under casting to bring lid to final grade	Major	Closed	2/1/2022 11:38:07 AM
Wastewater Treatment Plant - Delaplain - WWTP	Corrective Work Order	Landowner found leaking ARV on property	Minor	Complete	3/9/2022 6:50:51 AM
Clarifier 1 - Delaplain - WWTP	Corrective Work Order	Clarifier drive chain stretched and slipped off motor gear.	Minor	Complete	3/13/2022 6:24:34 PM
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	██████████ ██████████ at ██████████ Georgetown, KY 40324 (Delaplain) called to report a backup in his sewer line. He has roto rooter out at his home and they pulled the manhole cover stated & it looks like the issue is on our side. He is wanting ops to come out while roto rooter is there as well to confirm. He also wants to be contacted by ops; main line and manhole clear and free flowing	Emergency	Closed	4/11/2022 2:01:41 PM
Wastewater Customer Service Call - Delaplain - WWTP	CS - Corrective Work Order	DOW call to investigate possible spill and cleanup around pump station; Cleaned and remediated	Major	Complete	4/12/2022 8:23:34 AM
Wastewater Treatment Plant - Delaplain - WWTP	Corrective Work Order	Camera line at ██████████ as follow up to customer call 4/15/2022	Minor	Complete	4/18/2022 9:16:41 AM
Wastewater Treatment Plant - Delaplain - WWTP	Corrective Work Order	Vac and clean Cl2 contact basin	Minor	Complete	4/26/2022 2:06:47 PM

AssetDescription	WorkflowTitle	WorkOrderDescription	WorkOrderPriority	WorkOrderStatus	DateCreated
Clarifier 1 - Herrington Haven - WWTP	Corrective Work Order	Return line clogged.	Major	Complete	11/11/2021 10:05:10 AM
Wastewater Treatment Plant - Herrington Haven - WWTP	Corrective Work Order	Fixing return line. Trying to restore function and flow to return line.	Minor	Open	1/3/2022 7:33:33 AM
Wastewater Treatment Plant - Herrington Haven - WWTP	Corrective Work Order	Cleaned up river trash/debris from work site after river water subsided.	Minor	Closed	1/14/2022 2:26:14 PM
Wastewater Treatment Plant - Herrington Haven - WWTP	Corrective Work Order	1/6/22 Delivered and spread salt on driveway, tank, and contact chamber in prep for upcoming storm.	Minor	Complete	2/17/2022 11:54:08 PM
Blower Unit 1 - Herrington Haven - WWTP	Corrective Work Order	Blower found to be inoperable on 3/6/22 TNT will be our fix on 3/7/22.	Minor	Closed	3/7/2022 8:25:22 AM
Parcel - KY-HH-P-3	CS - Corrective Work Order	██████████ at ██████████, Lancaster, KY 40444 (Herrington Haven) reported the sewer system on Herrington Haven sounds like it's going to explode. He stated the noise has been happening all weekend and it sounds like the bearings are out. Contact #: ██████████ Also reporting: ██████████ at ██████████ Lancaster, KY 40444 ██████████; Blower was seized and bolts had broken off. Resolved	Critical	Closed	3/14/2022 7:43:40 AM
Parcel - KY-HH-P-6	CS - Corrective Work Order	██████████ at ██████████ Lancaster, KY 40444 (Herrington Haven) called to state that the neighborhood septic system beside his home is making a loud noise sounding like something was about to go out. ██████████ Blower was seized and bolts had broken off. Resolved	Critical	Canceled	3/14/2022 4:57:48 PM
De-Chlor 1 - Herrington Haven - WWTP	Corrective Work Order	Due to flooding dechlor chamber is under six river. Created new temporary dechlor system using perforated pvc and tablets.	Minor	Closed	3/21/2022 6:57:25 AM
Wastewater Treatment Plant - Herrington Haven - WWTP	Corrective Work Order	Fence planks broken by sanitation truck hose. Installed new planks. Zw	Minor	Closed	3/21/2022 6:59:16 AM
Wastewater Treatment Plant - Herrington Haven - WWTP	Corrective Work Order	Cleaned driftwood left in yard. Put in burn pile per.	Minor	Open	3/23/2022 2:25:27 PM
WW Lab Results - Herrington Haven - WWTP	Kentucky WW Lab Data	Lab Data entry forms in the compliance module.	Minor	Open	5/24/2022 9:02:35 AM

AssetDescription	WorkFlowTitle	WorkOrderDescription	WorkOrderPriority	WorkOrderStatus	DateCreated
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Found and repaired (installed new caps) two pipes in two separate places in field.	Minor	Complete	11/12/2021 6:48:31 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Located. 2 broken pipes/caps in field. Bought replacement pipes/caps and installed new Pipes and caps.	Minor	Complete	11/15/2021 7:42:30 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Pumps not functioning.	Minor	Complete	11/15/2021 2:20:53 PM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Irrigation line in area 4B leaking ,dig up repair line	Minor	Closed	12/11/2021 6:49:23 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Valve busted in field 1A , replace valve	Minor	Closed	12/11/2021 6:55:11 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	1/6/22 Delivered and spread salt on driveway, tank, in prep for upcoming storm.	Minor	Complete	2/18/2022 12:00:42 AM
Parcel - KY-SC-P-5	CS - Corrective Work Order	reported that main sewer line was hit at [REDACTED] Nicholasville, KY 40356 (Springcrest) and [REDACTED] Nicholasville, KY 40356 (Springcrest). [REDACTED] y from Metro Net was running optic cable under ground and punctured the main sewer line. His number is [REDACTED]	Emergency	Closed	3/24/2022 2:01:50 PM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Emergency corrective work order continuing from WO#273037557 plumber was incorrect, leak persisted after pumps to leachate field had been shut down. Tried to find on my own then Contacted Buchanan's.	Minor	Closed	3/30/2022 10:02:28 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Locate leak.	Critical	Complete	4/4/2022 1:01:45 PM
Parcel - KY-SC-P-34	CS - Corrective Work Order	Csts at [REDACTED] Nicholasville, KY 40356 (Springcrest) and [REDACTED] Nicholasville, KY 40356 (Springcrest) are reporting sewer in their yards. Phone # for [REDACTED] 2; investigated and found no trace of sewage in the yard	Emergency	Closed	4/5/2022 11:29:28 AM
Parcel - KY-SC-P-5	CS - Corrective Work Order	[REDACTED], Nicholasville, KY 40356 & [REDACTED], Nicholasville, KY 40356. Leach fields are overflowing and running into the backyards of these two residences; lateral lines hit and customers notified	Critical	Complete	4/8/2022 9:08:43 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Dug out around pipe and installed new cap for clean out.	Minor	Closed	4/25/2022 7:20:48 AM
Wastewater Treatment Plant - Springcrest - WWTP	Corrective Work Order	Received emergency locate for [REDACTED] il.	Minor	Closed	4/26/2022 6:28:16 PM

AssetDescription	WorkFlowTitle	WorkOrderDescription	WorkOrderPriority	WorkOrderStatus	DateCreated
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Return line clogged.	Major	Complete	11/11/2021 10:07:46 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Repair skimmer line	Minor	Complete	1/18/2022 12:21:39 PM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog ras line	Minor	Complete	1/18/2022 12:25:49 PM
Aeration Basin 1 - Woodland Acres - WWTP	Corrective Work Order	Power outage set up generator for pumps	Minor	Complete	2/6/2022 7:20:54 PM
Wastewater Treatment Plant - Woodland Acres - WWTP	Corrective Work Order	RAS line clogged. worked to unclog it	Minor	Complete	2/18/2022 12:16:18 AM
Aeration Basin 1 - Woodland Acres - WWTP	Corrective Work Order	Reseed plant	Minor	Complete	3/8/2022 11:28:45 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog ras line	Minor	Complete	3/16/2022 11:21:40 AM
Aeration Basin 1 - Woodland Acres - WWTP	Corrective Work Order	Seed plant	Minor	Complete	4/1/2022 9:15:32 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog ras line	Minor	Complete	4/13/2022 7:19:42 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog waste line	Minor	Complete	4/13/2022 7:21:04 AM
Aeration Basin 1 - Woodland Acres - WWTP	Corrective Work Order	Reseed plant	Minor	Complete	4/13/2022 9:08:04 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog ras line	Minor	Complete	4/26/2022 11:03:04 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Unclog ras line	Minor	Complete	4/28/2022 9:51:42 AM
Wastewater Treatment Plant - Woodland Acres - WWTP	Corrective Work Order	Replace water pipe	Minor	Complete	5/2/2022 9:43:43 AM
Clarifier 1 - Woodland Acres - WWTP	Corrective Work Order	Pump down contact chamber overflow	Minor	Complete	5/16/2022 9:51:29 AM