

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION OF	)	CASE NO.
INTERCONNECTION AND NET METERING	)	2020-00302
GUIDELINES	)	

RESPONSE OF:
JACKSON ENERGY COOPERATIVE CORPORATION TO COMMISSION STAFF'S
SECOND REQUEST FOR INFORMATION
DATED SEPTEMBER 1, 2026

Jessica Hays (97522)
Notary Public

EAST KENTUCKY POWER COOPERATIVE, INC.
CASE NO. 2020-00302
SECOND REQUEST FOR INFORMATION RESPONSE

STAFF'S SECOND INFORMATION REQUEST DATED SEPTEMBER 1, 2026

REQUEST 1

RESPONSIBLE PARTY: Ryan Henderson

Request 1. Refer to Commission Staff's First Request for Information, Item 1c.

- a. Explain how the utility calculated the percentage of cumulative capacity of the utility's single hour peak load during calendar year 2025.
- b. Provide a breakdown of the calculation and any supporting calculations or documents in Excel spreadsheet format with all formulas, rows, and columns unprotected and fully accessible.

Response 1.

- a. Jackson Energy's current percentage of cumulative capacity of the single hour peak load for 2025 is 0.6345%. Our previous Response 1c from Staff's First Request for Information incorrectly stated 0.6352%. This was due to a keying error. This was calculated by taking Jackson Energy's net metering capacity (2,084kW as reported on the 2025 EIA Survey) and dividing by one percent (1%) of the single-hour peak for 2025 which was 3,284.53kW. The single-hour peak load includes Jackson Energy's entire load.
- b. Not applicable.