

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION OF	)	CASE NO.
INTERCONNECTION AND NET METERING	)	2020-00302
GUIDELINES	)	

RESPONSE OF:
FLEMING-MASON ENERGY COOPERATIVE, INC.
TO COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION
DATED SEPTEMBER 1, 2026

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION OF	)	CASE NO.
INTERCONNECTION AND NET METERING	)	2020-00302
GUIDELINES	)	

VERIFICATION OF BRANDON HUNT

Brandon Hunt, President & Chief Executive Officer of Fleming-Mason Energy Cooperative, Inc., being duly sworn, states that he has supervised the preparation of the responses of Fleming-Mason Energy Cooperative, Inc. to the Commission Staff's Request for Information in the above-referenced case, and that the matters and things set forth therein are true and accurate to the best of his knowledge, information, and belief, formed after reasonable inquiry.

Witness my hand this 10th day of September 2026



Brandon Hunt

Subscribed and sworn before me the 10th day of September 2026



Notary Public

My commission expires: 12/22/26



Jennifer L. McRoberts
Commonwealth of Kentucky
Notary Public
Commission No. KYNP61556
My Commission Expires 12/22/2026

QUESTION 1:

Refer to Commission Staff's First Request for Information, Item 1c.

- a. Explain how the utility calculated the percentage of cumulative capacity of the utility's single hour peak load during calendar year 2025.
- b. Provide a breakdown of the calculation and any supporting calculation or documents in Excel spreadsheet format with all formulas, rows, and columns unprotected and fully accessible.

RESPONSE:

- a. Fleming-Mason Energy's current percentage of cumulative capacity of its single hour peak load for 2025 was 35.1% This was calculated by taking Fleming-Mason's net metering capacity (708 kW as reported on the 2025 DOE filing) and dividing by one percent (1%) of the single-hour peak load, which was 2,015.99 kW. The single-hour peak load includes Fleming-Mason's entire load.
- b. Not applicable.