

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION OF	)	CASE NO.
INTERCONNECTION AND NET METERING	)	2020-00302
GUIDELINES	)	

RESPONSE OF:

TAYLOR COUNTY RURAL ELECTRIC COOPERATIVE CORPORATION

TO COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION

DATED SEPTEMBER 1, 2026

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION


In the Matter of:

ELECTRONIC INVESTIGATION OF	)	CASE NO.
INTERCONNECTION AND NET METERING	)	2020-00302
GUIDELINES	)	

VERIFICATION OF LANDON RUSSELL


COMMONWEALTH OF KENTUCKY)
)
COUNTY OF TAYLOR)

Landon Russell, Manager of Engineering of Taylor County Rural Electric Cooperative Corporation, being duly sworn, states that he has supervised the preparation of the responses of Taylor County Rural Electric Cooperative Corporation to the Commission Staff's Request for Information in the above-referenced case, and that the matters and things set forth therein are true and accurate to the best of his knowledge, information, and belief, formed after reasonable inquiry.



Landon Russell

The foregoing Verification was signed, acknowledged and sworn to before me this 10th day of September, 2026, by Patsy Walters.



KYNP71941
Commission expiration: 5/20/27



TAYLOR COUNTY RURAL ELECTRIC COOPERATIVE CORPORATION.

CASE NO. 2020-00302

SECOND REQUEST FOR INFORMATION RESPONSE

Request 1. Refer to Commission Staff's First Request for Information, Item 1c.

- a. Explain how the utility calculated the percentage of cumulative capacity of the utility's single hour peak load during calendar year 2025.
- b. Provide a breakdown of the calculation and any supporting calculations or documents in Excel spreadsheet format with all formulas, rows, and columns unprotected and fully accessible.

Response 1.

- a. Taylor County RECC took the summation of the lesser value of the generation source rating or the inverter rating for each connected install on the system. Taylor County RECC divided that cumulative capacity by the single hour peak load provided by EKPC.
- b. Please refer to Item 1 Exhibit A for the breakdown of calculations.