



**356 Wendover Road
Hyden, Kentucky 41749
(606) 672-2791**

December 21, 2021

Ms. Linda C. Bridwell, P.E.
Executive Director
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602-0615

**Re: Case No. 2020-00340
Hyden-Leslie County Water District**

Dear Ms. Bridwell:

Enclosed for filing in the above-referenced case is Hyden-Leslie County Water District's Monthly Water Loss Report for November 2021. The report was inadvertently omitted from the December Monthly Surcharge Report filed on 12/13/2021.

Please contact me if Commission Staff has any questions regarding the enclosed report.

Sincerely,

L.J. Turner
General Manager

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:

For the Month of: Year:

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	25,930
3	Water Purchased	
4	TOTAL PRODUCED AND PURCHASED	25,930
5		
6	WATER SALES	
7	Residential	12,445
8	Commercial	2,607
9	Industrial	
10	Bulk Loading Stations	
11	Wholesale	
12	Public Authorities	
13	Other Sales (explain)	
14	TOTAL WATER SALES	15,052
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	6,120
18	Wastewater Plant	
19	System Flushing	520
20	Fire Department	12
21	Other Usage (explain)	
22	TOTAL OTHER WATER USED	6,652
23		
24	WATER LOSS	
25	Tank Overflows	
26	Line Breaks	1,013
27	Line Leaks	3,213
28	Excavation Damages	
29	Theft	
30	Other Loss (explain)	
31	TOTAL WATER LOSS	4,226
32		
33	Note: Line 14 + Line 22 + Line 31 MUST Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 divided by Line 4)	16.30%