

## Methodology: Economic Analysis

The following subsections provide a methodology for performing the economic calculations to derive gross values in \$/kWh for each of the VOS components. These gross component values will then be entered into the VOS Calculation Table, which is the second of the two key transparency elements.

Important Note: The economic analysis is initially performed as if PV was centrally-located (without loss-saving benefits of distributed location) and with output perfectly correlated to load. Real-world adjustments are made later in the final VOS summation by including the results of the loss savings and load match analyses.

### Discount Factors

By convention, the analysis year 0 corresponds to the year in which the VOS tariff will begin. As an example, if a VOS was done in 2013 for customers entering a VOS tariff between January 1, 2014 and December 31, 2014, then year 0 would be 2014, year 1 would be 2015, and so on.

For each year  $i$ , a discount factor is given by

$$DiscountFactor_i = \frac{1}{(1 + DiscountRate)^i} \quad (8)$$

The *DiscountRate* is the utility Weighted Average Cost of Capital.

Similarly, a risk-free discount factor is given by:

$$RiskFreeDiscountFactor_i = \frac{1}{(1 + RiskFreeDiscountRate)^i} \quad (9)$$

The *RiskFreeDiscountRate* is based on the yields of current Treasury securities<sup>13</sup> of 1, 2, 3, 5, 7, 10, 20, and 30 year maturation dates. The *RiskFreeDiscountRate* is used once in the calculation of the Avoided Fuel Costs.

Finally, an environmental discount factor is given by:

$$EnvironmentalDiscountFactor_i = \frac{1}{(1 + EnvironmentalDiscountRate)^i} \quad (10)$$

<sup>13</sup> See <http://www.treasury.gov/resource-center/data-chart-center/interest-rates/Pages/TextView.aspx?data=yield>

The *EnvironmentalDiscountRate* is based on the 3% *real* discount rate that has been determined to be an appropriate societal discount rate for future environmental benefits.<sup>14</sup> As the methodology requires a nominal discount rate, this 3% *real* discount rate is converted into its equivalent 5.61% nominal discount rate as follows:<sup>15</sup>

$$\begin{aligned} \text{NominalDiscountRate} & & (11) \\ & = (1 + \text{RealDiscountRate}) \times (1 + \text{GeneralEscalationRate}) - 1 \end{aligned}$$

The *EnvironmentalDiscountRate* is used once in the calculation of the Avoided Environmental Costs.

PV degradation is accounted for in the economic calculations by reductions of the annual PV production in future years. As such, the PV production in kWh per kW-AC for the marginal PV resource in year *I* is given by:

$$PVProduction_i = PVProduction_0 \times (1 - PVDegradationRate)^i \quad (12)$$

where *PVDegradationRate* is the annual rate of PV degradation, assumed to be 0.5% per year – the standard PV module warranty guarantees a maximum of 0.5% power degradation per annum.

*PVProduction<sub>0</sub>* is the Annual Avoided Energy for the Marginal PV Resource.

PV capacity in year *i* for the Marginal PV Resource, taking into account degradation, equals:

$$PVCapacity_i = (1 - PVDegradationRate)^i \quad (13)$$

## Avoided Fuel Cost

Avoided fuel costs are based on long-term, risk-free fuel supply contracts. This value implicitly includes both the avoided cost of fuel as well as the avoided cost of price volatility risk that is otherwise passed from the utility to customers through fuel price adjustments.

PV displaces energy generated from the marginal unit, so it avoids the cost of fuel associated with this generation. Furthermore, the PV system is assumed to have a service life of 25 years, so the uncertainty in fuel price fluctuations is also eliminated over this period. For this reason, the avoided fuel cost must take into account the fuel as if it were purchased under a guaranteed, long term contract.

---

<sup>14</sup> <http://www.epa.gov/oms/climate/regulations/scc-tds.pdf>

<sup>15</sup> [http://en.wikipedia.org/wiki/Nominal\\_interest\\_rate](http://en.wikipedia.org/wiki/Nominal_interest_rate)