

January 5, 2021

ELECTRONICALLY FILED

Kentucky State Board on Electric Generation and Transmission Siting Kentucky Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, Kentucky 40602

Re: Notice of Intent to File Application of Horus Kentucky 1 LLC for Certificate of Construction for: an approximately 69.3-Megawatt Merchant Electric Solar Generating Facility in Simpson County, Kentucky pursuant to KRS 278.700, *et seq.*, and 807 KAR 5:110, Case No. 2020-00417

To Whom It May Concern:

Horus Kentucky 1 LLC hereby submits for filing this Notice of Intent to File an Application for a Certificate of Construction for an approximately 69.3-MW solar facility ("Horus Kentucky 1 Project").

a. The name, address, and telephone number of the person who intends to file the application is:

Horus Kentucky 1 LLC 110 Front Street, Suite #330 Juniper, Florida 33477 Phone: (617) 530-0029

Attention: Braden Houston, Senior Director - Solar Development

Email: bhouston@opdenergy.com

b. The proposed construction is briefly described as follows:

The Horus Kentucky 1 Project will consist of approximately 550 acres of solar photovoltaic panels and associated racking (approximately 69.3MW), 22 inverters, and a project substation transformer which will connect to the Tennessee Valley Authority's L5402 – 161kv transmission line near the City of Franklin in Simpson County, Kentucky.

c. The street address of the proposed Horus Kentucky 1 Project is Tyree Chapel Road, Franklin, Simpson County, Kentucky and the latitude and longitude are 36° 40′ 6.65″

North and 86° 32' 37.86" West. The Horus Kentucky 1 Project is not located within the limits of any city.

- d. The Simpson County Planning & Zoning with an address of Historic Courthouse, P.O. Box 1025, Franklin, Kentucky 42135 has jurisdiction over the site.
- e. Simpson County Zoning Regulation section 9.8 provides the following set-back requirements applicable to this site: (1) 50 feet from public road right-of-way; (2) 100 feet from any abutting agricultural properties; and (3) 250 feet from any residential-zoned properties, churches, cemeteries, nursing homes, and schools.
- f. Pursuant to KRS 278.704(4), the applicant will not request a deviation from the setback requirements found in KRS 278.704(2) because the local planning and zoning requirements have primacy.

Thank you for accepting this Notice of Intent to File Application. Please feel free to contact me at (304) 526-3507 or randy.saunders@nelsonmullins.com if you have any questions or need further information.

Sincerely,

Randall L. Saunders