



GERALD WUETCHER
DIRECT DIAL: (859) 231-3017
DIRECT FAX: (859) 259-3517
gerald.wuetcher@skofirm.com

300 WEST VINE STREET
SUITE 2100
LEXINGTON, KY 40507-1801
MAIN: (859) 231-3000
FAX: (859) 253-1093

May 19, 2026

Ms. Linda C. Bridwell, P.E.
Executive Director
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602-0615

Re: Case No. 2021-00063
East Logan Water District

Dear Ms. Bridwell:

Enclosed for filing in the above-referenced matter is East Logan Water District's ("the District") Water Loss Report for the First Quarter of Calendar Year 2026 (January 1 – March 31). Regarding its efforts to fund and construct the projects identified in its 2021 Capital Improvement Plan, the status of those efforts remains unchanged from that reported in the District's letter of January 31, 2026.

In accordance with 807 KAR 5:001, Section 8, and the Public Service Commission's Order of July 22, 2021 in Case No. 2020-00085, I certify that this letter was transmitted to the Public Service Commission this day and that currently no party in this proceeding has been excused by the Public Service Commission from electronic filing procedures.

Sincerely,

Stoll Keenon Ogden PLLC

A handwritten signature in blue ink that reads "Gerald E. Wuetcher".

Gerald E. Wuetcher

Enclosure

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: East Logan Water District PWSID: KY0710951

For the Month of: January Year: 2026

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	0
3	Water Purchased	28,638
4	TOTAL PRODUCED AND PURCHASED	28,638
5		
6	WATER SALES	
7	Residential	20,289
8	Commercial	0
9	Industrial	0
10	Bulk Loading Stations	0
11	Wholesale	0
12	Public Authorities	0
13	Other Sales (explain) _____ 0	0
14	TOTAL WATER SALES	20,289
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	0
18	Wastewater Plant	0
19	System Flushing	150
20	Fire Department	150
21	Other Usage (explain) _____ 0	0
22	TOTAL OTHER WATER USED	300
23		
24	WATER LOSS	
25	Tank Overflows	0
26	Line Breaks	3,416
27	Line Leaks	0
28	Excavation Damages	0
29	Theft	0
30	Other Loss (explain) _____ Unknown Loss	4,633
31	TOTAL LINE LOSS	8,049
32		
33	Note: Line 14 + Line 22 + Line 31 Must Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 Divided by Line 4)	28.11%

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: East Logan Water District PWSID: KY0710951

For the Month of: February Year: 2026

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	0
3	Water Purchased	25,087
4	TOTAL PRODUCED AND PURCHASED	25,087
5		
6	WATER SALES	
7	Residential	18,893
8	Commercial	0
9	Industrial	0
10	Bulk Loading Stations	0
11	Wholesale	0
12	Public Authorities	0
13	Other Sales (explain) _____ 0	0
14	TOTAL WATER SALES	18,893
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	0
18	Wastewater Plant	0
19	System Flushing	150
20	Fire Department	0
21	Other Usage (explain) _____ 0	0
22	TOTAL OTHER WATER USED	150
23		
24	WATER LOSS	
25	Tank Overflows	0
26	Line Breaks	1,122
27	Line Leaks	0
28	Excavation Damages	0
29	Theft	0
30	Other Loss (explain) _____ Unknown Loss	4,922
31	TOTAL LINE LOSS	6,044
32		
33	Note: Line 14 + Line 22 + Line 31 Must Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 Divided by Line 4)	24.09%

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: East Logan Water District PWSID: KY0710951

For the Month of: March Year: 2026

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	0
3	Water Purchased	24,787
4	TOTAL PRODUCED AND PURCHASED	24,787
5		
6	WATER SALES	
7	Residential	18,658
8	Commercial	0
9	Industrial	0
10	Bulk Loading Stations	0
11	Wholesale	0
12	Public Authorities	0
13	Other Sales (explain) _____ 0	0
14	TOTAL WATER SALES	18,658
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	0
18	Wastewater Plant	0
19	System Flushing	100
20	Fire Department	0
21	Other Usage (explain) _____ 0	0
22	TOTAL OTHER WATER USED	100
23		
24	WATER LOSS	
25	Tank Overflows	0
26	Line Breaks	1,306
27	Line Leaks	0
28	Excavation Damages	0
29	Theft	0
30	Other Loss (explain) _____ Unknown Loss	4,724
31	TOTAL LINE LOSS	6,029
32		
33	Note: Line 14 + Line 22 + Line 31 Must Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 Divided by Line 4)	24.32%