Attachment 14


Final Geotechnical Study





Geotechnical Report

ibV Energy - Rhudes Creek Solar Project



Eric Pauli, PE KY PE No. 36372

Table of Contents

1	Intro	oduction	3
2	Met	nodology	3
	2.1	Soil Borings	3
	2.2	Electrical Resistivity Testing	4
	2.3	Pile Load Testing	4
	2.3.1	Test Pile Installation	4
	2.3.2	Uplift Load Testing	4
	2.3.3	Lateral Load Testing	4
	2.3.4	Pile Extraction	4
	2.4	Karst Investigation	4
3	Geo	logy and Subsurface Conditions	5
4	Lab	pratory Results	6
	4.1	Soil Index Testing	6
	4.2	Compressive Strength of Rock	6
	4.3	Thermal Resistivity Testing	6
	4.4	Corrosivity Testing	7
	4.5	California Bearing Ratio	7
5	Pile	Load Testing Results	8
6	Seis	mic Site Classification	9
	6.1	Preliminary Seismic Evaluation	9
7	Kars	st Investigation	9
	7.1	Investigation Findings	9
	7.2	Recommendations	10
8	Fou	ndation Considerations	11
	8.1	Corrosion Considerations	12
	8.2	Frost & Adfreeze Considerations	12
	8.3	Recommended Soil Parameters for Pile Design	12
	8.4	Recommended Soil Parameters for General Foundation Design	13
9	Con	struction Recommendations	13
	9.1	Excavation	13
	9.2	Dewatering	13
	9.3	Subgrade Preparation	14
	9.4	Backfilling and Re-use of Native Soils	14
	9.5	Access Roads	15
	9.6	Flooding and Erosion	15
	9.7	Pile Drivability	15
10) Limi	tations	16



1 Introduction

ANS Geo, Inc. is pleased to provide this Geotechnical Report (Report) to ibV Energy (ibV) to summarize the results of our geotechnical field investigations in support of the proposed Rhudes Creek Solar project located in Hardin County, Kentucky. At the time of this Report, it is our understanding that the solar facility is planned to include a substation, access roadways, and solar panel arrays. In addition, the purpose of this Geotechnical Report is to provide preliminary information for schematic design, as well as Information for Bidders to inform them of expected subsurface conditions for the proposed photovoltaic development, as well as support their respective designs.

ANS Geo notes that our geotechnical program was conducted to supplement Terracon's preliminary investigation completed in 2020. The factual results of their investigation, summarized in their *Preliminary Geotechnical Engineering Report* dated December 30, 2020 (**Attachment H**), were reviewed and incorporated as factual data points, to the extent practical, into our report and evaluations to provide a singular comprehensive report. Our design-level geotechnical program encompassed a desktop study of local geologic conditions and available reports, soil borings, field electrical resistivity testing, pile load testing, geophysical testing as part of a karst investigation, laboratory thermal resistivity and corrosion testing, California Bearing Ratio (CBR) and laboratory soil material testing.

In addition to a traditional geotechnical investigation to support the proposed solar facility, it is known from publicly-available geologic records and Terracon's preliminary investigation that the site is underlain by a geologic formation exhibits signs and dissolution features typical of a karstic environment. As part of our investigation, a geophysics investigation, consisting of Electrical Resistivity Imaging (ERI) and 1-D multichannel analysis of surface wave (MASW) testing, was also conducted to perform a high-level evaluation as to the extent and type of karst features across the project site.

2 Methodology

2.1 Soil Borings

ANS Geo retained Tri-State Drilling, (TSD) of Chattanooga, Tennessee to advance 29 soil borings (B-12 through B-38, B-SS-1, and B-SS-2) completed at select locations across the project site between February 22 and 27, 2021. ANS Geo notes that our soil boring nomenclature intentionally begins at "B-12" as borings B-1 through B-11 were completed at the project site within Terracon's preliminary investigation program. The soil boring locations are depicted in the Investigation Location Plan, provided as **Attachment A**. Soil borings B-12 through 34 were completed within the planned array area(s), borings B-35 through 38 were positioned along the planned utility right-of-way, and borings B-SS-1 and B-SS-2 were situated within the substation footprint.

Each soil boring was generally advanced to approximately 20 feet below ground surface (BGS) or until practical refusal, whichever was encountered first. Select soil borings (B-27, 29, SS-1, and SS-2) were extended to practical refusal to collect additional, deeper information. A CME-55 ATV track rig was used to collect soil samples using the Standard Penetration Test (SPT) Method through hollow-stem augers in accordance with ASTM Standard D1586. Soil samples were generally collected continuously within the upper 10 feet in each boring, then in five-foot intervals thereafter to the termination depth. Within boring B-36, rock coring was conducting using a wireline retrieval method in accordance with ASTM D2113 to confirm the presence and type of bedrock. Soil borings, proposed by ANS Geo and confirmed by ibV review, were located at relatively evenly spread locations throughout the project footprint. All soil borings were overseen and logged by an ANS Geo representative under the direction of a Professional Engineer licensed in the State of Kentucky.

At select soil boring locations, auger cuttings were collected within four (4) feet of grade with the purpose of obtaining bulk soil samples for laboratory California Bearing Ratio (CBR), thermal resistivity testing (TRT), and corrosivity testing. Upon completion, each borehole was backfilled to its existing grade with soil cuttings and bentonite holeplug.



2.2 Electrical Resistivity Testing

As part of our field investigation program, ANS Geo performed field Electrical Resistivity Tomography (ERT) testing at six (6) locations within the proposed array area(s), and one (1) additional location within the proposed substation footprint. In-situ soil resistivity measurements were obtained by utilizing the Wenner 4-Pin Method in accordance with ASTM G57 and IEEE Standard 80. Two (2) mutually perpendicular traverses were collected at each location utilizing "a"-spacings of 2, 5, 10, 25, and 50 feet, with additional 100 and 150-foot spacings at the substation location. Test results are presented as **Attachment C**.

2.3 Pile Load Testing

2.3.1 Test Pile Installation

As part of our scope of work, ANS Geo conducted pile load testing at 19 locations across the proposed solar array area(s) between February 27 and March 6, 2021. Each test location included a pair of test piles, totaling 38 piles tested for both uplift and lateral capacities. At each test location, W6x9 steel sections ("piles") were installed to between 7 and 11 feet BGS through the overburden via direct push to significant resistance, then driven to their targeted depths using a GAYK HRE 4000 Pile Driver. Installation rates varied between 16.7 and 50.1 seconds per foot (average around 30 seconds per foot). The installation and load testing program was overseen and logged by an ANS Geo geotechnical representative under the direction of a Professional Engineer licensed in the State of Kentucky.

2.3.2 Uplift Load Testing

Once driven to the targeted embedment depth (varying between 6.0 and 9.9 feet BGS), an uplift load test was performed on each test pile in accordance with the ASTM D3689 (uplift) test method. The tension load was generally applied through a load cylinder fastened to a tripod apparatus which was mounted to the pile driver. Uplift loads were generally applied in one-minute, 500-pound increments up to 2,000 pounds. Once achieved, the load was then unloaded in similar increments and timing. After the tension was fully released, the piles were reloaded up to a maximum uplift load of roughly 10,000 pounds.

2.3.3 Lateral Load Testing

A lateral load test was also performed at each test location, following each uplift load test, in accordance with ASTM D3966 (lateral) test method. Horizontal loads were applied at approximately three (3) feet above grade on each pile using a "twin-pile" setup. The pair of piles were strapped together and loaded, in tension, using the pulling force of the interior load cylinder. Each test load was applied cyclically in one-minute, 500-pound increments up to 4,000 pounds, where feasible. Once achieved, the load was immediately released and reloaded up to a maximum deflection of approximately one-inch, if not already achieved.

The location of each pile load test is depicted in the Investigation Location Plan, provided as **Attachment A**. Results of the pile load testing program are summarized within **Section 5**.

2.3.4 Pile Extraction

Upon completion of the testing program, each test pile was excavated in its entirety with a backhoe and stockpiled on site per the landowner's approval.

2.4 Karst Investigation

As common within central Kentucky, the project site is mapped as an "area underlain by bedrock with high potential for karst development" as depicted within the Kentucky Geological Survey's *Karst Occurrence in Kentucky* map. Karst terrains include regions where the topography is formed and altered by the dissolution of bedrock (commonly limestone or dolomite). Karst landscapes are commonly characterized by features such as surficial depressions, sinkholes, sinking streams, subsurface drainage, springs, and caves. This karst



classification is defined by thick-bedded, typically fine-grained and pure limestone units with little or no insoluble content. Units in this class will exhibit mature karst, including caves, sinkholes, and springs where they crop out. In addition, this unit is commonly covered by as much as 30 feet of soil, which is fairly consistent with the completed geotechnical investigations (Terracon and ANS Geo) which revealed auger refusal depths of 6.5 to 34.5 feet below grade across the site. As several surficial depressions and karst-associated features were evident at the project site, ANS Geo designed and implemented a high-level karst investigation program.

To conduct the work, ANS Geo retained THG Geophysics to support a limited geophysical investigation at the project site to evaluate the potential for karst features. The survey activities completed by THG included the use of electrical resistivity imaging (EI) and multichannel analysis of surface wave (MASW) testing to characterize subsurface soils and bedrock in an area expected to exhibit signs of karst. THG utilized a GF Instruments' ARES II electrical resistivity meter and a Geometrics Geode seismograph to image the subsurface. Given the size of the project site, testing locations were selected to be distributed across the property while also targeting potential karst features in the field such as visible topographic depressions, lowlying areas collecting and holding surface water, and waterbody features such as creeks.

It should be noted that purpose of the geophysical program was not intended to be an exhaustive evaluation of the entirety of the site, as that intent would require extensive and comprehensive canvassing and investigation across each parcel of the proposed solar farm. However, the investigation was intended to gain a general understanding of the subsurface conditions and gauge the preliminary impact which karst geohazards may or may not contribute to the design, siting, and construction of the proposed solar farm.

3 Geology and Subsurface Conditions

ANS Geo conducted a brief, desktop review of surficial and bedrock geology maps and reports made available by the United States Geological Survey (USGS) and the USDA Natural Resources Conservation Service (NRCS) prior to conducting our field investigation. We also consulted Terracon's *Preliminary Geotechnical Engineering Report* within our review. The available mapping and reports indicate that the native surficial soils are classified as predominantly clays and silts underlain by limestone bedrock which, on average, exists between 20 and 40 feet below grade. Localized areas of elevated/shallow bedrock are also expected to be present throughout the project extents. The mapped soil formations identified within our desktop study are consistent with the findings of our field investigations.

ANS Geo has provided the generalized subsurface conditions within Table 1 below based upon the observations made during our geotechnical investigation for the solar project. ANS Geo notes that this profile is highly generalized and that soil boring logs, been provided as **Attachment B**, should be reviewed for location-specific subsurface conditions.

Avg. Depth (ft)	Material	Avg. Consistency	Description
0' - 0.5'	Topsoil	-	Two (2) to 10 inches of topsoil existed at surface across most of the project.
0.5 – 20'	Clay / Silt	Stiff	Clays and/or medium to high plasticity silts were encountered as the primary soil type across the project site. Soil consistency typically ranged between medium and very stiff, and maintained average pocket penetrometer measurements of 1.0 to 2.5 tons per square foot. Occasional sand inclusions were observed at depths of 6 feet or greater, within a few boring locations.
Boulders / Weathered Rock		Very dense	Refusal on dense material, likely including cobbles, boulders, or limestone bedrock, was encountered in four (14 percent) of the drilled boring locations within 20 feet of grade. The shallowest drilled refusal was recorded at 14.8 feet below grade; hand auger refusal was encountered at 4.2 feet within Boring B-38, likely due to cobble, boulder, or stiff soil.

Table 1 - Generalized Subsurface Profile



Based on observations recorded at the time of our investigation program, seasonal high groundwater is expected to exist at six (6) feet below grade or deeper. Wet soils recovered at shallower depths within our explorations are, in our opinion, indicative of perched water conditions in localized areas.

4 Laboratory Results

4.1 Soil Index Testing

Representative soil samples were collected during our investigation and submitted to ANS's accredited materials testing laboratory. A summary of the index laboratory test results is provided within Table 2. Asreceived laboratory test results are included within **Attachment D**.

Table 2 - Soil Index Testing Summary

rable 2 – oon maex resting outlinary						
Boring ID	Sample ID	Depth (feet)	% Gravel	% Sand	% Fines	% Moisture
B-15	S-4	6 - 8	0	70.2	29.8	11.1
B-21	S-5	8 - 10	0	80.4	19.6	11.9
Boring ID	Sample ID	Depth (feet)	Liquid Limit	Plastic Limit	Plasticity Index	USCS Soil Type
B-12	S-4	6 - 8	29.8	20.3	9.5	CL
B-16	S-1	0 - 2	30.8	19.6	11.2	CL
B-17	S-5	8 - 10	27.4	18.9	8.5	CL
B-18	S-2	2 - 4	30.5	20.6	9.9	CL
B-19	S-3	4 - 6	26.7	19.2	7.5	CL
B-20	S-4	6 - 8	29.5	18.3	11.2	CL
B-24	S-3	4 - 6	29.7	19.7	10.0	CL
B-26	S-1	0 - 2	28.9	18.2	10.7	CL
B-27	S-4	6 - 8	29.6	18.8	10.8	CL
B-29	S-2	2 - 4	28.7	18.7	10.0	CL
B-31	S-3	4 - 6	31.8	19.2	12.6	CL
B-33	S-5	8 - 10	28.6	19.7	8.9	CL
B-35	S-5	8 - 10	26.4	19.2	7.4	CL
B-37	S-2	2 - 4	29.8	18.7	11.1	CL
B-38	G-3	4 - 5	29.2	18.5	10.7	CL
B-SS-1	S-3	4 - 6	27.4	18.4	9.0	CL
B-SS-2	S-S	2 - 4	28.0	19.1	8.9	CL

4.2 Compressive Strength of Rock

A rock sample was cored within one soil boring locations (B-36) which was submitted to ANS's laboratory for Unconfined Compressive Strength testing in accordance with ASTM D2938. In summary, the tested limestone exhibited a corrected compressive strength of 8,660 pounds per square inch. Full test results are included within **Attachment D**.

4.3 Thermal Resistivity Testing

ANS Geo collected bulk samples from three (3) locations throughout the project area from two (2) to four (4) feet below grade for laboratory testing of Thermal Resistivity. Soils were collected in a five-gallon bucket and delivered to ANS Consultants' accredited laboratory for testing. The soil was compacted to 85 percent of its Standard Proctor Density in accordance with ASTM D698, and Thermal Resistivity Testing was conducted in accordance with IEEE Standard 442-2017. Results of the thermal testing are summarized within Table 3. Complete, as-received results have been provided within **Attachment D**.



Table 3 - Thermal Resistivity Testing Summary

	Material Type	Thermal Resistivity Values at Various Moisture Contents					Received	
Location ID		% water	% water	% water	% water	% water	Moisture Content (%)	Re-Molded Dry Density (lb/ft ³)
		(°C-cm/W)	(°C-cm/W)	(°C-cm/W)	(°C-cm/W)	(°C-cm/W)		, ,
B-15	Clay	0.0	2.5	5.0	7.5	10.1	20.8	98.0
D-15		462	232	136	114	107		
B-31	Clay	0.0	3.8	7.5	11.3	14.6	20.8	93.7
D-31		647	248	112	85	77	20.6	93.7
B-SS-2	Clay	0.0	3.8	7.5	11.3	14.2	22.5	97.0
D-33-2	Clay	669	301	204	182	170	23.5	87.9

4.4 Corrosivity Testing

ANS Geo collected additional samples from zero (0) to three (3) feet below grade at five (5) locations for corrosivity testing. The results of the testing, completed by ANS Consultants, have been summarized within Table 4 and are detailed within **Attachment D**.

Table 4 – Corrosivity Testing Summary

Location ID	рН	Sulfate (mg/kg)	Chloride (mg/kg)	Soil Box (Calculated Resistivity) (Ω/cm)	Redox Potential (average) (mV)
B-14	6.94	17	40	7,000	121
B-20	6.88	25	50	9,000	129
B-23	7.07	14	35	8,000	117
B-32	6.88	27	50	9,500	135
B-SS-1	6.74	21	45	10,000	125

4.5 California Bearing Ratio

ANS Geo collected an additional sample within two (2) feet of grade, stripped of any topsoil or organics, at three (3) locations for testing of California Bearing Ratio (CBR) in accordance with ASTM D1883 at approximately 90 percent of its Standard Proctor Density (ASTM D698). The results of the testing, completed by ANS Consultants, have been summarized within Table 5 and are detailed within **Attachment D**.

Table 5 - California Bearing Ratio Summary

Location ID	CBR Ratio (%)				
B-21	4.9				
B-38	1.5				
B-SS-1	0.9				



5 Pile Load Testing Results

Table 6 presents the summarized results of the pile load testing program at each test location. Complete Load Testing Logs are provided as **Attachment E** and should be referenced for detailed information.

Table 6 - Pile Load Testing Summary

	rable 0 - File Load Testing Summary							
Load Test ID	Embedment Depth (ft.)	Average Pile Installation Rate (sec/ft)	Approx. Uplift Load at 0.75-inch Deflection (lbs)	Approx. Lateral Load at 1-inch Deflection (lbs)				
PLT-01 A	9	17.5	> 10,000	5,500				
PLT-01 B	9	25.1	> 10,000	5,100				
PLT-02 A	9	30.3	> 10,000	4,400				
PLT-02 B	9	38.6	> 10,000	4,500				
PLT-03 A	7	22.6	> 10,000	5,700				
PLT-03 B	7	22.4	> 10,000	5,600				
PLT-04 A	8	37.4	> 10,000	5,600				
PLT-04 B	8	40.7	> 10,000	5,800				
PLT-05 A	8	35.8	> 10,000	5,400				
PLT-05 B	8	36.7	> 10,000	5,100				
PLT-06 A	11	28.4	> 10,000	3,800				
PLT-06 B	11	34.4	> 10,000	4,000				
PLT-07 A	10	26.3	> 10,000	4,100				
PLT-07 B	10	26.1	> 10,000	4,200				
PLT-08 A	11	30.2	> 10,000	5,100				
PLT-08 B	11	29.6	> 10,000	5,500				
PLT-09 A	8	22.2	> 10,000	5,000				
PLT-09 B	8	25.3	> 10,000	5,600				
PLT-10 A	9	27.9	> 10,000	4,900				
PLT-10 B	9	29.2	> 10,000	4,900				
PLT-11 A	9	27.9	> 10,000	4,800				
PLT-11 B	9	29.1	> 10,000	4,700				
PLT-12 A	9	34.2	> 10,000	5,100				
PLT-12 B	9	42.6	> 10,000	5,100				
PLT-13 A	8	16.2	> 10,000	3,700				
PLT-13 B	8	26.7	> 10,000	4,100				
PLT-14 A	9	27.9	> 10,000	3,300				
PLT-14 B	9	25.5	> 10,000	3,300				
PLT-15 A	10	22.1	> 10,000	3,400				
PLT-15 B	10	21.4	> 10,000	3,400				
PLT-16 A	7	26.2	> 10,000	5,300				
PLT-16 B	7	31.1	> 10,000	5,300				
PLT-17 A	10	26.1	> 10,000	4,300				
PLT-17 B	10	23.4	> 10,000	3,900				
PLT-18 A	8	23.4	> 10,000	4,100				
PLT-18 B	8	24.0	> 10,000	4,500				
PLT-19 A	10	29.3	> 10,000	4,600				
PLT-19 B	10	50.1	> 10,000	6,000				

ANS Geo notes that the depicted lateral loading conditions represent deflections measured at approximately four (4) inches above ground surface as a result of horizontal loads applied perpendicular to the pile's strong axis at three (3) feet above grade.



6 Seismic Site Classification

ANS Geo utilized the average shear wave velocity method as prescribed in Chapter 20 of ASCE 7-16 to determine the Seismic Site Classification. Multichannel Analysis of Surface Waves (MASW) testing was conducted as part of the geophysical karst investigation program which obtained shear wave velocity data at 11 locations throughout the project site. Based on the average shear wave velocities collected within 100 feet of grade, Site Class C can be assumed as the average condition across the project site.

The following Site Class C seismic ground motion values were obtained from the USGS Seismic Hazard Maps, referenced in ASCE 7-16 Standard, for this site:

- 0.2 second spectral response acceleration, S_S= 0.208 g
- 1 second spectral response acceleration, S₁= 0.110 g
- Maximum spectral acceleration for short periods, S_{MS}= 0.271 g
- Maximum spectral acceleration for a 1-second period, S_{M1}= 0.165 g
- 5% damped design spectral acceleration at short periods, S_{DS}= 0.180 g
- 5% damped design spectral acceleration at 1-second period, S_{D1}= 0.110 g

6.1 Preliminary Seismic Evaluation

The designated seismic site class is anticipated based on results from our investigation program and using select areas of the site which have been investigated by ANS Geo. Seismic support data is provided as **Attachment F**. Based on our observation of subsurface conditions, estimated Site Class ratings, and review of USGS's 2018 National Seismic Hazard Map, ANS Geo concludes that there is a low risk of significant seismic activity which may impact the proposed solar facility.

7 Karst Investigation

7.1 Investigation Findings

Within the karst investigation, a total of 29 El profiles and 11 MASW tests were completed. THG's full geophysical report has been provided as **Attachment G**; however, the conclusions are summarized below:

- The project site is located in a geological setting with a high potential for karst development.
- Electrical imaging acquired from February 9 to 11, 2021, confirms the presence of karst features at this site.
 - The project site was divided into nine (9) discrete "Areas", each denoting an array area from a conceptual site plan provided to us by ibV Energy in January 2021.
 - A number of "lines", or an alignment where the geophysical sensors were placed in a linear fashion, were taken in each of the Areas.
 - Each line provided a two-dimensional cross section profile of the subsurface resistivity measured beneath and along the survey line. The length of the line, measured in feet, begins at 0-feet (start of line) to the maximum extent of the line.
 - Depressions or features are noted and identified by their location along the line, denoted by the range [feet] the feature exists along the line.
- Depth to bedrock is variable, but is commonly greater than 20 feet below grade within the solar project footprint.
- Topographically-derived sinkhole features developed by KGS located with Areas 6 and 8 (A key map of
 areas is defined and illustrated as Figure 2 of the THG report). Other areas not geophysically surveyed,
 either because they were not observed in the field or conditions were too wet to access.



- Shallow (within 30 ft below grade) karst features, which may impact the siting of array areas, inverter pads, substation, and other ancillary features, may exist at the following locations:
 - Line 12: 45-58 ft and 155-226 ft
 - Line 15: 20-120 ft (potential air-filled void)
- Deeper (greater than 45 ft) karst conditions may exist at the following locations:

Line 4: 155-226 ft
Line 21: 110-160 ft
Line 22: 160-200 ft
Line 23: 20-115 ft
Line 24: 140-180 ft

7.2 Recommendations

ANS Geo recommends additional geotechnical drilling and investigation be conducted at specific areas identified in the geophysical study as having karst potential and risk. However, notwithstanding additional site investigations, we recommend that solar areas and critical structures avoid "higher-risk" locations, or locations where surface depressions are readily apparent, or geophysics has observed shallow karst features. While smaller surface depressions do currently and have formerly existed across the site, these particular areas of "higher-risk" have generally show signs of continual subsidence over time, indicating that they will continue to develop into the future. Results of the geophysics investigation pinpoints areas along the survey line where karstic subsurface anomalies may occur.

The "higher-risk" designated areas were adjusted based on the results from the geophysics investigation. It is our professional opinion that critical structures (ie. substation elements) should avoid these "higher-risk" locations, wherever possible, with a minimum 100-foot buffer from the nearest extent of such "higher-risk" area or topographic depression. If required to be sited in "higher-risk" areas, foundations for these structures should consist of deep foundations that are bearing on a competent, intact subsurface layer. Bedrock-supported foundations will aid in minimizing future deflection or displacement of critical structures which may be otherwise adversely impacted by continued overburden subsidence. These "higher-risk" karst areas are depicted in the Karst Hazard Map, provided within **Attachment G**.

In areas where geophysics has identified relic karst features (previously-mapped KGS features), or deeper karst conditions, it is possible that loose, raveled soils are likely to exist in these "moderate-risk" areas. These areas may need longer or stiffer pile sections to achieve necessary loading capacities. A "moderate-risk" designation denotes areas where loose soils, likely those which "raveled" (soils that filled into depressions or below-grade cavities) may exist.

It should be noted that the term "high" risk is relative, and these terms do not preclude the potential for detrimental karst activity and subsidence elsewhere at non-delineated and named locations across the site. In addition, our relative risk classification is limited by our investigation program, specifically the alignments and locations which our investigations were conducted. We are unable to extrapolate, deduce, or evaluate the subsurface conditions outside of these investigated areas, and as such, other depressions, remnant, or active karst features may exist within uninvestigated locations. It should also be noted that the southeastern project parcel, located east of the existing railroad tracks, was not investigated as part of our investigation programs. The prepared Karst Hazard Map (**Attachment G**) was extended to include this area solely based on KGS-documented features, and not field observations.

Karst is frequently a complex system which are impacted by groundwater flow direction, infiltration and precipitation, changes in landform and topography, as well as man-made development. A change in any of these conditions, such as re-grading and re-direction of quantity, drainage, and infiltration of stormwater, can result in a change in the risk profile for areas across the site. Off-site impacts, such as groundwater pumping



or increased infiltration caused by storm events can also alter the groundwater flow direction which can modify subsurface conditions. It is suggested that the developer and site/civil engineer review available resources prepared by the Kentucky Geological Society (KGS) related to best management practices for site development, including, but not limited to the *Ordinance for the Control of Urban Development in Sinkhole Areas in the Blue Grass Karst Region* (Dinger and Rebmann, 1991).

7.3 Monitoring

Sinkholes (and associated ground movement) generally occur in two ways: the first, as a sudden collapse caused by exceeding the capacity of bridging support which exists above an air-filled void; and, the second, a longer-duration and gradual ground surface movement as surface soils and subsurface soils are washed into cavities and karst features by groundwater movement. Based on our experience with the project area, review of geophysical and soil boring data, as well as the nature of karst formations in the local area, it is expected that the method of sinkhole formation and movement at this site will be more gradual in nature than sudden cover-collapse. Review of geophysical data did not show prominent air-filled voids; however, the presence of soil-filled voids, throats, and relic karst features appear to show that groundwater action is creating karst but is simultaneously filling voids by carrying in clay, silt, and sand sediment. In addition, no "rod drops" or signs of open voids were identified by any of the soil borings advanced at the project site.

Therefore, in addition to an offset buffer from potential karst risk zones as identified in Section 7.2, it is recommended that a monitoring program is implemented to identify, understand, and mitigate/remediate during long-term operation of the development. The intent of the monitoring program is to evaluate larger-scale, ground-level movement attributable to karst, such as the gradual "bowl-like" movement which gradually occurs as a sinkhole feature develops over time. The monitoring program is intended to determine topographic variations over time, which would result in bending, tilting, and added stress to racking, modules, and structural components. This type of monitoring can be accomplished by installing survey monuments on fixed points, such as rigid steel markers at the end of panel rows/strings and installing a fixed survey marker/nail on top of concrete inverter and substation slabs. A separate survey monument, such as a sole steel post driven specifically for the purpose of monitoring each "area", may also be installed to allow for rapid evaluation. It is recommended that, at minimum, one monument be installed for each one-half acre of developed area.

Following installation of monitoring points, the owner/operator should conduct at least annual surveys of the monitoring points and compare the year-over-year movement between points. If individual monitoring points are not possible, annual LiDAR or drone surveying may be possible to rapidly evaluate the entire project area. If monitoring points show a change in individual elevation, or differential movement compared to nearby reference points, a detailed evaluation should be undertaken. This should include engaging a geotechnical engineer to conduct geophysical investigations (electrical resistivity tomography or other recognized method) to evaluate the potential development of detrimental karst activity. In addition, re-setting of panels, racking, or other structural elements may become necessary if movement is shown from monitoring to prevent flexure of sensitive PV modules, cracking of glass, or added stress and/or shearing of connection pins, bolts, and other hardware.

8 Foundation Considerations

ANS Geo anticipates that, as typical with solar farm construction, embedded posts, such as W6x9 or W8x10 H-piles, will be used to support the proposed solar panels. Conventional shallow foundations such as sonotubes, spread footings, or similar systems may also be utilized for equipment pads and associated support structures.



8.1 Corrosion Considerations

Given the soil's measured acidity, sulfate and chloride concentrations, resistivity, and redox potential summarized in **Section 4.4** (Table 4), in consideration with the soil and moisture conditions observed, the influence of corrosion attack on embedded steel piles is considered to be generally low (Corrosion Category C2).

8.2 Frost & Adfreeze Considerations

Within Hardin County, Kentucky, frost depth is mapped to exist at approximately 24 inches below grade. As such, ANS Geo recommends that all structural foundations be founded at 24 inches (2 feet) below grade or deeper to ensure adequate protection from frost conditions which may jeopardize the integrity of subgrade soils and associated substructure.

Given the location of the project and soils encountered, the potential for frost heave against post foundations should be considered. Fine-grained soils, or granular soils with greater than 10 percent fine-grained content are frost-susceptible due to the inability of entrapped moisture from infiltrating or evaporating prior to freezing. Trapped moisture will begin to create ice lenses, which will grip the steel posts or embedded structures, followed by ice-jacking due to frost heave. The phenomenon is more commonly referred to as "adfreeze stress", which can be considered as an external, upward force applied to the post. The magnitude of the upward force will depend on the depth/thickness of the frost zone, the interface bond stress between embedded structure/material and the surrounding area, and the surface area of the structure/material in contact with this bond stress. As predominantly silty and clayey soils were observed near grade, ANS Geo recommends that an unfactored adfreeze (uplift) stress of 1,500 pounds per square foot (10.4 psi) be considered for the upper 12 inches (1 foot) of overburden soil during panel foundation sizing and design.

8.3 Recommended Soil Parameters for Pile Design

Based on our interpretation of the subsurface conditions observed within our investigation programs and results of pile load testings, ANS Geo recommends that the soil parameters, as depicted within Table 7, be considered for foundation post design purposes.

Effective Internal Soil Soil **Allowable Allowable** Depth Material Unit Friction Cohesion Modulus Strain Bearing Side Weight Angle (k) (E₅₀) Capacity Resistance Topsoil 0' - 1' 105 lb/ft³ 750 lb/ft² 0.010 (Soft Clay) Silt 1' - 2'105 lb/ft3 750 lb/ft² 0.010 300 lb/ft² (Soft Clay) Clav 2' - 6'115 lb/ft3 1.800 lb/ft² 200 lb/in³ 0.007 2,000 lb/ft² 600 lb/ft² (Mod. Stiff Clay w/o Free Water) Clay 6' - 8'120 lb/ft3 2,500 lb/ft² 350 lb/in3 0.005 700 lb/ft² 3,000 lb/ft² (Mod. Stiff Clay w/o Free Water) Clay 200 lb/in3 0.007 8' + 115 lb/ft³ 1,800 lb/ft² 3,500 lb/ft² 700 lb/ft² (Mod. Stiff Clay w/o Free Water)

Table 7 - Recommended LPILE Soil Parameters

Note: Italicized material types represent our recommended LPILE soil models.

ANS Geo recommends that allowable side resistance within the upper foot be neglected due to anticipated surficial disturbance, and adfreeze stresses as noted in **Section 8.2** should be considered. Pile load testing



results and subsurface observations were evaluated by ANS Geo using LPILE software to provide these refined soil parameters. ANS Geo notes that the soil parameters depicted within Table 7 represent values calibrated to curve-fit our lateral load test data; these parameters (effective unit weight and internal friction angle) should not be relied upon for axial design or other site foundation designs. It is our recommendation that verification load testing and detailed structural calculations be performed prior to construction to confirm these recommendations.

8.4 Recommended Soil Parameters for General Foundation Design

For foundations other than posts for solar panels (ie. substation elements, inverter slabs, transformers, etc.), ANS Geo recommends the design parameters depicted in Table 8.

Depth	Depth Material		Internal Friction Angle	Cohesion	Allowable Bearing Capacity
0' – 1'	Topsoil	95 lb/ft ³		300 lb/ft ²	300 lb/ft ²
1' – 2'	Silt	100 lb/ft ³		500 lb/ft ²	500 lb/ft ²
2' - 6'	Clay	110 lb/ft ³		1,000 lb/ft ²	1,000 lb/ft ²
6' - 8'	Clay	115 lb/ft ³		1,500 lb/ft ²	2,000 lb/ft ²
8' +	Clay	110 lb/ft ³		1,000 lb/ft ²	2,500 lb/ft ²

Table 8 – Recommended Soil Parameters (non-post foundations)

9 Construction Recommendations

9.1 Excavation

Depending on the depths of basins, drainage features, and foundation elements, some excavations may extend deeper than four feet below grade. As such, excavations deeper than four feet should be shored or sloped and benched, in accordance with OSHA regulations, to ensure safe working conditions within the excavations. For benching purposes, overburden clays and silts may be considered as "Type A" material and should be sloped no steeper than $\frac{3}{4}$ H:1V (horizontal to vertical). OSHA soil classifications should be field-determined by the contractor's "competent person" prior to excavation. Any proposed shoring systems should be designed by the contractor's "competent person", be certified by a Professional Engineer licensed in the State of Kentucky, and should be submitted to the engineer for review.

Permanent excavations for drainage swales, ditches, or similar features should be limited to a maximum slope of 3H:1V and should be protected from erosion via stone, riprap, jute-mat, or similar method.

9.2 Dewatering

ANS Geo observed perched water at or near grade at the time of our investigation program. As such, the contractor should be prepared to manage shallow groundwater, perched water, and/or infiltrated stormwater as needed using localized pump-and-sump or similar techniques to allow for subgrade preparation and concrete foundation construction in-the-dry. Water discharge should be managed in compliance with applicable state and local regulations. The contractor should be sure to grade the surface as necessary to divert stormwater away from open excavation to the extent possible.



9.3 Subgrade Preparation

Prior to the installation of shallow concrete foundations, ANS Geo recommends overexcavating the subgrade by at least six (6) inches, lining the exposed material with a geotextile separation fabric, and bringing the subgrade back up to the design foundation elevation with compacted structural fill as specified within Table 9. Native material beneath the separation fabric should be inspected for unsatisfactory conditions such as standing water, frozen soil, organics, or deleterious materials. Should any unsatisfactory conditions exist within the native subgrade, the excavation should be undercut an additional six inches (12 total inches beneath proposed foundation depth) prior to placement of the geotextile separation fabric.

Table 9 - Recommended Gradation of Structural Fill

Sieve Size	Percent Passing
3-inch	100
1 ½-inch	60 – 100
No. 4	30 – 60
No. 200	0 – 10

Structural fill material should be placed in loose lifts not exceeding eight (8) inches in height and be compacted to at least 95 percent of its Modified Proctor Density in accordance with ASTM D1557.

9.4 Backfilling and Re-use of Native Soils

ANS Geo notes that native fine-grained soils (clays and silts) on site will likely be difficult to handle, place, and compact without proper moisture conditioning and protection. ANS Geo recommends the following measures be considered to reduce the adverse impacts of moisture-sensitive soils:

- Positive measure should be implemented and maintained to intercept and direct surface water away from moisture-sensitive subgrade surfaces.
- Subgrade surfaces should be sloped and, as appropriate, seal-rolled to facilitate proper drainage.
 Surfaces should be properly prepared in anticipation of inclement weather. Moisture should not be allowed to collect on subgrade surfaces.
- To the extent practical, the limits of exposed subgrade soils should be minimized.
- Construction traffic should be limited to properly constructed haul roads.
- Disturbed soils should be removed and replaced with compacted controlled fill material.
- In place moisture contents should be maintained with two percent wet/dry of the optimum moisture content as determined by the Modified Proctor Test (ASTM D1557).

These soils may be re-used across the project area for fill in landscaped areas; however, it should not be used under or above foundations or load-bearing structures where typically imported structural fill is used. Native material used as backfill for cable trenches should be handled and placed at a moisture content at or above its optimum value to ensure representative thermal properties are maintained.

In areas around and above installed foundations, large utilities, and other buried site features, ANS Geo recommends importing a clean granular material with less than 15 percent fine-grained content for use as general backfill. General backfill material should be screened of cobbles, boulders, and any particles larger than 3 inches in diameter, and should not be used beneath any load-bearing structures. General backfill should be placed in loose lift thicknesses not exceeding 12 inches and be compacted to at least 95 percent of its Modified Proctor Density (ASTM D1557). Soil used as backfill should not be handled when frozen and should be free of excessive moisture, organics, and deleterious material.

In fill areas beneath foundations, access roads, and load-bearing structures, ANS Geo recommends structural fill as described in **Section 9.3** and Table 9.



9.5 Access Roads

ANS Geo understands that an access road will likely be required for post-construction use to enter and exit the project site as well as provide access to the equipment pad locations. It is also our understanding that this access road will likely be unpaved, to accommodate occasional light vehicular traffic such as utility pickup truck or similar vehicle. As such, ANS Geo recommends that access roads be constructed with at least 10 inches of crushed stone as specified within Table 10.

Sieve Size	Percent Passing
1 ½-inch	100
¾-inch	55 – 90
No. 4	25 – 50
No. 50	5 – 20
No. 200	3 – 10

If a biaxial geogrid is placed atop the proof-rolled and prepared subgrade, access road thickness may be reduced by two inches. A biaxial geogrid such as Tensar BX1200 or equal is recommended.

Prior to roadway construction, the subgrade should be stripped of vegetation and topsoil, and be proof-rolled with at least four (4) roundtrip passes of a smooth-drum roller with a minimum operating weight of eight (8) tons. The prepared subgrade should be confirmed to maintain a minimum CBR value of 10. If required, additional stabilization may be obtained through chemical treatment of the subgrade including introduction of lime or cement. Crushed stone should be placed in loose lifts not exceeding eight (8) inches in height and be compacted to at least 95 percent of its Modified Proctor Density (ASTM D1557).

9.6 Flooding and Erosion

Using the US Department of Agriculture National Resources Soil Conservation (USDA NRCS) Web Soil Survey, the site geology consists of soils predominately of the Crider, Otwood, and Bedford silt loam units which indicates the frequency of flooding as "rare". However, given presence of fine-grained soils and observed wet conditions at the time of our investigations, it is possible that ponding of water may occur during following significant storm events. ANS Geo understands that the proposed site plan will maintain drainage swales, berms, and/or ditches to intercept and divert such stormwater thus reducing the likelihood of appreciate flooding.

From our review of the site conditions, the project area maintains a "hummocky" topography, however, slopes across the site are generally less than 10 percent. Therefore, we believe the risk of erosion to be low. Based on the site's topography and soil composition, the NRCS Web Soil Survey has listed the predominant soil types as maintaining a generally "moderate" concern for erosion. Notwithstanding, we anticipate that proper housekeeping will be maintained during construction such as limiting the amount of disturbance and earth moving, and compaction and wetting of soils which are exposed for structural and foundation purposes. Therefore, we believe the overall risk of erosion will be minor and will be mostly managed during construction with proper soil erosion and sediment control measures.

9.7 Pile Drivability

ANS Geo anticipates that, as typical with solar farm construction, solar panels will be supported by steel H-Piles (wide-flanged sections) driven to approximately 8 to 10 feet below grade. It is ANS Geo's professional opinion that the parameters provided in **Section 8.3** may be used to preliminarily size the proposed piles, however, we recommend verification load testing prior to construction. These steel piles are typically installed via direct-push, vibration, and/or percussive hammer methods.



10 Limitations

ANS Geo notes that the findings and recommendations presented within this Geotechnical Report are based on our investigation program conducted in February and March, 2021 and our engineering judgment. Should the scope of the project or proposed site layout change, ANS Geo should be given the opportunity to review the applicability of the collected information and modify our recommendations, as needed.

We sincerely appreciate the opportunity to support this project, and please feel free to contact us should you have any questions regarding the findings of this Report.

Attachments

Attachment A – Investigation Location Plan

Attachment B - Soil Boring Logs

Attachment C - Electrical Resistivity Testing Results

Attachment D - Laboratory Results

Attachment E – Pile Load Testing Logs

Attachment F - Seismic Support Data

Attachment G – Geophysical Report (Karst Investigation)


Attachment H - Terracon's Preliminary Geotechnical Engineering Report



Attachment A

Investigation Location Plan






Attachment B

Soil Boring Logs





In-Borehole Water Levels						
Date / Time Casing Bot. of Water Tip (ft) Hole (ft) Lvl (ft)						

20


General Notes


T = Water Level (if observed)


BGS = Below Ground Surface


End of Boring at 20 feet BGS Borehole backfilled with cuttings


Toughness:Low (L), Medium (M), High (H)
Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
PP = Pocket Penetrometer, measured in tons per square ft.
TV = Torvane (Shear Vane), measured in tons per square ft.















In-Borehole Water Levels				General Notes	
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS = Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (chear valie), measured in tone per equale it.




In-Borehole Water Levels				General Notes	
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)		▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity: Non-Plastic (NP), Low (L), Medium (M), High (H)
				bgs = below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (official valie), measured in terio per equare it.
	1				









In-Borehole Water Levels				General Notes	
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity: Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (chear valie), measured in tone per equale it.





In-Borehole Water Levels				General Notes	· · · · ·
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.




In-Borehole	e Water L	evels.		General Notes	
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS = Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (chair valie), measured in tone per equal on.












Soil Boring Log

B-27
(Continued)


Client:ibV EnergyDrilling Firm:Tri-State Drilling, LLCCoordinates:-85.99372222 N, 37.656346 E

Project:Rhudes Creek Solar ProjectDrill Crew:Shannon / BrandonHoriz. Datum:NAD 83Location:Hardin County, KentuckyBoring Start:2/25/2021Elevation:0Inspector:Diego MelgarBoring End:2/25/2021Vert. Datum:Grade

Inspe	ector	: Dieg	o Mel	gar				Boring End:	2/25/2021					Vert	. Dat	tum	:	Grade
Depth (ft)	Sample No. Rec. (in) Blows per 6" N-Value USCS Symbol Graphic Log				A Plasticity PP (tsf)			TV (tsf)		N-Va 20		40	Drilling & Strata Notes					
							Auger I	refusal at 25 feet Boring at 25 feet BGS ble backfilled with cutti	S									-
							Boreho	ole backfilled with cutti	ings									-
-																		-
-																		-
30-																		-30
-																		-
+																		-
-																		-
-																		-
35—																		-35
-																		-
1																		_
-																		-
1																		
40																		-4 0
																		-
1																		
45—																		45
*]																		-
																		-
																		-
																		-
50-														 				- 50
-																		-
-																		-
	In-Borehole Water Levels				evels		Γ	General Notes									L	
	Date / Time Casing Bot. of Water				Bot. of	Water					Toughness:Low (L), Medium (M), High (H)), Medium (M), High (H)				
	2/25/2021 Tip (ft) Hole (ft) Lvl (ft) 2/3				Hole (ft)		BGS = Below Grou	ind Surface					Plast PP = TV =	ficity: Pock Torva	:Non et Pe ane (-Plas enetro Shea), Medium (M), High (H) stic (NP), Low (L), Medium (M), High (H) ometer, measured in tons per square ft. ar Vane), measured in tons per square ft.	
													`		, i i i i i i i i i i i i i i i i i i i			



- [In-Borehole	Water L	.evels		General Notes	
ı	Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (I
					BG3 - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square TV = Torvane (Shear Vane), measured in tons per square
-						To valie (effectivenes), measured in tone per square
1						
-						






Soil Boring Log


B-29 (Continued)

 Client:
 ibV Energy
 Drilling Firm:
 Tri-State Drilling, LLC
 Coordinates:
 -86.00381111 N, 37.657351 E


Project:Rhudes Creek Solar ProjectDrill Crew:Shannon / BrandonHoriz. Datum:NAD 83Location:Hardin County, KentuckyBoring Start:2/26/2021Elevation:0Inspector:Diego MelgarBoring End:2/26/2021Vert. Datum:Grade

		. Dieg	o Mel	gar				Boring En	d: 2/26/2021						Ver	t. Da	tum:		Grade
Sample No. Rec. (in) Blows per 6" N-Value USCS Symbol		Visual Classification			Toughness	Plasticity	PP (tsf)	TV (tsf)	10	N-Va 20		10	Drilling & Strata Notes						
-																			
$\frac{1}{2}$																			-
$\frac{1}{2}$							Auger r End of	refusal at 27.5 fee Boring at 27.5 fee le backfilled with	et et BGS										-
-							Boreho	le backfilled with	cuttings										-
																			-3 0
																			-
$\frac{1}{4}$																			-
$\frac{1}{2}$																			-
5-																			- 35
1																			-
																			_
																			-
0-																			- 40
+																			_
-																			-
5—																			- 45
-																			-
$\frac{1}{2}$																			-
+																			-
0-																			- 50
																			-
-																			-
		In-E	Boreh	ole Wa					General N	lotes									
	Date / Time Casing Bot. of Water Tip (ft) Hole (ft) Lvl (ft)			Water	▼ = Water Level (if observed) BGS = Below Ground Surface						Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H) PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.								







In-Borehole	e Water L	evels.		General Notes	
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity: Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (chear valie), measured in tone per equale it.




In-Borehol	e Water L	evels	General Notes		
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface		Toughness:Low (L), Medium (M), High (H) Plasticity: Non-Plastic (NP), Low (L), Medium (M), High (H)
			BGS - Below Ground Surface		PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.






L						
	In-Borehole	e Water L	.evels		General Notes	
	Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity: Non-Plastic (NP), Low (L), Medium (M), High (H)
					BGS - Delow Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
ļ						
ı						
Į						



In-Borehol	e Water L	.evels		General Notes	•
Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	Water Lvl (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To remain (eneal valle), measures in tene per equal on



	In-Borehole	e Water L	evels	General Notes	
	Date / Time	Casing Tip (ft)	Bot. of Hole (ft)	▼ = Water Level (if observed) BGS = Below Ground Surface	Toughness:Low (L), Medium (M), High (H) Plasticity:Non-Plastic (NP), Low (L), Medium (M), High (H)
				BGS - Below Ground Surface	PP = Pocket Penetrometer, measured in tons per square ft. TV = Torvane (Shear Vane), measured in tons per square ft.
					To valie (chair valie), measured in tone per square it.
L					



Core Boring Log

B-36

Client: ibV Energy Drilling Firm: Tri-State Drilling, LLC Coordinates: -86.00394647 N, 37.66466711 E


Rhudes Creek Solar Project Horiz. Datum: Project: **Drill Crew:** Shannon / Brandon NAD 83 2/27/2021 Elevation: Location: Hardin County, Kentucky **Boring Start:** 0 Boring End: 2/27/2021 Vert. Datum: Inspector: Diego Melgar Grade


 Rig Model:
 CME-55
 Casing Type:
 Core Barrel Type:
 Core Bit Type:
 Imp. Diamond


 Rig Type:
 Track
 Casing Length:
 4 feet
 Core Barrel Length:
 5 feet
 Core Bit Length:
 6 inches


Drill Method: Hollow Stem Auger | Casing I.D.: 4 inches | Core Barrel I.D.: | Core Bit I.D.:

Drill Method: Hollow Stem Auger		r	Casing I.D.: 4 inches Core Barrel I.D.:			Core Bit I.D.:							I.D.:				
	e /ft)	١.	λ.		s	βu				t.)		Dis		tinui	ties		
Depth (ft)	Avg Core Rate (min/ft)	Run No.	Recovery (in. / %)	RQD (in. / %)	Hardness	Weathering	Graphic Log	Visual Classification	on	Depth (ft.)	Туре	Dip Angle	Roughness	Weathering	Aperture	Infilling	Drilling & Strata Notes
-	2.0							LIMESTONE, gray, fine grained, weathered, weak, moderate to w discontinuities	slightly videly spaced	21	J	10		DE	vw	N	
-	2.3																Apparent dissolution or cavity from 21.5 to 22 feet BGS.
-	2.3	R-1	60 100%	46 77%	R2	SL				23.4	J	10	P,Sm	DG	vw	CL	
-	2.8																
25—	3.4							End of boring at 25.5 feet BGS.									
-								Borehole backfilled with bentonit soil cuttings.	e holeplug and								
30-																	
35— -																	
-																	
40-																	
	I	n-Bor	ehole							Gen	eral	Note	es				
	Date / 1	Γime		Casir Tip (f	ig E t) H	Bot. of lole (ft)	Water Lvl (ft)	▼ = Water Level (if observed)	BGS = Belo	ow Gro	und :	Surfa	ice				
					\perp												











Soil Boring Log

B-SS-2

Client:ibV EnergyDrilling Firm:Tri-State Drilling, LLCCoordinates:-86.00446277 N, 37.66147358 E

 Project:
 Rhudes Creek Solar Project
 Drill Crew:
 Shannon / Brandon
 Horiz, Datum:
 NAD 83

 Location:
 Hardin County, Kentucky
 Boring Start:
 2/27/2021
 Elevation:
 0

 Inspector:
 Diego Melgar
 Project Fig. 1
 2/27/2021
 Vert Datum:
 Grade

Inspector: Diego Melgar					Ve	Vert. Datum:				Grade		
Depth (ft) Sample No. Rec. (in) Blows per 6"	USCS Symbol Graphic Log	Visual Classification	Toughness	Plasticity	PP (tsf)	TV (tsf)	1	N -	- Valu 0 3		0	Drilling & Strata Notes
- S-9 24 2 30	Soft	t, brown, CLAY, some Silt, wet (CH)	L	М	.5	1.9					-	- - - -30
- - 35— - -	Aug End Bore	jer refusal at 34.5 feet l of Boring at 34.5 feet BGS ehole backfilled with cuttings										- 35 -
40												- - -40 -
45—												- -45 -
50												- 50
In-Borehole	Water Levels	General Notes										
Date / Time	Casing Bot. of Wate Tip (ft) Hole (ft) Lvl (ft	BGS = Below Ground Surface					To Pla	ughr	ness ity: N	:Low	v (L), Plast	, Medium (M), High (H) ic (NP), Low (L), Medium (M), High (H) meter, measured in tons per square ft.
2/27/2021	13						۲۷ 	= Po	orvan	e (S	ietro hear	meter, measured in tons per square ft. Vane), measured in tons per square ft.

Attachment C

Electrical Resistivity Testing Results





Soil Resistivity Results

Client:	ibV Energy	Date:	2/9/2021 - 2/10/2021
Project Name:	Rhudes Creek Solar Project	Weather:	Sunny
Project Location:	Hardin County, Kentucky	Temperature:	55° F
Equipment:		AGI MiniSting	
Test Method:	Wen	ner 4 Electrode Array	_


Λ		Data	Array spacing (ft)											
Arr	ау	Data	2	5	10	25	50	100	150					
	N-S	Measured Resistance (Ω)	38.22	16.26	8.67	2.08	0.82	-	-					
ER-07	IN-3	Apparent Resistivity (Ω-ft)	480	511	545	327	256	-	-					
EK-U/	E-W	Measured Resistance (Ω)	36.89	16.97	8.12	2.25	1.00	·	1					
	L-VV	Apparent Resistivity (Ω-ft)	464	533	510	354	314	ı	ı					
	N-S	Measured Resistance (Ω)	55.58	22.15	9.30	4.03	1.01	·	1					
ER-08	14-3	Apparent Resistivity (Ω-ft)	698	696	584	632	316	-	-					
EN-00	E-W	Measured Resistance (Ω)	52.34	21.34	8.57	4.91	0.98	-	-					
	E-VV	Apparent Resistivity (Ω-ft)	658	670	538	771	308	=	1					
	N-S	Measured Resistance (Ω)	52.34	22.76	12.50	2.70	1.01	-	-					
ER-09	IN-3	Apparent Resistivity (Ω-ft)	658	715	785	425	318	-	-					
EK-09	E-W	Measured Resistance (Ω)	51.73	31.89	10.02	2.52	1.02	-	-					
	E-VV	Apparent Resistivity (Ω-ft)	650	1,002	630	396	319	-	-					
	N-S	Measured Resistance (Ω)	32.36	12.09	7.18	2.28	1.19	-	-					
ER-10	IN-S	Apparent Resistivity (Ω-ft)	407	380	451	358	374	-	-					
EK-10	E 14/	Measured Resistance (Ω)	33.58	12.50	7.07	2.07	0.93	-	-					
	E-W	Apparent Resistivity (Ω-ft)	422	393	444	326	293	-	-					
	N-S	Measured Resistance (Ω)	41.98	29.54	10.12	3.29	1.61	-	-					
ED 11	IN-S	Apparent Resistivity (Ω-ft)	528	928	636	517	505	-	-					
ER-11	E 14/	Measured Resistance (Ω)	40.66	18.39	10.15	3.46	1.44	-	-					
	E-W	Apparent Resistivity (Ω-ft)	511	578	638	543	453	-	-					
	N. C	Measured Resistance (Ω)	58.24	21.24	6.71	1.27	0.67	-	-					
ED 43	N-S	Apparent Resistivity (Ω-ft)	732	667	421	199	210	-	-					
ER-12	E 14/	Measured Resistance (Ω)	57.53	20.63	7.39	1.81	0.99	-	-					
	E-W	Apparent Resistivity (Ω-ft)	723	648	464	284	311	-	-					
	N.C	Measured Resistance (Ω)	21.75	4.94	4.48	0.69	0.66	0.84	1.40					
ED CC 4	N-S	Apparent Resistivity (Ω-ft)	273	155	282	108	208	526	1,321					
ER-SS-1	E \A/	Measured Resistance (Ω)	24.84	5.81	3.51	2.97	1.89	1.88	1.38					
	E-W	Apparent Resistivity (Ω-ft)	312	182	220	466	593	1,180	1,299					
		Site Average (Ω)	42.72	18.32	8.13	2.59	1.09	1.36	1.39					
		Site Average (Ω-ft)	537	576	511	407	341	853	1,310					

Attachment D

Laboratory Results



SIEVE ANALYSIS RESULTS



GRAIN SIZE - mm. % Gravel % Sand % Fines % +3" Coarse Fine Coarse Medium Fine Silt Clay 0.0 0.0 0.0 0.0 7.0 63.2 29.8

SIEVE	PERCENT	SPEC.*	PASS?
SIZE	FINER	PERCENT	(X=NO)
#16	100.0		
#30	98.4		
#50	82.0		
#100	48.5		
#200	29.8		
* /	.10" (1 14		

	Material Description	on
silty sand		
	A. 1 = 1 - 1	
PL= NP	Atterberg Limits LL= NV	PI= NP
D ₉₀ = 0.3778 D ₅₀ = 0.1553 D ₁₀ =	Coefficients D ₈₅ = 0.3240 D ₃₀ = 0.0756 C _u =	D ₆₀ = 0.1916 D ₁₅ = C _c =
USCS= SM	Classification AASHT	O= A-2-4(0)
In-Situ %MC=11. F.M.=0.71	Remarks 1	

(no specification provided)

Location: B-15, S-4

Sample Number: S-4 Depth: 6'-8'

Client: ANS GEO, Inc.

Project: ibv Energy - Rhudes creek, Cecilia, KY


South Plainfield, New Jersey

ANS CONSULTANTS, INC.

Project No: AOS-5632

Figure 4 F 1

Date:



GRAIN SIZE - IIIII.							
% +3"	% Gr	ravel	% Sand % Fines		3		
/6 +3	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	5.1	75.3	19.6	

PERCENT	SPEC.*	PASS?
FINER	PERCENT	(X=NO)
100.0		
19.6		
	FINER	FINER PERCENT 100.0 97.0 82.8 28.0

silty sand	Material Descriptio	on
PL= NP	Atterberg Limits	PI= NP
D ₉₀ = 0.3487 D ₅₀ = 0.2005 D ₁₀ =	Coefficients D ₈₅ = 0.3118 D ₃₀ = 0.1552 C _u =	D ₆₀ = 0.2242 D ₁₅ = C _c =
USCS= SM	Classification AASHT	O= A-2-4(0)
In-Situ %MC=11. F.M.=0.92	Remarks 9	

(no specification provided)

Location: B-21, S-5, **Sample Number:** S-10

Depth: 8'-10'

Date:

ANS CONSULTANTS, INC.

Client: ANS GEO, Inc.


Project: ibv Energy - Rhudes creek, Cecilia, KY


South Plainfield, New Jersey


Project No: AOS-5632

Figure 10 F 1

ATTERBERG LIMITS RESULTS











Figure 7 F 3

South Plainfield, New Jersey




Location: B-19, S-3 Sample Number: S-8


Depth: 4'-6'


ANS CONSULTANTS, INC.


South Plainfield, New Jersey


Figure 8 F 3
































COMPRESSIVE ROCK STRENGTH RESULTS



Tel: (800) 545-ATUL (908) 754-8383

Fax: (908) 754-8633

NJ EDA Approved Testing Laboratory • MBE/DBE Certified • NJ DEP Certified www.ANSConsultants.net

Soil, Concrete, Masonry, Rebar, Asphalt, Structural Steel, Precast, Piles, Caissons, Fire-proofing, Roofing, Soil Boring, Concrete/Rock Coring, UST Removal, Environmental Testing & Reports

CLIENT:

ANS GEO, Inc.

Cecilia, KY

DATE:

03/13/2021

FILE NO.:

AOS-5632

PROJECT:

ibv Energy - Rhudes Creek

REPORT No.: 27

TEST REQUIRED :

Unconfined Compression Strength of intact Rock Core

AS PER ASTM D 2938

DATE RECEIVED:

03/07/2021

DATE TESTED: 03/13/2021

IDENTIFICATION	R-36		
Depth (feet)		2 Thir 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	
Length of Core Drilled (in):	10.000		
Length of Core Prepared (in):	3.8220		
Diameter (in) :	1.9245		
Area (sq. in.):	2.0930		
Ratio H to D :	2.0000		
Correction Factor:	1.0000		
Crushing Load (lbs) :	25,190		
P. S. L. :	8,658		
Corrected P. S. I. :	8,660		ر بر
Density pcf	156.33		***************************************

REMARKS:

- 1. Average compressive strength of one (1) core was 8,660 psi.
- 2. Rock core was conventional weight with density (unit weight) of ± 156.3 lb./ft³.
- 3. Compression testing machine of 500,000 lb. Capacity, manufactured by Test Mark Industries, Sr. No. 10897, Model # CM-5000 EBS (Extended Frame) was utilized for testing core.

THERMAL RESISTIVITY RESULTS



Tel: (800) 545-ATUL (908) 754-8383

Fax: (908) 754-8633

NJ EDA Approved Testing Laboratory • MBE/DBE Certified • NJ DEP Certified www.ANSConsultants.net

Soil, Concrete, Masonry, Rebar, Asphalt, Structural Steel, Precast, Piles, Caissons, Fire-proofing, Roofing, Soil Boring, Concrete/Rock Coring, UST Removal, Environmental Testing & Reports

THERMAL CONDUCTIVITY OF SOIL & SOFT ROCK BY THERMAL NEEDLE PROBE -IEEE 442

CLIENT: ANS Geo, Inc.

4405 South Clinton Avenue, Suite#A

South Plainfield, NJ 07080

DATE: 03/19/2021

FILE NO: AOS-5632

PROJECT: ibV Energy - Rhudes Creek, KY


Cecilia, KY

REPORT NO: S-20

Test Data- Sample No. S-20 (B-15, Thermal-15, 2'- 4')

Standard Proctor Value: 115.3 Remolded Dry Density: 98.005 (85%) Optimum Moisture Content: 10.1% In-Situ Moisture Content: 20.83%

Moisture Content (%)	Initial Soil Temperature (°C)	Thermal Resistivity (°C-cm/W)	
0	26.5	462	
2.5	26.2	232	
5	25.9	136	
7.5	25.7	114	
10.1	25.5	107	



119 [117 10.1%, 115.3 pcf 115 113 111 109 10 15 20 25 Water content, %

Dry density, pcf

Curve No. S-20

Test Specification: ASTM D 698-12 Method B Standard

Hammer Wt.	-	5.5 lb.
nammer wt.		
Hammer Drop		12 in.
Number of Lag	yers	three
Blows per Lay	er	25
Mold Size	0.03	333 cu. ft.
Test Performs Passing	3/8 in	Sieve
NM	_ LL	PI
Sp.G. (ASTM I	-	
%>3/8 in	%<1	No.200
USCS	AASH	ITO
Date Sampled		
Date Tested		

	1	2	3	4	5	6
WM + WS	13.17	13.47	13.72	13.74		
WM	9.43	9.43	9.43	9.43		
WW + T #1	814.0	674.8	631.9	746.3		
WD + T #1	793.6	633.5	561.3	641.9		
TARE #1	0.0	0.0	0.0	0.0		
WW + T #2						
WD + T #2						
TARE #2						
MOISTURE	2.6	6.5	12.6	16.3		
DRY DENSITY	109.7	113.8	114.6	111.2		

TEST RESULTS	Material Description			
Maximum dry density = 115.3 pcf				
Optimum moisture = 10.1 %	Remarks:			
Project No. AOS-5632 Client: ANS GEO, Inc.				
Project: ibv Energy - Rhudes creek, Cecilia, KY				
O Location: TR-15 Depth: 2'-4 Sample Number: S-20	Checked by:			
ANS CONSULTANTS, INC.	Title:			
South Plainfield, New Jersey	Figure 20 F 2			



CONSULTANTS, INC. 4405 South Clinton Avenue South Plainfield, NJ 07080

Tel: (800) 545-ATUL (908) 754-8383

Fax: (908) 754-8633

NJ EDA Approved Testing Laboratory • MBE/DBE Certified • NJ DEP Certified www.ANSConsultants.net

Soil, Concrete, Masonry, Rebar, Asphalt, Structural Steel, Precast, Piles, Caissons, Fire-proofing, Roofing, Soil Boring, Concrete/Rock Coring, UST Removal, Environmental Testing & Reports

THERMAL CONDUCTIVITY OF SOIL & SOFT ROCK BY THERMAL NEEDLE PROBE -IEEE 442

CLIENT: ANS Geo, Inc.

4405 South Clinton Avenue, Suite#A

South Plainfield, NJ 07080

DATE: 03-19-2021

FILE NO: AOS-5632

PROJECT: ibV Energy – Rhudes Creek, KY


Cecilia, KY


REPORT NO: S-21

Test Data- Sample No. S-21 (B-31, Thermal-31, 2'-4')

Standard Proctor Value: 110.2 Remolded Dry Density: 93.67 (85%) Optimum Moisture Content: 14.6% In-Situ Moisture Content: 20.83%

Moisture Content (%)	Initial Soil Temperature (°C)	Thermal Resistivity (°C-cm/W)	
0	26.4	647	
3.75	26	248	
7.5	25.7	112	
11.25	25.6	85	
14.6	25.5	77	





Dry density, pcf

Curve No. S-21

Test Specification: ASTM D 698-12 Method B Standard

Preparation Metho	od			
Hammer Wt.	5.5	5.5 lb.		
Hammer Drop	1.	2 in.		
Number of Layers	i	three		
Blows per Layer		25		
Mold Size	0.03333	cu. ft.		
Passing L	L	Sieve Pl		
Sp.G. (ASTM D 85	4)			
%>3/8 in	% <no.2< th=""><th>.00</th></no.2<>	.00		
USCS	AASHTO			
Date Sampled				
Date Campica				
Date Tested				

	1	2	3	4	5	6
WM + WS	13.08	13.46	13.71	13.84	7=	
WM	9.43	9.43	9.43	9.43		
WW + T #1	615.9	704.1	842.2	855.6		
WD + T #1	593.4	637.2	719.5	693.4		
TARE #1	0.0	0.0	0.0	0.0		
WW + T #2						
WD + T #2						
TARE #2						
MOISTURE	3.8	10.5	17.1	23.4		
DRY DENSITY	105.7	109.4	109.9	107.3		

TEST RESULTS	Material Description
Maximum dry density = 110.2 pcf	
Optimum moisture = 14.6 %	Remarks:
Project No. AOS-5632 Client: ANS GEO, Inc.	
Project: ibv Energy - Rhudes creek, Cecilia, KY	
○ Location: TR-31 Depth: 2'-4' Sample Number: S-21	Checked by:
ANS CONSULTANTS, INC.	Title:
South Plainfield, New Jersey	Figure 21 F 2



CONSULTANTS, INC. 4405 South Clinton Avenue South Plainfield, NJ 07080

Tel: (800) 545-ATUL (908) 754-8383

Fax: (908) 754-8633

NJ EDA Approved Testing Laboratory • MBE/DBE Certified • NJ DEP Certified www.ANSConsultants.net

Soil, Concrete, Masonry, Rebar, Asphalt, Structural Steel, Precast, Piles, Caissons, Fire-proofing, Roofing, Soil Boring, Concrete/Rock Coring, UST Removal, Environmental Testing & Reports

THERMAL CONDUCTIVITY OF SOIL & SOFT ROCK BY THERMAL NEEDLE PROBE -IEEE 442

CLIENT: ANS Geo, Inc.

4405 South Clinton Avenue, Suite#A

South Plainfield, NJ 07080

DATE: 03-19-2021

FILE NO: AOS-5632

PROJECT: ibV Energy - Rhudes Creek, KY


Cecilia, KY


REPORT NO: S-22

Test Data - Sample No. S-22 (B-SS-2, Thermal-SS-2, 2'- 4')

Standard Proctor Value: 103.4 Remolded Dry Density: 87.89 (85%) Optimum Moisture Content: 14.2% In-Situ Moisture Content: 23.5 %

Moisture Content (%)	Initial Soil Temperature (°C)	Thermal Resistivity (°C-cm/W)	
0	26.7	669	
3.75	26.3	301	
7.5	26	204	
11.25	25.8	182	
14.2	25.6	170	





Curve No. S-22

Test Specification:

ASTM D 698-12 Method B Standard

Preparation M	ethod			
Hammer Wt.		5.5 lb.		
Hammer Drop		12	in.	
Number of Lag	yers		three	
Blows per Layer			25	
Mold Size				
Test Performe	ed on Ma	terial		
Passing	3/8	3/8 in. Sieve		
NM	LL		PI	
Sp.G. (ASTM	D 854)			
%>3/8 in.	9/	% <no.20< td=""><td>00</td></no.20<>	00	
USCS	AA	SHTO		
Date Sampled				
Date Tested				
Tested By				

	1	2	3	4	5	6
WM + WS	12.90	13.21	13.43	13.49		
WM	9.43	9.43	9.43	9.43		
WW + T #1	633.0	703.6	618.5	930.2		
WD + T #1	599.3	634.9	529.7	762.9		
TARE #1	0.0	0.0	0.0	0.0		
WW + T #2						
WD + T #2						
TARE #2						
MOISTURE	5.6	10.8	16.8	21.9		
DRY DENSITY	98.6	102.6	103.0	100.1		

TEST RESULTS	Material Description
Maximum dry density = 103.4 pcf	
Optimum moisture = 14.2 %	Remarks:
Project No. AOS-5632 Client: ANS GEO, Inc.	
Project: ibv Energy - Rhudes creek, Cecilia, KY	
O Location: TR-SS-2 Depth: 2'-4' Sample Number: S-22	Checked by:
ANS CONSULTANTS, INC.	Title:
South Plainfield, New Jersey	Figure 22 F 2

CORROSIVITY SUITE RESULTS

Tel: (800) 545-ATUL (908) 754-8383

Fax: (908) 754-8633

NJ EDA Approved Testing Laboratory • MBE/DBE Certified • NJ DEP Certified www.ANSConsultants.net

Soil, Concrete, Masonry, Rebar, Asphalt, Structural Steel, Precast, Piles, Caissons, Fire-proofing, Roofing, Soil Boring, Concrete/Rock Coring, UST Removal, Environmental Testing & Reports

CERTIFICATE OF TEST - CORROSION ANALYSIS

CLIENT: ANS Geo, Inc.

4405 South Clinton Avenue South Plainfield, NJ 07080 DATE: 03/23/2021

FILE NO: AOS-5632

PROJECT: ibV Energy – Rhudes Creek, KY

Cecilia, KY

REPORT NO: S-26

TEST PERFORMED: 1) Standard Test Method for Water Soluble Sulfate in Soil AS PER ASTM C-1580

2) Standard Test Method for measuring pH of Soil for use in Corrosion Testing AS PER ASTM G51-18


3) Standard Test Method for Measurement of Oxidation-Reduction Potential (ORP) of Soil AS PER ASTM G-200


4) Standard Method for Test for Determining Water Soluble Chloride Ion AS PER AASHTO T-291

5) Standard Test Method for Measuring Soil Resistivity using two-Electrode AS PER ASTM G187-18

Sample No.	Sample ID	Sulfate (mg/Kg)	рН	ORP (mV)	Chloride (mg/Kg)	Resistivity (Ohm-cm)
S-26	CRT-SS, CRT-SS, 0'- 3'	21	6.74	+125	45	10,000
S-28	CRT-14, CRT-14, 0'- 3'	17	6.94	+121	40	7,000
S-29	CRT-20, CRT-20, 0'- 3'	25	6.88	+129	50	9,000
S-30	CRT-23, CRT-23, 0'- 3'	14	7.01	+117	35	8,000
S-31	CRT-32, CRT-32, 0'- 3'	27	6.88	+135	50	9,500

CALIFORNIA BEARING RATIO RESULTS





Dry density, pcf

Curve No. S-24


Test Specification:

ASTM D 698-12 Method B Standard

Preparation Meth	od
Hammer Wt.	5.5 lb.
Hammer Drop	12 in.
Number of Layers	s three
Blows per Layer	25
Mold Size	0.03333 cu. ft.
Test Performed o Passing	3/8 in. Siev e
	l Di
	.L PI 54)
Sp.G. (ASTM D 88 %>3/8 in.	1,570.0
Sp.G. (ASTM D 88 %>3/8 in.	% <no.200< th=""></no.200<>
Sp.G. (ASTM D 85 %>3/8 in. USCS	% <no.200< th=""></no.200<>

	1	2	3	4	5	6
WM + WS	13.29	13.68	13.93	14.01		
WM	9.43	9.43	9.43	9.43		
WW + T #1	613.4	749.2	748.3	875.7		
WD + T #1	591.3	681.9	645.5	721.5		
TARE #1	0.0	0.0	0.0	0.0		
WW + T #2						
WD + T #2						
TARE #2						
MOISTURE	3.7	9.9	15.9	21.4		
DRY DENSITY	111.9	116.1	116.6	113.3		

TEST RESULTS	Material Description
Maximum dry density = 117.0 pcf	
Optimum moisture = 13.6 %	Remarks:
Project No. AOS-5632 Client: ANS GEO, Inc.	
Project: ibv Energy - Rhudes creek, Cecilia, KY	
○ Location: CBR-21 Depth: 0'-2' Sample Number: S	-24 Checked by:
ANS CONSULTANTS, INC.	Title:
South Plainfield, New Jersey	Figure 24 F 2



ANS CONSULTANTS, INC.

Figure 25 F 4

113.5 [14,7%, 112.2 pcf 112 110.5 109 107.5 106 10 15 20 25 Water content, %

Dry density, pcf


Curve No. S-25

Test Specification: ASTM D 698-12 Method B Standard

Preparation Met		
Hammer Wt.	5	.5 lb.
Hammer Drop		12 in.
Number of Layer	rs	three
Blows per Layer		25
Mold Size	0.0333	3 cu. ft.
Test Performed	on Material	
Passing	3/8 in.	Sieve
NM	LL	PI
Sp.G. (ASTM D 8	54)	
%>3/8 in	% <no.< td=""><td>200</td></no.<>	200
USCS	AASHTO	o
		()
Date Sampled		
Date Sampled Date Tested		

1.00							
	1	2	3	4	5	6	
WM + WS	13.14	13.52	13.79	13.87			
WM	9.43	9.43	9.43	9.43			
WW + T #1	696.5	818.8	744.0	963.0			
WD + T #1	671.4	741.2	635.0	785.3			
TARE #1	0.0	0.0	0.0	0.0			
WW + T #2							
WD + T #2							
TARE #2							
MOISTURE	3.7	10.5	17.2	22.6			
DRY DENSITY	107.4	111.3	111.8	108.7			

TEST RESULTS	Material Description
Maximum dry density = 112.2 pcf	
Optimum moisture = 14.7 %	Remarks:
Project No. AOS-5632 Client: ANS GEO, Inc.	
Project: ibv Energy - Rhudes creek, Cecilia, KY	
○ Location: CBR-38 Depth: 0'-2' Sample Number: S-25	Checked by:
ANS CONSULTANTS, INC.	Title:
South Plainfield, New Jersey	Figure 25 F 2



103
101
101
99
97
95
0 10 20 30 40 50 60
Water content, %

Dry density, pcf

Curve No. S-23

Test Specification:

ASTM D 698-12 Method B Standard

Preparation Me	thod	
Hammer Wt.		5.5 lb.
Hammer Drop		12 in.
Number of Lay	ers	three
Blows per Laye	er	25
Mold Size	0.03	3333 cu. ft.
Test Performed	d on Mate	rial
Passing	3/8 in	. Sieve
NM	LL	PI
Sp.G. (ASTM D		
%>3/8 in	%<	No.200
USCS	AASI	нто
Date Sampled		
Date Tested _		
Tested By		

	1	2	3	1	E	
			3	4	5	6
WM + WS	12.80	13.27	13.64	13.82		
WM	9.43	9.43	9.43	9.43		
WW + T #1	849.9	714.2	966.5	913.6		
WD + T #1	818.8	632.5	782.7	692.2		
TARE #1	0.0	0.0	0.0	0.0		
WW + T #2						
WD + T #2						
TARE #2						
MOISTURE	3.8	12.9	23.5	32.0		
DRY DENSITY	97.5	102.0	102.5	99.8		

	TEST RES	ULTS	Material Description
Maximum dry density =	= 102.9 pcf		
Optimum moisture = 18	3.9 %	Remarks:	
Project No. AOS-5632	Client: ANS GI		
Project: ibv Energy - Rhudes creek, Cecilia, KY			
○ Location: CBR-SS-1	Depth: 0'-2'	Sample Number: S-23	Checked by:
ANS CONSULTANTS, INC.			Title:
			F: 00 F 0
S	outh Plainfield,	Figure 23 F 2	

Attachment E

Pile Load Testing Logs





Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-1 A
Date/Time Installed:	3/1/2021 15:50	Date/Time Tested:	7:40AM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	17.5	Pile Section	W6x9x15

Embedment Data					
Embedn	nent Data				
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	5.17				
4	12.34				
5	19.54				
6	29.32				
7	28.08				
8	33.43				
9	34.43				
	_				
	_				
Total Time (s) =	157.14				


				me (s			
	0	0	10	20	3	0	40
	1						
	2						
		\					
	3	\vdash					
			\				
£.)	4		$-$ \				
Depth (ft.)				\setminus			
Dep	5			$-$ \			
	6				Δ		
	7						
	,				\	(
						\	
	8					_	
	9						

		Tens	ile Testing								
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)						
1	0	0	0.0000	0.0000	0.0000						
1	250	240	0.0025	0.0020	0.0023						
1	500	500	0.0055	0.0040	0.0048						
1	1000	1100	0.0140	0.0095	0.0118						
1	1500	1520	0.0185	0.0120	0.0153						
1	2000	2000	0.0235	0.0140	0.0188						
1	1500	1520	0.0205	0.0120	0.0163						
1	1000	1020	0.0145	0.0095	0.0120						
1	500	500	0.0080	0.0050	0.0065						
1	250	280	0.0045	0.0030	0.0038						
1	0	0	0.0020	0.0010	0.0015						
		Target [Deflection (in.)								
1	0.5		-	-	-						
1	0.75		-	-	-						
1	1	-	-	-	-						
	Target Load										
1	10000	10000	0.1095	0.1155	0.1125						
1	0	0	0.0735	0.078	0.0758						
		Late	ral Testing		Lateral Testing						

Lateral Load Height Above Grade (ft):		3	Deflection G (ir		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0805	0.0575	0.0690
1	1000	1000	0.1555	0.1175	0.1365
1	1500	1500	0.2270	0.1780	0.2025
1	0	0	0.0165	0.0295	0.0230
1	500	500	0.0950	0.0920	0.0935
1	1000	1000	0.1685	0.1410	0.1548
1	1500	1500	0.2350	0.1940	0.2145
1	2000	2000	0.3105	0.2580	0.2843
1	2500	2500	0.3950	0.3285	0.3618
1	0	0	0.0275	0.0460	0.0368
1	2500	2500	0.4120	0.3550	0.3835
1	3000	3000	0.4930	0.4135	0.4533
1	3500	3500	0.5885	0.5020	0.5453
1	4000	4000	0.6885	0.6085	0.6485
		Target [Deflection (in.)		
1	0.25	1900	0.2855	0.221	0.2533
1	0.5	3150	0.5345	0.4695	0.5020
1	1	5560	1.0355	0.9820	1.0088
		Tai	rget Load		
1	6000	-	-	-	-
1	0	0	0.1165	0.1265	0.1215

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-1 B
Date/Time Installed:	3/1/2021 16:00	Date/Time Tested:	7:55AM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	=	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	25.1	Pile Section	W6x9x15

Embedmer	Embedment Data						
Depth (ft.)	Time (s)						
0	0						
1	0						
2	0						
3	7.05						
4	15.82						
5	26.24						
6	32.87						
7	42.93						
8	50.18						
9	58.18						
Total Time (s) =	226.22						



		Т	ensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)			
1	0	0	0.0000	0.0000	0.0000			
1	250	280	0.0010	0.0005	0.0008			
1	500	500	0.0020	0.0010	0.0015			
1	1000	1000	0.0035	0.0010	0.0023			
1	1500	1500	0.0050	0.0015	0.0033			
1	2000	2000	0.0065	0.0020	0.0043			
1	1500	1540	0.0055	0.0025	0.0040			
1	1000	1040	0.0035	0.0020	0.0028			
1	500	500	0.0025	0.0010	0.0018			
1	250	260	0.0020	0.0010	0.0015			
1	0	0	0.0010	0.0010	0.0010			
		Targ	et Deflection (in.)					
1	0.5	-		-	-			
1	0.75	-	-	-	-			
1	1	-	-	-	-			
			Target Load					
1	10000	10000	0.0575	0.0675	0.0625			
1	0	0	0.012	0.01	0.0110			
		L	ateral Testing					
	oad Height	3	Deflection Gau	ge Height (in):	4			

Average

Deflection (in.)

0.0000

0.0800

0.1630

0.2333

0.0218

0.1145

0.1805

0.2390

0.3078

0.3855

0.0360

0.4083

0.4993

0.5960

0.7130

0.2568

0.4993

1.0125

0.159

Deflection 2 (in.

0.0000

0.1175

0.2010

0.2780

0.0150

0.1295

0.2120

0.2845

0.3405

0.4260

0.0155

0.4695

0.5395

0.6360

0.7590

0.305

0.5395

1.1235

0.1145


	oad Height Grade (ft):	3	Deflection Gaug
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)
1	0	0	0.0000
1	500	500	0.0425
1	1000	1000	0.1250
1	1500	1500	0.1885
1	0	0	0.0285
1	500	500	0.0995
1	1000	1000	0.1490
1	1500	1500	0.1935
1	2000	2000	0.2750
1	2500	2500	0.3450
1	0	0	0.0565
1	2500	2500	0.3470
1	3000	3000	0.4590
1	3500	3500	0.5560
1	4000	4000	0.6670
		Targ	et Deflection (in.)
1	0.25	1720	0.2085
1	0.5	3000	0.4590
1	1	5180	0.9015
			Target Load
1	6000	-	-
1	0	0	0.2035



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-2 A
Date/Time Installed:	3/1/2021 16:10	Date/Time Tested:	12:15AM 3/6/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	30.3	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	6.25			
4	9.77			
5	18.36			
6	29.53			
7	36.69			
8	52.01			
9	59.59			
Total Time (s) =	205.95			

		Ten	sile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	300	0.0030	0.0040	0.0035
1	500	520	0.0055	0.0065	0.0060
1	1000	1000	0.0100	0.0100	0.0100
1	1500	1500	0.0135	0.0125	0.0130
1	2000	2000	0.0160	0.0155	0.0158
1	1500	1480	0.0140	0.0135	0.0138
1	1000	980	0.0110	0.0110	0.0110
1	500	480	0.0060	0.0070	0.0065
1	250	240	0.0030	0.0045	0.0038
1	0	0	0.0000	0.0100	0.0050
		Target	Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
		Ta	arget Load	•	
1	10000	10000	0.0515	0.0515	0.0515
1	0	0	0.0195	0.023	0.0213
		Late	eral Testing		



Lateral Load Height Above Grade (ft):		1 3 Detlection Gauge Hei		ge Height (in):	4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0780	0.0800	0.0790
1	1000	1000	0.1530	0.1830	0.1680
1	1500	1500	0.2325	0.2810	0.2568
1	0	0	0.0340	0.0420	0.0380
1	500	500	0.1185	0.1380	0.1283
1	1000	1000	0.1815	0.2225	0.2020
1	1500	1500	0.2360	0.2925	0.2643
1	2000	2000	0.3170	0.3825	0.3498
1	2500	2500	0.4000	0.4835	0.4418
1	0	0	0.0490	0.0640	0.0565
1	2500	2500	0.4340	0.5120	0.4730
1	3000	3000	0.5225	0.6165	0.5695
1	3500	3500	0.6220	0.7340	0.6780
1	4000	4000	0.7455	0.8825	0.8140
		Target	Deflection (in.)		
1	0.25	1500	0.2325	0.2810	0.2568
1	0.5	2750	0.4755	0.5585	0.5170
1	1	4500	0.9280	1.0890	1.0085
		Ta	arget Load		
1	6000	-	-	-	-
1	0	0	0.0825	0.109	0.09575

Project: ibV Energy-Rhudes Creek		Pile ID:	PLT-2 B
Date/Time Installed:	3/1/2021 16:10	Date/Time Tested:	3/6/2021 12:30
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	38.6	Pile Section	W6x9x15

Embedmei	
Depth (ft.)	Time (s)
0	0
1	0
2	0
3	8.5
4	13.97
5	24.53
6	34.88
7	47.44
8	66.08
9	75.01
Total Time (s) =	261.91

		Tei	nsile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	280	0.0030	0.0055	0.0043
1	500	500	0.0070	0.0120	0.0095
1	1000	1000	0.0135	0.0235	0.0185
1	1500	1520	0.0180	0.0305	0.0243
1	2000	2040	0.0235	0.0385	0.0310
1	1500	1480	0.0195	0.0345	0.0270
1	1000	1020	0.0140	0.0270	0.0205
1	500	600	0.0085	0.0190	0.0138
1	250	280	0.0040	0.0100	0.0070
1	0	0	0.0010	0.0045	0.0028
		Targe	t Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	=	-	-
Target Load					
1	10000	10000	0.048	0.118	0.0830
1	0	0	0.012	0.018	0.0150


		Lat	teral Testing		
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0910	0.1005	0.0958
1	1000	1000	0.1985	0.1820	0.1903
1	1500	1500	0.3085	0.2740	0.2913
1	0	0	0.0250	0.0310	0.0280
1	500	500	0.1410	0.1320	0.1365
1	1000	1000	0.2355	0.2185	0.2270
1	1500	1500	0.3145	0.2780	0.2963
1	2000	2000	0.4170	0.3690	0.3930
1	2500	2500	0.5250	0.4560	0.4905
1	0	0	0.0480	0.0415	0.0448
1	2500	2500	0.5475	0.4770	0.5123
1	3000	3000	0.6490	0.5635	0.6063
1	3500	3500	0.7500	0.6580	0.7040
1	4000	4000	0.8850	0.7745	0.8298
		Targe	t Deflection (in.)		
1	0.25	1350	0.2745	0.238	0.2563
1	0.5	2520	0.538	0.4695	0.5038
1	1	4500	1.0540	0.9560	1.0050
	•		Farget Load	•	
1	6000		-	-	-
1	0	0	0.086	0.064	0.075



Project: ibV Energy-Rhudes Creek		Pile ID:	PLT-3 A
Date/Time Installed: 3/1/2021 13:30		Date/Time Tested:	11:20AM 3/6/21
Pre-Auger (Y/N)?: N		Pushed to Depth (ft.):	2
Pre-Auger Depth (ft): -		Embedment Depth (ft.):	7
Avg. Installation Rate (sec/ft.): 22.6		Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	10.08				
4	13.32				
5	22.54				
6	31.35				
7	35.71				
Total Time (s) =	102.92				

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	260	0.0000	0.0005	0.0003	
1	500	500	0.0005	0.0015	0.0010	
1	1000	1000	0.0010	0.0025	0.0018	
1	1500	1500	0.0020	0.0040	0.0030	
1	2000	2000	0.0050	0.0050	0.0050	
1	1500	1500	0.0030	0.0035	0.0033	
1	1000	980	0.0025	0.0025	0.0025	
1	500	500	0.0020	0.0020	0.0020	
1	250	260	0.0020	0.0020	0.0020	
1	0	0	0.0015	0.0015	0.0015	
		Target Def	lection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.175	0.145	0.1600	
1	0	0	0.1085	0.0985	0.1035	
	Lateral Testing					
Lateral Lo	ad Height		Deflection	n Gauge		




Lateral Testing					
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.1165	0.0525	0.0845
1	1000	1000	0.1845	0.1490	0.1668
1	1500	1500	0.2530	0.2225	0.2378
1	0	0	0.0280	0.0160	0.0220
1	500	500	0.1155	0.1015	0.1085
1	1000	1000	0.2065	0.1625	0.1845
1	1500	1500	0.2765	0.2220	0.2493
1	2000	2000	0.3390	0.2925	0.3158
1	2500	2500	0.4050	0.3780	0.3915
1	0	0	0.0560	0.0260	0.0410
1	2500	2500	0.4350	0.3810	0.4080
1	3000	3000	0.5050	0.4530	0.4790
1	3500	3500	0.6125	0.5140	0.5633
1	4000	4000	0.6975	0.5970	0.6473
		Target Def	lection (in.)		
1	0.25	1500	0.2765	0.2220	0.2493
1	0.5	3200	0.5365	0.4895	0.5130
1	1	5780	1.1075	0.9365	1.0220
		Targe	t Load		
1	6000	-	-	-	-
1	0	0	0.1495	0.098	0.12375

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-3 B
Date/Time Installed:	3/1/2021 13:40	Date/Time Tested:	11AM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	7
Avg. Installation Rate (sec/ft.):	22.4	Pile Section	W6x9x15

Embedment Data						
Depth (ft.)	Time (s)					
0	0					
1	0					
2	0					
3	6.32					
4	9.99					
5	20.42					
6	32.42					
7	42.86					
Total Time (s) =	105.69					

		Te	nsile Testing			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	240	0.0000	0.0015	0.0008	
1	500	500	0.0010	0.0030	0.0020	
1	1000	1000	0.0025	0.0060	0.0043	
1	1500	1460	0.0040	0.0090	0.0065	
1	2000	2000	0.0050	0.0110	0.0080	
1	1500	1440	0.0040	0.0100	0.0070	
1	1000	960	0.0030	0.0080	0.0055	
1	500	500	0.0010	0.0050	0.0030	
1	250	260	0.0005	0.0035	0.0020	
1	0	0	0.0000	0.0010	0.0005	
		Targe	t Deflection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
	Target Load					
1	10000	10000	0.3085	0.351	0.3298	
1	0	0	0.299	0.3045	0.3018	
	Lateral Testing					
1-4	1					




Lateral Testing					
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0825	0.0580	0.0703
1	1000	1000	0.1610	0.1340	0.1475
1	1500	1500	0.2325	0.1925	0.2125
1	0	0	0.0125	0.0310	0.0218
1	500	500	0.1010	0.0925	0.0968
1	1000	1000	0.1805	0.1470	0.1638
1	1500	1500	0.2450	0.1980	0.2215
1	2000	2000	0.3150	0.2565	0.2858
1	2500	2500	0.3930	0.3250	0.3590
1	0	0	0.0285	0.0530	0.0408
1	2500	2500	0.4105	0.3555	0.3830
1	3000	3000	0.4880	0.4310	0.4595
1	3500	3500	0.5850	0.4985	0.5418
1	4000	4000	0.6750	0.5695	0.6223
		Targe	t Deflection (in.)		
1	0.25	1850	0.2755	0.2285	0.2520
1	0.5	3200	0.5365	0.4585	0.4975
1	1	5700	1.0520	0.9555	1.0038
		1	Target Load		
1	6000	-	-	-	-
1	0	0	0.1435	0.0825	0.113



Project:		ibV Energy-Rhudes Creek	Pile ID:	PLT-4 A
	Date/Time Installed:	3/1/2021 14:00	Date/Time Tested:	10AM 3/6/21
	Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
	Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
	Avg. Installation Rate (sec/ft.):	37.4	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	8.32			
4	19.16			
5	33.88			
6	50.12			
7	53.33			
8	59.72			
_				
Total Time (s) =	216.21			

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	260	0.0015	0.0030	0.0023	
1	500	500	0.0045	0.0065	0.0055	
1	1000	1000	0.0100	0.0140	0.0120	
1	1500	1500	0.0160	0.0220	0.0190	
1	2000	2100	0.0215	0.0300	0.0258	
1	1500	1440	0.0165	0.0245	0.0205	
1	1000	1040	0.0125	0.0185	0.0155	
1	500	520	0.0065	0.0105	0.0085	
1	250	200	0.0020	0.0045	0.0033	
1	0	0	0.0000	0.0015	0.0008	
		Target Defl	ection (in.)			
1	0.5		-	-	-	
1	0.75	-	-	-	-	
1	1	•	-	-	-	
		Target	Load			
1	10000	10000	0.0555	0.084	0.0698	
1	0	0	0.0155	0.0195	0.0175	
	Lateral Testing					
Lateral Load Height Above Deflection Course						




1	U	U	0.0155	0.0195	0.0175
		Lateral '	Testing		
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0570	0.0670	0.0620
1	1000	1000	0.1165	0.1515	0.1340
1	1500	1500	0.1830	0.2040	0.1935
1	0	0	0.0075	0.0265	0.0170
1	500	500	0.0340	0.1290	0.0815
1	1000	1000	0.1355	0.1580	0.1468
1	1500	1500	0.1670	0.2460	0.2065
1	2000	2000	0.2455	0.3025	0.2740
1	2500	2500	0.3040	0.4035	0.3538
1	0	0	0.0215	0.0455	0.0335
1	2500	2500	0.3250	0.4060	0.3655
1	3000	3000	0.3940	0.4900	0.4420
1	3500	3500	0.4875	0.5515	0.5195
1	4000	4000	0.5675	0.6480	0.6078
		Target Defl	ection (in.)		
1	0.25	1850	0.2155	0.2855	0.2505
1	0.5	3400	0.4655	0.5395	0.5025
1	1	5700	0.9705	1.0450	1.0078
		Target	Load		
1	6000	-	-	-	-
1	0	0	0.2755	0.1195	0.1975

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-4 B
Date/Time Installed:	3/1/2021 14:35	Date/Time Tested:	10:15AM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	40.7	Pile Section	W6x9x15

Embedmer	nt Data
Depth (ft.)	Time (s)
0	0
1	0
2	0
3	8.94
4	32.29
5	39.74
6	51.06
7	58.93
8	53.08
Total Time (s) =	235.1
Total Time (s) =	235.1

		Te	nsile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	300	0.0005	0.0005	0.0005
1	500	500	0.0010	0.0040	0.0025
1	1000	1000	0.0030	0.0050	0.0040
1	1500	1500	0.0070	0.0100	0.0085
1	2000	2000	0.0105	0.0150	0.0128
1	1500	1520	0.0095	0.0095	0.0095
1	1000	1000	0.0060	0.0065	0.0063
1	500	540	0.0035	0.0030	0.0033
1	250	240	0.0015	0.0015	0.0015
1	0	0	0.0010	0.0010	0.0010
		Targe	t Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
		1	Target Load		
1	10000	10000	0.092	0.056	0.0740
1	0	0	0.012	0.0105	0.0113
	_	La	teral Testing		
	ad Height Above ade (ft):	3	Deflection Gaug	ge Height (in):	4
COLD TO SERVE				D - (1 1 2	



	Lateral Testing					
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	500	500	0.0685	0.0590	0.0638	
1	1000	1000	0.1590	0.1145	0.1368	
1	1500	1500	0.2035	0.1895	0.1965	
1	0	0	0.0150	0.0105	0.0128	
1	500	500	0.1235	0.0405	0.0820	
1	1000	1000	0.1720	0.1215	0.1468	
1	1500	1500	0.2405	0.1650	0.2028	
1	2000	2000	0.3075	0.2505	0.2790	
1	2500	2500	0.4045	0.3240	0.3643	
1	0	0	0.0360	0.0205	0.0283	
1	2500	2500	0.4090	0.3355	0.3723	
1	3000	3000	0.5195	0.3960	0.4578	
1	3500	3500	0.5510	0.4710	0.5110	
1	4000	4000	0.7060	0.5320	0.6190	
		Targe	t Deflection (in.)			
1	0.25	1750	0.2795	0.228	0.2538	
1	0.5	3400	0.5405	0.4585	0.4995	
1	1	5820	1.1095	0.8950	1.0023	
		1	Target Load			
1	6000		-	-	-	
1	0	0	0.2165	0.119	0.16775	



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-5 A
Date/Time Installed:	3/1/2021 12:30	Date/Time Tested:	3/4/2021 11:00
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	35.8	Pile Section	W6x9x15

Depth (ft.) Time (s) 0 0 1 0 2 1.32 3 5.67 4 17.23 5 28.84 6 43.28	
1 0 2 1.32 3 5.67 4 17.23 5 28.84 6 43.28	
2 1.32 3 5.67 4 17.23 5 28.84 6 43.28	
3 5.67 4 17.23 5 28.84 6 43.28	
4 17.23 5 28.84 6 43.28	
5 28.84 6 43.28	
6 43.28	
7 50.0	
7 58.6	
8 61.05	
Total Time (s) = 209	

		1	1	-	
				Tai	rget Lo
		1	10000	10000	0.
me (s) =	209	1	0	0	0
				Late	ral Te
		Lateral Lo	ad Height	3	D
Time (sec	conds) 60 80	Above G	rade (ft):	3	
20 40		Hold Time (min)	Target Load (lbs)	Load (lbs)	Defl
		1	0	0	
		1	500	500	0
		1	1000	1000	0.
		1	1500	1500	0.
		1	0	0	0
		1	500	540	0.
\backslash		1	1000	1000	0
		1	1500	1580	0
\		1	2000	2000	0.
		1	2500	2500	0.
		1	0	0	0
		1	2500	2500	0
		1	3000	3000	0
		1	3500	3500	0
		1	4000	4000	0.
				Target D	eflect
		1	0.25	1800	0
		1	0.5	2240	0

Tensile Testing						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0	
1	250	340	0	0.001	0.0005	
1	500	500	0.0005	0.001	0.0008	
1	1000	1000	0.0015	0.0015	0.0015	
1	1500	1540	0.0025	0.002	0.0023	
1	2000	2000	0.0025	0.0025	0.0025	
1	1500	-	-	-	-	
1	1000	1140	0.0015	0.0015	0.0015	
1	500	-	-	-	-	
1	250	240	0	0.001	0.0005	
1	0	0	0	0	0	
		Target D	eflection (in.)			
1	0.5	-	-	-	-	
1	0.75	-		-	-	
1	1	-		-	-	
		Tar	get Load			
1	10000	10000	0.0305	0.03	0.0303	
1	0	0	0.011	0.007	0.0090	
Lateral Testing						
Lateral Load Height Deflection Gauge						

ū					
	Lateral Load Height Above Grade (ft):			on Gauge et (in):	4
		 		Deflection 2	********
	Target Load	Load (lbs)			Average
(min)	(lbs)		(in.)	(in.)	Deflection (in.)
1	0	0	0	0	0.0000
1	500	500	0.086	0.046	0.0660
1	1000	1000	0.1715	0.1035	0.1375
1	1500	1500	0.2566	0.164	0.2103
1	0	0	0.019	0.026	0.0225
1	500	540	0.1465	0.0945	0.1205
1	1000	1000	0.204	0.129	0.1665
1	1500	1580	0.277	0.1815	0.2293
1	2000	2000	0.3515	0.2385	0.2950
1	2500	2500	0.4445	0.3165	0.3805
1	0	0	0.031	0.0405	0.0358
1	2500	2500	0.464	0.3345	0.3993
1	3000	3000	0.546	0.411	0.4785
1	3500	3500	0.648	0.511	0.5795
1	4000	4000	0.7505	0.6195	0.6850
		Target D	Deflection (in.)		
1	0.25	1800	0.311	0.2065	0.2588
1	0.5	3240	0.578	0.4385	0.5083
1	1	5440	1.046	0.9825	1.0143
		Tar	rget Load		
1	6000	-	-	-	-
1	0	0	0.065	0.1255	0.09525

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-5 B
Date/Time Installed:	3/1/2021 13:20	Date/Time Tested:	3/4/2021 11:00
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1.75
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	36.7	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	9.02				
4	18.22				
5	31.29				
6	45.25				
7	53.78				
8	62.68				
Total Time (s) =	211.22				

	Time (seconds) 0 50 1	00
0	50 1	1
1		
2		
3		
(£t;)		
Depth (ft.)		
6		
7		
8		
9		

	Tourille Teating						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0	0	0.0000		
1	250	260	0.001	0.002	0.0015		
1	500	520	0.001	0.003	0.0020		
1	1000	1040	0.0015	0.005	0.0033		
1	1500	1500	0.002	0.007	0.0045		
1	2000	2020	0.003	0.009	0.0060		
1	1500	-	-	-	-		
1	1000	1120	0.002	0.0065	0.0043		
1	500	600	0.0015	0.0045	0.0030		
1	250	260	0.001	0.0045	0.0028		
1	0	0	0.0005	0.0025	0.0015		
Target Deflection (in.)							
1	0.5	-	-	-	-		
1	0.75	-	-	-	-		
1	1	-	-	-	-		
	Target Load						
1	10000	10000	0.0325	0.02	0.0263		
1	0	0	0.0115	0.0105	0.0110		
Lateral Testing							
	ad Height	3 Deflection Gauge Height (in): 4		4			

	oad Height rade (ft):	3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0	0	0.0000
1	500	500	0.067	0.069	0.0680
1	1000	1000	0.1405	0.136	0.1383
1	1500	1500	0.219	0.2085	0.2138
1	0	0	0.0106	0.023	0.0168
1	500	540	0.1205	0.119	0.1198
1	1000	1000	0.172	0.164	0.1680
1	1500	1500	0.242	0.227	0.2345
1	2000	2000	0.316	0.297	0.3065
1	2500	2500	0.414	0.3885	0.4013
1	0	0	0.03	0.0305	0.0303
1	2500	2500	0.438	0.408	0.4230
1	3000	3000	0.525	0.4995	0.5123
1	3500	3500	0.631	0.6045	0.6178
1	4000	4000	0.75	0.7195	0.7348
		Tai	rget Deflection (in.)		
1	0.25	1800	0.275	0.258	0.2665
1	0.5	3000	0.525	0.4995	0.5123
1	1	5160	1.0325	1.0005	1.0165
			Target Load	•	
1	6000		-	-	-
1	0	0	0.076	0.108	0.092



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-6 A
Date/Time Installed:	3/1/2021 7:30	Date/Time Tested:	11:20AM 3/5/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	3
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	11
Avg. Installation Rate (sec/ft.):	28.4	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	0				
4	5.11				
5	10.65				
6	35.58				
7	38.06				
8	40.11				
9	41.47				
10	44.55				
11	40.11				
Total Time (s) =	255.64				


0	0	Time (seconds)	60	
2					
4					
Depth (ft.)					
8					
10					
12					

		Tensi	le Testing		
Hold Time	Target Load	Load (lbs)	Deflection 1	Deflection 2	Average
(min)	(lbs)	Loau (IDS)	(in.)	(in.)	Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	260	0.0020	0.0025	0.0023
1	500	540	0.0040	0.0060	0.0050
1	1000	1000	0.0065	0.0110	0.0088
1	1500	1500	0.0095	0.0160	0.0128
1	2000	2000	0.0115	0.0210	0.0163
1	1500	1540	0.0105	0.0185	0.0145
1	1000	1060	0.0075	0.0140	0.0108
1	500	520	0.0035	0.0085	0.0060
1	250	240	0.0010	0.0055	0.0033
1	0	0	0.0000	0.0030	0.0015
		Target D	eflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
Target Load					
1	10000	10000	0.051	0.0565	0.0538
1	0	0	0.0065	0.0105	0.0085
		Later	al Testing		

2010.01.100.00					
	Lateral Load Height		Deflection	•	4
Above G	rade (ft):	3	Height (in):		·
Hold Time	Target Load	Load (lbs)	Deflection 1	Deflection 2	Average
(min)	(lbs)	Load (IDS)	(in.)	(in.)	Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.1345	0.0800	0.1073
1	1000	1000	0.2690	0.1800	0.2245
1	1500	1500	0.4020	0.2895	0.3458
1	0	0	0.0570	0.0465	0.0518
1	500	500	0.2085	0.1395	0.1740
1	1000	1000	0.3245	0.2205	0.2725
1	1500	1500	0.4305	0.3120	0.3713
1	2000	2000	0.5480	0.4160	0.4820
1	2500	2500	0.6660	0.5290	0.5975
1	0	0	0.1160	0.0905	0.1033
1	2500	2500	0.7010	0.5720	0.6365
1	3000	3000	0.8190	0.6920	0.7555
1	3500	3500	0.9575	0.8455	0.9015
1	4000	-	-	-	-
		Target D	eflection (in.)		
1	0.25	1250	0.3075	0.2185	0.2630
1	0.5	2150	0.5815	0.462	0.5218
1	1	3900	1.0565	0.9580	1.0073
		Tar	get Load	,	•
1	6000		-	-	-
1	0	0	0.1855	0.2025	0.194

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-6 B
Date/Time Installed:	3/1/2021 7:40	Date/Time Tested:	3/5/2021 11:35
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	11
Avg. Installation Rate (sec/ft.):	34.4	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	5.85				
4	12.11				
5	32.58				
6	34.12				
7	36.54				
8	40.25				
9	45.96				
10	50.17				
11	52.05				
Total Time (s) =	303.78				



			Tensile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	260	0.0015	0.0030	0.0023
1	500	520	0.0040	0.0060	0.0050
1	1000	1020	0.0070	0.0105	0.0088
1	1500	1500	0.0100	0.0140	0.0120
1	2000	2000	0.0120	0.0175	0.0148
1	1500	1500	0.0095	0.0130	0.0113
1	1000	1000	0.0065	0.0100	0.0083
1	500	560	0.0040	0.0085	0.0063
1	250	260	0.0010	0.0050	0.0030
1	0	0	0.0000	0.0030	0.0015
		Ta	rget Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
			Target Load		
1	10000	10000	0.0115	0.025	0.0183
1	0	0	0.0085	0.0085	0.0085
			Lateral Testing		
	ad Height rade (ft):	-		4	
Hold Time	Target Load		Defication 4 (in)	Deficition 2 (in)	Average

	ad Height rade (ft):	3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (Ibs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.1400	0.0475	0.0938
1	1000	1000	0.2550	0.1140	0.1845
1	1500	1500	0.3610	0.2005	0.2808
1	0	0	0.0515	0.1550	0.1033
1	500	500	0.1900	0.0825	0.1363
1	1000	1000	0.2825	0.1685	0.2255
1	1500	1500	0.3720	0.2600	0.3160
1	2000	2000	0.4680	0.3870	0.4275
1	2500	2500	0.5790	0.4810	0.5300
1	0	0	0.1070	0.0295	0.0683
1	2500	2500	0.6250	0.5110	0.5680
1	3000	3000	0.7380	0.6230	0.6805
1	3500	3500	0.8760	0.8205	0.8483
1	4000	4000	1.0295	0.9355	0.9825
		Ta	rget Deflection (in.)		
1	0.25	1250	0.335	0.1985	0.2668
1	0.5	2250	0.5485	0.4375	0.4930
1	1	4120	1.0825	0.9555	1.0190
			Target Load		
1	6000		-	-	-
1	0	0	0.175	0.0675	0.12125



Project:	Project: ibV Energy-Rhudes Creek		PLT-7 A
Date/Time Installed:	3/1/2021 7:50	Date/Time Tested:	10:25am 3/5/21
Pre-Auger (Y/N)?: N		Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	26.3	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	4.58				
4	12.45				
5	18.75				
6	26.52				
7	30.98				
8	34.88				
9	36.25				
10	45.74				
Total Time (s) =	205.57				
10(01 11116 (3) =	203.37				


	Time	e (seconds	:)	
_				
0	20	40	60	
0				
2				
2				
	\			
	\			
	\			
4	\			
4				
	\			
	\			
÷	\ \			
) (f	\			
pth 9		\		
Depth (ft.)		\		
		1		
		\		
8		1		
8				
		- U		
		\		
40		\ \		
10				
12				
12 -				

	Tensile Testing						
Hold Time	Target Load	Load (lbs)	Deflection 1	Deflection 2	Average		
(min)	(lbs)	LOAG (IDS)	(in.)	(in.)	Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	250	280	0.0030	0.0045	0.0038		
1	500	540	0.0060	0.0085	0.0073		
1	1000	1000	0.0100	0.0150	0.0125		
1	1500	1500	0.0145	0.0215	0.0180		
1	2000	2000	0.0185	0.0275	0.0230		
1	1500	1500	0.0140	0.0215	0.0178		
1	1000	1000	0.0120	0.0190	0.0155		
1	500	540	0.0075	0.0125	0.0100		
1	250	260	0.0040	0.0070	0.0055		
1	0	0	0.0010	0.0030	0.0020		
		Target D	eflection (in.)				
1	0.5	-		-	-		
1	0.75	-		-	-		
1	1	-	-	-	-		
	Target Load						
1	10000	10000	0.038	0.0805	0.0593		
1	0	0	0.0015	0.009	0.0053		
	•	Later	al Testing				

		-0.00			
	Lateral Load Height Above Grade (ft):		Deflection Heigh	_	4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0885	0.0965	0.0925
1	1000	1000	0.1925	0.2030	0.1978
1	1500	1500	0.2930	0.3065	0.2998
1	0	0	0.0085	0.0155	0.0120
1	500	500	0.1085	0.1165	0.1125
1	1000	1000	0.2055	0.2175	0.2115
1	1500	1500	0.2895	0.3030	0.2963
1	2000	2000	0.3895	0.4030	0.3963
1	2500	2500	0.4850	0.5040	0.4945
1	0	0	0.0200	0.0455	0.0328
1	2500	2500	0.5245	0.5455	0.5350
1	3000	3000	0.6250	0.6545	0.6398
1	3500	3500	0.7535	0.7920	0.7728
1	4000	4000	0.9120	0.9630	0.9375
		Target D	eflection (in.)		
1	0.25	1200	0.2455	0.2605	0.2530
1	0.5	2550	0.49	0.515	0.5025
1	1	4180	0.9825	1.0380	1.0103
		Tar	get Load		
1	6000	-	-	-	-
1	0	0	0.0905	0.0108	0.05065

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-7 B
Date/Time Installed:	3/1/2021 7:55	Date/Time Tested:	3/5/2021 10:10
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	3
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	26.1	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	0				
4	5.55				
5	13.67				
6	20.75				
7	30.66				
8	33.81 45.67				
9					
10	58.94				
Total Time (s) =	209.05				



			Tensile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0.0000	0.0000	0.0000
1	250	280	0.0010	0.0020	0.0015
1	500	500	0.0020	0.0045	0.0033
1	1000	1060	0.0035	0.0075	0.0055
1	1500	1520	0.0060	0.0100	0.0080
1	2000	2000	0.0070	0.0120	0.0095
1	1500	1540	0.0065	0.0105	0.0085
1	1000	1000	0.0030	0.0085	0.0058
1	500	520	0.0010	0.0055	0.0033
1	250	260	0.0005	0.0035	0.0020
1	0	0	0.0000	0.0015	0.0008
		Ta	rget Deflection (in.)		
1	0.5		-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
			Target Load		
1	10000	10000	0.0275	0.0215	0.0245
1	0	0	0.0055 0.0045		0.0050
			Lateral Testing		
Lateral Load Height		3	Deflection Gau	ge Height (in):	4


Euteral resting						
	oad Height rade (ft):	3	Deflection Gau	Deflection Gauge Height (in):		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	500	500	0.0565	0.1075	0.0820	
1	1000	1000	0.1375	0.2055	0.1715	
1	1500	1500	0.2280	0.3010	0.2645	
1	0	0	0.0215	0.0085	0.0150	
1	500	500	0.0920	0.1010	0.0965	
1	1000	1000	0.1655	0.1995	0.1825	
1	1500	1500	0.2340	0.2795	0.2568	
1	2000	2000	0.3265	0.3810	0.3538	
1	2500	2500	0.4270	0.4845	0.4558	
1	0	0	0.0530	0.0025	0.0278	
1	2500	2500	0.4675	0.5260	0.4968	
1	3000	3000	0.5775	0.6315	0.6045	
1	3500	3500	0.7045	0.7640	0.7343	
1	4000	4000	0.8840	0.9295	0.9068	
		Tai	rget Deflection (in.)			
1	0.25	1500	0.2340	0.2795	0.2568	
1	0.5	2500	0.4675	0.5260	0.4968	
1	1	4260	0.9645	1.0435	1.0040	
			Target Load			
1	6000		-	-	-	
1	0	0	0.123	0.059	0.091	



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-8 A	
Date/Time Installed:	3/1/2021 7:55	Date/Time Tested:	9:10AM 3/5/21	
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2	
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	11	
Avg. Installation Rate (sec/ft.):	30.2	Pile Section	W6x9x15	

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	6.19			
4	13.54			
5	19.75			
6	25.21			
7	30.05			
8	36.16			
9	44.07			
10	47.05			
11	49.89			
Total Time (s) =	271.91			

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	240	0.0010	0.0010	0.0010	
1	500	500	0.0050	0.0085	0.0068	
1	1000	1000	0.0095	0.0155	0.0125	
1	1500	1500	0.0130	0.0215	0.0173	
1	2000	2000	0.0175	0.0290	0.0233	
1	1500	1300	0.0135	0.0235	0.0185	
1	1000	1000	0.0110	0.0210	0.0160	
1	500	400	0.0040	0.0105	0.0073	
1	250	240	0.0015	0.0080	0.0048	
1	0	0	0.0000	0.0030	0.0015	
		Target Defl	ection (in.)			
1	0.5	-			-	
1	0.75	-	-	٠	-	
1	1	-			-	
	Target Load					
1	10000	10000	0.095	0.112	0.1035	
1	0	0	0.0325	0.0415	0.0370	
	Lateral Testing					
Lateral Loa	nd Height Above	3	Deflectio	n Gauge	4	



1 0		U	0.0323	0.0413	0.0370	
	Lateral Testing					
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.	
1	0	0	0.0000	0.0000	0.0000	
1	500	500	0.0935	0.0570	0.0753	
1	1000	1000	0.1780	0.1245	0.1513	
1	1500	1500	0.2620	0.1865	0.2243	
1	0	0	0.0120	0.0220	0.0170	
1	500	500	0.1390	0.9300	0.5345	
1	1000	1000	0.2095	0.1375	0.1735	
1	1500	1500	0.2785	0.1955	0.2370	
1	2000	2000	0.3575	0.2615	0.3095	
1	2500	2500	0.4495	0.3310	0.3903	
1	0	0	0.0280	0.0375	0.0328	
1	2500	2500	0.4845	0.3555	0.4200	
1	3000	3000	0.5740	0.4305	0.5023	
1	3500	3500	0.6970	0.5255	0.6113	
1	4000	4000	0.8160	0.6250	0.7205	
		Target Def	ection (in.)			
1	0.25	1600	0.2915	0.2155	0.2535	
1	0.5	3000	0.5740	0.4305	0.5023	
1	1	5180	1.1455	0.8725	1.0090	
		Targe	t Load			
1	6000		-	-	-	
1	0	0	0.0785	0.108	0.09325	

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-8 B
Date/Time Installed:	3/1/2021 7:55	Date/Time Tested:	9:20AM 3/5/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	11
Avg. Installation Rate (sec/ft.):	29.6	Pile Section	W6x9x15

Embedment Data			
Depth (ft.)	Time (s)		
0	0		
1	0		
2	0		
3	7.68		
4	17.31		
5	24.08		
6	26.7		
7	32.65		
8	35.03		
9	36.92		
10	40.83		
11	44.94		
Total Time (s) =	266.14		

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	300	0.0025	0.0030	0.0028	
1	500	500	0.0035	0.0045	0.0040	
1	1000	1000	0.0050	0.0085	0.0068	
1	1500	1500	0.0085	0.0115	0.0100	
1	2000	2000	0.0115	0.0150	0.0133	
1	1500	1440	0.0080	0.0130	0.0105	
1	1000	980	0.0055	0.0105	0.0080	
1	500	580	0.0030	0.0080	0.0055	
1	250	260	0.0020	0.0050	0.0035	
1	0	0	0.0000	0.0030	0.0015	
		Targe	t Deflection (in.)			
1	0.5		-	-	-	
1	0.75		-	-	-	
1	1	•	-	-	-	
Target Load						
1	10000	10000	0.045	0.094	0.0695	
1	0	0	0.0425	0.0505	0.0465	
	•	Lat	teral Testing		•	
Lateral Load	Height Above					

	0	20	seconds)	60
	0			
	2			
	4			
Depth (ft.)	6	\perp		
De	8			
	10		\setminus	
	12			


	Lateral Testing							
Lateral Load Height Above Grade (ft):		3 Deflection Gauge Height		ge Height (in):	4			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)			
1	0	0	0.0000	0.0000	0.0000			
1	500	500	0.0795	0.0620	0.0708			
1	1000	1000	0.1810	0.1290	0.1550			
1	1500	1500	0.2790	0.2030	0.2410			
1	0	0	0.0160	0.0215	0.0188			
1	500	500	0.1205	0.0960	0.1083			
1	1000	1000	0.2025	0.1525	0.1775			
1	1500	1500	0.2880	0.2170	0.2525			
1	2000	2000	0.3770	0.2875	0.3323			
1	2500	2500	0.3620	0.3620	0.3620			
1	0	0	0.0400	0.0360	0.0380			
1	2500	2500	0.4815	0.3855	0.4335			
1	3000	3000	0.5590	0.4595	0.5093			
1	3500	3500	0.6650	0.5500	0.6075			
1	4000	4000	0.7765	0.6455	0.7110			
		Targe	t Deflection (in.)					
1	0.25	1500	0.2880	0.2170	0.2525			
1	0.5	3000	0.5590	0.4595	0.5093			
1	1	5560	1.1000	0.9005	1.0003			
	•		Target Load		•			
1	6000	-	-	-	-			
1	0	0	0.0935	0.121	0.10725			



	Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-9 A
Date/Time Installed: Pre-Auger (Y/N)?:		3/1/2021 10:10	Date/Time Tested:	3/5/2021 7:50
		N	Pushed to Depth (ft.):	2
	Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
	Avg. Installation Rate (sec/ft.):	22.2	Pile Section	W6x9x15

Embedn	nent Data
Depth (ft.)	Time (s)
0	0
1	0
2	0
3	2.9
4	7.53
5	18.43
6	28.1
7	36.47
8	39.59
Total Time (s) =	130.12

Tensile Testing						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	300	0.0025	0.0055	0.0040	
1	500	500	0.0045	0.0085	0.0065	
1	1000	1000	0.0105	0.0155	0.0130	
1	1500	1500	0.0160	0.0215	0.0188	
1	2000	2000	0.0205	0.0275	0.0240	
1	1500	1500	0.0175	0.0250	0.0213	
1	1000	1000	0.0120	0.0200	0.0160	
1	500	500	0.0060	0.0140	0.0100	
1	250	240	0.0015	0.0105	0.0060	
1	0	0	0.0000	0.0030	0.0015	
		Target Defl	ection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.1085	0.1095	0.1090	
1	0	0	0.0305	0.042	0.0363	
		Lateral	Testing			




Lateral Testing						
Lateral Load Height Above Grade (ft):		3		Deflection Gauge Height (in):		
Hold Time	Target Load	Load (lbs)	Deflection 1		Average	
(min)	(lbs)	Lodd (103)	(in.)	(in.)	Deflection (in.)	
1	0	0	0.0000	0.0000		
1	500	500	0.0875	0.0895	0.0885	
1	1000	1000	0.1640	0.1840	0.1740	
1	1500	1500	0.2355	0.2800	0.2578	
1	0	0	0.0485	0.0510	0.0498	
1	500	500	0.1215	0.1515	0.1365	
1	1000	1000	0.1555	0.2400	0.1978	
1	1500	1500	0.2640	0.3175	0.2908	
1	2000	2000	0.3360	0.3995	0.3678	
1	2500	2500	0.4135	0.4920	0.4528	
1	0	0	0.0345	0.0445	0.0395	
1	2500	2500	0.4325	0.5128	0.4727	
1	3000	3000	0.5120	0.6065	0.5593	
1	3500	3500	0.6055	0.7088	0.6571	
1	4000	4000	0.7010	0.8135	0.7573	
		Target Defl	ection (in.)			
1	0.25	1500	0.2355	0.2800	0.2578	
1	0.5	2760	0.471	0.548	0.5095	
1	1	5040	0.9400 1.0685		1.0043	
		Targe	t Load			
1	6000	-	-	-	-	
1	0	0	0.1435	,1195	0.1435	

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-9 B
Date/Time Installed:	3/1/2021 10:15	Date/Time Tested:	3/5/2021 8:10
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	25.3	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	7.14			
4	12.37			
5	25.39			
6	34.07			
7	34.36			
8	38.44			
Total Time (s) =	144.63			

Tensile Testing							
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	250	260	0.0010	0.0020	0.0015		
1	500	500	0.0010	0.0040	0.0025		
1	1000	1000	0.0035	0.0080	0.0058		
1	1500	1500	0.0050	0.0105	0.0078		
1	2000	2000	0.0065	0.0135	0.0100		
1	1500	1560	0.0055	0.0120	0.0088		
1	1000	1080	0.0035	0.0105	0.0070		
1	500	560	0.0010	0.0070	0.0040		
1	250	260	0.0005	0.0050	0.0028		
1	0	0	0.0000	0.0030	0.0015		
		Targ	et Deflection (in.)				
1	0.5	-	-	-	-		
1	0.75	-	-	-	-		
1	1	-	-	-	-		
Target Load							
1	10000	10000	0.0715	0.091	0.0813		
1	0	0	0.068	0.0695	0.0688		
		L	ateral Testing				




Lateral Testing						
	Lateral Load Height Above Grade (ft):		Deflection Gaug	e Height (in):	4	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	500	500	0.0815	0.0550	0.0683	
1	1000	1000	0.1590	0.1240	0.1415	
1	1500	1500	0.2270	0.1910	0.2090	
1	0	0	0.0060	0.0505	0.0283	
1	500	500	0.0935	0.1080	0.1008	
1	1000	1000	0.1740	0.1635	0.1688	
1	1500	1500	0.2465	0.2215	0.2340	
1	2000	2000	0.3190	0.2860	0.3025	
1	2500	2500	0.3930	0.3625	0.3778	
1	0	0	0.0140	0.0525	0.0333	
1	2500	2500	0.4065	0.3810	0.3938	
1	3000	3000	0.4875	0.4550	0.4713	
1	3500	3500	0.5750	0.5450	0.5600	
1	4000	4000	0.6650	0.6360	0.6505	
		Targ	et Deflection (in.)			
1	0.25	1800	0.278	0.234	0.2560	
1	0.5	3280	0.5125	0.501	0.5068	
1	1	5640	1.0055	1.0185	1.0120	
			Target Load			
1	6000	-	-	-	-	
1	0	0	0.0245	0.1345	0.0795	



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-10 A
Date/Time Installed:	3/1/2021 9:40	Date/Time Tested:	2:55PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	27.9	Pile Section	W6x9x15

Embedn	nent Data
Depth (ft.)	Time (s)
0	0
1	0
2	0
3	6.11
4	11.77
5	18.64
6	26.85
7	35.94
8	41.62
9	54.67
Total Time (s) =	195.6

Tensile Testing						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	240	0.0035	0.003	0.0033	
1	500	540	0.0055	0.005	0.0053	
1	1000	1000	0.0085	0.0085	0.0085	
1	1500	1520	0.011	0.011	0.0110	
1	2000	2000	0.013	0.013	0.0130	
1	1500	1560	0.0115	0.012	0.0118	
1	1000	980	0.0085	0.01	0.0093	
1	500	500	0.0055	0.0075	0.0065	
1	250	260	0.0025	0.0065	0.0045	
1	0	0	0.0045	0.0045	0.0045	
		Target Defl	ection (in.)			
1	0.5		-	-	-	
1	0.75	-	-	-	-	
1	1		-	-	-	
Target Load						
1	10000	10000	0.0235	0.023	0.0233	
1	0	0	0.012	0.0105	0.0113	
		Lateral	Testing			
Lateral Load Height Above Deflection Gauge				n Gauge		




		Laterai	Testing		
	nd Height Above ade (ft):	3	Deflection Heigh	n Gauge t (in):	4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0685	0.0695	0.0690
1	1000	1020	0.1435	0.144	0.1438
1	1500	1560	0.225	0.2275	0.2263
1	0	0	0.012	0.0325	0.0223
1	500	500	0.077	0.103	0.0900
1	1000	1000	0.162	0.179	0.1705
1	1500	1500	0.2225	0.233	0.2278
1	2000	2000	0.306	0.3165	0.3113
1	2500	2500	0.392	0.3815	0.3868
1	0	0	0.027	0.046	0.0365
1	2500	2540	0.416	0.4085	0.4123
1	3000	3000	0.5165	0.495	0.5058
1	3500	3500	0.6185	0.5865	0.6025
1	4000	4000	0.7555	0.7065	0.7310
		Target Defi	ection (in.)		
1	0.25	1800	0.245	0.255	0.2500
1	0.5	3000	0.5165	0.495	0.5058
1 1		5000	1.0555	0.9585	1.0070
•		Targe	t Load		
1	6000	-	-	-	-
1	0	0	0.0685	0.1185	0.0935

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-10 B
Date/Time Installed:	3/1/2021 9:50	Date/Time Tested:	3:05PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.5
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	29.2	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	1.46			
4	9.17			
5	15.97			
6	27.53			
7	36.48			
8	53.28			
9	60.33			
Total Time (s) =	204.22			

		To	ensile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0	0	0.0000
1	250	300	0.0065	0.005	0.0058
1	500	580	0.012	0.0105	0.0113
1	1000	980	0.0195	0.0105	0.0150
1	1500	1500	0.0275	0.026	0.0268
1	2000	2000	0.0355	0.0325	0.0340
1	1500	1460	0.0305	0.0285	0.0295
1	1000	1000	0.025	0.0235	0.0243
1	500	560	0.016	0.0135	0.0148
1	250	280	0.0105	0.0075	0.0090
1	0	0	0.0035	0.0005	0.0020
		Targ	et Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
			Target Load		
1	10000	10000	0.112	0.0875	0.0998
1	0	0	0.009	0.0005	0.0048
		La	ateral Testing		
Lateral Load Height					




	Lateral Testing						
	Load Height Grade (ft):	3	Deflection Gauge Height (in): 4		4		
Hold Time (min)	Target Load (Ibs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	500	500	0.0575	0.089	0.0733		
1	1000	1020	0.14	0.216	0.1780		
1	1500	1560	0.233	0.32	0.2765		
1	0	0	0.001	0.04	0.0205		
1	500	500	0.062	0.16	0.1110		
1	1000	1000	0.1625	0.262	0.2123		
1	1500	1500	0.2325	0.3395	0.2860		
1	2000	2000	0.3325	0.44	0.3863		
1	2500	2500	0.4335	0.5505	0.4920		
1	0	0	0.029	0.0395	0.0343		
1	2500	2540	0.401	0.42	0.4105		
1	3000	3000	0.515	0.5305	0.5228		
1	3500	3500	0.6165	0.6285	0.6225		
1	4000	4000	0.751	0.7585	0.7548		
		Targ	et Deflection (in.)				
1	0.25	1400	0.2105	0.2885	0.2495		
1	0.5	2550	0.4455	0.5685	0.5070		
1	1	5000	1.013	1.025	1.0190		
			Target Load				
1	6000	-	-	-	-		
1	0	0	0.0785	0.0855	0.082		



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-11 A
Date/Time Installed:	3/1/2021 9:00	Date/Time Tested:	2:10PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	27.9	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	6.11			
4	11.77			
5	18.64			
6	26.85			
7	35.94			
8	41.62			
9	54.67			
Total Time (s) =	189.49			

Tensile Testing						
Hold Time (min)	Target Load (Ibs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	300	0.001	0.0005	0.0008	
1	500	520	0.001	0	0.0005	
1	1000	1000	0.003	0.001	0.0020	
1	1500	1540	0.003	0.0015	0.0023	
1	2000	2100	0.0035	0.0025	0.0030	
1	1500	1480	0.003	0.002	0.0025	
1	1000	820	0.0025	0.001	0.0018	
1	500	480	0.0015	0.001	0.0013	
1	250	260	0.001	0.001	0.0010	
1	0	0	0	0.0005	0.0003	
		Target Defi	ection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
		Targe	t Load			
1	10000	10000	0.035	0.0125	0.0238	
1	0	0	0.0085	0.003	0.0058	
		Lateral	Testing			
Lateral	Load Height	_	Deflection	n Gauge	_	




Lateral Load Height Above Grade (ft):		3	Deflection Heigh	•	4
Hold Time	Target Load	Load (lbs)		Deflection 2	Average
(min)	(lbs)		(in.)	(in.)	Deflection (in.
1	0	0	0	0	0.0000
1	500	500	0.0565	0.1	0.0783
1	1000	1000	0.138	0.189	0.1635
1	1500	1500	0.208	0.2595	0.2338
1	0	0	0.016	0.0235	0.0198
1	500	500	0.084	0.1435	0.1138
1	1000	1000	0.154	0.214	0.1840
1	1500	1500	0.2155	0.273	0.2443
1	2000	2000	0.2895	0.3445	0.3170
1	2500	2500	0.3565	0.416	0.3863
1	0	0	0.037	0.036	0.0365
1	2500	2500	0.372	0.4475	0.4098
1	3000	3060	0.473	0.5745	0.5238
1	3500	3520	0.545	0.6705	0.6078
1	4000	4000	0.6385	0.7995	0.7190
		Target Def	ection (in.)		•
1	0.25	1740	0.236	0.2885	0.2623
1	0.5	2960	0.456	0.5585	0.5073
1	1	4820	0.899	1.1035	1.0013
		Targe	t Load		•
1	6000	-	-	-	-
1	0	0	0.0675	0.116	0.09175

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-11 B
Date/Time Installed:	3/1/2021 9:20	Date/Time Tested:	2:25PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.5
Pre-Auger Depth (ft):	•	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	29.1	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	1.46				
4	9.17				
5	15.67				
6	27.53				
7	36.48				
8	53.26				
9	60.33				
Total Time (s) =	202.44				

		Te	ensile Testing			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	-	-	-	-	
1	500	440	0.0015	0.0035	0.0025	
1	1000	1000	0.0025	0.0055	0.0040	
1	1500	1500	0.0035	0.0065	0.0050	
1	2000	2000	0.005	0.008	0.0065	
1	1500	1580	0.0045	0.0075	0.0060	
1	1000	980	0.0045	0.006	0.0053	
1	500	450	0.004	0.0045	0.0043	
1	250	260	0.004	0.004	0.0040	
1	0	0	0.003	0.003	0.0030	
		Targe	et Deflection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.0555	0.0125	0.0340	
1	0	0	0.0215	0.0115	0.0165	
		La	iteral Testing			




Lateral Testing						
	Load Height Grade (ft):	3	Deflection Gauge Height (in):		4	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	500	500	0.04	0.138	0.0890	
1	1000	1000	0.11	0.2405	0.1753	
1	1500	1500	0.1835	0.3305	0.2570	
1	0	0	0.0435	0.0075	0.0255	
1	500	500	0.0105	0.171	0.0908	
1	1000	1000	0.1555	0.268	0.2118	
1	1500	1500	0.212	0.344	0.2780	
1	2000	2000	0.293	0.436	0.3645	
1	2500	2500	0.3685	0.523	0.4458	
1	0	0	0.0655	0.035	0.0503	
1	2500	2500	0.408	0.5405	0.4743	
1	3000	3060	0.514	0.673	0.5935	
1	3500	3520	0.586	0.76	0.6730	
1	4000	4000	0.6805	0.8735	0.7770	
		Targe	et Deflection (in.)			
1	0.25	1500	0.1835	0.3305	0.2570	
1	0.5	2780	0.438	0.5875	0.5128	
1	1	4820	0.8995 1.129		1.0143	
			Target Load			
1	6000	-	-	-	-	
1	0	0	0.111	0.1025	0.10675	



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-12 A
Date/Time Installed: 3/1/2021 8:30		Date/Time Tested:	1PM 3/4/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	34.2	Pile Section	W6x9x15

Embedn	nent Data				
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	6.77				
4	12.54				
5	26.98				
6	29.95				
7	42.25				
8	55.62				
9	64.92				
Total Time (s) =	239.03				

Tensile Testing						
		Tensile	Testing			
Hold Time	Target Load (lbs)	Load (lbs)	Deflection 1	Deflection 2	Average	
(min)	ranget Load (103)	Lodd (103)	(in.)	(in.)	Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	260	0.002	0.002	0.0020	
1	500	520	0.004	0.0045	0.0043	
1	1000	1000	0.0085	0.0085	0.0085	
1	1500	1500	0.012	0.0135	0.0128	
1	2000	2000	0.0155	0.0175	0.0165	
1	1500	-	-	-	-	
1	1000	900	0.0085	0.0105	0.0095	
1	500	540	0.005	0.0085	0.0068	
1	250	260	0.0015	0.0055	0.0035	
1	0	0	0.0015	0.003	0.0023	
		Target Defl	ection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
		Target	Load			
1	10000	10000	0.025	0.0585	0.0418	
1	0	0	0.023	0.0275	0.0253	
	•	Lateral	Testing		•	




		Lateral	Testing		
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time			Deflection 1 Deflection 2		Average
(min)	Target Load (lbs)	Load (lbs)	(in.)	(in.)	Deflection (in.
1	0	0	0	0	0.0000
1	500	520	0.0585	0.103	0.0808
1	1000	980	0.1315	0.1865	0.1590
1	1500	1600	0.2335	0.2955	0.2645
1	0	0	0.0295	0.0085	0.0190
1	500	480	0.0805	0.1055	0.0930
1	1000	1080	0.1655	0.2175	0.1915
1	1500	1540	0.227	0.288	0.2575
1	2000	2060	0.3085	0.3685	0.3385
1	2500	2520	0.3865	0.442	0.4143
1	0	0	0.0475	0.0195	0.0335
1	2500	2540	0.413	0.465	0.4390
1	3000	3000	0.488	0.5394	0.5137
1	3500	3520	0.581	0.631	0.6060
1	4000	4040	0.6845	0.7325	0.7085
Target Deflection (in.)					
1	0.25	1600	0.2335	0.2955	0.2645
1	0.5	2900	0.4685	0.52	0.4943
1	1	5250	0.9975 1.0335		1.0155
Target Load					
1	6000	-	-	-	-
1	1 0 0		0.102	0.0205	0.06125

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-12 B	
Date/Time Installed:	3/1/2021 8:40	Date/Time Tested:	1:20PM 3/4/21	
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2	
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9	
Avg. Installation Rate (sec/ft.):	42.6	Pile Section	W6x9x15	

s)
5
7
)
7
5
5
3

	Tensile Testing					
Hold Time (min)	Target Load (Ibs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	280	0.0015	0.0045	0.0030	
1	500	520	0.0045	0.0085	0.0065	
1	1000	1060	0.0115	0.0165	0.0140	
1	1500	1540	0.0165	0.024	0.0203	
1	2000	2000	0.022	0.032	0.0270	
1	1500	1480	0.017	0.027	0.0220	
1	1000	1000	0.0115	0.02	0.0158	
1	500	520	0.0045	0.012	0.0083	
1	250	260	0.001	0.0085	0.0048	
1	0	0	0.0025	0.0045	0.0035	
Target Deflection (in.)						
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.097	0.069	0.0830	
1	0	0	0.0065	0.012	0.0093	
Lateral Testing						
Lateral Load Height						




Lateral Testing							
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0	0	0.0000		
1	500	520	0.077	0.077	0.0770		
1	1000	980	0.1465	0.1435	0.1450		
1	1500	1600	0.238	0.2435	0.2408		
1	0	0	0.025	0.0235	0.0243		
1	500	480	0.0875	0.09	0.0888		
1	1000	1080	0.1695	0.175	0.1723		
1	1500	1540	0.227	0.227	0.2270		
1	2000	2060	0.3965	0.3175	0.3570		
1	2500	2520	0.364	0.3955	0.3798		
1	0	0	0.0345	0.05	0.0423		
1	2500	2540	0.3895	0.425	0.4073		
1	3000	3000	0.462	0.5011	0.4816		
1	3500	3520	0.55	0.603	0.5765		
1	4000	4040	0.654	0.7185	0.6863		
Target Deflection (in.)							
1	0.25	1740	0.2565	0.2715	0.2640		
1	0.5	3050	0.478	0.5179	0.4980		
1	1	5200	0.9325	1.0735	1.0030		
Target Load							
1	6000	-	-	-	-		
1	0	0	0.0565	0.077	0.06675		



Project:	Project: ibV Energy-Rhudes Creek		PLT-13 A
Date/Time Installed:	2/27/2021 13:30	Date/Time Tested:	2:15PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	16.2	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	5.53				
4	10.65				
5	14.78				
6	19.65				
7	21.85				
8	24.88				
Total Time (s) =	97.34				

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	300	0.007	0.0035	0.0053	
1	500	540	0.012	0.0085	0.0103	
1	1000	1000	0.0215	0.0175	0.0195	
1	1500	1500	0.0315	0.0285	0.0300	
1	2000	2020	0.043	0.0405	0.0418	
1	1500	1460	0.0375	0.0345	0.0360	
1	1000	1080	0.031	0.027	0.0290	
1	500	480	0.019	0.012	0.0155	
1	250	240	0.013	0.006	0.0095	
1	0	0	0.0075	0.0005	0.0040	
		Target De	flection (in.)			
1	0.5		-	-	-	
1	0.75		-	-	-	
1	1	•	-	-	-	
		Targ	et Load			
1	10000	10000	0.14	0.165	0.1525	
1	0	0	0.002	0.0145	0.0083	
	Lateral Testing					
I ataval I as	storel Load Height Above Deflection Course Height					



1	U	U	0.002	0.0145	0.0083
		Latera	l Testing		
Lateral Load Height Above Grade (ft):		3		Deflection Gauge Height (in):	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0	0	0.0000
1	500	500	0.089	0.1295	0.1093
1	1000	1000	0.164	0.256	0.2100
1	1500	1500	0.238	0.368	0.3030
1	0	0	0.012	0.038	0.0250
1	500	500	0.112	0.1975	0.1548
1	1000	1000	0.186	0.3085	0.2473
1	1500	1500	0.249	0.3975	0.3233
1	2000	2000	0.3385	0.511	0.4248
1	2500	2500	0.471	0.662	0.5665
1	0	0	0.02	0.062	0.0410
1	2500	2500	0.505	0.7065	0.6058
1	3000	3000	0.615	0.83	0.7225
1	3500	3500	0.765	0.984	0.8745
-	-		-	-	-
		Target De	flection (in.)		
1	0.25	1350	0.204	0.315	0.2595
1	0.5	2360	0.419	0.603	0.5110
1	1	3800	0.89	1.1355	1.0128
		Targ	et Load		
1	6000	-	-	-	-
1	0	0	0.0475	0.112	0.07975

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-13 B
Date/Time Installed: 2/27/2021 13:30		Date/Time Tested:	2:25PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	26.7	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	8.59				
4	18.57				
5	30.55				
6	32.83				
7	33.87				
8	35.51				
Total Time (s) =	159.92				

		Tei	nsile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0	0	0.0000
1	250	400	0.003	0.003	0.0030
1	500	560	0.004	0.0035	0.0038
1	1000	1000	0.007	0.0065	0.0068
1	1500	1540	0.01	0.0105	0.0103
1	2000	2020	0.0125	0.012	0.0123
1	1500	1520	0.011	0.011	0.0110
1	1000	900	0.008	0.008	0.0080
1	500	520	0.005	0.0045	0.0048
1	250	100	0.0015	0.0005	0.0010
1	0	0	0.001	0	0.0005
		Target	t Deflection (in.)		
1	0.5		-	ı	-
1	0.75	-	-		-
1	1	-	-	-	-
		Т	arget Load		
1	10000	10000	0.0115	0.036	0.0238
1	0	0	0.0085	0.012	0.0103
		Lat	eral Testing		
Lateral Load Height Above Grade (ft):		3	Deflection Gaug	e Height (in):	4

		Time (seconds)					
1	0	10	20	30	40		
	0						
	1						
	2						
	3	\setminus					
Depth (ft.)	4						
Dept	5			\setminus			
	6			+			
	7			\dashv			
	8			\			
	9						


	e (ft):	3	Deflection Gaug	e Height (in):	4			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)			
1	0	0	0	0	0.0000			
1	500	500	0.057	0.092	0.0745			
1	1000	1020	0.1345	0.1945	0.1645			
1	1500	1520	0.2395	0.2895	0.2645			
1	0	0	0.0435	0.0085	0.0260			
1	500	500	0.119	0.111	0.1150			
1	1000	1000	0.1805	0.1985	0.1895			
1	1500	1480	0.25	0.2765	0.2633			
1	2000	2000	0.332	0.353	0.3425			
1	2500	2520	0.471	0.475	0.4730			
1	0	0	0.1085	0.01	0.0593			
1	2500	2580	0.5565	0.5175	0.5370			
1	3000	2990	0.657	0.618	0.6375			
1	3500	3440	0.8165	0.7755	0.7960			
1	4000	4020	0.908	0.891	0.8995			
		Target	t Deflection (in.)					
1	0.25	1480	0.2205	0.2725	0.2465			
1	0.5	2400	0.5195	0.4895	0.5045			
1	1	4200	1.051	1.005	1.0280			
		Т	arget Load		•			
1	6000		-		-			
1	0	0	0.138	0.0105	0.07425			



Project: ibV Energy-Rhudes Creek		Pile ID:	PLT-14 A
Date/Time Installed: 2/27/2021 14:30		Date/Time Tested:	12:45PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1
Pre-Auger Depth (ft): -		Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	27.9	Pile Section	W6x9x15

Embedment Data			
Depth (ft.)	Time (s)		
0	0		
1	0		
2	5.77		
3	10.23		
4	19.74		
5	28.65		
6	36.97		
7	43.71		
8	44.5		
9	51.87		
Total Time (s) =	225.44		

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	280	0.0035	0.004	0.0038	
1	500	500	0.006	0.0065	0.0063	
1	1000	1000	0.012	0.0135	0.0128	
1	1500	1500	0.0175	0.0195	0.0185	
1	2000	2040	0.0235	0.0265	0.0250	
1	1500	1500	0.0195	0.0225	0.0210	
1	1000	1080	0.016	0.0185	0.0173	
1	500	660	0.01	0.012	0.0110	
1	250	300	0.005	0.007	0.0060	
1	0	0	0.001	0.002	0.0015	
		Target Defl	ection (in.)			
1	0.5		-	-	-	
1	0.75	-	-	-	-	
1	1		-	-	-	
		Targe	t Load			
1	10000	10000	0.0545	0.1	0.0773	
1	0	0	0.0095	0.0195	0.0145	
	Lateral Testing					
Lateral Loa	ateral Load Height Above Deflection Gauge					



	Lateral Testing				
	d Height Above ade (ft):	3	Deflection Heigh	0 -	4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0	0	0.0000
1	500	500	0.111	0.785	0.4480
1	1000	1020	0.1955	0.124	0.1598
1	1500	1540	0.3285	0.221	0.2748
1	0	0	0.0255	0.0245	0.0250
1	500	500	0.1355	0.127	0.1313
1	1000	980	0.2485	0.1905	0.2195
1	1500	1500	0.328	0.241	0.2845
1	2000	2000	0.51	0.37	0.4400
1	2500	2540	0.6675	0.526	0.5968
1	0	0	0.115	0.1105	0.1128
1	2500	2500	0.7405	0.5995	0.6700
1	3000	3000	0.9205	0.748	0.8343
1	3500	3500	1.135	0.9455	1.0403
1	4000	-	-	-	-
		Target Defl	ection (in.)		
1	0.25	1400	0.2955	0.2005	0.2480
1	0.5	2100	0.5385	0.4475	0.4930
1	1	3500	1.135	0.9455	1.0403
		Target	Load		
1	6000	-	-	-	-
1	0	0	0.218	0.152	0.185

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-14 B
Date/Time Installed:	2/27/2021 14:45	Date/Time Tested:	12:45PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	9
Avg. Installation Rate (sec/ft.):	25.5	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	6.05				
3	9.51				
4	18.74				
5	24.55				
6	32.74				
7	42.1				
8	43.5				
9	50.9				
Total Time (s) =	212.53				

Tensile Testing						
Hold Time	Target Load	Load (lbs)	Deflection 1 (in.)	Deflection 2	Average	
(min)	(lbs)	2000 (100)	Dericetion 1 (iii)	(in.)	Deflection (in.)	
1	0	0	0	0	0.0000	
1	250	240	0	0.0025	0.0013	
1	500	580	0.0015	0.0055	0.0035	
1	1000	1000	0.0035	0.0085	0.0060	
1	1500	1500	0.0065	0.012	0.0093	
1	2000	2060	0.0085	0.015	0.0118	
1	1500	-	-	-	-	
1	1000	800	0.003	0.0085	0.0058	
1	500	500	0.002	0.0045	0.0033	
1	250	300	0.001	0.005	0.0030	
1	0	0	0.0005	0.002	0.0013	
		Targe	et Deflection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.019	0.0415	0.0303	
1	0	0	0.0135	0.0105	0.0120	
		La	teral Testing			

			seconds)	
	0	20	40	60
	1			
	\			
	2			
	3			
	4	\setminus		
Depth (ft.)	5	Λ		
Dep	6	\		
	7			
	8		+	
	9		\	_
	10			


Lateral Testing						
	Lateral Load Height Above Grade (ft):		Deflection Gauge Height (in):		4	
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	500	500	0.1055	0.0855	0.0955	
1	1020	1000	0.1745	0.1145	0.1445	
1	1500	1540	0.322	0.2385	0.2803	
1	0	0	0.0555	0.0515	0.0535	
1	500	500	0.1575	0.1025	0.1300	
1	1000	1020	0.2485	0.1965	0.2225	
1	1500	1500	0.3455	0.2505	0.2980	
1	2000	2000	0.5015	0.3905	0.4460	
1	2500	2540	0.6775	0.522	0.5998	
1	0	0	0.117	0.1095	0.1133	
1	2500	2500	0.7065	0.599	0.6528	
1	3000	3000	0.9115	0.7245	0.8180	
1	3500	3500	1.145	0.9175	1.0313	
1	4000	-	-	-	-	
		Targe	et Deflection (in.)			
1	0.25	1500	0.315	0.2105	0.2628	
1	0.5	2100	0.558	0.441	0.4995	
1	1	3500	1.145	0.9175	1.0313	
			Target Load			
1	6000		-	-	-	
1	0	0	0.218	0.152	0.185	



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-15 A
Date/Time Installed:	2/27/2021 15:10	Date/Time Tested:	3:45PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1
Pre-Auger Depth (ft):	i	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	22.1	Pile Section	W6x9x15

Embedn	nent Data
Depth (ft.)	Time (s)
0	0
1	0
2	3.71
3	5.24
4	8.8
5	20.85
6	24.36
7	28.79
8	31.84
9	33.65
10	41.88
Total Time (s) =	199.12

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	300	0.004	0.0045	0.0043	
1	500	540	0.0075	0.0085	0.0080	
1	1000	1020	0.0165	0.0165	0.0165	
1	1500	1520	0.023	0.024	0.0235	
1	2000	2020	0.0305	0.033	0.0318	
1	1500	1240	0.024	0.0255	0.0248	
1	1000	940	0.0195	0.0205	0.0200	
1	500	540	0.013	0.0145	0.0138	
1	250	220	0.0065	0.0085	0.0075	
1	0	0	0.002	0.004	0.0030	
		Target Defle	ection (in.)			
1	0.5	9560	0.4155	0.6155	0.5155	
1	0.75	9920	0.7085	0.845	0.7768	
1	1	10000	0.9065	1.1265	1.0165	
		Target	Load		•	
1	10000	10000	0.9065	1.1265	1.0165	
1	0	0	0.8965	1.0655	0.9810	
		Lateral '	Testing	•		
Lateral Land Haint Abarra						




	Lateral Testing				
	Lateral Load Height Above Grade (ft):		Deflection Heigh	on Gauge et (in):	4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0925	0.0625	0.0775
1	1000	1000	0.185	0.1145	0.1498
1	1500	1540	0.318	0.2385	0.2783
1	0	0	0.0485	0.0425	0.0455
1	500	500	0.1485	0.11	0.1293
1	1000	1020	0.258	0.1875	0.2228
1	1500	1500	0.3585	0.241	0.2998
1	2000	2000	0.4995	0.3815	0.4405
1	2500	2500	0.6875	0.5155	0.6015
1	0	0	0.1255	0.101	0.1133
1	2500	2500	0.7355	0.5875	0.6615
1	3000	3000	0.901	0.7355	0.8183
1	3500	3500	1.115	0.9255	1.0203
1	4000	-	-	-	-
		Target Defle	ection (in.)		
1	0.25	1400	0.3285	0.2255	0.2770
1	0.5	2250	0.6255	0.4522	0.5389
1	1	3500	1.115	0.9255	1.0203
	•	Target	Load		
1	6000	-	-	-	-
1	0	0	0.115	0.158	0.1365

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-15 B
Date/Time Installed:	2/27/2021 13:30	Date/Time Tested:	12:45PM 3/3/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	21.4	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	3.65			
3	6.25			
4	9.2			
5	19.78			
6	21.65			
7	23.49			
8	30.67			
9	31.88			
10	45.66			
Total Time (s) =	192.23			

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	340	0.0005	0.0015	0.0010	
1	500	540	0.0005	0.003	0.0018	
1	1000	1020	0.001	0.005	0.0030	
1	1500	1560	0.001	0.0075	0.0043	
1	2000	2080	0.001	0.01	0.0055	
1	1500	1320	0.001	0.0085	0.0048	
1	1000	1080	0.0005	0.008	0.0043	
1	500	-	-	-	-	
1	250	220	0.0005	0.0035	0.0020	
1	0	0	0.001	0.002	0.0015	
		Targe	et Deflection (in.)			
1	0.5	9600	0.501	0.5185	0.5098	
1	0.75	9890	0.7545	0.802	0.7783	
1	1	10000	1.065	1.0245	1.0448	
	Target Load					
1	10000	10000	1.065	1.0245	1.0448	
1	0	0	1.065	1.0245	1.0448	
	Lateral Testing					




Lateral Testing								
Lateral Load Height Above Grade (ft):		3	Deflection Gaug	ge Height (in):	4			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)			
1	0	0	0.0000	0.0000	0.0000			
1	500	500	0.09	0.062	0.0760			
1	1000	1000	0.1945	0.1345	0.1645			
1	1500	1540	0.328	0.2385	0.2833			
1	0	0	0.05	0.0435	0.0468			
1	500	500	0.1595	0.109	0.1343			
1	1000	1020	0.249	0.1745	0.2118			
1	1500	1500	0.351	0.26	0.3055			
1	2000	2000	0.488	0.371	0.4295			
1	2500	2500	0.65	0.5065	0.5783			
1	0	0	0.1905	0.142	0.1663			
1	2500	2500	0.722	0.5675	0.6448			
1	3000	3000	0.8925	0.7175	0.8050			
1	3500	3500	1.0825	0.9	0.9913			
1	4000		-	-	-			
		Targe	et Deflection (in.)					
1	0.25	1540	0.328	0.2385	0.2833			
1	0.5	2300	0.61	0.4555	0.5328			
1	1	3550	1.116	0.9265	1.0213			
			Target Load					
1	6000	-	-	-	-			
1	0	0	0.218	0.152	0.185			



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-16 A
Date/Time Installed:	2/27/2021 13:30	Date/Time Tested:	3/3/2021 13:30
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	7
Avg. Installation Rate (sec/ft.):	26.2	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	5.71				
4	13.85				
5	28.94				
6	36.57				
7	45.66				
Total Time (s) =	130.73				

	Tensile Testing						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	250	300	0.001	0.0025	0.0018		
1	500	500	0.0015	0.0035	0.0025		
1	1000	1040	0.003	0.008	0.0055		
1	1500	1520	0.0045	0.012	0.0083		
1	2000	2040	0.0055	0.016	0.0108		
1	1500	-	-	-	#DIV/0!		
1	1000	1040	0.003	0.0105	0.0068		
1	500	560	0.0015	0.0065	0.0040		
1	250	280	0.0005	0.003	0.0018		
1	0	0	0	0	0.0000		
		Target Defle	ction (in.)				
1	0.5	-	-	-	-		
1	0.75	-	-	-	-		
1	1	-	-	-	-		
		Target	Load				
1	10000	10200	0.01	0.0875	0.0488		
1 0		0	0.0085	0.0105	0.0095		
		Lateral T	esting				
Lateral Lo	ad Height Above	3	Deflectio	n Gauge	4		



1	U	U	0.0065	0.0105	0.0095
		Lateral T	esting		
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.064	0.064	0.0640
1	1000	1000	0.1375	0.133	0.1353
1	1500	1500	0.2075	0.2045	0.2060
1	0	0	0.0075	0.009	0.0083
1	500	500	0.0715	0.0725	0.0720
1	1000	1000	0.14	0.14	0.1400
1	1500	1500	0.2045	0.209	0.2068
1	2000	2000	0.2855	0.288	0.2868
1	2500	2500	0.3725	0.377	0.3748
1	0	0	0.0245	0.011	0.0178
1	2500	2500	0.3645	0.3985	0.3815
1	3000	3000	0.443	0.4785	0.4608
1	3500	3500	0.542	0.579	0.5605
1	4000	-	-	-	-
		Target Defle	ection (in.)		
1	0.25	1860	0.2565	0.2605	0.2585
1	0.5	3150	0.4875	0.536	0.5118
1	1	5380	0.9965	1.034	1.0153
		Target	Load		
1	6000	-	-	-	-
1	0	0	0.062	0.027	0.0445

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-16 B
Date/Time Installed:	2/27/2021 13:30	Date/Time Tested:	3/3/2021 13:45
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	7
Avg. Installation Rate (sec/ft.):	31.1	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	6.94			
4	19.54			
5	33.51			
6	44.01			
7	51.23			
Total Time (s) =	155.23			

Tot	al Time (s) =	155.23
100	ai iiiie (S) =	155.23
0	Time (se	econds) 40 60
1		
2		
3		
Depth (ft.)		
5		
6		
7		
8		

		Te	ensile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.
1	0	0	0.0000	0.0000	0.0000
1	250	240	0	0.0005	0.0003
1	500	500	0.001	0.0015	0.0013
1	1000	1040	0.001	0.003	0.0020
1	1500	1520	0.0015	0.0045	0.0030
1	2000	2000	0.002	0.0055	0.0038
1	1500	1400	0.001	0.0045	0.0028
1	1000	960	0.001	0.0035	0.0023
1	500	460	0.001	0.0025	0.0018
1	250	260	0.001	0.0015	0.0013
1	0	0	0	0.001	0.0005
		Targe	et Deflection (in.)		
1	0.5	-	-	-	-
1	0.75	-	-	-	-
1	1	-	-	-	-
			Target Load		
1	10000	10000	0.07	0.0565	0.0633
1	0	0	0.0485	0.044	0.0463
		La	teral Testing		
Lateral	Load Height				

	Load Height Grade (ft):	3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.066	0.0585	0.0623
1	1000	1000	0.1325	0.136	0.1343
1	1500	1500	0.199	0.21	0.2045
1	0	0	0.0195	0.011	0.0153
1	500	500	0.0815	0.0725	0.0770
1	1000	1000	0.142	0.143	0.1425
1	1500	1500	0.2015	0.214	0.2078
1	2000	2000	0.277	0.2975	0.2873
1	2500	2500	0.36	0.385	0.3725
1	0	0	0.049	0.018	0.0335
1	2500	2500	0.349	0.4075	0.3783
1	3000	3000	0.4275	0.4875	0.4575
1	3500	3500	0.525	0.5875	0.5563
1	4000	4000	0.629	0.696	0.6625
		Targe	t Deflection (in.)		
1	0.25	1860	0.25	0.2685	0.2593
1	0.5	3150	0.482	0.542	0.5120
1	1	5380	0.986	1.07	1.0280
			Target Load		
1	6000	-	-		-
1	0	0	0.109	0.0505	0.07975



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-17 A
Date/Time Installed:	3/1/2021 13:30	Date/Time Tested:	9:20AM 3/4/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.5
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	26.1	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	2.05				
4	6.96				
5	16.82				
6	25.78				
7	33.05				
8	38.21				
9	42.38				
10	43.22				
Total Time (s) =	208.47				


	0	Time (s	econds)	60
	2			
	\			
	4			
(ft.)				
Depth (ft.)	6			
	8			
1	.0			
1	2			

		Tensi	le Testing		
Hold Time	Target Load	1 (11)	Deflection 1	Deflection 2	Average
(min)	(lbs)	Load (lbs)	(in.)	(in.)	Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	300	0.0005	0.0025	0.0015
1	500	520	0.001	0.003	0.0020
1	1000	1040	0.003	0.006	0.0045
1	1500	1540	0.004	0.008	0.0060
1	2000	2040	0.0045	0.009	0.0068
1	1500	1480	0.0035	0.0085	0.0060
1	1000	1020	0.003	0.0085	0.0058
1	500	600	0.002	0.0065	0.0043
1	250	250	0.0005	0.0045	0.0025
1	0	0	0.0005	0.0035	0.0020
		Target D	eflection (in.)		
1	0.5		-	-	-
1	0.75	•	-	-	-
1	1	•	-	-	-
		Tar	get Load		
1	10000	10000	0.01	0.01	0.0100
1	0	0	0.006	0.005	0.0055
		Later	al Testing		

			u cot6		
	Lateral Load Height Above Grade (ft):		Deflection Heigh	•	4
Hold Time	Target Load	Load (lbs)	Deflection 1	Deflection 2	Average
(min)	(lbs)	,	(in.)	(in.)	Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	520	0.1125	0.157	0.1348
1	1000	1000	0.18	0.225	0.2025
1	1500	1520	0.257	0.301	0.2790
1	0	0	0.032	0.0455	0.0388
1	500	500	0.1025	0.1565	0.1295
1	1000	1000	0.1905	0.2445	0.2175
1	1500	1500	0.262	0.3115	0.2868
1	2000	2000	0.351	0.3945	0.3728
1	2500	2500	0.4695	0.501	0.4853
1	0	0	0.107	0.1405	0.1238
1	2500	2500	0.518	0.538	0.5280
1	3000	3000	0.6225	0.6305	0.6265
1	3500	3500	0.7845	0.778	0.7813
1	4000	4000	0.925	0.918	0.9215
		Target D	eflection (in.)		
1	0.25	1380	0.236	0.2805	0.2583
1	0.5	2420	0.4865	0.5195	0.5030
1	1	4380	1.021	0.9965	1.0088
	,	Tar	get Load		•
1	6000		-		-
1	0	0	0.1215	0.113	0.11725

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-17 B
Date/Time Installed:	3/1/2021 13:30	Date/Time Tested:	9:35AM 3/4/2021
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.75
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	23.4	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	1.18				
4	4.75				
5	12.16				
6	20.38				
7	29.06				
8	36.03				
9	40.27				
10	43.05				
Total Time (s) =	185.7				



			Tensile Testing		
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	250	260	0.0025	0.0005	0.0015
1	500	540	0.0045	0.001	0.0028
1	1000	1040	0.008	0.003	0.0055
1	1500	1520	0.0115	0.0045	0.0080
1	2000	2020	0.015	0.006	0.0105
1	1500	1420	0.013	0.013 0.005	
1	1000	-	-		
1	500	680	0.0085	0.003	0.0058
1	250	240	0.0045	1	0.5023
1	0	0	0.002 0.001		0.0015
		Ta	rget Deflection (in.)		
1	0.5	-	-	-	
1	0.75	-	-	-	-
1	1	-			-
			Target Load		
1	10000	10000	0.069	0.0055	0.0373
1	0	0	0.017 0.012		0.0145
			Lateral Testing	•	
Lateral Load Height 3 Deflection Gauge Height (in): 4				4	


	ad Height rade (ft):	3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	520	0.1195	0.1765	0.1480
1	1000	1000	0.2045	0.253	0.2288
1	1500	1520	0.301	0.3605	0.3308
1	0	0	0.025	0.0725	0.0488
1	500	500	0.115	0.176	0.1455
1	1000	1000	0.227	0.277	0.2520
1	1500	1500	0.318	0.361	0.3395
1	2000	2000	0.429	0.4675	0.4483
1	2500	2500	0.5615	0.5975	0.5795
1	0	0	0.1045	0.1845	0.1445
1	2500	2500	0.5955	0.6505	0.6230
1	3000	3000	0.7055	0.755	0.7303
1	3500	3500	0.8585	0.905	0.8818
1	4000	4000	0.9955	1.0255	1.0105
		Ta	rget Deflection (in.)		
1	0.25	1200	0.24	0.2935	0.2668
1	0.5	2250	0.4865	0.5195	0.5030
1	1	4000	0.9955	1.0255	1.0105
			Target Load		
1	6000		-	-	-
1	0	0	0.1315	0.207	0.16925



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-18 A
Date/Time Installed:	3/1/2021 16:30	Date/Time Tested:	1:45PM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.5
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	23.4	Pile Section	W6x9x15

Embedment Data				
Depth (ft.)	Time (s)			
0	0			
1	0			
2	0			
3	2.01			
4	9.58			
5	17.96			
6	29.23			
7	38.78			
8	42.74			
Total Time (s) =	140.3			

	Tensile Testing						
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	250	280	0.0010	0.0010	0.0010		
1	500	500	0.0015	0.0030	0.0023		
1	1000	1060	0.0025	0.0075	0.0050		
1	1500	1480	0.0035	0.0115	0.0075		
1	2000	2060	0.0075	0.0160	0.0118		
1	1500	-	-	-	-		
1	1000	1140	0.0035	0.1050	0.0543		
1	500	500	0.0025	0.0085	0.0055		
1	250	300	0.0015	0.0060	0.0038		
1	0	0	0.0015	0.0025	0.0020		
		Target De	eflection (in.)				
1	0.5	-	-	-	-		
1	0.75	-	-	-	-		
1	1	-	-	-	-		
	Target Load						
1	10000	10000	0.019	0.022	0.0205		
1	0	0	0.01	0.02	0.0150		
		Latera	al Testing				



1	U	U	0.01	0.02	0.0150
	•	Latera	l Testing		
Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in
1	0	0	0.0000	0.0000	0.0000
1	500	600	0.1300	0.0945	0.1123
1	1000	1000	0.2290	0.1865	0.2078
1	1500	1500	0.3505	0.3100	0.3303
1	0	0	0.0445	0.0380	0.0413
1	500	500	0.1265	0.1325	0.1295
1	1000	1000	0.2490	0.2370	0.2430
1	1500	1500	0.3505	0.3290	0.3398
1	2000	2000	0.4620	0.4335	0.4478
1	2500	2500	0.5760	0.5425	0.5593
1	0	0	0.0625	0.0725	0.0675
1	2500	2500	0.6085	0.5850	0.5968
1	3000	3000	0.7270	0.6970	0.7120
1	3500	3500	0.8450	0.8050	0.8250
1	4000	4000	0.9860	0.9360	0.9610
	•	Target De	eflection (in.)		
1	0.25	1300	0.278	0.234	0.2560
1	0.5	2200	0.5355	0.4795	0.5075
1	1	4200	1.0390	0.9860	1.0125
		Targ	et Load		
1	6000	-	-	-	
1	0	0	0.1105	0.155	0.13275

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-18 B
Date/Time Installed:	3/1/2021 16:45	Date/Time Tested:	2PM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	2.5
Pre-Auger Depth (ft):		Embedment Depth (ft.):	8
Avg. Installation Rate (sec/ft.):	24.0	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0				
3	2.85				
4	10.25				
5	19.58				
6	28.09				
7	39.51				
8	43.95				
Total Time (s) =	144.23				

		Te	ensile Testing			
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	280	0.0010	0.0030	0.0020	
1	500	520	0.0025	0.0045	0.0035	
1	1000	1000	0.0045	0.0085	0.0065	
1	1500	1500	0.0080	0.0140	0.0110	
1	2000	2000	0.0100	0.0180	0.0140	
1	1500	-	-	-	-	
1	1000	1160	0.0060	0.0135	0.0098	
1	500	480	0.0010	0.0085	0.0048	
1	250	260	0.0010	0.0065	0.0038	
1	0	0	0.0000	0.0040	0.0020	
		Targe	et Deflection (in.)			
1	0.5	-	-	-	-	
1	0.75	-	-	-	-	
1	1	-	-	-	-	
Target Load						
1	10000	10000	0.055	0.049	0.0520	
1	0	0	0.019	0.02	0.0195	
		La	teral Testing			
Lateral I	nad Height					

	Time (seconds)			
	0	20	40	60
	Ĭ			
	1			
	2			
	1			
	3			
	-1			
~	4			
Depth (ft.)	'	\setminus		
)ept	5	\mathbf{A}		
	3			
	6	1		
	7		1	
			- 1	
	8		_1_	
	9			

	Load Height Grade (ft):	3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.
1	0	0	0.0000	0.0000	0.0000
1	500	600	0.0770	0.0980	0.0875
1	1000	1000	0.1410	0.1880	0.1645
1	1500	1500	0.2275	0.2900	0.2588
1	0	0	0.0385	0.4550	0.2468
1	500	500	0.1010	0.1250	0.1130
1	1000	1000	0.1755	0.2205	0.1980
1	1500	1500	0.2395	0.2990	0.2693
1	2000	2000	0.3160	0.3885	0.3523
1	2500	2500	0.4045	0.4870	0.4458
1	0	0	0.0690	0.0585	0.0638
1	2500	2500	0.4400	0.5415	0.4908
1	3000	3000	0.5385	0.6585	0.5985
1	3500	3500	0.6415	0.7790	0.7103
1	4000	4000	0.7750	0.9290	0.8520
		Targe	et Deflection (in.)		
1	0.25	1500	0.2275	0.2900	0.2588
1	0.5	2500	0.4400	0.5415	0.4908
1	1	4660	0.9255	1.1250	1.0253
			Target Load		
1	6000	-	-	-	-
1	0	0	0.163	0.1315	0.14725



Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-19 A
Date/Time Installed:	3/1/2021 16:30	Date/Time Tested:	3PM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1.5
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	29.3	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	0.79				
3	9.8				
4	14.05				
5	18.01				
6	25.12				
7	37.22				
8	42.08				
9	53.32				
10	62.95				
Total Time (s) =	263.34				

	Tensile Testing					
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)	
1	0	0	0.0000	0.0000	0.0000	
1	250	240	0.0015	0.0025	0.0020	
1	500	500	0.0045	0.0055	0.0050	
1	1000	1000	0.0085	0.0120	0.0103	
1	1500	1500	0.0125	0.0170	0.0148	
1	2000	2000	0.0160	0.0215	0.0188	
1	1500	1460	0.0140	0.0185	0.0163	
1	1000	1000	0.0095	0.0120	0.0108	
1	500	500	0.0060	0.0075	0.0068	
1	250	240	0.0030	0.0035	0.0033	
1	0	0	0.0010	0.0010	0.0010	
		Target De	flection (in.)			
1	0.5	ı	-		-	
1	0.75		-		-	
1	1		-		-	
	Target Load					
1	10000	10000	0.035	0.075	0.0550	
1	0	0	0.003	0.0075	0.0053	
		Latera	l Testing			
1-411		1	D-6141-	_		

0	20	ne (sec		80
0	20	0	30	00
2				
\				
	۱			
4	\			
,	1			
	\			
Depth (ft.)	\			
£ 6				
ă				
		\		
8		$-$ \		
		\		
10			\	

Lateral Testing					
	Lateral Load Height Above Grade (ft):		Deflection Gauge Height (in):		4
Hold Time	Target		Deflection 1		Average
(min)	Load (lbs)	Load (lbs)	(in.)	(in.)	Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0530	0.0880	0.0705
1	1000	1000	0.1215	0.1700	0.1458
1	1500	1500	0.2000	0.2600	0.2300
1	0	0	0.0305	0.0565	0.0435
1	500	500	0.0845	0.1225	0.1035
1	1000	1000	0.1480	0.2025	0.1753
1	1500	1500	0.2150	0.2770	0.2460
1	2000	2000	0.2880	0.3640	0.3260
1	2500	2500	0.3880	0.4795	0.4338
1	0	0	0.0765	0.1040	0.0903
1	2500	2500	0.4255	0.5225	0.4740
1	3000	3000	0.5235	0.6275	0.5755
1	3500	3500	0.6380	0.7510	0.6945
1	4000	4000	0.7785	0.8850	0.8318
		Target De	flection (in.)		
1	0.25	1550	0.2200	0.2890	0.2545
1	0.5	3150	0.4685	0.552	0.5103
1	1	4700	0.9545	1.0655	1.0100
		Targe	et Load		
1	6000	-	-	-	-
1	0	0	0.34	0.4195	0.37975

Project:	ibV Energy-Rhudes Creek	Pile ID:	PLT-19 B
Date/Time Installed:	3/1/2021 16:30	Date/Time Tested:	3:15PM 3/6/21
Pre-Auger (Y/N)?:	N	Pushed to Depth (ft.):	1.75
Pre-Auger Depth (ft):	-	Embedment Depth (ft.):	10
Avg. Installation Rate (sec/ft.):	50.1	Pile Section	W6x9x15

Embedment Data					
Depth (ft.)	Time (s)				
0	0				
1	0				
2	3.69				
3	12.48				
4	25.47				
5	37.63				
6	53.73				
7	61.74				
8	70.96				
9	84.03				
10	101.08				
Total Time (s) =	450.81				

450.81
ds)
150

		Т	ensile Testing				
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)		
1	0	0	0.0000	0.0000	0.0000		
1	250	300	0.0005	0.0010	0.0008		
1	500	500	0.0010	0.0020	0.0015		
1	1000	1000	0.0030	0.0030	0.0030		
1	1500	1500	0.0040	0.0035	0.0038		
1	2000	2000	0.0065	0.0040	0.0053		
1	1500	1350	0.0045	0.0040	0.0043		
1	1000	940	0.0040	0.0040	0.0040		
1	500	460	0.0035	0.0035	0.0035		
1	250	200	0.0030	0.0030	0.0030		
1	0	0	0.0010	0.0010	0.0010		
		Targ	et Deflection (in.)				
1	0.5	-	-	-	-		
1	0.75	-	-	-	-		
1	1	-	-	-	-		
	Target Load						
1	10000	10000	0.075	0.065	0.0700		
1	0	0	0.016	0.0095	0.0128		
		L	ateral Testing				
Lateral I	Lateral Load Height						

Lateral Load Height Above Grade (ft):		3	Deflection Gauge Height (in):		4
Hold Time (min)	Target Load (lbs)	Load (lbs)	Deflection 1 (in.)	Deflection 2 (in.)	Average Deflection (in.)
1	0	0	0.0000	0.0000	0.0000
1	500	500	0.0780	0.0335	0.0558
1	1000	1000	0.1510	0.1010	0.1260
1	1500	1500	0.2245	0.1650	0.1948
1	0	0	0.0305	0.0100	0.0203
1	500	500	0.1010	0.0890	0.0950
1	1000	1000	0.1715	0.1205	0.1460
1	1500	1500	0.2380	0.1890	0.2135
1	2000	2000	0.3010	0.2335	0.2673
1	2500	2500	0.3805	0.2975	0.3390
1	0	0	0.0475	0.0335	0.0405
1	2500	2500	0.4105	0.3130	0.3618
1	3000	3000	0.4855	0.3990	0.4423
1	3500	3500	0.5690	0.4605	0.5148
1	4000	4000	0.6605	0.5505	0.6055
		Targ	et Deflection (in.)		
1	0.25	2000	0.3010	0.2335	0.2673
1	0.5	3400	0.5540	0.4505	0.5023
1	1	6000	1.0365 0.9345		0.9855
			Target Load		
1	6000	6000	1.0365	0.9345	0.9855
1	0	0	0.1145	0.1995	0.157

Attachment F

Seismic Support Data





Address:

No Address at This Location


ASCE 7 Hazards Report

Standard: ASCE/SEI 7-16 Elevation: 704.01 ft (NAVD 88)

Risk Category: II Latitude: 37.656346
Soil Class: C - Very Dense Longitude: -85.993722

Soil and Soft Rock








Seismic


Site Soil Class: C - Very Dense Soil and Soft Rock


Results:


S _S :	0.208	S _{D1} :	0.11
S_1 :	0.11	T_L :	12
F _a :	1.3	PGA:	0.101
F _v :	1.5	PGA _M :	0.131
S _{MS} :	0.271	F _{PGA} :	1.299
S _{M1} :	0.165	l _e :	1
S _{DS} :	0.18	C_v :	0.708

Seismic Design Category B









Data Accessed:

Wed Mar 31 2021

Date Source:


USGS Seismic Design Maps based on ASCE/SEI 7-16 and ASCE/SEI 7-16 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-16 Ch. 21 are available from USGS.



The ASCE 7 Hazard Tool is provided for your convenience, for informational purposes only, and is provided "as is" and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE 7 standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE 7 standard.


In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE 7 Hazard Tool.



Attachment G

Geophysical Report (Karst Investigation)





GEOPHYSICAL INVESTIGATION Rhudes Creek Solar Project Cecilia, Kentucky

Prepared for:
ANS Geo, Inc.
4405 S Clinton Ave
South Plainfield, NJ 07080

February 24, 2021

Prepared by:

THG Geophysics, Ltd.
4280 Old William Penn Highway
Murrysville, Pennsylvania 15668
724-325-3996
www.thggeophysics.com
THG Project No. 1265-10736

TABLE OF CONTENTS

1.0 INTRODUCTION						
	1.2				2	
2.0	GEOF 2.1	Electrical Imaging Theory 2.1.1 Introduction			3	3
	2.2 2.3	Processing				1
3.0	GEOL	OGY			5	5
4.0	GEOF 4.1	Introduction4.1.1 Electrical Imaging			6 6	3
	4.2 4.3 4.4 4.5	Area 1Area 3Area 4			7 7 7	7 7 3
	4.6 4.7 4.8 4.9	Area 6 Areas 7-8			3 2 2	9
5.0	CONC	CLUSION			10)
6.0	REFE	RENCES			11	l
			TABLE	S		
1. 2.		ASW Shear Wave Velocity Data ABLE 2	ı			
			FIGUR	ES		
1. 2. 3. 4. 5. 6. 7.	Geoph Site Ge Area 1 Area 2 Area 3 Area 4	ocation Map ysical Survey Map eological Map – El Profiles 1-3 – El Profiles 4-7 – El Profiles 8-15 – El Profiles 16-18 – El Profiles 8-9		9. 10. 11. 12. 13. 14. 15.	Area 6 – El Profiles 21-24 Areas 7 & 8 – El Profiles 25-28 ROW – El Profile 29 Shear Wave Velocity Profiles M1-M3 Shear Wave Velocity Profiles M4-M6 Shear Wave Velocity Profiles M7-M9 Shear Wave Velocity Profiles M10-M11	

1.0 INTRODUCTION

1.1 BACKGROUND

THG Geophysics, Ltd. (THG) conducted a geophysical investigation to characterize a sampling of the subsurface across approximately 950 acres of the proposed Rhudes Creek Solar Project and transmission line Right-of-Way (ROW) located near Cecilia, Kentucky. The project site is in an area prone to development of sinkholes and other karst phenomena. The survey was completed February 8-12, 2021 (**Figure 1**).

1.2 WORK SCOPE

The scope of work included the use of electrical resistivity imaging (EI) and multichannel analysis of surface wave (MASW) testing to characterize bedrock in an area known to be impacted by karst. THG utilized a GF Instruments' ARES II electrical resistivity meter and a Geometrics Geode seismograph to image the subsurface. Given the size of the project site, testing locations were selected to be distributed across the property while also targeting potential karst features determined in the field (**Figure 2**).

2.0 GEOPHYSICAL INVESTIGATION

2.1 ELECTRICAL IMAGING THEORY

2.1.1 Introduction

Electrical resistance is based upon Ohm's Law:

$$R = \frac{V}{I}$$
 [ohms]

Where, resistance, **R**, is equal to the ratio of potential, **V** (volts) to current flow, **I** (amperes).

Resistivity is the measure of the resistance along a linear distance of a material with a known cross-sectional area. Consequently, resistivity is measured in Ohm-meters. This report presents the geophysical results as geo-electrical profiles of modeled resistance plotted as 2-dimensional profiles of distance and depth, in units of feet.

Electrical currents propagate as a function of three material properties (1) ohmic conductivity, (2) electrolytic conductivity, and (3) dielectric conductivity. Ohmic conductivity is a property exhibited by metals. Electrolytic conductivity is a function of the concentration of total dissolved solids and chlorides in the groundwater that exists in the pore spaces of a material. Dielectric conductivity is a function of the permittivity of the matrix of the material. Therefore, the matrix of most soil and bedrock is highly resistive. Of these three properties, electrolytic conductivity is the dominant material characteristic that influences the apparent resistivity values collected by this method. In general, resistivity values decrease in water-bearing rocks and soil with increasing:

- a. Fractional volume of the rock occupied by groundwater;
- b. Total dissolved solid and chloride content of the groundwater;
- c. Permeability of the pore spaces; and,
- d. Temperature.

Materials with minimal primary pore space (i.e., limestone, dolomite) or those which lack groundwater in the pore spaces will exhibit high resistivity values (Mooney, 1980). Highly porous, moist, or saturated soil will exhibit very low resistivity values.

In homogeneous ground, the apparent resistivity is the true ground resistivity; however, in heterogeneous ground, the apparent resistivity represents a weighted average of all formations through which the current passes. Many electrode placements (arrays) have been proposed (for examples see Reynolds, 1997); however, the Schlumberger array has proven to be an effective configuration for imaging bedrock. The following Schlumberger array was used in the collection of data:

$$R_i = \frac{\pi a^2}{b} [1 - \frac{b^2}{4a^2}] R; a = 5b$$

Where, R_i , resistivity, is related to the number of poles, n, the separation distance between the current source and current sink b, and the pole spacing, a.

2.1.2 Methods

The resistivity survey was performed using the ARES II multi-electrode cable system (GF Instruments, s.r.o., Brno, Czech Republic). The survey was conducted using stainless steel electrodes and passive multi-electrode cables with switch boxes. Twenty nine (29) El profiles were collected with a 3-m step-out Schlumberger array. The locations and elevations of all data were recorded in the field using a Trimble Geo-7XH global positioning system (DGPS).

2.2 PROCESSING

A forward modeling subroutine was used to calculate the apparent resistivity values using the EarthImager2D program (AGI, 2002). This program is based on the smoothness-constrained least-squares method (deGroot-Hedlin and Constable, 1990; Loke and Barker, 1996). The smoothness-constrained least-squares method is based upon the following equation:

$$J^T g = (J^T J + \mu F)d$$

Where, ${\bf F}$ is a function of the horizontal and vertical flatness filter, ${\bf J}$ is the matrix of partial derivatives, ${\bf \mu}$ is the damping factor, ${\bf d}$ is the model perturbation vector, and ${\bf g}$ is the discrepancy vector.

The EarthImager2D program divides the subsurface 2-D space into a number of rectangular blocks. Resistivities of each block are then calculated to produce an apparent resistivity pseudo section. The pseudo section is compared to the actual measurements for consistency. A measure of the difference is given by the root-mean-squared (rms) error.

2.3 MULTICHANNEL ANALYSIS OF SURFACE WAVES THEORY

Multichannel Analysis of Surface Waves (MASW) is a method of collecting shear-wave data using surface wave velocity analysis (Xia, et al., 2000). MASW uses surface wave fronts (i.e., Raleigh and Love waves) to predict the shear wave velocity often to a depth of 75 feet or greater. This method is non-destructive and non-intrusive. MASW theory holds that the penetration depth of a surface wave increases with wavelength. Further, propagation velocity (i.e., phase velocity) is determined mainly by shear-wave velocity of penetrated materials; consequently, surface waves have nearly the same velocity as shear wave at depth. Through the use of dispersion curves, or the change of propagation speed (i.e., phase velocity) with wavelength (or frequency), the shear wave velocity with depth can be derived.

One-dimensional multichannel analysis of surface waves (MASW) data was collected at eleven (11) locations across the site. Elastic waves were initiated using a 16-lbs sledge hammer striking a 12-in by 12-in aluminum plate. The velocity data were collected using a 24-channel seismograph and 4.5-Hz geophones in a 5-foot step-out array. Three events (5 stacks each) were recorded and processed using SurfSeis 6.0.1.4 software. The location of each MASW test was recorded using a Trimble Geo-7XH DGPS.

3.0 GEOLOGY

The bedrock in the project area primarily consists of the Mississippian-aged Ste. Genevieve Limestone (**Figure 3**). This unit consists of limestone, dolomite, and shale. Limestone is light yellowish gray and massive, interbedded with sublithographic to medium-grained clastic limestone. Dolomite is yellowish gray, very fine grained and massive. Shale is yellowish to greenish gray. This unit is commonly covered by as much as 30 feet of soil (Kepferle 1963). This soil coverage is consistent with a preliminary geotechnical report performed by Terracon that revealed auger refusal depths of 6.5 to 26 feet below grade (ft bg) across the site.

The Karst Potential Classification developed by the Kentucky Geological Survey (KGS) classifies this unit as having very high karst potential. This classification is defined by thick-bedded, typically fine-grained and pure limestone units with little or no insoluble content. Units in this class will exhibit mature karst, including caves, sinkholes, and springs where they crop out (KGS Karst Potential Index).

The Kentucky Geological Survey also developed a GIS database of topographically mapped depressions resulting from karst processes (i.e. sinkholes). This database was developed by digitizing the highest elevation, closed, topographic contour as a polygon. Although these data do not indicate the probability of future cover-collapse or bedrock collapse, they do identify areas where karst features are likely to have developed. These features are common along the eastern and western borders of the project site (Purple hashed polygons, **Figure 2**).

4.0 GEOPHYSICAL ANALYSES

4.1 INTRODUCTION

This report covers the 950-acre proposed Rhudes Creek Profect and is divided into eight project areas and a transmission line right-of-way (ROW). This naming scheme does not necessarily divide the site into distinct subsurface conditions, but was instead based on polygon divisions provided by ANS during the proposal phase of this survey (Areas 1-8 & ROW, **Figure 2**).

4.1.1 Electrical Imaging

Twenty-nine (29) El profiles were collected within the eight (8) project areas and ROW (**Figures 2-11**). All profiles were acquired using a three-meter (9.8 feet) electrode spacing and imaged to a depth of approximately forty-eight (48) feet below grade (ft bg), with slight variations depending on topography.

El test locations were selected to get both a sampling of subsurface conditions across the site and to delineate potential karst features. Potential karst features were determined in the field using a combination of aerial imagery showing farmer-avoidance areas; observations of depressions that either ephemerally or actively held shallow standing water (orange polygons, **Figure 2**); and low-grade erosional creeks that lead to depressions. This report does not include all depressions within the nine (9) study areas.

Low apparent resistivity values are typically associated with soils, saturated materials, and highly weathered bedrock, whereas high apparent resistivity values are associated with rock (increasing with rock competence). Clay materials can exhibit a range of resistivity from 1-100 Ohm-m, sand and shale can exhibit a range from 20-300 Ohm-m, and limestone units can exhibit a range of resistivity from 100-1,000,000 Ohm-m, depending on weathering and porosity. Consequently, very high apparent resistivity measurements can indicate very hard, non-permeable rock (i.e., limestone) or air–filled voids. Very low apparent resistivity measurements can indicate soil or saturated voids.

The preliminary geotechnical report by Terracon observed groundwater between 3-18.5 ft bg at this site. Because groundwater is relatively close to the surface, voids may exist within rock zones that show high variability. Similarly, drier soils near the surface overlying saturated soils at depth are commonly exhibited as resistivity inversions at this site, where a more resistive layer near the surface is underlain by a less resistive layer. In areas with deeper soil, this is likely due to increases in saturation with depth. However, in areas with shallow rock, this resistivity inversion may be caused by more competent rock underlain by more vuggy, saturated rock.

4.1.2 MASW

Eleven (11) 1-D MASW profiles were collected at the center point (~113 feet) of each El profile. MASW test locations were selected to provide a relatively even distribution across the project site and to help further characterize El data. Results are included in this report as stand-alone intervals (**Table 1, Figures 12-15**) and as overlays on El profiles, highlighting velocity increases that may indicate the transition from overburden to bedrock (Vs overlays, **Figures 4-10**). These must be the stars that are on the figures – you have lable them on the figures

Various rock types display unique shear wave velocities that are further impacted by factors such as saturation, temperature, and porosity. Shale has a shear wave velocity of 1,500-8,000 ft/s and limestones exhibit shear wave velocities from 1,000-8,000 ft/s (Greenwood, 2015).

4.2 Area 1

Area 1 is located along the western edge of the project site and measures approximately 75 acres (**Figure 4**). At the time of this survey, this area was highly saturated and is adjacent to an alluvial deposit along the creek (**Figure 3**). KGS sinkhole GIS identified potential karst features along the northern and western edge of this area (Paylor et al. 2003).

El Lines 1 and 3 were collected in saturated surface soil conditions through observed depressions, while Line 2 was collected in a drier area. Additionally, El Line 3 was collected diagonally across the footprint of a proposed substation near the entrance to the transmission line ROW.

No anomalies were identified in EI profiles collected near depressions. However, EI Line 1 exhibits some lateral variation in resistivity at depth, likely due to irregular weathering of limestone surface at depth.

MASW tests M1 and M2, collected in Area 1, indicate that top of rock is at approximately 35-40 ft bg where tested, consistent with an increase in resistivity at those depths along the EI profiles (Vs overlay, **Table 1**; **Figure 4**; **Figure 12**).

4.3 Area 2

Area 2 is located along the southwestern edge of the project site and measures approximately 75 acres (**Figure 5**). Four (4) El profiles and one (1) MASW test were acquired in Area 2. No field depressions or KGS sinkholes were identified in this area, but El Lines 4-5 were collected perpendicular to a low-grade erosional creek that held standing water in some areas (Paylor et al. 2003).

El Lines 4, 6, and 7 exhibit resistivity inversions to varying extents along each profile (**Table 2**). The inversion at 140-226 feet along El Line 4 overlies a decrease in resistivity at depth, indicating a possible increase in shallow porosity caused by deeper karst features. Inversions on El Lines 6 and 7 are likely related to changes in saturation with depth.

MASW test M3, collected in Area 2, indicates that top of rock is at approximately 30 bg, consistent with an increase in resistively at that depth along El Line 7 (Vs overlay, **Table 1**; **Figure 5**; **Figure 12**).

4.4 Area 3

Area 3 is located in the central portion of the project site and measures approximately 204 acres (**Figure 6**). Eight (8) El profiles and two (2) MASW tests were acquired in Area 3. Five (5) field depressions exist along the creek in this area and were imaged on El Lines 9, 10, 11, 14, and 15. These depressions occurred on or near the edges of an alluvial deposit (**Figure 3**).

El Lines 8, 12, 13, 14, and 15 exhibit resistivity inversions to varying extents along each profile (**Table 2**). Inversions on El Lines 8, 13, and 14 are likely related to increasing saturation with depth through a thick overburden layer.

From 45 to 58 feet and 155 to 226 feet along El Line 12, more conductive areas are present in an otherwise resistive shallow subsurface that connects to laterally varied resistivity inversions at depth. These features are characteristic of karst features in saturated conditions. From 20 to 120 feet along El Line 15, apparent resistivities were far greater than other profiles, requiring the use of a different color scale than the rest of the profiles. This highly resistive feature, which overlaps with a dry depression on the surface, is characteristic of an <u>air-filled</u> void.

MASW tests M4 and M5, collected in Area 3, indicate that the top of rock is at approximately 33-38 feet below grade, consistent with an increase in resistivity at those depths along the El profiles (Vs overlay, **Table 1; Figure 6**; **Figure 13**).

4.5 Area 4

Area 4 is located in the north-central portion of the project site and measures approximately 144 acres (**Figure 7**). Three (3) EI profiles and two (2) MASW tests were acquired in Area 4. No field depressions or KGS sinkholes were identified in this area, but EI line 17 was collected perpendicular to a dry erosional creek (Paylor et al. 2003).

El Lines 16 and 17 exhibit resistivity inversions to varying extents along each profile (**Table 2**). These inversions are likely related to increasing saturation with depth through a thick overburden layer. None of the El profiles collected in this area are interpreted to image karst-related features.

MASW tests M6 and M7, collected in Area 4, indicate that there is a variable top of rock at between approximately 17 to 44 feet below grade, consistent with an increase in resistivity at those depths along their respective EI profiles (Vs overlay, **Table 1**; **Figure 7**; **Figures 13-14**)

4.6 Area 5

Area 5 is located in the south-central portion of the project site and measures approximately 115 acres (**Figure 8**). Two (2) El profiles and one (1) MASW tests were acquired in Area 5. No field depressions or KGS sinkholes were identified in this area (Paylor et al. 2003).

El Lines 19 and 20 exhibit laterally extensive resistivity inversions along each profile (**Table 2**). These inversions are likely related to increasing saturation with depth through a thick overburden layer. None of the El profiles collected in this area are interpreted to image karst-related features.

MASW test M8, collected in Area 5, indicates that the top of rock is at approximately 43 feet below grade, consistent with an increase in resistivity at that depth along El Line 20 (**Table 1**; Vs overlay, **Figure 8**; **Figure 14**).

4.7 Area 6

Area 6 is located in the northeastern portion of the project site and measures approximately 141 acres (**Figure 9**). Four (4) El profiles and one (1) MASW tests were acquired in Area 6. No field depressions or KGS sinkholes were identified in this area (Paylor et al. 2003). One field depression was identified in this area and is imaged by El Line 24. KGS sinkholes are present along the northern edge of the project site, including one within the project site that was not observed or imaged in the field. El Line 23 was collected perpendicular to an erosional creek leading into an off-property sinkhole.

All four El Lines collected in this area (Lines 21-24) exhibit laterally varied resistivity inversions along each profile (**Table 2**). This lateral inconsistency suggests that these features may be related to karst features instead of increased saturation with depth in the overburden. While the profiles likely did not image karst features directly, they may be the result of increased porosity in the overlying soils caused by deeper karst features.

MASW test M9, collected in Area 6, indicates that the top of rock is at approximately 41 feet below grade, consistent with an increase in resistivity at that depth along El Line 23 (Vs overlay, **Table 1; Figure 9**; **Figure 14**).

4.8 Areas 7-8

Areas 7 and 8 are located along the southeastern edge of the project site and measure approximately 143 acres combined (**Figure 10**). Four (4) El profiles and one (2) MASW tests were acquired in Areas 7-8. Several KGS sinkholes are located along the eastern edge of Areas 7-8 (Paylor et al. 2003). El Line 26 was collected perpendicular to an erosional creek leading into a sinkhole in the southeast corner of Area 7. Following a heavy rain during field work, the large sinkhole along the southeastern edge of Area 8 was too wet to access and/or survey.

All four EI Lines (Lines 25-28) collected in this area exhibit resistivity inversions to varying extents along each profile (**Table 2**). Inversions on EI Lines 25, 27, and 28 are likely related to changes in saturation with depth in the soil overburden.

From 40-70 feet along EI profile 26, a slight inversion in resistivity may be related to the sinkhole located just east of the profile.

MASW tests M10 and M11, collected in Areas 7 and 8, indicate that the top of rock is at approximately 34-36 feet below grade, consistent with an increase in resistivity at those depths along each EI profile (Vs overlay, **Table 1; Figure 10**; **Figure 15**).

4.9 Right-of-Way (ROW)

The transmission line ROW is a narrow corridor of land extending north of the project site measuring approximately 40 acres (**Figure 11**). ANS request that two additional areas of interest be imaged along this ROW, if time allowed after completing the primary project areas. One surrounded a wetlands area around the middle of the ROW, and the other was for a substation near the northern extent. One El profile was collected about two-thirds of the way

across the central area of interest. However, heavy rain and flooding along the only identified access to the northern portion of the ROW prevent further surveying.

No anomalies were identified in El Line 29, collected over the wetlands area of interest. However, this profile exhibits some lateral variation in resistivity at depth, likely due to irregular weathering of limestone surface.

5.0 CONCLUSION

This geophysical report characterizes a sampling of the subsurface at the approximately 950-acre Rhudes Creek Solar Project located southwest of Cecilia, Kentucky. The area is characterized by surface features that indicate karst is present in the subsurface. Electrical imaging acquired from February 9-11, 2021, confirms the presence of karst features at this site.

The findings and conclusions in this report are stated with a reasonable degree of scientific certainty. THG's findings and conclusions are as follows:

- 1. The project site is located in a geological setting with a high potential for karst development.
- 2. Depth to bedrock is variable, but is commonly greater than 20 feet below grade within the solar project footprint.
- 3. Topographically-derived sinkhole features developed by KGS located with Areas 6 and 8 were not geophysically surveyed, either because they were not observed in the field or conditions were too wet to access.
- 4. Shallow (within 30 ft bg) karst conditions may exist at the following locations:
 - Line 12: 45-58 ft and 155-226 ft
 - Line 15: 20-120 ft (potential air-filled void)
- 5. Deeper (greater than 45 ft) karst conditions may exist at the following locations:
 - Line 4: 155-226 ft
 - Line 21: 110-160 ft
 - Line 22: 160-200 ft
 - Line 23: 20-115 ft
 - Line 24: 140-180 ft
- 6. The results of this survey should be confirmed with drilling.

6.0 REFERENCES

- AGI (2002). EarthImager Program. American Geosciences Inc., Austin Texas.
- deGroot-Hedlin, C. and Constable, S. (1990). Occam's inversion to generate smooth, twodimensional models from magnetotelluric data. Geophysics, V. 55, 1613-1624.
- Greenwood, William (2015). In Situ Shear Wave Velocity Measurements in Rocks. Rock Mechanics Geo Engineer.
- Kepferle, R. C. (1963). Geology of the Cecilia Quadrangle, Kentucky. Kentucky Geologic Survey. Map GQ-263.
- Kepferle, R. C. (1963). Geology of the Howe Valley Quadrangle, Kentucky. Kentucky Geologic Survey. Map GQ-232.
- KGS Databases, Maps, and Publications. KGS Web Map Services: Karst Potential Index (KPI): Kentucky Geological Survey.
- Loke, M. N., and Barker, R. D. (1996). Rapid least-squares inversion of apparent resistivity pseudosection by quasi-Newton method. Geophysical Prospecting, V. 44, 131-152.
- Mavko, G. (2019). Conceptual Overview of Rock and Fluid Factors that Impact Seismic Velocity and Impedance. Stanford Rock Physics Laboratory.
- Mooney, H. M. (1980). Handbook of Engineering Geophysics: Volume 2: Electrical Resistivity, Bison Instruments, Inc.
- Paylor, R.L., Florea, L., Caudill, M., & Currens, J. C. (2003). A GIS Sinkhole Coverage for the Karst Areas of Kentucky. Kentucky Speleological Survey, Inc., 228 Mining and Minerals Resources Building, Lexington, KY.
- Reynolds, J. M. (1997). An Introduction to Applied and Environmental Geophysics. New York, NY, Wiley.
- Xia, J.; Miller, R. D.; Park, C. B.; Hunter J. A.; Harris, J. B.; and Ivanov, J., (2002), Comparing shear-wave velocity profiles inverted from multi-channel surface wave with borehole measurements: *Soil Dynamics Earthquake Engineering*, Vol. 22, pp. 181-190.

Geophysical investigations are a non-invasive method of interpreting physical properties of the shallow earth using electrical, electromagnetic, or mechanical energy. This document contains geophysical interpretations of responses to induced or real-world phenomena. As such, the measured phenomenon may be impacted by variables not readily identified in the field that can result in a false-positive and/or false negative interpretations. THG makes no representations or warranties as to the accuracy of the interpretations.

TABLE 1
MASW Shear Wave Velocity Data

MASW ID	Easting	Northing	Elevation at	Depth	Elevation	Shear Wave
IIIAOW IB	Laoting	Northing	Surface	(ft/bg)		Velocity (ft/S)
				-2	710	749
				-3	708	764
				-6	705	808
				-9	702	864
М1	4,847,395	3,764,117	711	-13	699	859
'*'	4,047,090	5,704,117	711	-17	694	742
				-23	688	751
				-30	681	929
				-39	672	1,105
				-49	662	1,876
				-3	699	542
				-7	695	492
				-12	690	534
				-19	684	686
Ma	4 047 567	3,764,507	703	-26	676	935
М2	4,847,567			-36	666	1,168
				-49	654	1,285
				-64	639	1,428
				-83	619	1,580
				-104	599	2,521
	4,845,895	3,760,254	735	-2	733	872
				-4	731	915
				-8	728	965
				-11	724	973
				-16	719	913
М3				-22	713	910
				-30	705	1,013
				-39	696	1,146
				-51	684	1,367
				-64	671	2,108
				-3	719	909
				-6	716	924
				-10	712	920
				-15	707	872
	4.040.070	0.704.007	700	-21	701	756
M4	4,849,376	3,764,237	722	-29	693	815
				-38	684	1,056
				-51	671	1,414
				-66	656	1,758
				-82	640	2,859

NOTES:

Coordinates - NAD83 State Plane (Kentucky Single Zone), US Survey ft

TABLE 1
MASW Shear Wave Velocity Data

MASW ID	Easting	Northing	Elevation at Surface	Depth (ft/bg)	Elevation	Shear Wave Velocity (ft/S)
				-4	701	921
				-9	696	638
				-15	690	638
				-23	682	847
	4 050 740	0.700.047	705	-33	672	1,144
M5	4,850,718	3,762,617	705	-45	660	1,296
				-60	645	1,475
				-79	626	1,748
				-102	602	2,173
				-128	577	3,702
				-2	744	776
				-5	742	875
				-8	738	792
				-13	734	792
М6	4,852,592	3,763,903	747	-18	728	965
""	4,002,092			-25	722	749
				-34	713	834
				-44	702	1,168
				-57	689	1,344
				-72	675	1,785
			3,216 719	-1	718	1,160
				-3	717	1,033
	4,855,650			-4	715	907
				-7	713	907
М7		3,763,216		-9	710	907
		-,,		-13	706	907
				-17	702	1,274
				-23	697	1,737
				-30	690	1,688
				-37	682	2,381
				-3	694	783
				-6	691	783
				-11	686	783
				-17	681	783
М8	4,852,128	3,760,690	697	-24	674	783
				-32	665	913
				-43	654	1,454
				-57	640	1,142
				-74	623	1,805
				-93	604	2,071

NOTES:

Coordinates - NAD83 State Plane (Kentucky Single Zone), US Survey ft

TABLE 1
MASW Shear Wave Velocity Data


MASW ID	Easting	Northing	Elevation at Surface	Depth (ft/bg)	Elevation	Shear Wave Velocity (ft/S)
				-2	711	736
				-5	709	862
				-8	706	777
				-12	701	784
М9	4,856,770	3,762,376	713	-17	696	698
IVIS	4,630,770	3,702,370	713	-24	690	617
				-32	682	998
				-41	672	1,241
				-54	660	1,434
				-67	646	2,392
			727	-2	725	803
	4,856,106	3,760,208		-4	723	877
				-7	720	829
				-10	716	829
M10				-15	712	829
14110				-20	706	885
				-27	700	646
				-36	691	877
				-46	680	1,148
				-58	669	1,673
				-2	696	699
				-4	693	932
				-7	691	825
				-10	687	825
M11	4,854,104	3,757,464	697	-14	683	966
'*' '	-7,007,107	0,101,707	007	-20	678	691
				-26	671	941
				-34	663	748
				-45	653	1,398
				-56	641	1,530


NOTES:


Coordinates - NAD83 State Plane (Kentucky Single Zone), US Survey ft

TABLE 2 El Profile Features

Figure	Area	El Line	Surface	Surface	Resistivity	Potentially Karst	Notes
1 iguio	Aiou		Feature	Location (ft)	Inversion	Related	110100
		1	Depression	72 - 141			
4	1	2			Yes		
		3	Depression	130 - 170			Standing water; Substation
		4	Erosion creek	132	Yes	Yes, Deep	
5	2	5	Erosion creek	116			Standing water
5		6			Yes		
		7	Pond	170 SW	Yes		
		8	Boring B-7	110	Yes		
		9	Depression	70 - 167			Standing water
		10	Depression	77 - 156			Standing water
6	3	11	Depression	40 - 160			Standing water
O	3	12			Yes	Yes	
		13	Pond	260 N	Yes		Wet area
		14	Depression	47 - 141	Yes		
		15	Depression	74 - 160	Yes	Yes, air-filled	Different color scale
		16	Pond	100 NW	Yes		
7	4	17	Erosion creek	87	Yes		Dry
		18	Depression	100 NE			Trees-not farmed
8	5	19			Yes		
0	ວ	20			Yes		
		21			Yes	Yes, Deep	
0	_	22	Pond	22 E	Yes	Yes, Deep	
9	6	23	Erosion creek	70	Yes	Yes, Deep	Leads into sinkhole
		24	Depression	87 - 175	Yes	Yes, Deep	Standing water
10	7	25	Erosion creek	50	Yes		Leads into sinkhole
10	'	26			Yes	Yes, offset from profile	
10	0	27			Yes		
10	8	28	Erosion creek	80	Yes		
11	ROW	29	Depression	300 - 474			Standing water







Notes

Geophysical survey conducted February 8-12, 2021 using a GF Instruments ARES II electrical resistivity meter with active multi-electrode cable sections and Geometrics Geode 24-channel seismograph.

Real-time positioning of data using fully integrated Trimble Geo-7X global positioning system set to NAD 1983 US State Plane (Kentucky Single Zone) coordinate system in US Survey feet.

Locations are approximate.


GIS Overlays: Topography Provided by TRC Companies on 4/7/2021


Water Bodies & Stream Flow Lines USGS NHD for Hydrologic Unit 8 - 05110001, 2021


Sinkholes
Paylor, R.L., Florea, L., Caudill, M., & Currens, J. C. (2003). A GIS Sinkhole Coverage for the Karst Areas of Kentucky. Kentucky Speleological Survey, Inc., 228 Mining and Minerals Resources Building, Lexington, KY.


DRN	AXB	2/15/21	PROJECT:		
DE\$	AXB	2/15/21	Geophysical Investigation Rhudes Creek Solar Project Cecilia, Kentucky		
СНК	PJH	2/23/21			
REV	MLT	4/15/21			
PROJ. MGR.	АХВ	2/23/21			
SCALE: 1	in = 750) ft	DRAWING NO.:		
	S High Roimagery	esolution 2012	Karst Hazard Map		
PREPARED FO	R:		PROJECT NO.: 1265-1073	36	
			SHEET TITLE: DWG10736F		

Line 1 W Depression Distance (ft) E O 20 40 60 80 100 120 140 160 180 200 220 -10 -10 -10 -20 -40 -40









Notes

Geophysical survey conducted February 8-12, 2021 using a GF Instruments ARES II electrical resistivity meter with active multi-electrode cable sections and Geometrics Geode 24-channel seismograph.

Horizontal Scale 1 in = 40 ft Vertical Scale 1 in = 40 ft No Vertical Exaggeration.

DRN	AXB	2/16/21	PROJ
DES	AXB	2/16/21	
СНК	PJH	2/23/21	
REV			
PROJ. MGR.	AXB	2/23/21	
SCALE:	DRAWIN		

USGS 2012

4280 Old William Penn Hwy
Murrysville, Pennsylvania 15668
(724) 325-3996 Fax: (724) 733-7901
www.thggeophysics.com

Geophysical Investigation
Rhudes Creek Solar Project
Cecilia, Kentucky


DRAWING NO.:


Figure 4El Profiles - Area 1


PARED FOR:




1265-10736 SHEET TITLE:











Color Scale (Ohm-m)







Electrical Imaging Profile (arrow indicates direction)

Project Boundary

Geotechnical Boring

1D MASW

Right-of-Way

Area of Interest/ Substation NHD Water Bodies

Topographically-derived Sinkholes (Paylor et al. 2003)

Shear Wave Velocity Profile (Vs, ft/s) Star at 1st interval >1,000 ft/s

1265-10736

DWG10736F5


Observed Depressions (field)


Notes

Geophysical survey conducted February 8-12, 2021 using a GF Instruments ARES II electrical resistivity meter with active multi-electrode cable sections and Geometrics Geode 24-channel seismograph.


Horizontal Scale 1 in = 30 ft Vertical Scale 1 in = 30 ft No Vertical Exaggeration.


			HGEOPHYSICS 4280 Old William Penn Hwy Murrysville, Pennsylvania 15668 (724) 325-3996 Fax: (724) 733-7901 www.thggeophysics.com
DRN	AXB	2/16/21	PROJECT:
DES	AXB	2/16/21	Geophysical Investigation
СНК	PJH	2/23/21	Rhudes Creek Solar Project
REV			Cecilia, Kentucky
PROJ. MGR.	AXB	2/23/21]
SCALE: As Shown			DRAWING NO.: Figure 5
	SGS 2012 irthimage	-	El Profiles - Area 2
DDEDARED CO	n.		PROJECT NO.:







Line 19 SW Distance (ft) NE 20 40 60 80 100 120 140 160 180 200 220 Depth (ft bg) -20 -20 -30--30 -40









Legend

Electrical Imaging Profile (arrow indicates direction)

☆ 1D M

1D MASW

Project Boundary

Right-of-Way

Geotechnical Boring

Area of Interest/ Substation

NHD Water Bodies

NHD Flow Lines

Topographically-derived Sinkholes (Paylor et al. 2003)

Observed Depressions (field)

<u>Notes</u>

Shear Wave

(Vs, ft/s)

>1,000 ft/s

Velocity Profile

Star at 1st interval

Geophysical survey conducted February 8-12, 2021 using a GF Instruments ARES II electrical resistivity meter with active multi-electrode cable sections and Geometrics Geode 24-channel seismograph.

Horizontal Scale 1 in = 40 ft Vertical Scale 1 in = 40 ft No Vertical Exaggeration.



4280 Old William Penn Hwy
Murrysville, Pennsylvania 15668
(724) 325-3996 Fax: (724) 733-7901
www.thggeophysics.com

PROJECT:

2/16/21

2/16/21

2/23/21

2/23/21

AXB

РЈН

As Shown

USGS 2012 Earthimager 2D Geophysical Investigation Rhudes Creek Solar Project Cecilia, Kentucky

DRAWING NO.:

Figure 8
El Profiles - Area 5

PARED FOR:

PROJ. MGR. AXB


DES


снк


REV





1265-10736 sheet title: DWG10736F8















Color Scale (Ohm-m)





Notes

Geophysical survey conducted February 8-12, 2021 using a GF Instruments ARES II electrical resistivity meter with active multi-electrode cable sections and Geometrics Geode 24-channel seismograph.


Horizontal Scale 1 in = 30 ft Vertical Scale 1 in = 30 ft No Vertical Exaggeration.

		,		
			GEOPHYSICS	4280 Old William Penn Hwy Murrysville, Pennsylvania 15668 (724) 325-3996 Fax: (724) 733-7901 www.thggeophysics.com
DRN	AXB	2/16/21	PROJECT:	
DES	AXB	2/16/21	Geophy	sical Investigation
снк	PJH	2/23/21	Rhudes Creek Solar Project Cecilia, Kentucky	
REV				
PROJ. MGR.	AXB	2/23/21		
SCALE: As Shown			DRAWING NO.:	Figure 9
SOURCE: USGS 2012 Earthimager 2D			EIP	rofiles - Area 6
PREPARED FOR:		NIC	PROJECT NO.: 1265-10736	
A				SHEET TITLE: DWG10736F9






Depth (ft bg)




Depth	Shear Wave	
(ft bgs)	Velocity (ft/s)	
() ,	, (, ,	
-2	749	
-3	764	
-6	808	
-9	864	
-13	859	
-17	742	
-23	751	
-30	929	
-39	1,105	
-49	1,876	

MASW M2



Depth	Shear Wave
(ft bgs)	Velocity (ft/s)
-3	542
-7	492
-12	534
-19	686
-26	935
-36	1,168
-49	1,285
-64	1,428
-83	1,580
-104	2,521

MASW M3



Depth	Shear Wave
(ft bgs)	Velocity (ft/s)
-2	872
-4	915
-8	965
-11	973
-16	913
-22	910
-30	1,013
-39	1,146
-51	1,367
-64	2,108


Notes

Geophysical survey conducted February 8-12, 2020 using Geometrics ES-3000 seismograph, 4.5 Hz geophones and SurfSeis 6.0.1.46 software.

			4280 Old William Penn Hwy Murrysville, Pennsylvania 15668 (724) 325-3996 Fax: (724) 733-7901 www.thggeophysics.com	
DRN	AXB	2/17/21	PROJECT:	
DES	AXB	2/17/21	Geophysical Investigation Rhudes Creek Solar Project	
снк	РЈН	2/18/21		
REV			Cecilia, Kentucky	
PROJ. MGR.	AXB	2/18/21		
SCALE: Not to Scale		ale	DRAWING NO.: Figure 12	
SOURCE: SurfSeis 6.0.1.46		0.1.46	MASW Data - M1-M3	


11-M3

1265-10736 DWG10736F12




Shear Wave
Velocity (ft/s)
909
924
920
872
756
815
1,056
1,414
1,758
2,859

MASW M5



Depth (ft bgs)	Shear Wave Velocity (ft/s)
-4	921
-9	638
-15	638
-23	847
-33	1,144
-45	1,296
-60	1,475
-79	1,748
-102	2,173
-128	3,702

MASW M6




Depth (ft bgs)	Shear Wave Velocity (ft/s)
-2	776
-5	875
-8	792
-13	792
-18	965
-25	749
-34	834
-44	1,168
-57	1,344
-72	1,785

DWG10736F13

Notes


Geophysical survey conducted February 8-12, 2020 using Geometrics ES-3000 seismograph, 4.5 Hz geophones and SurfSeis 6.0.1.46 software.

			GEOPHYSICS Murrysville (724) 325-3	Villiam Penn Hwy e, Pennsylvania 15668 1996 Fax: (724) 733-7901 eophysics.com
DRN	AXB	2/17/21	PROJECT:	
DES	AXB	2/17/21	Geophysical In	vestigation
снк	РЈН	2/18/21	Rhudes Creek Solar Project Cecilia, Kentucky	
REV				
PROJ. MGR.	АХВ	2/18/21]	
SCALE: Not to Scale			DRAWING NO.: Figure	13
SOURCE: SurfSeis 6.0.1.46			MASW Data - M4-M6	
PREPARED FO	R:		NIC	PROJECT NO.: 1265-10736




Depth (ft bgs)	Shear Wave Velocity (ft/s)
-1	1,160
-3	1,033
-4	907
-7	907
-9	907
-13	907
-17	1,274
-23	1,737
-30	1,688
-37	2,381

MASW M8



Depth	Shear Wave
(ft bgs)	Velocity (ft/s)
-3 -6 -11 -17 -24 -32 -43	783 783 783 783 783 913 1,454 1,142
-74	1,805
-93	2,071

MASW M9




Depth	Shear Wave
(ft bgs)	Velocity (ft/s)
-2	736
-5	862
-8	777
-12	784
-17	698
-24	617
-32	998
-41	1,241
-54	1,434
-67	2,392

DWG10736F14

<u>Notes</u>


Geophysical survey conducted February 8-12, 2020 using Geometrics ES-3000 seismograph, 4.5 Hz geophones and SurfSeis 6.0.1.46 software.

			HGEOPHYSICS Murrysville, Pennsylvania 15668 (724) 325-3996 Fax: (724) 733-7901 www.thggeophysics.com	
DRN	AXB	2/17/21	PROJECT:	
DES	AXB	2/17/21	Geophysical Investigation	
снк	PJH	2/18/21	Rhudes Creek Solar Project Cecilia, Kentucky	
REV				
PROJ. MGR.	AXB	2/18/21		
SCALE: Not to Scale		ale	DRAWING NO.: Figure 14	
Source: SurfSeis 6.0.1.46			MASW Data - M7-M9	
PREPARED FO	R:	A	PROJECT NO.: 1265-10736	



Depth	Shear Wave	
(ft bgs)	Velocity (ft/s)	
-2	803	
-4	877	
-7	829	
-10	829	
-15	829	
-20	885	
-27	646	
-36	877	
-46	1,148	
-58	1,673	

MASW M11



Depth	Shear Wave	
(ft bgs)	Velocity (ft/s)	
-2	699	
-4	932	
-7	825	
-10	825	
-14	966	
-20	691	
-26	941	
-34	748	
-45	1,398	
-56	1,530	

Notes

Geophysical survey conducted February 8-12, 2020 using Geometrics ES-3000 seismograph, 4.5 Hz geophones and SurfSeis 6.0.1.46 software.

			4280 Old William Penn Hwy Murrysville, Pennsylvania 15668 (724) 325-3996 Fax: (724) 733-7901 www.thggeophysics.com	
DRN	AXB	2/17/21	PROJECT:	
DES	AXB	2/17/21	Geophysical Investigation Rhudes Creek Solar Project Cecilia, Kentucky	
СНК	PJH	2/18/21		
REV				
PROJ. MGR.	AXB	2/18/21		
SCALE: Not to Scale		ale	DRAWING NO.: Figure 15	
Source: SurfSeis 6.0.1.46			MASW Data - M10-M11	
PREPARED FOR: PROJECT NO.: 1265-10736 SHEET TITLE:				

DWG10736F15

Attachment H

Terracon's Preliminary Geotechnical Engineering Report





LGE-KU Solar Project Cecilia, Hardin County, Kentucky

December 30, 2020 Terracon Project No. 57205074

Prepared for:

ibV Energy Partners, LLC Miami, Florida

Prepared by:

Terracon Consultants, Inc. Louisville, Kentucky

Environmental Facilities Geotechnical Materials

December 30, 2020



ibV Energy Partners, LLC 777 Brickell Ave Ste 500 Miami, Florida 33131-2809

Attn: Mr. Steven Link, Sr. Director – Project Development

P: (954) 319-4143

E: steven.link@ibvenergy.com

Re: Preliminary Geotechnical Engineering Report

LGE-KU Solar Project

Cecilia, Hardin County, Kentucky Terracon Project No. 57205074

Dear Mr. Link:

We have completed the Preliminary Geotechnical Engineering services for the above referenced project. This study was performed in general accordance with Terracon Proposal No. P57205074 dated September 25, 2020. This report presents the findings of the subsurface exploration and provides preliminary geotechnical recommendations concerning earthwork and solar panel foundations for the proposed project.

We appreciate the opportunity to be of service to you on this project. If you have any questions concerning this report or if we may be of further service, please contact us.

Sincerely,

Terracon Consultants, Inc.

Sadra Javadi, Ph.D. Geotechnical Engineer Benjamin W. Taylor, P.E. Principal, Regional Manager

SME Reviewer: James M. Jackson, P.E. (FL)

Terracon Consultants, Inc. 13050 Eastgate Park Way Suite 101 Louisville, Kentucky 40223 P (502) 456 1278 F (502) 456 1278 terracon.com

REPORT TOPICS

INTRODUCTION	1
SITE CONDITIONS	2
PROJECT DESCRIPTION	3
GEOTECHNICAL CHARACTERIZATION	4
GEOTECHNICAL OVERVIEW	5
CONTRIBUTORY RISK COMPONENTS	7
PRELIMINARY RECOMMENDATIONS FOR DRIVEN PILE FOUNDATIONS	ç
PRELIMINARY RECOMMENDATIONS FOR ISOLATED SLAB FOUNDATIONS	
PRELIMINARY RECOMMENDATIONS FOR SUBSTATION AND TRANSMISS	ION
LINE FOUNDATIONS	
PRELIMINARY EARTHWORK RECOMMENDATIONS	16
SEISMIC CONSIDERATIONS	16
CORROSIVITY	
GENERAL COMMENTS	
FIGURES	1
ATTACHMENTS	2

Note: This report was originally delivered in a web-based format. **Orange Bold** text in the report indicates a referenced section heading. The PDF version also includes hyperlinks which direct the reader to that section and clicking on the **GeoReport** logo will bring you back to this page. For more interactive features, please view your project online at client.terracon.com.

ATTACHMENTS

PHOTOGRAPHY LOG
EXPLORATION AND TESTING PROCEDURES
SITE LOCATION AND EXPLORATION PLANS
EXPLORATION RESULTS
SUPPORTING INFORMATION

Note: Refer to each individual Attachment for a listing of contents.

LGE-KU Solar Project
Cecilia, Hardin County, Kentucky
Terracon Project No. 57205074
December 30, 2020

INTRODUCTION

This report presents the results of our preliminary subsurface exploration and geotechnical engineering services performed for the proposed 100-Megawatt (Mw) AC photovoltaic (PV) solar power facility to be located in Cecilia, Hardin County, Kentucky. The purpose of these services is to provide information and preliminary geotechnical engineering recommendations relative to:

- Subsurface Soil Conditions
- Foundation Design and Construction
- Corrosivity Testing
- Site Preparation and Earthwork
- Groundwater Considerations
- Seismic Site Classification per IBC
- Thermal Resistivity Testing

The scope of services for this project included the advancement of 18 test borings to the depths ranging between 9½ to 46 feet below existing site grades, field electrical resistivity and laboratory testing.

Maps showing the site and exploration locations are shown in the **Site Location** and **Exploration Plans**. The results of the laboratory testing performed on soil samples obtained from the site during the field exploration are included on the boring logs and/or as separate graphs in the **Exploration Results** section.

The General Comments section provides an understanding of the report limitations.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



SITE CONDITIONS

The following description of site conditions is derived from our site visit in association with the field exploration and our review of publicly available geologic and topographic maps.

Item	Description		
Parcel Information	The project site consists of approximately 945 acres and 7,300 linear feet of Right of Way (ROW) located on Hardinsburg Road in Cecilia, Hardin County, Kentucky. The approximate coordinates of the site are: 37.655705°, -85.990534°. See Site Location		
Existing in a northeast-southwest direction. Multiple small wooded areas within the project boundaries. A train track parallel to the South Road crosses the southeast portion of the site.			
Current Ground Cover	The project site is covered with crops, bare soil, and grass with isolated stands of trees presenting between the fields, residential houses, roads/driveways, and ponds.		
Site-specific topographic survey was not available at the time of a Based on review of topographic elevation in Google Earth Pro ^T observation during exploration, the site appears to generally be hill surface sloping from an approximate elevation of 770 feet in the We 695 feet in the Southeast.			
	The project site is mapped within an area reported by the Kentucky Geological Survey (KGS) to have a very high karst potential. Multiple sinkholes are mapped by the KGS within 1-mile of the site. Further, there are several sinkholes mapped within the site boundaries. A quarry is mapped to the Southeast of the site. It is common for quarry operations to cause fluctuations in the local groundwater levels which can affect sinkhole development in adjacent areas.		
Coology	The project site mapped with the following underlying bedrock geology:		
Geology	Ste. Genevieve Limestone		
Cecilla Quadrangle GQ-263 Hardin County, KY by the Kentucky Geological Survey (KGS)	Primary Lithology: Limestone, dolomite, and Shale Limestone is light-yellowish-gray that is weathered partially with white to light- gray color, interbedded with about equal amounts of light-gray to light-brownish- gray sublithographic to medium-grained clastic limestone, locally shaly, cherty or pyritic. Dolomite is yellowish gray, very fine grained, massive; locally calcareous and contains fist-sized vugs filled with crystalline calcite. Silty clay shale is yellowish to greenish gray, locally calcareous.		
	Alluvium Primary Lithology: Sand, silt, clay, and gravel Sand is very fine to fine grained, poorly graded, interbedded with silt and clay. Gravel composed of pebbles, cobbles, and scattered boulders of chert, limestone, and some cemented sandstone. Clayey and silty sand in large shallow sinks. Bedrock exposed in stream beds of West Rhudes, Shaw, and Valley Creeks in narrow strips too small to show on map.		

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



PROJECT DESCRIPTION

Our understanding of the project conditions is as follows:

Item	Description		
Information Provided	The updated project boundary New LGE-KU Sites- Primary RoW.kmz was provided to us by Mr. Link with ibV via email dated September 8, 2020. The ALTA/NSPS TITLE SURVEY dated January 29, 2020, prepared by Harris Gary, LLC. was provided to us via email on August 19, 2020. The ALTA map was preliminary and did not include the elevations.		
Project Description	It is our understanding that the Client intends to develop a 100 MWac solar facility consisting of photovoltaic (PV) solar facility. Ultimately, the facility will consist of solar panels and various other equipment associated with the substation and O&M Building (e.g. switchgear, transformers, inverters, and overhead and underground electrical conveyance). We understand that electrical transmission lines are planned to be constructed at right-of-way. We assumed transmission towers will be supported on drilled shaft foundation.		
Proposed Structures	Photovoltaic panels are anticipated to be supported on steel racking system founded on wide flange piles (W6x9 or similar) or other proprietary sections. Electrical equipment will be supported on concrete slabs-on-grade, spread footings, or drilled piers.		
Maximum Loads	Structural loads were not provided at the time of this report. Based on our experience with fixed rack systems, we have assumed the following structural loading. Downward: 3 to 7 kips Uplift: 2 kips Lateral: 1.5 to 3.5 kips Substation Structures: 1,500 psf (Substation dimensions were not provided to us at the time of this report. Based on the provided kmz file we assumed that the substation dimensions are 350 ft by 400 ft) O&M Building: 5 kips per linear foot (klf)		
Grading/Slopes	A site grading plan has not been developed at this time. It is anticipated that the site work will be minimal, with cuts and fills within +/- 2 feet of existing grade. Localized high and low areas may require greater cut and/or fill.		
Pavement	We anticipate low-volume, aggregate-surfaced and native soil access roads will primarily service relatively light maintenance vehicles (pick-up trucks) with a few heavier delivery vehicles (maximum load of 30,000 lbs.) throughout their post-construction life.		
Estimated Start of Construction			

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



GEOTECHNICAL CHARACTERIZATION

We have developed a general characterization of the subsurface conditions based upon our review of the subsurface exploration, laboratory data, geologic setting and our understanding of the project. This characterization, termed GeoModel, forms the basis of our geotechnical calculations and evaluation of site preparation and foundation options. Conditions encountered at each exploration point are indicated on the individual logs. The individual logs can be found in the **Exploration Results** section and the GeoModel can be found in the **Figures** section of this report.

As part of our analyses, we identified the following model layers within the subsurface profile. For a more detailed view of the model layer depths at each boring location, refer to the GeoModel.

Model Layer	Layer Name	General Description
1	LEAN CLAY (CL)	with silt, trace fine sand, brown with reddish brown, soft to hard
2	FAT CLAY (CH)	trace fine sand, with limestone fragments, reddish brown to brown and gray, soft to stiff
3	SILTY SAND (SM)	black, medium dense
4	LIMESTONE	light with dark gray, moderate to very close spacing, thin bedding, unweathered to slightly weathered, medium strong to very strong rock

The boreholes were observed while drilling and after completion for the presence and level of groundwater. The water levels observed in the exploration locations can be found on the boring logs in **Exploration Results** and are summarized below.

Boring Number	Approximate Depth to Groundwater while Drilling ¹ (ft)
B-3	12
B-6	18½
ROW-1	3½
ROW-2 ²	13
ROW-4 ²	13
ROW-5 ²	3
ROW-7 ²	8

^{1.} Below ground surface.

Groundwater was not observed in the other borings while drilling, or for the short duration the borings could remain open. However, this does not necessarily mean the borings terminated above groundwater, or the water levels summarized above are stable groundwater levels. Due to

^{2.} Water was used as drilling fluid during for rock coring and the actual water level could be affected due to the introduced water to the borehole.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



the relatively low permeability of the soils encountered in the boring, a relatively long period of time may be necessary for a groundwater level to develop and stabilize in a borehole in these materials. Long-term observations in piezometers or observation wells sealed from the influence of surface water are often required to define groundwater levels in materials of this type.

Groundwater level fluctuations occur due to seasonal variations in the amount of rainfall, runoff and other factors not evident at the time the borings were performed. Therefore, groundwater levels during construction or at other times in the life of the structure may be higher or lower than the levels indicated on the boring logs. The possibility of groundwater level fluctuations should be considered when developing the design and construction plans for the project.

GEOTECHNICAL OVERVIEW

Our exploration encountered overburden that generally consisted of low plasticity LEAN CLAY (CL) underlain by highly plastic FAT CLAY (CH). At boring B-3, SILTY SAND (SM) was encountered below the FAT CLAY (CH). The consistency of native cohesive soils ranged from soft to hard. Rock coring was performed as part of this preliminary exploration at borings B-11, and ROW-1 through ROW-7. Rock core samples consist of unweathered to slightly weathered, medium to very strong limestone.

As discussed in the Geology section, the site is reported to have a very high karst potential. Multiple sinkholes are mapped by the KGS within 1-mile radius inside and on west, north, and east side of the site. Soil softening with depth, which can be indicative of soil raveling into subsurface voids was observed below depths of:

- 5 feet at ROW-4,
- 10 feet at borings B-2, B-4, B-6, B-8, ROW-2, and
- 15 feet at borings B-5, B-7, B-9, B-10, B-11, and ROW-1

Considering the very high karst potential and sinkholes previously mapped by the Kentucky Geological Survey (KGS) as well as the observations noted from boring logs, we recommend Terracon be engaged to perform a karst survey for the site during the project's preliminary assessment and design phase. The purpose of the karst survey will be to identify and delineate existing karst features, evaluate site feasibility for development, assess karst risk, and recommend avoidance and mitigation measures.

Borings were advanced to auger refusal at depths of 6½ to 26 feet below existing grade. Auger refusal is defined as the depth below the ground surface at which a test boring can no longer be advanced with the soil drilling technique being used. Karst bedrock, such as the Ste. Genevieve Limestone formation is known for producing several obstructions that can cause the augers to refuse above sound bedrock.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074




These obstructions can range from floaters to rock pinnacles as illustrated in Examples A, B, C, and D in the figure. Depth to competent bedrock can vary greatly over short distances. The possibility of varying depths to bedrock should be considered when developing the design and construction plans for this project.

Specific conditions encountered at the exploration locations are indicated by the **Exploration Results**. Stratification boundaries on the boring log represent the approximate location of changes in soil types; in-situ, the transition between materials may be gradual.

Due to the residual nature of the overburden soils, rock fragments, chert, and cobbles should be expected. Therefore, it is possible that piles driven into the overburden soils and weathered rock stratum can

AUGER REFUSAL ILLUSTRATION



THIS FIGURE IS FOR ILLUSTRATIVE PURPOSES ONLY AND DOES NOT NECESSARILY DEPICT THE SPECIFIC BEDROCK CONDITIONS AT THIS SITE

encounter difficult driving or shallow refusal across most of the site. Pre-drilling of undersized holes and backfilling with soil cuttings may be required to accommodate pile installation in areas where driving piles is difficult. We recommend a pile driving and testing program be developed to assess the difficulty of piles penetrating the onsite soils. The pile test program should include pre-drilling.

Design recommendations and construction considerations for the solar PV panel foundations are presented in the **Foundations** section of this report.

Terracon should be retained for final, design-level geotechnical engineering services and during construction of the project to observe earthwork and to perform necessary tests and observations during pile driving, subgrade preparation; proof-rolling; placement and compaction of controlled compacted fill; backfilling of excavations in the completed subgrade; and for construction of foundations.

Preliminary recommendations contained in this report are based upon the data obtained from the limited number of test borings. This report does not reflect conditions between the points investigated, or between sampling intervals in test borings. The nature and extent of variations between test borings and sampling intervals may not become evident until the course of construction. A detailed subsurface geotechnical investigation should be completed prior to final design and construction to assess localized subsurface conditions at proposed structure locations.

The General Comments section provides an understanding of the report limitations.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



CONTRIBUTORY RISK COMPONENTS

ITEM	DESCRIPTION		
Supplemental Exploration and Services	Additional soil test borings should be performed to adequately explore the site as part of a design-level study. Additionally, a full-scale pile load testing (PLT) program should be considered as the project design progresses. The results of a full scale PLT program in conjunction with soil test boring/test pit results are often successful in reducing the design embedment depth when compared to designs solely based on explorative results and analytical methods.		
Soil Conditions	Project site subsurface profile consisted of predominately native cohesive soil underlain by limestone to the depths explored. The surface layer at the site generally contained top soil up to approximately 18 inches thick. These soils are not considered suitable for subgrade support or reuse as fill material. The borings encountered highly expansive soils. Please see information related to expansion soil hazards below.		
Karst Potential	Borings were advanced to auger refusal at depths of 6½ to 26 feet below existing grade. Auger refusal is defined as the depth below the ground surface at which a test boring can no longer be advanced with the soil drilling technique being used. Karst bedrock, such as the Ste. Genevieve Limestone formation is known for producing several obstructions that can cause the augers to refuse above sound bedrock. Depth to competent bedrock can vary greatly over short distances. The possibility of varying depths to bedrock should be considered when developing the design and construction plans for this project. Based on the auger refusal depth encountered in our exploration program, the bedrock elevation varies across the site. The project site is mapped within an area reported by the Kentucky Geological Survey (KGS) to have a very high karst potential. Multiple sinkholes are mapped by the KGS within 1-mile of the site. Further, there are several sinkholes mapped within the site boundaries. A quarry is mapped to the Southeast of the site. It is common for quarry operations to cause fluctuations in the local groundwater levels which can affect sinkhole development in adjacent areas.		
Access	Wet and loose/soft surface conditions due to rainwater will create access issues for vehicles. The site will generally be more accessible in the summer and early fall due to the improved drying conditions.		
Grading	We anticipate very little grading will be required. On-site materials that are used as fill or backfill will likely require drying prior to re-compaction as engineered fill. Alternatively, these materials could be replaced with imported soils containing an appropriate moisture content. We expect localized areas of unsuitable conditions will be encountered prior to placing fill and within the subgrade for roadways and shallow foundations that are planned. Stabilization measures, such as over-excavation and replacement, should be expected.		
Groundwater	Groundwater was observed in 7 borings at completion of drilling, and was not observed at the rest of borings. However, this does not necessarily mean the borings terminated above groundwater. Due to the relatively low permeability of the soils encountered in the boring, a relatively long period of time may be necessary for a groundwater level to develop and stabilize in a borehole in these		

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



ITEM	DESCRIPTION		
	materials. Based on our experience in the project area, groundwater level fluctuation should be anticipated at times during the design period for the project. Excavations, such as trenches for electrical cable and conduit, could encounter groundwater and require dewatering. Excavations for shallow foundations could also encounter groundwater, especially if construction is performed during periods of seasonally high groundwater.		
Site Drainage	Final site grading may impact the drainage within the site. A drainage study should be performed once a grading plan has been finalized to review potential drainage or flooding issues.		
Corrosion Hazard ¹	Based on field resistivity data and laboratory testing for electrical resistivity and chemical properties, the site soils have a moderate corrosion range to buried metal per corrosion guideline from U.S Department of Transportation Federal Highway Administration. The soils have a 'negligible' classification for sulfate exposure according to ACI Design Manual. The results of our laboratory testing of soil chemical properties (provided in the attachment) are expected to assist a qualified engineer to design corrosion protection for the production piles and other project elements.		
Expansive Soil Hazards	Except boring ROW-3, highly expansive soils were encountered at all boring locations within the upper 10 ft during the subsurface exploration and soils in the region may experience moisture content fluctuations to some extent. Therefore, expansive behavior may be anticipated for the site soils. Further impact of highly expansive soils should be investigated in detail using additional evaluations such as swell test. This report provides recommendations to help mitigate the effects of soil shrinkage and expansion. However, even if these procedures are followed, some movement and (at least minor) cracking in the structure should be anticipated. The severity of cracking and other damage such as uneven floor slabs will probably increase if modification of the site results in excessive wetting or drying of the expansive soils. Eliminating the risk of movement and distress may not be feasible, but it may be possible to further reduce the risk of movement if significantly more expensive measures are used during construction. Depending on the final grading plan, remedial measures may be implemented to limit swelling potential, such as over-excavation and replacement with 2-foot of low volume change (LVC) materials, treatment with a chemical admixture, etc.		
Slope Hazards	The site is generally located in a relatively flat area.		
Anticipated Pile Drivability	Due to the medium stiff to hard consistency of the overburden and variable depth to bedrock due to karst geology, there is a chance of encountering difficulties/obstructions during pile driving. If difficult pile driving is encountered, we anticipate pre-drilling to be required.		
General Construction Considerations	The near-surface soils are moderately moisture sensitive and subject to degradation with exposure to moisture. To the extent practical, earthwork should be performed during warmer and drier periods of weather to reduce the amount of necessary subgrade remedial measures for soft and unsuitable conditions beneath access roadways, equipment pads, etc.		

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



ITEM DESCRIPTION

1. The soil properties that can significantly affect the aggressiveness of corrosion to buried metal structures include: pH, oxidation-reduction potential, sulfates, sulfides, total dissolved salts, chlorides, resistivity, and moisture content. These properties were measured, and the results are reported in the attachment. These test results are provided to assist the designers of corrosion protection for the project.

PRELIMINARY RECOMMENDATIONS FOR DRIVEN PILE FOUNDATIONS

We have performed preliminary geotechnical analyses for driven pile foundations to support the typical PV panel racking system. Subsequent analyses will be required once design level geotechnical information is available and once other design considerations are more fully defined. THEREFORE, THE RESULTS OF THE ANALYSES DESCRIBED BELOW ARE NOT SUITABLE FOR FINAL DESIGN. Instead, this analysis is intended to assist you in roughly evaluating construction costs and development viability for the proposed project. It should also be noted that our analyses are based on short-term conditions based on boring information. For this type of foundation system, provisions for flexible or adjustable connection between the posts and the array superstructure are recommended.

Adfreeze Stress

The overburden soils encountered in the borings are frost susceptible. In cold weather climates, design to resist frost heave forces exerted on foundations is often the limiting factor in the foundation design. Specifically, pile lengths will need to be long enough to counteract potential heave forces in the seasonal frost zone.

As the frost penetrates deeper into the soil and the ground swells due to freezing, the ground surface will rise due to frost heaving. The upward displacement is due to freezing water contained in the soil voids along with the formation of ice lenses in the soil. The freezing material grips the steel pile and exerts an uplift force due to the adfreeze stress developed around the surface area of the pile. The amount of upward force depends on the following:

- The thickness of ice lenses formed in the seasonal frozen ground
- The bond between the steel pile surface and the frozen ground
- The surface area of the steel pile in the seasonally frozen ground

Based on our review of soil samples, we recommend an adfreeze stress of 1,500 psf be considered when determining the frost heave load on a pile. The box perimeter of the pile (two times the depth plus two times the flange width) acting over a maximum depth of about 1-foot below ground surface should be considered when determining the frost heave load on a pile.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Uplift forces will govern the design and length of the driven pile; therefore, uplift will be the primary factor in foundation costs. The factor of safety against uplift should be determined based on discussions with the owner and design engineer considering the desired level or risk, construction costs, and the long-term maintenance program.

Geotechnical Axial Capacity

The following preliminary geotechnical parameters can be used to estimate the capacity of driven W-section pile foundations. These values should also be suitable to prepare a full-scale pile load testing program which is recommended as part of the overall project design. Final design values will vary from the preliminary estimates below. The upper 1 foot of soil should be neglected when calculating the ultimate capacity from skin friction.

Depth (feet bgs)	Ultimate Unit Skin Friction, q _s (psf) ¹	Ultimate End Bearing Capacity, Qp (psf)			
	Zone A (B-1)				
0 – 1					
1 – 9½	650	9,000 ²			
below 91/2	2,000	100,000 ^{2, 3}			
	Zone B (B-3)				
0 – 1					
1 – 13½	750	13,500 ²			
13½ – 20	650	69,000 ²			
Zone C (All borings except B-1 and B-3)					
0 – 1					
1 – 3½	650				
3½ – 13	750	13,500 ²			
13 – 20	750	9,000 ²			

- 1. The upper 1 foot should be neglected in pile design due to frost heave.
- 2. Appropriate for pile toe bearing at depths of at least 5 feet below the ground surface. The ultimate end bearing capacity values are selected based on the type of the soil/rock and our experience with similar geology. We assumed that section W6X9 would be utilized for the pile foundations.
- 3. The skin friction and ultimate end bearing capacity for rock stratum at B-1 is based on our experience with similar geology

The above values are to be used in the following equations to obtain the ultimate uplift or compression load capacity of a pile:

$$\begin{aligned} Q_{\text{ult (compressive)}} &= q_t \ x \ A + H \ x \ P \ x \ q_s \\ Q_{\text{ult (uplift)}} &= H \ x \ P \ x \ q_s \end{aligned}$$

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Q_{ult} = Ultimate uplift or compression capacity of post (lbs.)

Q_{ult (end)} = Ultimate end bearing capacity per table above (lbs.)

H = Depth of embedment of pile (ft.)

P = Perimeter area/ft. of pile. (i.e. W6x9 = 1.64 sf/ft.)

q_s = Skin friction per depth per table above (psf)

q_t = unit toe-bearing resistance per table above (psf)

A = cross sectional area of pile (i.e. W6x9 = 0.019 sf).

The recommended geotechnical design parameters in this table are based on average conditions encountered in our borings. Additional subsurface exploration and pile load testing should be performed to determine actual design parameters across the site.

The skin friction is appropriate for uplift and compressive loading and represents ultimate values. A factor of safety of 2 should be applied to the skin friction values. The end bearing is also an ultimate value and should have a factor of safety of 2 applied for design.

Piles should have a minimum center-to-center spacing of at least 3 times their largest crosssectional dimension to prevent reduction in the axial capacities due to group effects. If the piles are designed using the above parameters, settlements are not anticipated to exceed 1 inch.

Geotechnical Lateral Capacity

The parameters in the following table can be used for a preliminary analysis of the lateral capacity of driven steel piles in support of solar panel arrays:

Depth (feet bgs)	LPILE Soil Type	Unit Weight (pcf) ¹	Undrained Cohesion, c (psf)	Friction Angle (Deg)	Uniaxial Compressive Strength (psi)	Strain Factor £50	RQD (%)	Rock Mass (PSI)	P- Multiplier
			Z	one A – (B	-1)				
0 – 1	Stiff Clay without Free	125	750			default			0.7
1 – 9½	Water (Reese)	125	750			default			1.0
below 9½	Weak Rock (Reese) ²	135			100	0.0005	10	50,000	1.0
			Z	one B – (B	-3)				
0 – 1	Stiff Clay without Free	120	1,500			default			0.7
1 – 13½	Water (Reese)	120	1,500			default			1.0
13½ – 20	Sand (Reese) ³	130		32		default			1.0

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Depth (feet bgs)	LPILE Soil Type	Unit Weight (pcf) ¹	Undrained Cohesion, c (psf) Cone C – (All b	Friction Angle (Deg) orings exc	Uniaxial Compressive Strength (psi) ept B-1 and B-3)	Strain Factor _{\$50}	RQD (%)	Rock Mass (PSI)	P- Multiplier
0 – 1	Stiff Clay	120	750			default			0.7
1 – 3½	without Free	125	750			default			1.0
3½ – 13	Water (Reese)	128	1,500			default			1.0
13 – 20	(110636)	125	1,000			default			1.0

- 1. Effective unit weight should be used for stratum below groundwater table.
- 2. For the weathered limestone stratum at B-1 and anticipated limestone bedrock below refusal, we assumed a preliminary parameter based on our experience with similar projects. For the final design, rock coring should be performed to confirm the strength parameters.
- 3. Use default value for Soil Modulus, k.

The above indicated effective unit weight and effective friction angle have no factor of safety and may be used to analyze suitability of the proposed section and serviceability requirements. These parameters are based on correlations with SPT results, published values, and our experience with similar soil types. Existing p-y models typically under-predict the lateral capacity of shallow driven piles. Therefore, the P-multiplier is most likely higher but would need to be confirmed based on results of site-specific load test results.

PRELIMINARY RECOMMENDATIONS FOR ISOLATED SLAB FOUNDATIONS

We understand that some equipment may be supported on mat/slab foundations while other structures and O&M building may be supported on shallow foundations. Medium stiff lean clay was encountered near the surface and might require improvement prior to foundation construction. Based on the anticipated types of structures and the expected magnitude of loading, surface compaction using an adequately loaded vehicle such as a fully-loaded tandem-axle dump truck with total weight of 20 tons or greater should provide adequate improvement for shallow foundation support of these structures. As discussed in **Geotechnical Overview**, we recommend that fat clay if encountered be undercut a minimum of 2-foot below design foundation bearing elevation and replaced with LVC engineered fill, or lean concrete extending to at least stiff clay. We would expect an allowable bearing capacity of 1,700 psf with total and differential settlements of about 1 inch and ¾ inch, respectively, depending on minimum foundation width and embedment.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



PRELIMINARY RECOMMENDATIONS FOR SUBSTATION AND TRANSMISSION LINE FOUNDATIONS

Our recommendations provided below are based on the subsurface information encountered near boring locations B-11 and ROW-1 through ROW-7. If the location of the new substation and equipment pad areas change we should be consulted prior to the design and construction of foundations.

It is anticipated that some of the substation structures/appurtenances will be supported on deep foundation systems such as drilled shaft/pier foundation elements. It is recommended that each drilled shaft element be at least 1.5 feet in diameter. Based on our subsurface findings near the boring locations B-11 and ROW-1 through ROW-7, it is recommended that drilled shaft lengths should be at least 3 times the shaft diameter and it should be terminated within native cohesive soil of at least stiff consistency.

It is recommended that the drilled shaft design should incorporate a factor of safety of 3.0 for end bearing and 2.5 for side resistance, when subjected to axial compression loading situation. A factor of safety of 3.0 is recommended for side resistance against uplift loading situation. Soil parameters for axial design of drilled shaft are provided in the following section.

Depth (feet bgs)	Ultimate Skin Friction, f (psf)	Ultimate End Bearing Pressure, Qp (psf)			
	B-11				
0-21					
2 – 7	1,200				
7 – 15	1,050	27,000 ²			
15 – 26	950	9,000			
26 – 46	18,000	28,000			
	ROW-1				
0-21					
2 – 3½	250				
3½ – 20	1,500	16,500			
20 – 30	950	9,000			
	ROW-2				
0 – 2 ¹					
2 – 13	1,500	18,000			
13 – 18½	250	2,250			
18½ – 23½	20,000	28,000			
	ROW-3				
0-21					
2 – 18½	1,125	11,250			
18½ – 23½	22,900	28,000			

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Depth (feet bgs)	Ultimate Skin Friction, f (psf)	Ultimate End Bearing Pressure, Qp (psf)			
B-11					
	ROW-4				
0 – 2 ¹					
2 – 18	1,350	13,500			
18 – 23	22,000	28,000			
	ROW-5				
0-21					
2 – 6	500				
6 – 10	1,500	15,750			
10 – 15	20,000	28,000			
	ROW-6				
0 – 2 1					
2 – 6½	950				
6½ – 16½	12,500	28,000			
	ROW-7				
0 – 2 ¹					
2 – 7	1,125				
7 – 15	750	6,750			
15 – 20	21,000	28,000			

^{1.} The side resistance of the uppermost 2 feet of the soil should be ignored due to the potential for disturbance caused during the drilled shaft construction.

Recommended geotechnical parameters of drilled shaft foundations have been developed for use in the L-PILE computer program. Based on the encountered subsurface conditions, laboratory test results, and field penetration test results, generalized engineering properties have been provided at boring locations B-11 and ROW-1 through ROW-7, as shown in the following table:

Depth (feet bgs)	LPILE Soil Type	Unit Weight (pcf) 1	Undrained Cohesion, c (psf)	Uniaxial Compressive Strength (psi)	Strain Factor ε ₅₀
		Е	3-11		
0 – 7	Stiff Clay without Free Water (Reese)	125	1,500		default
7 – 15		128	3,000		default
15 – 26		120	1,000		default
26 – 46	Strong Rock (Vuggy Limestone)	167		12,000	0.00001
ROW-1					
0 – 3½	Soft Clay (Matlock)	115	250		default

^{2.} Drilled shafts should be founded at a depth of at least 10 feet below the ground surface.

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Depth (feet bgs)	LPILE Soil Type	Unit Weight (pcf) ¹	Undrained Cohesion, c (psf)	Uniaxial Compressive Strength (psi)	Strain Factor _{\$50}
		В	-11		
3½ – 20	Stiff Clay without Free	120	1,850		default
20 – 30	Water (Reese)	120	1,000		default
		RC)W-2		
0 – 13	Stiff Clay without Free Water (Reese)	120	2000		default
13 – 18½	Soft Clay (Matlock)	115	250		default
18½ – 23½	Strong Rock (Vuggy Limestone)	165		17,000	0.00001
		RC	DW-3		
0 – 18½	Stiff Clay without Free Water (Reese)	120	1,250		default
18½ – 23½	Strong Rock (Vuggy Limestone)	158		6,000	0.00001
		RC	OW-4		
0 – 18½	Stiff Clay without Free Water (Reese)	125	1,500		default
18½ – 23½	Strong Rock (Vuggy Limestone)	165		8,000	0.00001
		RC	OW-5		
0 – 2	Stiff Clay without Free Water (Reese)	120	1500		default
2 – 6	Soft Clay (Matlock)	115	500		default
6 – 10	Stiff Clay without Free Water (Reese)	120	1750		default
10 – 15	Strong Rock (Vuggy Limestone)	166		6,000	0.00001
		RC	OW-6		
0 – 6½	Stiff Clay without Free Water (Reese)	120	1,000		default
6½ – 16½	Strong Rock (Vuggy Limestone)	167		15,200	0.00001
ROW-7					
0 – 7	Stiff Clay without Free Water (Reese)	120	1,250		default
7 – 15	Soft Clay (Matlock)	115	750		default
15 – 20	Strong Rock (Vuggy Limestone)	163		9,800	0.00001
 Effective unit weight should be used for stratum below groundwater table. 					

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



PRELIMINARY EARTHWORK RECOMMENDATIONS

The site work conditions will be largely dependent on the weather conditions and the contractor's means and methods in controlling surface drainage and protecting the subgrade. Final surrounding grades for any possible structures and inverters should be sloped away from structures on all sides to prevent ponding of water. All grades must provide effective drainage away from the structures during and after construction. Site preparation where inverter mat foundations will be installed should include clearing and grubbing, installation of a site drainage system (where necessary), subgrade preparation, and proof-rolling as necessary. Site preparation is not necessary in the PV Array field or where inverters will be supported on driven piles except to improve site drainage where necessary.

We would expect typical earthmoving equipment (bulldozers, excavators, fully-loaded tandem-axle dump truck) to be suitable for completion of earthwork activities on the site. The most challenging obstacle for earthwork construction will be the control of surface and groundwater, especially during wet season. The site should be graded to prevent ponding of surface water. Additionally, dewatering (rim ditches, sump pumps, well points, etc.) may be needed to lower the groundwater and allow for adequate compaction in trenches.

Typical unpaved access roads in the lightly loaded array areas consisting of about 4 to 6 inches of aggregate base on compacted native soil should be suitable. The substation access road will likely require 6 to 8 inches of aggregate base over 12 inches of stabilized subgrade or native soils reinforced with a geogrid.

SEISMIC CONSIDERATIONS

The seismic design requirements for buildings and other structures are based on Seismic Design Category. Site Classification is required to determine the Seismic Design Category for a structure. The Site Classification is based on the upper 100 feet of the site profile defined by a weighted average value of either shear wave velocity, standard penetration resistance, or undrained shear strength in accordance with Section 20.4 of ASCE 7 and the International Building Code (IBC). Based on the soil properties encountered at the site and as described on the exploration logs and results, it is our professional opinion that the **Seismic Site Classification is C**. Subsurface explorations at this site were extended to a maximum depth of 46 feet. The site properties below the boring depth to 100 feet were estimated based on our experience and knowledge of geologic conditions of the general area. We recommend geophysical testing be performed to confirm the conditions below the current boring depth; preliminarily, we expect that the geophysical testing may result in better site class.

CORROSIVITY

The results of laboratory testing for water soluble sulfate, sulfides, soluble chloride, RedOx, Total

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



Salts, Resistivity, and pH are presented in **EXPLORATION RESULTS**. The values may be used by others to estimate potential corrosive characteristics of the on-site soils with respect to contact with the various underground materials which will be used for project construction.

GENERAL COMMENTS

Our analysis and opinions are based upon our understanding of the project, the geotechnical conditions in the area, and the data obtained from our site exploration. Natural variations will occur between exploration point locations or due to the modifying effects of construction or weather. The nature and extent of such variations may not become evident until during or after construction. Terracon should be retained as the Geotechnical Engineer, where noted in this report, to provide observation and testing services during pertinent construction phases. If variations appear, we can provide further evaluation and supplemental recommendations. If variations are noted in the absence of our observation and testing services on-site, we should be immediately notified so that we can provide evaluation and supplemental recommendations.

Our Scope of Services does not include either specifically or by implication any environmental or biological (e.g., mold, fungi, bacteria) assessment of the site or identification or prevention of pollutants, hazardous materials or conditions. If the owner is concerned about the potential for such contamination or pollution, other studies should be undertaken.

Our services and any correspondence or collaboration through this system are intended for the sole benefit and exclusive use of our client for specific application to the project discussed and are accomplished in accordance with generally accepted geotechnical engineering practices with no third-party beneficiaries intended. Any third-party access to services or correspondence is solely for information purposes to support the services provided by Terracon to our client. Reliance upon the services and any work product is limited to our client and is not intended for third parties. Any use or reliance of the provided information by third parties is done solely at their own risk. No warranties, either express or implied, are intended or made.

Site characteristics as provided are for design purposes and not to estimate excavation cost. Any use of our report in that regard is done at the sole risk of the excavating cost estimator as there may be variations on the site that are not apparent in the data that could significantly impact excavation cost. Any parties charged with estimating excavation costs should seek their own site characterization for specific purposes to obtain the specific level of detail necessary for costing. Site safety, and cost estimating including, excavation support, and dewatering requirements/design are the responsibility of others. If changes in the nature, design, or location of the project are planned, our conclusions and recommendations shall not be considered valid unless we review the changes and either verify or modify our conclusions in writing.

FIGURES


Contents:

GeoModel

GEOMODEL

LGE-KU Solar Project Cecilia, KY Terracon Project No. 57205074





This is not a cross section. This is intended to display the Geotechnical Model only. See individual logs for more detailed conditions.

Model Layer	Layer Name	General Description
1	LEAN CLAY (CL)	with silt, trace fine sand, brown with reddish brown, soft to hard
2	FAT CLAY (CH)	trace fine sand, with limestone fragments, reddish brown to brown and gray, soft to stiff
3	SILTY SAND (SM)	black, medium dense
4	LIMESTONE	light with dark gray, moderate to very close spacing, thin bedding, unweathered to slightly weathered, medium strong to very strong rock

LEGEND

Topsoil	Silty Sand
Lean Clay	Limeston
Fat Clay	

▼ First Water Observation

Groundwater levels are temporal. The levels shown are representative of the date and time of our exploration. Significant changes are possible over time. Water levels shown are as measured during and/or after drilling. In some cases, boring advancement methods mask the presence/absence of groundwater. See individual logs for details.

NOTES:

Layering shown on this figure has been developed by the geotechnical engineer for purposes of modeling the subsurface conditions as required for the subsequent geotechnical engineering


for this project.

Numbers adjacent to soil column indicate depth below ground surface.

GEOMODEL

LGE-KU Solar Project Cecilia, KY Terracon Project No. 57205074





This is not a cross section. This is intended to display the Geotechnical Model only. See individual logs for more detailed conditions.

Model Layer	Layer Name	General Description
1	LEAN CLAY (CL)	with silt, trace fine sand, brown with reddish brown, soft to hard
2	FAT CLAY (CH)	trace fine sand, with limestone fragments, reddish brown to brown and gray, soft to stiff
3	SILTY SAND (SM)	black, medium dense
4	LIMESTONE	light with dark gray, moderate to very close spacing, thin bedding, unweathered to slightly weathered, medium strong to very strong rock

LEGEND

Topsoil	Limeston
Lean Clay	
Fat Clay	

▼ First Water Observation

Groundwater levels are temporal. The levels shown are representative of the date and time of our exploration. Significant changes are possible over time. Water levels shown are as measured during and/or after drilling. In some cases,

boring advancement methods mask the presence/absence of groundwater. See individual logs for details.

NOTES:

Layering shown on this figure has been developed by the geotechnical engineer for purposes of modeling the subsurface conditions as required for the subsequent geotechnical engineering

for this project.

Numbers adjacent to soil column indicate depth below ground surface.

ATTACHMENTS

Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



PHOTOGRAPHY LOG



B-11 - Rock Core Run 1 - 26 to 36 feet



B-11 - Rock Core Run 1 - 36 to 46 feet

Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074





ROW-2 - Rock Core Run 1 - 181/2 to 231/2 feet



ROW-3 - Rock Core Run 1, 2, 3 - 10 to 231/2 feet

Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074





ROW-4 - Rock Core Run 1 – 18 to 23 feet ROW-5 - Rock Core Run 1 – 10 to 15 feet



ROW-6 - Rock Core Run 1, 2 - 61/2 to 161/2 feet

Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074





ROW-7 - Rock Core Run 1 - 15 to 20 feet

Preliminary Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



EXPLORATION AND TESTING PROCEDURES

Field Exploration

Number of Borings	Boring Depth (feet)	Explored Locations
10	9½ to 20	Proposed PV array areas
1	46	Proposed substation area
7	15 to 30	Proposed transmission line right-of-way

Boring Layout and Elevations: Terracon personnel provided the boring layout. Coordinates were obtained with a handheld recreational GPS unit (estimated horizontal accuracy of about ±10 feet) and approximate elevations were obtained by interpolation from the Google Earth™. If elevations and a more precise boring layout are desired, we recommend exploration locations be surveyed.

Subsurface Exploration Procedures: We advanced the borings with a track-mounted rotary drill rig using continuous flight hollow stem augers. Four samples were obtained in the upper 10 feet of each boring and at intervals of 5 feet thereafter. In the thin-walled tube sampling procedure, a thin-walled, seamless steel tube with a sharp cutting edge was pushed hydraulically into the soil to obtain a relatively undisturbed sample. In the split-barrel sampling procedure, a standard 2-inch outer diameter split-barrel sampling spoon was driven into the ground by a 140-pound automatic hammer falling a distance of 30 inches. The number of blows required to advance the sampling spoon the last 12 inches of a normal 18-inch penetration is recorded as the Standard Penetration Test (SPT) resistance value. The SPT resistance values, also referred to as N-values, are indicated on the boring logs at the test depths. We observed and recorded groundwater levels during drilling and sampling. For safety purposes, all borings were backfilled with auger cuttings and bentonite chips upon completion.

The sampling depths, penetration distances, and other sampling information was recorded on the field boring logs. The samples were placed in appropriate containers and taken to our soil laboratory for testing and classification by a Geotechnical Engineer. Our exploration team prepared field boring logs as part of the drilling operations. These field logs included visual classifications of the materials encountered during drilling and our interpretation of the subsurface conditions between samples. Final boring logs were prepared from the field logs. The final boring logs represent the Geotechnical Engineer's interpretation of the field logs and include modifications based on observations and tests of the samples in our laboratory.

Field (In-Situ) Electrical Resistivity: Utilizing AEMC Model 6471 Digital Ground Resistance Tester, electrical resistivity surveys were performed within the PV array areas. The surveys were performed in general accordance with the Wenner Four Point method (ASTM G57). Two mutually

Preliminary Geotechnical Engineering Report

LGE-KU Solar Project ■ Cecilia, Hardin County, Kentucky December 30, 2020 ■ Terracon Project No. 57205074



perpendicular arrays with "a" spacing of 2.5, 5, 10, 20, 50, 100, and 150 feet were performed at each location.

Laboratory Testing

The project engineer reviewed the field data and assigned laboratory tests to understand the engineering properties of the various soil strata. Procedural standards noted below are for reference to methodology in general. In some cases, variations to methods were applied because of local practice or professional judgment. Standards noted below include reference to other, related standards. Such references are not necessarily applicable to describe the specific test performed.

- ASTM D2216 Standard Test Methods for Laboratory Determination of Water (Moisture)
 Content of Soil and Rock by Mass.
- ASTM D4318 Standard Test Methods for Liquid Limit, Plastic Limit, and Plasticity Index of Soils.
- ASTM D422 Standard Test Method for Particle-Size Analysis of Soils.
- ASTM D2166/D2166M Standard Test Method for Unconfined Compressive Strength of Cohesive Soil.
- ASTM D7012 Standard Test Methods for Compressive Strength and Elastic Moduli of Intact Rock Core Specimens under Varying States of Stress and Temperatures
- ASTM D698 Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort

The laboratory testing program included observation of soil samples by an engineer or geologist. Based on the material's texture and plasticity, we described and classified the soil samples in accordance with the Unified Soil Classification System.

SITE LOCATION AND EXPLORATION PLANS

Contents:

Site Location Exploration Plan

Note: All attachments are one page unless noted above.

SITE LOCATION

LGE-KU Solar Project • Cecilia, Hardin County, Kentucky December 30, 2020 • Terracon Project No. 57205074






EXPLORATION PLAN

LGE-KU Solar Project • Cecilia, Hardin County, Kentucky December 30, 2020 • Terracon Project No. 57205074





EXPLORATION RESULTS

Contents:

Boring Logs (B-1 through B-11 & ROW-1 through ROW-7)
Atterberg Limits Results
Unconfined Compression Test Results (2 pages)
Grain Size Distribution
Field Electrical Resistivity (6 pages)
Results of Corrosion Analysis (1 pages)
Standard Compaction Test Results (3 pages)
Thermal Resistivity Results (4 pages)

Note: All attachments are one page unless noted above.


THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL 57205074 PRELIMINARY GEOTE.GPJ TERRACON_DATATEMPLATE.GDT 12/30/20

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL 57205074 PRELIMINARY GEOTE.GPJ TERRACON DATATEMPLATE.GDT 12/30/20

THIS BORING LOG IS NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GEO SMART LOG-NO WELL 57205074 PRELIMINARY GEOTE.GPJ TERRACON DATATEMPLATE.GDT 12/30/20

ATTERBERG LIMITS RESULTS


ASTM D4318



B6 ★	10 0		•••	* •	ML or	· OL			or OH			
	0	20			40	LIC	60 OUID LIMIT		8	0	100	
В	oring ID	Depth	LL	PL	PI	Fines	USCS	Descri	ption			
•	B-1A	2 - 4	36	16	20		CL	Lean Clay	/			
	B-3	6 - 7.5	52	18	34		CH	Fat Clay				
	B-4A	1 - 3	45	17	28		CL	Lean Clay	/			
*	B-5A	2 - 4	33	18	15		CL	Lean Clay	/			
•	B-7A	3 - 5	46	20	26		CL	Lean Clay	/			
۰	B-9A	2 - 4	25	17	8		CL	Lean Clay	/			
0	B-11A	2 - 4	27	19	8		CL	Lean Clay	/			
Δ	B-11A	5 - 7	35	15	20		CL	Lean Clay	/			
\otimes	ROW-1	3.5 - 5	73	24	49		СН	Fat Clay				
\oplus	ROW-4A	3 - 5	31	20	11		CL	Lean Clay	/			
	ROW-5	8.5 - 10	62	21	41		CH	Fat Clay				
•	ROW-6A	2 - 4	45	19	26		CL	Lean Clay	/			
]												
P	ROJECT: LGE-KU \$	Solar Project			7	- -	ארר	חו	PROJEC	T NUMBER	R: 57205074	
S	ITE: Hardinsburg Ro Cecilia, KY	pad			13	050 Eastgate P Louisvil	ark Way Ste 1 le, KY	101	CLIENT:	ibV Energy Miami, FL	/ Partners LLC	



ASTM D2166



SPE	CIMEN	FAILUR	KE PHO	IOGRAPH



SPECIMI	EN TEST DATA	
Moisture Content:	%	18.0
Dry Density:	pcf	110
Diameter:	in.	2.84
Height:	in.	5.61
Height / Diameter Ratio:		1.98
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	3.60
Unconfined Compressive Strength	(tsf)	2.73
Undrained Shear Strength:	(tsf)	1.37
Strain Rate:	in/min	0.0673
Remarks:		

7	SAMPLE TYPE: Shelby Tube	SAMPLE LO	CATION:	B-1A @ 2 - 4	1 feet
5	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
Z U		36	16	20	

PROJECT: LGE-KU Solar Project




PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC Miami, FL

SITE: Hardinsburg Road Cecilia, KY

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIME	EN TEST DATA	
Moisture Content:	%	18.0
Dry Density:	pcf	109
Diameter:	in.	2.84
Height:	in.	5.60
Height / Diameter Ratio:		1.97
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	3.93
Unconfined Compressive Strength	(tsf)	4.61
Undrained Shear Strength:	(tsf)	2.31
Strain Rate:	in/min	0.0672
Remarks:		

SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		B-4A @ 1 - 3	3 feet
DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
	45	17	28	

PROJECT: LGE-KU Solar Project

SITE: Hardinsburg Road Cecilia, KY




PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC Miami, FL

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. UNCONFINED WITH PHOTOS 57205074 PRELIMINARY GEOTE. GPJ TERRACON_DATATEMPLATE. GDT 12/30/20

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMI	EN TEST DATA	
Moisture Content:	%	17.8
Dry Density:	pcf	108
Diameter:	in.	2.83
Height:	in.	5.60
Height / Diameter Ratio:		1.98
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	3.60
Unconfined Compressive Strength	(tsf)	2.01
Undrained Shear Strength:	(tsf)	1.00
Strain Rate:	in/min	0.0672
Remarks:		

SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		B-5A @ 2 - 4	1 feet
DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
	33	18	15	

PROJECT: LGE-KU Solar Project


SITE: Hardinsburg Road Cecilia, KY



PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



Moisture Content:	%	19.2
Dry Density:	pcf	107
Diameter:	in.	2.84
Height:	in.	5.60
Height / Diameter Ratio:		1.97
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	4.80
Unconfined Compressive Strength	(tsf)	4.96
Undrained Shear Strength:	(tsf)	2.48

SPECIMEN TEST DATA

Strain Rate: Remarks:

٧AL	SAMPLE TYPE: Shelby Tube	SAMPLE LO	CATION:	B-7A @ 3 - 5	5 feet
5	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
ή		46	20	26	

PROJECT: LGE-KU Solar Project

SITE: Hardinsburg Road Cecilia, KY




PROJECT NUMBER: 57205074

in/min

0.0672

CLIENT: ibV Energy Partners LLC

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIM	EN TEST DATA	
Moisture Content:	%	19.4
Dry Density:	pcf	103
Diameter:	in.	2.85
Height:	in.	5.61
Height / Diameter Ratio:		1.97
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	5.35
Unconfined Compressive Strength	(tsf)	3.26
Undrained Shear Strength:	(tsf)	1.63
Strain Rate:	in/min	0.0673
Remarks:		

,	SAMPLE TYPE: Shelby Tube	SAMPLE LO	CATION:	B-9A @ 2 - 4	l feet
5	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
		25	17	8	

PROJECT: LGE-KU Solar Project


SITE: Hardinsburg Road Cecilia, KY



PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMI	EN TEST DATA	
Moisture Content:	%	16.7
Dry Density:	pcf	112
Diameter:	in.	2.84
Height:	in.	5.59
Height / Diameter Ratio:		1.97
Calculated Saturation:	%	
Calculated Void Ratio:		
Assumed Specific Gravity:		
Failure Strain:	%	4.80
Unconfined Compressive Strength	(tsf)	3.18
Undrained Shear Strength:	(tsf)	1.59
Strain Rate:	in/min	0.0671
Remarks:		

	SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		B-11A @ 2 -	4 feet
5	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
		27	19	8	

PROJECT: LGE-KU Solar Project

SITE: Hardinsburg Road Cecilia, KY




PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC Miami, FL

Louisville, KY

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMEN TEST DATA							
Moisture Content:	%	16.7					
Dry Density:	pcf	101					
Diameter:	in.	2.85					
Height:	in.	5.58					
Height / Diameter Ratio:		1.96					
Calculated Saturation:	%						
Calculated Void Ratio:							
Assumed Specific Gravity:							
Failure Strain:	%	7.20					
Unconfined Compressive Strength	(tsf)	1.17					
Undrained Shear Strength:	(tsf)	0.59					
Strain Rate:	in/min	0.0670					
Remarks:							

,	SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		B-11A @ 5 -	7 feet
	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
		35	15	20	

PROJECT: LGE-KU Solar Project


SITE: Hardinsburg Road Cecilia, KY



PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMEN TEST DATA							
Moisture Content:	%	25.7					
Dry Density:	pcf	96					
Diameter:	in.	2.84					
Height:	Height: in.						
Height / Diameter Ratio:		1.97					
Calculated Saturation:	%						
Calculated Void Ratio:							
Assumed Specific Gravity:							
Failure Strain:	%	3.00					
Unconfined Compressive Strength	(tsf)	1.85					
Undrained Shear Strength:	(tsf)	0.93					
Strain Rate:	in/min	0.0672					
Remarks:							

SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		ROW-1A@	3 - 5 feet
DESCRIPTION:	LL	PL	PI	Percent < #200 Sieve

PROJECT: LGE-KU Solar Project


SITE: Hardinsburg Road Cecilia, KY



PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMEN TEST DATA Moisture Content: %

Dry Density: pcf 107 Diameter: in. 2.84 Height: in. 5.60 Height / Diameter Ratio: 1.97 % Calculated Saturation: Calculated Void Ratio: Assumed Specific Gravity: Failure Strain: 3.00 Unconfined Compressive Strength (tsf) 1.67 Undrained Shear Strength: (tsf) 0.83 Strain Rate: 0.0672 in/min

19.3

Remarks:

۷AL	SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		ROW-4A@	3 - 5 feet
5	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
ή		31	20	11	

PROJECT: LGE-KU Solar Project


SITE: Hardinsburg Road Cecilia, KY



PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC Miami, FL

ASTM D2166



SPECIMEN FAILURE PHOTOGRAPH



SPECIMEN TEST DATA							
Moisture Content:	%	22.6					
Dry Density:	pcf	97					
Diameter:	in.	2.85					
Height:	in.	4.18					
Height / Diameter Ratio:		1.46					
Calculated Saturation:	%						
Calculated Void Ratio:							
Assumed Specific Gravity:							
Failure Strain:	%	9.60					
Unconfined Compressive Strength	(tsf)	1.07					
Undrained Shear Strength:	(tsf)	0.53					
Strain Rate:	in/min	0.0501					
Remarks:							

į	SAMPLE TYPE: Shelby Tube	SAMPLE LOCATION:		ROW-6A@	2 - 4 feet
-	DESCRIPTION: Lean Clay	LL	PL	PI	Percent < #200 Sieve
į		45	19	26	

PROJECT: LGE-KU Solar Project

SITE: Hardinsburg Road Cecilia, KY




PROJECT NUMBER: 57205074

CLIENT: ibV Energy Partners LLC

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136





Test Line at B-1 location with approximate center poin: 37.64949°, -85.96873°

 Project LGE-KU Solar Project
 Weather Sunny


 Location Cecilia, Hardin County, KY
 Surface Soil Silty Clay

 Project # 57205074
 Instrument AEMC Model 6471

 Test Date November 24, 2020
 Tested By Colton M. Hall

Electrode Spacing "a"		Electrode Depth "b"		"A" T (Extende		"B" Test (Extended N-S)	
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "ρ"	Measured Resistance "R"	Apparent Resistivity "ρ"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	23.70	120.9	22.50	114.8
5	1.52	0.5	0.15	13.80	134.4	14.20	138.3
10	3.05	1	0.30	6.89	134.2	6.61	128.8
20	6.10	1	0.30	2.83	108.9	2.72	104.6
50	15.24	1	0.30	1.500	143.7	1.580	151.4
100	30.48	1	0.30	1.350	258.6	1.370	262.4
150	45.72	1	0.30	1.160	333.3	1.300	373.5

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$








Test Line at B-2 location with approximate center poin: 37.654627°, -85.990830°

ProjectLGE-KU Solar ProjectWeather Partially ClouidyLocation Cecilia, Hardin County, KYSurface Soil Silty ClayProject # 57205074Instrument AEMC Model 6471Test Date December 2, 2020Tested By Sadra Javadi

Electrode Spacing "a"		Electrode Depth "b"		"A" T (Extende		"B" Test (Extended N-S)	
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "p"	Measured Resistance "R"	Apparent Resistivity "ρ"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	29.60	151.1	31.60	161.3
5	1.52	0.5	0.15	14.40	140.3	14.20	138.3
10	3.05	1	0.30	6.01	117.1	6.80	132.5
20	6.10	1	0.30	2.40	92.3	2.64	101.6
50	15.24	1	0.30	1.120	107.3	0.980	93.9
100	30.48	1	0.30	0.830	159.0	0.780	149.4
150	45.72	1	0.30	0.770	221.2	0.710	204.0

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$







Test Line at B-4 location with approximate center poin: 37.64436°, -85.97974°

 Project LGE-KU Solar Project
 Weather Sunny


 Location Cecilia, Hardin County, KY
 Surface Soil Silty Clay

 Project # 57205074
 Instrument AEMC Model 6471

 Test Date November 24, 2020
 Tested By Colton M. Hall

Electrode Spacing "a"		Electrode Depth "b"		"A" T (Extende		"B" Test (Extended N-S)	
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "ρ"	Measured Resistance "R"	Apparent Resistivity "p"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	32.70	166.9	29.90	152.6
5	1.52	0.5	0.15	15.80	153.9	16.80	163.6
10	3.05	1	0.30	5.96	116.1	6.79	132.3
20	6.10	1	0.30	2.18	83.9	2.07	79.6
50	15.24	1	0.30	0.780	74.7	0.860	82.4
100	30.48	1	0.30	0.660	126.4	0.680	130.3
150	45.72	1	0.30	0.600	172.4	0.650	186.7

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$








Test Line at B-6 location with approximate center poin: 37.65708°, -85.990830°

ProjectLGE-KU Solar ProjectWeather Partially ClouidyLocationCecilia, Hardin County, KYSurface Soil Silty ClayProject # 57205074Instrument AEMC Model 6471Test DateDecember 2, 2020Tested By Sadra Javadi

Electrode	Spacing "a"	ng "a" Electrode Depth "b"		"A" Test (Extended E-W)		"B" Test (Extended N-S)	
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "ρ"	Measured Resistance "R"	Apparent Resistivity "p"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	20.60	105.1	21.30	108.7
5	1.52	0.5	0.15	11.70	114.0	12.20	118.8
10	3.05	1	0.30	6.35	123.7	6.29	122.5
20	6.10	1	0.30	2.86	110.0	3.04	116.9
50	15.24	1	0.30	2.090	200.3	1.810	173.4
100	30.48	1	0.30	0.740	141.7	0.820	157.1
150	45.72	1	0.30	0.710	204.0	0.750	215.5

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$








Test Line at B-7 location with approximate center poin: 37.66067°, -85.99841°

ProjectLGE-KU Solar ProjectWeatherPartially ClouidyLocationCecilia, Hardin County, KYSurface SoilSilty ClayProject #57205074InstrumentAEMC Model 6471Test DateDecember 2, 2020Tested BySadra Javadi

Electrode	Spacing "a" Electrode Depth "b"		"A" Test (Extended E-W)		"B" Test (Extended N-S)		
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "p"	Measured Resistance "R"	Apparent Resistivity "p"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	22.20	113.3	22.80	116.4
5	1.52	0.5	0.15	12.50	121.8	11.90	115.9
10	3.05	1	0.30	6.68	130.1	6.68	130.1
20	6.10	1	0.30	2.93	112.7	3.14	120.8
50	15.24	1	0.30	1.520	145.7	1.590	152.4
100	30.48	1	0.30	0.940	180.1	0.890	170.5
150	45.72	1	0.30	0.810	232.7	0.770	221.2

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$







Test Line at B-10 location with approximate center poin: 37.65115°, -86.00841°

Project LGE-KU Solar Project

Location Cecilia, Hardin County, KY

Project # 57205074

Test Date December 2, 2020

Weather Partially Clouidy


Surface Soil Silty Clay

Instrument AEMC Model 6471

Tested By Sadra Javadi

Electrode	Spacing "a"	Electrode Depth "b"		"A" Test (Extended E-W)		"B" Test (Extended N-S)	
[feet]	[meters]	[feet]	[meters]	Measured Resistance "R"	Apparent Resistivity "p"	Measured Resistance "R"	Apparent Resistivity "p"
				[Ohms]	[Ohm-meters]	[Ohms]	[Ohm-meters]
2.5	0.76	0.5	0.15	15.60	79.6	15.10	77.1
5	1.52	0.5	0.15	9.51	92.6	9.58	93.3
10	3.05	1	0.30	5.12	99.7	5.56	108.3
20	6.10	1	0.30	2.45	94.2	2.39	91.9
50	15.24	1	0.30	1.500	143.7	1.530	146.6
100	30.48	1	0.30	0.890	170.5	0.940	180.1
150	45.72	1	0.30	0.820	235.6	0.840	241.3

Apparent resistivity p is calculated as :
$$\rho = \frac{4\pi aR}{1 + \frac{2a}{\sqrt{a^2 + 4b^2}} - \frac{a}{\sqrt{a^2 + b^2}}}$$





CHEMICAL LABORATORY TEST REPORT

Project Number: 57205074 **Service Date:** 12/09/20 **Report Date:** 12/10/20



10400, State Highway 191 Midland, Texas (79707) (432)-684-9600

Client

ibV Energy Partners LLC 777 Brickell Ave Ste 500 Miami, FL 33131-2809

Project

LGE-KU Solar Project Hardinsburg Road Cecilia, KY

Sample Location	B-1	B-2	B-4	B-6	B-7	B-10
Sample Depth (ft.)	2'-3'	2'-3'	2'-3'	2'-3'	2'-3'	2'-3'
-						
pH Analysis, ASTM - G51-18	7.10	7.00	6.90	5.80	5.90	5.40
Water Soluble Sulfate (SO4), ASTM C 1580 (mg/kg)	116	100	41	37	32	33
Sulfides, ASTM - D4658-15, (mg/kg)	nil	nil	nil	nil	nil	nil
Chlorides, ASTM D 512 , (mg/kg)	16	10	6	6	5	25
RedOx, ASTM D-1498, (mV)	+435	+412	+417	+423	+420	+462
Total Salts, ASTM D1125-14, (mg/kg)	448	235	170	118	175	110
Resistivity, ASTM G187, (ohm-cm)	11358	10325	9293	14455	10325	12390

Analyzed By:


Nohelia Monasterios

Field Engineer

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.

MOISTURE-DENSITY RELATIONSHIP

ASTM D698/D1557




SITE: Hardinsburg Road Cecilia, KY



CLIENT: ibV Energy Partners LLC

MOISTURE-DENSITY RELATIONSHIP

ASTM D698/D1557




SITE: Hardinsburg Road Cecilia, KY



CLIENT: ibV Energy Partners LLC Miami, FL

MOISTURE-DENSITY RELATIONSHIP

ASTM D698/D1557



SITE: Hardinsburg Road Cecilia, KY

13050 Eastgate Park Way Ste 101 Louisville, KY

CLIENT: ibV Energy Partners LLC



December 18, 2020

21239 FM529 Rd., Bldg. F Cvpress, TX 77433

Tel: 281-985-9344 Fax: 832-427-1752 info@geothermusa.com

http://www.geothermusa.com

Terracon Consultants, Inc. 13050 Eastgate Park Way, Ste 101 Louisville, KY 40223

Attn: Sadra Javadi, Ph.D.

Re: Thermal Analysis of Native Soil Samples LGE - KU Solar Project - Cecilia, KY (PO No. 57205074)

The following is the report of thermal dryout characterization tests conducted on the three (3) soil samples from the referenced project sent to our laboratory.

<u>Thermal Resistivity Tests:</u> The samples were tested at the 'as received' moisture content and at 85% of the dry density *provided by Terracon.* The tests were conducted in accordance with the IEEE standard 442-2017. The results are tabulated below and the thermal dryout curves are presented in **Figures 1 to 3.**

Sample ID, Description, Thermal Resistivity, Moisture Content and Density

Sample ID	Description (Terracon)	Thermal F (°C-c		Moisture Content	Dry Density	
	,	Wet	Dry	(%)	(lb/ft³)	
B-1 @ 1'-4'	Silty Lean Clay	55	124	19	95	
B-6 @ 1'-4'	Lean/Fat Clay	59	169	23	93	
B-10 @ 1'-4'	Fat Clay	60	147	20	93	

<u>Comments:</u> The thermal characteristic depicted in the dryout curves apply for the samples at their respective test dry density.

Please contact us if you have any questions or if we can be of further assistance.


Geotherm USA

Nimesh Patel

COOL SOLUTIONS FOR UNDERGROUND POWER CABLES THERMAL SURVEYS, CORRECTIVE BACKFILLS & INSTRUMENTATION



THERMAL DRYOUT CURVE



Terracon Consultants, Inc. (PO No. 57205074)


Thermal Analysis of Native Soil

LGE - KU Solar Project - Cecilia, KY

December 2020 Figure 1



THERMAL DRYOUT CURVE



Terracon Consultants, Inc. (PO No. 57205074)


Thermal Analysis of Native Soil

LGE - KU Solar Project - Cecilia, KY

December 2020 Figure 2



THERMAL DRYOUT CURVE



Terracon Consultants, Inc. (PO No. 57205074)

Thermal Analysis of Native Soil

LGE - KU Solar Project - Cecilia, KY

December 2020 Figure 3

SUPPORTING INFORMATION

Contents:

General Notes Unified Soil Classification System Description of Rock Properties

Note: All attachments are one page unless noted above.

GENERAL NOTES

DESCRIPTION OF SYMBOLS AND ABBREVIATIONS

LGE-KU Solar Project ☐ Cecilia, KY Terracon Project No. 57205074



SAMPLING	WATER LEVEL		FIELD TESTS
	Water Initially Encountered	N	Standard Penetration Test Resistance (Blows/Ft.)
Rock Core Grab Sample	Water Level After a Specified Period of Time	(HP)	Hand Penetrometer
Shallov	Water Level After a Specified Period of Time	(T)	Torvane
Shelby Tube Split Spoon	Cave In Encountered	(DCP)	Dynamic Cone Penetrometer
	Water levels indicated on the soil boring logs are the levels measured in the borehole at the times indicated. Groundwater level variations will occur	uc	Unconfined Compressive Strength
	over time. In low permeability soils, accurate determination of groundwater levels is not possible with short term water level observations.		Photo-Ionization Detector
		(OVA)	Organic Vapor Analyzer

DESCRIPTIVE SOIL CLASSIFICATION

Soil classification as noted on the soil boring logs is based Unified Soil Classification System. Where sufficient laboratory data exist to classify the soils consistent with ASTM D2487 "Classification of Soils for Engineering Purposes" this procedure is used. ASTM D2488 "Description and Identification of Soils (Visual-Manual Procedure)" is also used to classify the soils, particularly where insufficient laboratory data exist to classify the soils in accordance with ASTM D2487. In addition to USCS classification, coarse grained soils are classified on the basis of their in-place relative density, and fine-grained soils are classified on the basis of their consistency. See "Strength Terms" table below for details. The ASTM standards noted above are for reference to methodology in general. In some cases, variations to methods are applied as a result of local practice or professional judgment.

LOCATION AND ELEVATION NOTES

Exploration point locations as shown on the Exploration Plan and as noted on the soil boring logs in the form of Latitude and Longitude are approximate. See Exploration and Testing Procedures in the report for the methods used to locate the exploration points for this project. Surface elevation data annotated with +/- indicates that no actual topographical survey was conducted to confirm the surface elevation. Instead, the surface elevation was approximately determined from topographic maps of the area.

STRENGTH TERMS						
(More than 50% re sie Density determi			CONSISTENCY OF FINE-GRAINED SOILS (50% or more passing the No. 200 sieve.) Consistency determined by laboratory shear strength testing, field visual-manual procedures or standard penetration resistance			оск
Descriptive Term (Density)	Standard Penetration or N-Value Blows/Ft.	Descriptive Term (Consistency)	Term Strength Penetration Penetration			Descriptive Term (Consistency)
Very Loose	0 - 3	Very Soft	less than 0.25	0 - 1	< 20	Weathered
Loose	4 - 9	Soft	0.25 to 0.50	2 - 4	20 - 29	Firm
Medium Dense	10 - 29	Medium Stiff	0.50 to 1.00	4 - 8	30 - 49	Medium Hard
Dense	30 - 50	Stiff	1.00 to 2.00	8 - 15	50 - 79	Hard
Very Dense	> 50	Very Stiff	2.00 to 4.00	15 - 30	>79	Very Hard
		Hard	> 4.00	> 30		

RELEVANCE OF SOIL BORING LOG

The soil boring logs contained within this document are intended for application to the project as described in this document. Use of these soil boring logs for any other purpose may not be appropriate.




						Soil Classification		
Criteria for Assign	ing Group Symbols	and Group Names	Using Laboratory Te	ests A	Group Symbol	Group Name ^B		
		Clean Gravels:	Cu ≥ 4 and 1 ≤ Cc ≤ 3 E		GW	Well-graded gravel F		
	Gravels: More than 50% of	Less than 5% fines ^C	Cu < 4 and/or [Cc<1 or Cc:	>3.0] E	GP	Poorly graded gravel F		
	coarse fraction retained on No. 4 sieve	Gravels with Fines:	Fines classify as ML or MH	ł	GM	Silty gravel F, G, H		
Coarse-Grained Soils:	retained on No. 4 sieve	More than 12% fines ^C	Fines classify as CL or CH		GC	Clayey gravel F, G, H		
More than 50% retained on No. 200 sieve		Clean Sands:	Cu ≥ 6 and 1 ≤ Cc ≤ 3 ^E		SW	Well-graded sand ^Ⅰ		
	Sands: 50% or more of coarse fraction passes No. 4 sieve	Less than 5% fines D	Cu < 6 and/or [Cc<1 or Cc>3.0] E		SP	Poorly graded sand		
		Sands with Fines: More than 12% fines D	Fines classify as ML or MH		SM	Silty sand G, H, I		
			Fines classify as CL or CH		sc	Clayey sand ^{G, H, I}		
		Inorgania	PI > 7 and plots on or above "A"		CL	Lean clay K, L, M		
	Silts and Clays:	Inorganic:	PI < 4 or plots below "A" line J		ML	Silt K, L, M		
	Liquid limit less than 50	Organic:	Liquid limit - oven dried	< 0.75	OL	Organic clay K, L, M, N		
Fine-Grained Soils: 50% or more passes the		Organic.	Liquid limit - not dried	< 0.75	OL	Organic silt K, L, M, O		
No. 200 sieve		Inorganic:	PI plots on or above "A" lin	е	CH	Fat clay K, L, M		
	Silts and Clays:	morganic.	PI plots below "A" line		MH	Elastic Silt K, L, M		
	Liquid limit 50 or more	Organic:	Liquid limit - oven dried	< 0.75	ОН	Organic clay K, L, M, P		
		Organio.	Liquid limit - not dried	₹0.75	OH	Organic silt K, L, M, Q		
Highly organic soils:	Primarily	organic matter, dark in co	olor, and organic odor		PT	Peat		

- A Based on the material passing the 3-inch (75-mm) sieve.
- If field sample contained cobbles or boulders, or both, add "with cobbles or boulders, or both" to group name.
- Gravels with 5 to 12% fines require dual symbols: GW-GM well-graded gravel with silt, GW-GC well-graded gravel with clay, GP-GM poorly graded gravel with silt, GP-GC poorly graded gravel with clay.
- Sands with 5 to 12% fines require dual symbols: SW-SM well-graded sand with silt, SW-SC well-graded sand with clay, SP-SM poorly graded sand with silt, SP-SC poorly graded sand with clay.

E Cu =
$$D_{60}/D_{10}$$
 Cc = $\frac{(D_{30})^2}{D_{10} \times D_{60}}$

- $^{\mbox{\it F}}$ If soil contains \geq 15% sand, add "with sand" to group name.
- ^G If fines classify as CL-ML, use dual symbol GC-GM, or SC-SM.

- HIf fines are organic, add "with organic fines" to group name.
- If soil contains ≥ 15% gravel, add "with gravel" to group name.
- J If Atterberg limits plot in shaded area, soil is a CL-ML, silty clay.
- K If soil contains 15 to 29% plus No. 200, add "with sand" or "with gravel," whichever is predominant.
- L If soil contains ≥ 30% plus No. 200 predominantly sand, add "sandy" to group name.
- MIf soil contains ≥ 30% plus No. 200, predominantly gravel, add "gravelly" to group name.
- NPI ≥ 4 and plots on or above "A" line.
- OPI < 4 or plots below "A" line.
- PI plots on or above "A" line.
- QPI plots below "A" line.



DESCRIPTION OF ROCK PROPERTIES



	WEATHERING
Term	Description
Unweathered	No visible sign of rock material weathering, perhaps slight discoloration on major discontinuity surfaces.
Slightly weathered	Discoloration indicates weathering of rock material and discontinuity surfaces. All the rock material may be discolored by weathering and may be somewhat weaker externally than in its fresh condition.
Moderately weathered	Less than half of the rock material is decomposed and/or disintegrated to a soil. Fresh or discolored rock is present either as a continuous framework or as corestones.
Highly weathered	More than half of the rock material is decomposed and/or disintegrated to a soil. Fresh or discolored rock is present either as a discontinuous framework or as corestones.
Completely weathered	All rock material is decomposed and/or disintegrated to soil. The original mass structure is still largely intact.
Residual soil	All rock material is converted to soil. The mass structure and material fabric are destroyed. There is a large change in volume, but the soil has not been significantly transported.

STRENGTH OR HARDNESS					
Description	Field Identification	Uniaxial Compressive Strength, psi (MPa)			
Extremely weak	Indented by thumbnail	40-150 (0.3-1)			
Very weak	Crumbles under firm blows with point of geological hammer, can be peeled by a pocket knife	150-700 (1-5)			
Weak rock	Can be peeled by a pocket knife with difficulty, shallow indentations made by firm blow with point of geological hammer	700-4,000 (5-30)			
Medium strong	Cannot be scraped or peeled with a pocket knife, specimen can be fractured with single firm blow of geological hammer	4,000-7,000 (30-50)			
Strong rock	Specimen requires more than one blow of geological hammer to fracture it	7,000-15,000 (50-100)			
Very strong	Specimen requires many blows of geological hammer to fracture it	15,000-36,000 (100-250)			
Extremely strong	Specimen can only be chipped with geological hammer	>36,000 (>250)			

	DISCONTINUITY DESCRIPTION					
Fracture Spacing (Joints	, Faults, Other Fractures)	Bedding Spacing (May Include Foliation or Banding)				
Description	Spacing	Description	Spacing			
Extremely close	< ¾ in (<19 mm)	Laminated	< ½ in (<12 mm)			
Very close	3⁄4 in – 2-1/2 in (19 - 60 mm)	Very thin	½ in – 2 in (12 – 50 mm)			
Close	2-1/2 in – 8 in (60 – 200 mm)	Thin	2 in – 1 ft. (50 – 300 mm)			
Moderate	8 in – 2 ft. (200 – 600 mm)	Medium	1 ft. – 3 ft. (300 – 900 mm)			
Wide	2 ft. – 6 ft. (600 mm – 2.0 m)	Thick	3 ft. – 10 ft. (900 mm – 3 m)			
Very Wide	6 ft. – 20 ft. (2.0 – 6 m)	Massive	> 10 ft. (3 m)			

<u>Discontinuity Orientation (Angle)</u>: Measure the angle of discontinuity relative to a plane perpendicular to the longitudinal axis of the core. (For most cases, the core axis is vertical; therefore, the plane perpendicular to the core axis is horizontal.) For example, a horizontal bedding plane would have a 0-degree angle.

ROCK QUALITY DESIGNATION (RQD) 1					
Description	RQD Value (%)				
Very Poor	0 - 25				
Poor	25 – 50				
Fair	50 – 75				
Good	75 – 90				
Excellent	90 - 100				

^{1.} The combined length of all sound and intact core segments equal to or greater than 4 inches in length, expressed as a percentage of the total core run length.

Reference: U.S. Department of Transportation, Federal Highway Administration, Publication No FHWA-NHI-10-034, December 2009 <u>Technical Manual for Design and Construction of Road Tunnels – Civil Elements</u>