

Darlington Creek
KY0105325
Notes: Quarterly

NH3 Nov-Apr 10/15 mg/L

Sample Date	CBOD 15/22.5 mg/L	TSS 30/45 mg/L	pH 6-9	E Coli 130/240	NH3 May-Oct 4/6 mg/L	DO >7	TRC .011/.019
6/21/2022	61	100	7.1	2420	1.95	7.7	0.31