

Darlington Creek							
KY0105325							
Notes: Quarterly							
					NH3 Nov-Apr 10/15 mg/L		
Sample Date	CBOD 15/22.5 mg/L	TSS 30/45 mg/L	pH 6-9	E Coli 130/240	NH3 May-Oct 4/6 mg/L	DO >7	TRC .011/.019
6/21/22	61	100	7.1	2420	1.95	7.7	0.3
6/30/22	0	1.6		36	0.35		
8/17/22	5	1.5	7.48	163	0	12.1	ND
8/20/22				131			