

**REBUTTAL TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2021-00370

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
I. INTRODUCTION	R1
II. PURPOSE OF REBUTTAL TESTIMONY	R2
III. GENERATING UNIT PERFORMANCE MEASURES	R3
IV. COMPARISON OF THE MITCHELL PLANT TO SPURLOCK.....	R8
V. CONCLUSION.....	R10

**REBUTTAL TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2021-00370

I. INTRODUCTION

1 **Q. PLEASE STATE YOUR NAME, POSITION, AND BUSINESS ADDRESS.**

2 A. My name is Timothy C. Kerns. My business address is 1 Riverside Plaza,
3 Columbus, OH 43215. In January 2024, I accepted the position of Senior Vice
4 President of Fossil Hydro Generating Assets where I lead the Fossil and Hydro
5 Generating Assets group under the American Electric Power Company, Inc.
6 Energy Services organization. Immediately prior to my current role, I was Vice
7 President of Generating Assets for Appalachian Power Company and Wheeling
8 Power Company starting March 2023. I have also served as Vice President of
9 Generating Assets for Kentucky Power Company (“Kentucky Power” or “the
10 Company”) and Indiana Michigan Power Company from 2020 to 2023.

11 **Q. ARE YOU THE SAME TIMOTHY C. KERNS WHO FILED DIRECT**
12 **TESTIMONY IN THIS PROCEEDING?**

13 A. Yes.

II. PURPOSE OF REBUTTAL TESTIMONY

1 **Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY IN THIS**
2 **PROCEEDING?**

3 A. I am responding to the incorrect assertions made in the testimony of the Office of
4 the Attorney General of the Commonwealth of Kentucky (“AG”) and the
5 Kentucky Industrial Utility Customers, Inc. (“KIUC”) Witness Lane Kollen that
6 the performance of Kentucky Power’s Mitchell units is “poor”. I address the
7 Mitchell Plant’s performance from a unit availability perspective. Company
8 Rebuttal Witness Vaughan addresses the operations (economic dispatch) of the
9 units, in particular as it affects Net Capacity Factor (“NCF”), the sole metric used
10 (inappropriately, in my view) by Mr. Kollen to measure performance.

11 I will specifically address the following aspects of Witness Kollen’s testimony
12 regarding the Mitchell Plant units’ generating performance:

- 13 1. Witness Kollen’s use of NCF as the sole metric for characterizing
14 generating unit performance; and
- 15 2. Witness Kollen’s comparison of the operating performance of the Mitchell
16 generating units to that of Eastern Kentucky Power Company’s (“EKPC”)
17 coal-fired H.L. Spurlock (“Spurlock”) units.

18 **Q. DO YOU ADDRESS THE PERFORMANCE OF ROCKPORT UNITS 1**
19 **AND 2?**

20 A. No. Witness Kollen asserts that the performance of the Rockport units was also
21 “poor.” These assertions are also not relevant to the adequacy of the service that
22 Kentucky Power provides to its customers. The Rockport Unit Power Agreement

1 (“UPA”) is a financial and contractual agreement, and Kentucky Power does not
2 control Rockport’s maintenance or dispatch. Additionally, Kentucky Power’s
3 interest in the Rockport UPA terminated prior to the events of Winter Storm
4 Elliott. Therefore, I do not address in my Rebuttal Testimony the operational
5 aspects of the Rockport Plant, which are outside the control of Kentucky Power.

III. GENERATING UNIT PERFORMANCE MEASURES

6 **Q. AG-KIUC WITNESS KOLLEN ASSERTS THAT THE MITCHELL UNITS**
7 **“OPERATED POORLY” DURING CALENDAR YEARS 2020 THROUGH**
8 **2022. DO YOU AGREE?**

9 A. No. For the reasons that I and other Company witnesses have explained in recent
10 Commission proceedings, including most recently in Kentucky Power’s 2021-
11 2023 Fuel Adjustment Clause Proceeding, Docket No. 23-000008, Kentucky
12 Power prudently maintains the Mitchell Plant and has achieved good results for
13 the plant. More to the point here, Mr. Kollen offers no valid evidence to support
14 his contention that the Mitchell Plant “operated poorly.” Mr. Kollen reaches his
15 conclusion by relying solely on NCF data, a metric that is not appropriate to
16 assess unit reliability and is not ordinarily used by plant operators to do so. He
17 also draws an inapt comparison to EKPC’s Spurlock units.

18 **Q. WHY DO PLANT OPERATORS NOT RELY ON NET CAPACITY**
19 **FACTOR DATA TO ASSESS GENERATOR PERFORMANCE?**

20 A. The primary reason that plant operators do not rely on NCF to assess generator
21 performance is that it is primarily an energy market-driven metric, the ratio of a
22 unit’s actual generation output to its maximum potential generation output (“Net

1 Maximum Capacity”) for a given period, as explained by Company Rebuttal
2 Witness Vaughan. That ratio is naturally affected by factors having nothing to do
3 with a plant’s availability. Anything that causes the unit’s output to be less than
4 its Net Maximum Capacity will reduce its NCF, including routine maintenance
5 and ordinary economic dispatch decisions by PJM. As a result, even a well-
6 maintained and well-performing plant may have a low NCF during several or
7 many months.

8 Here, Mr. Kollen fails to recognize that generating unit performance is a
9 result of economics and availability. Specifically, Mr. Kollen does not analyze the
10 extent to which Mitchell’s NCF is driven by prudent maintenance practices and
11 economics. Notably, as Mr. Vaughan discusses, Mitchell may operate for few
12 hours during certain months simply because it is less expensive to serve
13 customers with power purchased from the PJM power pool. Accordingly, a unit’s
14 NCF provides little insight into its performance.

15 The better measure of a unit’s performance is its Equivalent Availability
16 Factor (“EAF”), as supplemented by its Equivalent Planned, Maintenance, and
17 Forced Outage Factors. With these metrics, it is possible to understand when the
18 unit was available to run, and for those times it was not operational and why not.
19 The Equivalent Demand Forced Outage Factor (“EFORd”) is also an important
20 metric for describing unit reliability. Mr. Kollen addressed none of these.
21 Company Witness Rosenberger and I fully addressed Mitchell’s performance,
22 including outage planning, in our testimony in Docket No. 2023-000008.

1 **Q. CAN YOU ELABORATE ON WHY A WELL-PERFORMING PLANT'S**
 2 **NET CAPACITY FACTOR MAY APPEAR LOW EVEN WHEN THE**
 3 **PLANT IS PHYSICALLY AVAILABLE TO OPERATE?**

4 A. Yes, consider the following five scenarios for a hypothetical 100 MW plant's
 5 operation over a given month, which I summarize below in Figure TCK-R1:

- 6 • Scenario 1 – The 100 MW unit is available for operation at its rated output
 7 and dispatched for 100% of the hours in the month.
- 8 • Scenario 2 – The 100 MW unit is available for operation and dispatched
 9 for 100% of the month but has a forced de-rate of 50MW for the entire
 10 month.
- 11 • Scenario 3 – The 100 MW unit is available for operation at its rated output
 12 for only 50% of the hours in the month due to a Planned Outage. It is
 13 dispatched at its rated output for the remaining 50% of the month.
- 14 • Scenario 4 – The 100 MW unit is available for operation at its rated output
 15 for 100% of the month but is not selected for operation due to market
 16 conditions (Reserve Shutdown) during the month.
- 17 • Scenario 5 – The 100 MW Unit is available for operation at its rated
 18 output for 100% of the month but its actual output is 40% for that entire
 19 month due to market conditions.

**Figure TCK-R1 – NCF and EAF Relationships for a
 Theoretical 100 MW Rated Unit**

Scenario #	Percent of Month Available (%)	Derate Factor (%)	Outage Factor (%)	Dispatched (% of Month)	Available Unit Output (MW)	NCF (%)	EAF (%)
1	100	0	0	100	100	100	100
2	100	50	0	100	50	50	50
3	50	0	50	50	100	50	50
4	100	0	0	0	100	0	100
5	100	0	0	40	100	40	100

1 As you can see, the NCF is affected both by unit availability issues (scenarios 2
2 and 3) and market conditions (scenarios 4 and 5). The EAF, however, is affected
3 only by unit derates (curtailments) and outages. In my view, it does not make
4 sense to consider factors unrelated to a plant's ability to run when evaluating its
5 performance. Again, Mr. Vaughan also discussed how PJM makes economic
6 dispatch decisions.

7 **Q. MR. KOLLEN OBSERVES THAT BOTH MITCHELL UNITS DID NOT**
8 **OPERATE FOR ENTIRE MONTHS AT A TIME. DOES THAT PROVIDE**
9 **INSIGHT INTO THE UNITS' PERFORMANCE?**

10 A. No, for the same reason that NCF alone is not an appropriate metric to evaluate
11 plant performance; a plant can have a 0% NCF for reasons entirely unrelated to its
12 availability. Mr. Kollen's own Exhibit LK-2 proves the point: in most cases, EAF
13 percentages far exceed NCF percentages for the same period, showing that the
14 NCF is driven by factors other than availability. For example, when a plant is not
15 economically selected by PJM and not self-scheduled by the Company, it enters
16 Reserve Shutdown status, where it is disconnected from the grid by the Plant and
17 placed on standby. While the plant is in Reserve Shutdown status, however, it
18 remains available to PJM to start up within its stated operating parameters and
19 operate. During Reserve Shutdowns, a unit's NCF can be 0% while its EAF will
20 be 100%.

21 Moreover, a plant's NCF will be 0% during routine Planned and
22 Maintenance Outages. As I explained in my Direct Testimony (at 7:15-9:8, 11:1-
23 21), Company generating assets, including Mitchell, are maintained in accordance

1 with industry and manufacturer standards to provide safe, economical, and
2 reliable generation output. The Company typically schedules outages during
3 times when the market has historically been less volatile, that is, during shoulder
4 months March to May and October to December. Mr. Kollen has not questioned
5 the prudence of Kentucky Power's scheduling of Planned or Maintenance
6 Outages at Mitchell.

7 Finally, I also note that in 2021, Mitchell Unit 1 experienced a
8 catastrophic failure of the Phase 1 Generation Step-up ("GSU") Transformer,
9 which steps up the voltage from the generator output to the 765 kV line voltage
10 for one of the three phases. The incident was caused by an electrical fault inside
11 the transformer, leading to a gas buildup, breach, and significant fire. The fire
12 damaged portions of the surrounding building, electrical cables, bushings, and
13 buss-work. Relying on their training and experience, the plant team was able to
14 minimize the damage without any injuries or adverse environmental effects. But
15 because of the difficulty of removing, shipping, and replacing the large GSU
16 transformer, it took roughly two months (April 9, 2021 through June 5, 2021) to
17 return Mitchell Unit 1 to service. This catastrophic event was a rare occurrence
18 and is not expected to be a contributor to Forced Outages going forward.

IV. COMPARISON OF THE MITCHELL PLANT TO SPURLOCK

1 **Q. MR. KOLLEN ALSO SUPPORTS HIS CONCLUSIONS BY COMPARING**
2 **THE NET CAPACITY FACTORS FOR MITCHELL UNITS 1 AND 2 TO**
3 **SPURLOCK'S GENERATING UNITS. DO YOU BELIEVE MR.**
4 **KOLLEN'S ANALYSIS IS REASONABLE?**

5 A. Absolutely not. Initially, as discussed above, comparing plants' NCFs says as
6 much—or more—about the economics of their operations as their availability or
7 actual performance. Furthermore, these plants are not comparable in any case
8 because they are examples of two very different coal technologies—Mitchell is a
9 supercritical coal facility whereas Spurlock is a subcritical coal facility.

10 **Q. YOU REFERENCED THE ECONOMICS OF OPERATIONS. DO YOU**
11 **HAVE REASON TO BELIEVE THAT EKPC OPERATES SPURLOCK**
12 **USING DIFFERENT ECONOMIC PRINCIPLES THAN KENTUCKY**
13 **POWER OPERATES MITCHELL?**

14 A. Yes, Company Rebuttal Witness Vaughan discusses that further in his rebuttal
15 Testimony.

16 **Q. YOU REFERENCED DIFFERENT TECHNOLOGIES. WHY DOES IT**
17 **MATTER FOR MR. KOLLEN'S ANALYSIS THAT MITCHELL IS A**
18 **SUPERCritical PLANT WHEREAS SPURLOCK IS A SUBCRITICAL**
19 **PLANT?**

20 A. Simply put, because Mitchell is a supercritical plant and Spurlock is a subcritical
21 plant, Mr. Kollen's analysis is between apples and oranges.

1 By way of background, supercritical coal-fired units operate at high
2 pressure and temperature, above a thermodynamic “critical point,” reducing the
3 energy needed to change the water into steam. Consequently, supercritical units
4 require less coal to heat the same amount of water, considerably increasing the
5 plant’s design thermal efficiency. Subcritical coal-fired units, by contrast, operate
6 below the “critical point” and do not achieve the same benefits as a supercritical
7 unit. These inherent differences affect NCFs in two main ways.

8 First, the higher pressure and temperature of a supercritical unit results in
9 higher stresses on the components, requiring more frequent maintenance. This
10 can result in the need for more Planned and Maintenance Outages to keep the
11 units operating safely, efficiently, and reliably, and could potentially lead to
12 Forced Outages.

13 Second, the operating parameters of the technologies affect their economic
14 dispatch patterns. When they were originally built in the 1970s and 1980s,
15 supercritical units were considered baseload units that operated continuously,
16 whereas subcritical plants had greater flexibility. Now, energy prices are often
17 below the cost of operating supercritical units continuously. Moreover, because
18 of their limited operational flexibility, supercritical units are often not selected
19 even to satisfy intraday peaks. Accordingly, when following economic dispatch, I
20 would expect the NCFs of supercritical units in PJM to be generally lower than
21 those of subcritical units.

V. CONCLUSION

1 **Q. WHAT CONCLUSIONS SHOULD THE COMMISSION DRAW FROM**
2 **YOUR REBUTTAL TESTIMONY?**

3 A. First, the Commission should conclude that Mr. Kollen's assertion that the
4 performance of Kentucky Power's Mitchell units is "poor" is inaccurate. Mr.
5 Kollen relied solely on NCF, a generation performance metric that is substantially
6 affected by energy market conditions, and failed to acknowledge that a generating
7 unit's performance is a result of both economics and availability.

8 Secondly, Mr. Kollen's comparison of the operating performance of the
9 Mitchell generating units to that of EKPC's coal-fired Spurlock units is of no
10 relevance since these plants are not comparable in any case because they are
11 examples of two very different coal technologies, and the operating parameters of
12 the technologies affect their economic dispatch patterns.

13 Lastly, Kentucky Power's generating assets provide adequate performance
14 and safe, economic, environmentally compliant, and reliable generation output to
15 serve load and accommodate fluctuating customer needs. Notably, the Mitchell
16 Plant was available and operated during Winter Storm Elliott, in contrast to many
17 other PJM coal unit resources that experienced forced outages.

18 **Q. DOES THIS CONCLUDE YOUR REBUTTAL TESTIMONY?**

19 A. Yes, it does.

