## I.T.M. Inc.

Inspection, Testing, & Maintenance Inc. 578 Crowe Ln. Fordsville, Ky. 42343
Office: (270) 903-1586 Mobile: (270)-903-1230

Member K.R.W.A.
Public Service Comm.
License # W1111

itminc67599@bellsouth.net

## FIRE HYDRANTS-WATER METERS- BACKFLOW PREVENTION

## Water Meter Test Results

Tested for: Beech Grove Water System	Test Date: 1-4-22
Location: City of Henderson	Bench or Field: Field
Size: 6" Manufacturer: Badger	Type: <u>Turbine</u> #: <u>47681101</u>

	Single register Reading	Low Side Reading	High Side Reading
Beginning Reading	54409706.3		and the Meading
End Reading	54410222.3		

# of Gallons @ G.P.M.	Accuracy in percent
000 Gal. @ 400 GPM	94.8
000 Gal. @ 200 GPM	95.4
000 Gal. @ 50 GPM	99.2