

Beech Grove Water System

445 State Route 56 N

Calhoun, KY 42327

270-273-5738

Case No. 2022-00318

Dear Public Service Commission,

Beech Grove Water System would like to request approval to use money from the surcharge account to reimburse ourselves for the expenses from a water leak at 131 Hunt Road, Calhoun, Kentucky. These expenses would include materials, labor and the cost of the water that was lost.

Customers began to report lower than normal water pressure. Upon investigation by the operator, it was determined that there was water coming from the water line under the road at this address. A road bore was needed. New municipex pipe was run under the road from the water main to the meter service. The meter and setter needed to be replaced as well. Water loss estimation is approximately 300,000 gallons. Repairing this leak has helped the water systems monthly water loss.

CommonWealth Central Supply was the contractor hired to perform the repairs. Their invoices have detailed charges and are attached.

G&C Supply Co., Inc. is the supplier of all materials used. Their detailed invoices are also attached showing the job specific materials purchased.

Rice Contracting completed the road bore. Their invoice is attached.

Complete totals for this leak are as follows:

CommonWealth Central Supply	\$645.00
G&C Supply Co.	\$856.18
Rice Contracting, LLC	\$500.00

Beech Grove Water system would like to be able to use \$2,001.18 of money from the surcharge account for this specific leak.

Please contact us at 270-273-5738 or at beechgroviewaters@bellsouth.net for any questions.

Thank you,

Jennifer Ferguson

Jennifer Ferguson