

Beech Grove Water System

445 State Route 56 N

Calhoun, KY 42327

270-273-5738

Case No. 2022-00318

Dear Public Service Commission,

Beech Grove Water System would like to request approval to use money from the surcharge account to reimburse ourselves for the expenses from a water leak at 445 State Route 56 N, Calhoun, Kentucky. These expenses would include materials, labor and the cost of the water that was lost.

Water was noticed in the ditch across from the water office. It was determined that the pipe was leaking under the highway. A long road bore was needed to go under the state highway and clear the large ditch running along the road. The meter and setter needed to be replaced as well. Water loss estimation is approximately 120,000 gallons. Repairing this leak has helped the water systems monthly water loss. CommonWealth Central Supply was the contractor hired to perform the repairs. Their invoices have detailed charges and are attached. G&C Supply Co., Inc. is the supplier of all materials used. Their detailed invoices are also attached showing the job specific materials purchased. Road bore was completed by Edward Fannon. Payment record is attached.

Monthly water loss has been estimated to be 120,000 gallons. We have 2 water systems which we purchase water from. The average purchase price between the two is \$3.592 per 1,000 gallons. This would come to \$502.80 in estimated monthly water loss with this leak.

Complete totals for this leak are as follows:

445 State Route 56 N

CommonWealth	\$315.00
G&C	\$666.18
Road Bore	\$1,000.00
120,000 water loss	\$502.80

Total loss for this leak is \$2,483.98. Beech Grove Water System would like to be able to reimburse ourselves \$2,483.98 of money from the surcharge account for this specific leak.

Please contact us at 270-273-5738 or at beechgrovewaters@bellsouth.net for any questions.

Thank you,

Jennifer Ferguson

Jennifer Ferguson