

ANDY BESHEAR
GOVERNOR



REBECCA W. GOODMAN
SECRETARY

ENERGY AND ENVIRONMENT CABINET
DEPARTMENT FOR ENVIRONMENTAL PROTECTION

ANTHONY R. HATTON
COMMISSIONER

300 SOWER BOULEVARD
FRANKFORT, KENTUCKY 40601
TELEPHONE: 502-564-2150
TELEFAX: 502-564-4245

March 14, 2022

Daniel Clifford
Hardin County Water District No.1
1400 Rogersville Road
Radcliff, KY 40160

RE: Brizendine BPS Improvements
Hardin County, KY
Hardin Co Water District 1
AI #: 1673, APE20220001
PWSID #: 0470393-22-001

Dear Mr. Clifford:

We have reviewed the plans and specifications for the above referenced project. The plans include the construction of a booster pump station capable of 150 gpm @ 205 ft. of TDH each. This is to advise that plans and specifications for the above referenced project are APPROVED with respect to sanitary features of design, as of this date with the requirements contained in the attached construction permit.

If you have any questions concerning this project, please contact Michael Snyder at 502-782-1235.

Sincerely,

A handwritten signature in black ink, appearing to read "T. Humphries".

Terry Humphries, P.E.
Supervisor, Engineering Section
Water Infrastructure Branch
Division of Water

TH:MS
Enclosures

c: Cannon & Cannon, Inc.
Hardin County Health Department
Division of Plumbing