

Office:

8955 Main Street • P.O. Box 219  
Campbellsburg, KY 40011

Telephones:

(502) 532-6279 • (502) 532-6280  
1-800-256-2350

Fax:

(502) 532-0027



Water Treatment Plant:

3278 Morton Ridge Road  
Bedford, KY 40006

Telephone:

(502) 255-0126

Fax:

(502) 255-0347

IN THE MATTER OF:

Electronic Investigation into  
Compliance with Excavator Locate  
Requests pursuant to KRS367.49009 AND  
KRS 367.491(7)

Case No. 2022-00363

District's Response

The Henry County Water District #2, files this response to the Kentucky Public Service Commission  
Commission Case Number 2022-00363, the District states as follows:

- A) Since January 1, 2022, Henry County Water District #2 has received 128 line locates. Only 4 of the 124 locates called in were listed as an "emergency locate"  
HCWD#2 is not a participant of 811
- B) Since January 1, 2022, Henry County Water District #2 has received 2 second or subsequent request for the same locate. Both of those located were normal locates
- C) Since January 1, 2022 Henry County Water District #2 has responded to all locates within the statutory window. The average response time was between 24 – 48 hours. Once our employee is given a line locate he/she is to call the excavator, builder, homeowner, etc., before and after the locate has been completed. The locates are done with either blue flags and/or blue paint
- D) Since January 1, 2022 the Henry County Water District #2 has never had an agreement reached with an excavator outside the statutory limits required by KRS 367.4909
- E) Since January 1, 2022 all of the locates for Henry County Water District #2 have been performed by the Henry County Water District #2 staff.
- F) Records and Statistics of water line located accurate versus inaccurate are not kept.
- G) If there are any discrepancies between using a probe or going by our GPS units, we will dig up the water main to see if we were correct. This ensures accuracy
- H) After any locate is completed by the staff, our GPS/GIS specialist will map the lines, and waypoints. All of our new construction will be installed with tracer wire. The district would also dig up the water main to show that its accurate

Keith Morris

Henry County Water District #2  
Chief Operating Officer