

MAGOFFIN CONUTY WATER DISTRICT

P O BOX 490

SALYERSVILLE, KY 41465

Phone 606-349-6812

IN THE MATTER OF:

ELECTRONIC INVESTIGATION INTO

CASE NO.

COMPLIANCE WITH EXCAVATOR LOCATE

2022-00363

REQUESTS PURSUANT TO KRS 367.4909 AND

KRS 367.4917(7)


RESPONSE

Magoffin County Water District, as a non-municipal utility, files this response to the

Kentucky Public Service Commission Case Number 2022-00363, the District states as follows:

- A. Since January 1,2022 Magoffin County Water District has received 62 locate requests.
- B. Since January 1,2022 Magoffin County Water District has received 0 request for the same location.
- C. Since January 1,2022 Magoffin County Water District responded to all locate requests within the allotted time. The average response time was 24 hours and were marked with either blue flags or paint.
- D. Since January 1,2022 there has been no need to reach an agreement with an excavator to complete a locate request outside of the statutory limits.
- E. Since January 1,2022 all locate request have been performed by the Magoffin County Water District personnel.
- F. Since January 1,2022 no records were kept showing the number of accurately verses inaccurately located facilities. Magoffin County Water District has implemented locate work orders.
- G. The method to determine whether an underground facility has been located accurately verses inaccurately is to use as built maps.
- H. To help prevent inaccurately located lines, Magoffin County Water District requests as much information as possible when locate request is called in to the office, including the exact location, type of work being done, date work will begin, and name and phone number of the caller. New installs are equipped with tracer wire. This will help to prevent any inaccurately located facilities in the future.

MAGOFFIN County Water District

  
Allen McCarty (Superintendent)