

Commonwealth of Kentucky
Before The Public Service Commission of Kentucky

In The Matter of:

Electronic Investigation Into)	
Compliance With Excavator Locate)	Case No.
Requests Pursuant To KRS 367.4909)	2022-00363
And KRS 367.4917(7))	

RESPONSE

North Hopkins Water District, as a non-municipal utility, files this response to the Kentucky Public Service Commission Case Number 2022-00363. In response to case number 2022-00363, the District states as follows:

- a. Since January 1, 2022, North Hopkins Water District has received 57 locate requests. Those requests were broken into 53 normal requests and 4 emergency requests.
- b. North Hopkins Water District has not received any second requests normal, or emergency locates.
- c. Since January 1, 2022, North Hopkins Water District has responded to all requests within the time frame normally responding on the day we receive the request.
- d. Since January 1, 2022, North Hopkins Water District has not needed an agreement with any contractor beyond statutory time limits.
- e. Since January 1, 2022, 911 locates have been completed by North Hopkins Water District employees. No third-party contractors have been used.
- f. Since January 1, 2022, no records have been kept of accurate versus inaccurate locates.

- g. Water mains were installed without tracer wires so as built maps and probing are used and in rare cases excavating is utilized.
- h. Lines are located using the methods in section g. District employees will work with contractor during excavation and measurements are taken to show exact location of mains and services. We then correct on maps.

Steve Oakley

Superintendent

North Hopkins Water District