

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the matter of:

Electronic Investigation into
Compliance with excavator locate
Requests pursuant to KRS 367.4909
And KRS 367.4917(7)

Case # 2022-00363

A)

Electric	Gas	DOT	Construction	Misc	Total
28	4	25	20	52	129

B) N/A

C) Two business days. To my knowledge no one claimed an emergency call, so all locates were two days. Two days is within the statutory window.

D) N/A I've never been notified of any such agreement.

E) All locates are performed by utility personnel, SHWD does not contract out to 3rd parties.

F) We do not keep records of accurately located lines vs inaccurately located lines

G) There isn't really a method, the personnel locate lines by maps, asking other employees and by probing the lines.

H) As stated in "g", the line locaters probe for main lines, use maps/notes and discuss among each other where said lines are. If there aren't great notes or maps for older lines, the workers probe until the line is found to reduce the risk of inaccurate locates.

SOUTH HOPKINS WATER DISTRICT

 11-29-22
Kayla Goodaker Office Manager