

- g. When locate requests are received for an area of our system that has water mains buried with locator wire, we use appropriate locating equipment to connect to the wire and mark the area that should cover the width of the variance provided by KY 811 standards. In areas of our system that have mains that were buried with no locator wire, we either try to excavate the main to cover the locate request or we access records using our GIS system to see if previous work has been done during which we documented measurements of depth and nearest landmark.

- h. LWD #2 is not aware of any issue with inaccurately located lines within its service territory. LWD #2 has a Statement of Procedures (S.O.P.) that explains the step by step procedures to determine if a section of main has a locator wire or if it does not. There are then step by step procedures for line locates if the main has a locating wire and step by step procedure for line locates if the main has no locator wire.