

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION)
INTO COMPLIANCE WITH)
EXCAVATOR LOCATE REQUESTS) CASE NO. 2022-00363
PURSUANT TO KRS 367.4909 AND)
KRS 367.4917(7))

RESPONSE OF
WESTERN FLEMING COUNTY WATER DISTRICT
TO
COMMISSION'S NOVEMBER 16, 2022 ORDER

FILED: DECEMBER 22, 2022


COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION)
INTO COMPLIANCE WITH)
EXCAVATOR LOCATE REQUESTS) CASE NO. 2022-00363
PURSUANT TO KRS 367.4909 AND)
KRS 367.4917(7))

**RESPONSE OF WESTERN FLEMING COUNTY WATER DISTRICT
TO COMMISSION'S NOVEMBER 16, 2022 ORDER**

Comes WESTERN FLEMING COUNTY WATER DISTRICT (WFCWD)
for its Response to Commission's November 16, 2022 Order, and states as shown on
the following pages.



ALISON HAZELRIGG
PO BOX 16 EWING KY 41039
WFWD@WINDSTREAM.NET

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC INVESTIGATION)
INTO COMPLIANCE WITH)
EXCAVATOR LOCATE REQUESTS) CASE NO. 2022-00363
PURSUANT TO KRS 367.4909 AND)
KRS 367.4917(7))

**CERTIFICATION OF RESPONSE OF
TO COMMISSION'S NOVEMBER 16, 2022 ORDER**

This is to certify that I have supervised the preparation of WESTERN FLEMING COUNTY WATER DISTRICT'S Responses to Commission's November 16, 2022 Order. The response submitted on behalf of WESTERN FLEMING COUNTY WATER DISTRICT is true and accurate to the best of my knowledge, information, and belief formed after a reasonable inquiry.

Date: December 22, 2022



ALISON HAZELRIGG OFFICE MANAGER
WESTERN FLEMING COUNTY WATER
DISTRICT

CERTIFICATE OF SERVICE

In accordance with the Commission's Order of July 22, 2021 in Case No. 2020-00085 (Electronic Emergency Docket Related to the Novel Coronavirus COVID-19), this is to certify that the electronic filing has been transmitted to the Commission on December 22, 2022; and that there are currently no parties in this proceeding that the Commission has excused from participation by electronic means.


ALISON HAZELRIGG

WESTERN FLEMING COUNTY WATER DISTRICT

CASE NO. 2022-00363

Response to Commission's November 16, 2022 Order

Question No. 2

Responding Witness: ALISON HAZELRIGG, OFFICE MANAGER

Q-2(a). Since January 1, 2022, the number of locate requests received in total and broken out into the types of locate requests contained in KRS 367.4909(5);

A-2(a). Since January 1, 2022, WESTERN FLEMING COUNTY WATER DISTRICT (WFCWD) has received 2 locate requests. The current system of tracking the locate requests does not differentiate the requests by types of locate requests.

Q-2(b). Since January 1, 2022, the number of second or subsequent requests for the same locate request received in total and broken out into the types of locate requests contained in KRS 367.4909(5);

A-2(b). Since January 1, 2022, WFCWD has received 0 second or subsequent requests.

Q-2(c). Since January 1, 2022, the length of time required to respond to each requestor/excavator in total and broken out into the types of locate requests contained in KRS 367.4909(5). Also, provide information showing whether underground facilities are marked within the statutory window, and the average time it takes to respond to a locate request;

A-2(c). WFCWD to its knowledge has complied with KRS 367.4909(5) withing the statutory window. WFCWD does not keep record of markings within the statutory window.

Q-2(d). **Since January 1, 2022, the number of times an agreement has been reached with an excavator outside of the statutory time limits required by KRS 367.4909, with the aggregate numbers and broken out into the types of locate requests contained in KRS 367.4909(5);**

A-2(d). WFCWD has not needed to reach an agreement with an excavator outside the statutory time limit.

Q-2(e). **Since January 1, 2022, state whether locate requests have been performed by Utility personnel or by a third-party contractor. If the answer is both, provide the number of locate requests performed by Utility personnel and third-party contractors, respectively;**

A-2(e). All locate requests have been performed by the utility's personnel.

Q-2(f). **State whether records and statistics are kept of the number of underground facilities located accurately versus inaccurately. Provide all records and statistics compiled since January 1, 2022;**

A-2(f). Specific records or statistics are not kept referencing accurate versus inaccurate location of WFCWD'S infrastructure. However, our work orders indicate there were 0 service lines and 0 water mains that were compromised due to inaccurate information about our system.

Q-2(g). Explain the method used to determine whether an underground facility has been located accurately versus inaccurately; and

A-2(g). WFCWD considers the locate being accurately located if the water line has not been hit.

Q-2(h). State what policies and procedures have been implemented to reduce the number of inaccurately located facilities. Provide information detailing the efficacy of those procedures on reducing the number of inaccurately located underground facilities.

A-2(h). WFCWD uses its as-built maps and if the maps are not complete, we will spot dig the waterline for an accurate location.