

GCSSD – BYPASS REPORT -02/18/22

491- LIFT STN –

CALLED & REPORTED TO JEFF MALSI AT DIV OF WATER 859-525-4923 THAT A BYPASS HAD OCCURRED. THE BYPASS WAS DUE TO HEAVY RAIN THAT OCCURRED FROM 8:00 AM TO 11:00 PM 02/17/22.

THE OVERFLOW AMOUNT WAS APPX 5000 GALLONS, IT OCCURRED BETWEEN 7:00 PM AND 11:30 PM. WHEN IT WAS FOUND, ERNIE RYAN CLEANED UP THE AREA & LIMED THE AREA.