

GCSSD – BYPASS REPORT -12/9/21

WALLER DR PUMP STN

CALLED & REPORTED TO ADAM SMITH (MATT @ DOW SAID HE REASSIGNED ADAM SMITH TO THIS COUNTY) AT DIV OF WATER 859-525-4923 THAT A BYPASS HAD OCCURRED. THE BYPASS WAS DUE TO A BROKEN IMPELLER – THE OVERFLOW AMOUNT WAS APPX 3800 -4500 GALLONS. IT OCCURRED AT APPROXIMATELY 12:00 AM AND RAN OVER FOR 8 HRS UNTIL IT WAS FOUND & REPAIRED. WHEN IT WAS FOUND, ERNIE RYAN CLEANED UP THE AREA & LIMED THE AREA.