

COMMONWEALTH OF KENTUCKY
ENERGY and ENVIRONMENT CABINET
DEPARTMENT FOR ENVIRONMENTAL PROTECTION
Division of Enforcement

NOTICE OF VIOLATION

To: Grant Co Sanitary Sewer District WWTP
Mr. William L Catlett
PO Box 460

Crittenden, KY 41030

AI Name: Grant Co Sanitary Sewer District WWTP **AI ID:** 1480 **Activity ID:** ENV20200004
County: Grant
Enforcement Case ID:
Date(s) Violation(s) Observed: 09/04/2020

This is to advise that you are in violation of the provisions cited below:

1 Violation Description for Subject Item AIOO0000001480():

No person shall, directly or indirectly, throw, drain, run or otherwise discharge into any of the waters of the Commonwealth, or cause, permit or suffer to be thrown, drained, run or otherwise discharged into such waters any pollutant, or any substance that shall cause or contribute to the pollution of the waters of the Commonwealth in contravention of the standards adopted by the cabinet or in contravention of any of the rules, regulations, permits, or orders of the cabinet or in contravention of any of the provisions of this chapter. [KRS 224.70-110]

Description of Non Compliance:

Failing to comply with 40 CFR 122.41(a), as adopted by 401 KAR 5:065, Section 2(1), by failing to comply with the terms and conditions of KPDES Permit No. KY0091634, monitoring point 001-1, for CBOD. The permitted limit for CBOD is concentration max. weekly avg., less than or equal to 30 mg/L. The facility reported the following: concentration max. weekly avg. 35 mg/L for April 2020.

The remedial measure(s), and date(s) to be completed by are as follows:

The permittee shall comply with the terms and conditions of the KPDES Permit. [KRS 224.70-110]

2 Violation Description for Subject Item AIOO0000001480():

No person shall, directly or indirectly, throw, drain, run or otherwise discharge into any of the waters of the Commonwealth, or cause, permit or suffer to be thrown, drained, run or otherwise discharged into such waters any pollutant, or any substance that shall cause or contribute to the pollution of the waters of the Commonwealth in contravention of the standards adopted by the cabinet or in contravention of any of the rules, regulations, permits, or orders of the cabinet or in contravention of any of the provisions of this chapter. [KRS 224.70-110]

Description of Non Compliance:

Failing to comply with 40 CFR 122.41(a), as adopted by 401 KAR 5:065, Section 2(1), by failing to comply with the terms and conditions of KPDES Permit No. KY0091634, monitoring point 001-1, for pH. The permitted limit for pH is concentration max., less than or equal to 9 su. The facility reported the following: concentration max. 9.11 su for June 2020.

The remedial measure(s), and date(s) to be completed by are as follows:

The permittee shall comply with the terms and conditions of the KPDES Permit. [KRS 224.70-110]

Grant Co Sanitary Sewer District WWTP
Mr. William L Catlett
PO Box 460

Crittenden, KY 41030