

GCSSD – BYPASS REPORT -08/31/20

VINCENT LIFT STN –

CALLED & REPORTED TO ABIGAIL HARRIS AT DIV OF WATER 859-525-4923 THAT A BYPASS HAD OCCURRED. THE BYPASS WAS DUE TO A HOLE IN THE PUMP LINE – IT ONLY LEAKED WHEN IT WAS THE OVERFLOW AMOUNT WAS APPX 500-1000 GALLONS. WHEN IT WAS FOUND, ERNIE RYAN CLEANED UP THE AREA & LIMED THE AREA.