

GCSSD – BYPASS REPORT -09/03/20

491- LIFT STN –

CALLED & REPORTED TO ABIGAIL HARRIS AT DIV OF WATER 859-525-4923 THAT A BYPASS HAD OCCURRED. THE BYPASS WAS DUE TO HEAVY RAIN THAT OCCURRED FROM 1:00 PM TO 4:00 PM THE OVERFLOW AMOUNT WAS APPX 3000 GALLONS. WHEN IT WAS FOUND, ERNIE RYAN CLEANED UP THE AREA & LIMED THE AREA.