

RFI # 18



ANDY BESHEAR
GOVERNOR

REBECCA W. GOODMAN
SECRETARY

ENERGY AND ENVIRONMENT CABINET
DEPARTMENT FOR ENVIRONMENTAL PROTECTION

ANTHONY R. HATTON
COMMISSIONER

300 SOWER BOULEVARD
FRANKFORT, KENTUCKY 40601

July 20, 2021

Brian Simpson
PO Box 460
Crittenden, KY 41030

Re: 200,000 Gallon Equalization Basin
Grant County, Kentucky
Grant Co Sanitary Sewer District WWTP
Activity ID: 1480, APE20210001
Receiving Treatment Plant KPDES #: KY0091634

Dear Mr. Simpson:

We have reviewed the plans and specifications for the above referenced project. The plans include the construction of a 200,000-gallon equalization basin, flow diversion/splitter box, aeration blower with coarse bubble diffusers, and two pumps with a Valve Vault. This is to advise that plans and specifications for the above referenced project are APPROVED with respect to sanitary features of design, as of this date with the requirements contained in the attached construction permit.

If we can be of any further assistance or should you wish to discuss this correspondence, please do not hesitate to contact Michael Snyder at 502-782-1235.

Sincerely,

A handwritten signature in black ink, appearing to read "T. Humphries".

Terry Humphries, P.E.
Supervisor, Engineering Section
Water Infrastructure Branch
Division of Water

TH / MS
Enclosures

c: Grant County Health Department
HMB Professional Engineers Inc
Division of Plumbing