

Gas Conversion Impacts to Emissions

Mill Creek 1 and 2

- Emissions of SO₂ and particulate matter will decrease, permitting the unit to operate without the WFGD or PJFF.
- NOx emission rate exiting boiler will decrease, unclear if this will comply with NAAQS regulations going forward
- CO₂ emissions will decrease.
- CO emissions will increase.
- MATS will no longer apply
- NSR – Increased CO and VOC could result in NSR requirements. If generation increases, NOx tons may increase, resulting in NSR requirements.