

Gas Conversion Considerations Mill Creek 1, 2 and Brown 3



PPL companies

E.W. Brown Station
Mill Creek Station
Generation Engineering

Gas Conversion Study Driver

Bridge the generation gap between coal unit retirements and construction of new generation by converting Brown 3, Mill Creek 1 and/or Mill Creek 2 from coal to natural gas fuel.

Gas Conversion Considerations

- Gas Supply
 - Piping System Capacity
 - Gas Burner Design and Installation
- NFPA Review
 - Required modifications
- Unit Capacity and Efficiency Impacts
- Impact of Steam Conditions on the Turbine
- Impact to Emissions
- Impact to O&M Costs
- Capital Costs

Gas Supply Considerations

Brown 3

- Gas Supply
 - Piping System Capacity
 - Branch from existing pipeline to plant
 - High pressure regulating, metering and heating station, low pressure regulating station
 - Gas Burner Design and Installation
 - NFPA compliant gas supply piping system at the boiler

Mill Creek 1 and 2

- Gas Supply
 - Piping System Capacity
 - Current capacity is 1,327 Mcfh @ lowest inlet gas transmission pressure
 - Changing orifice plate size will permit 2,400 Mcfh
 - Gas regulation equipment capacity is 3,000 Mcfh
 - Mill Creek 1 and 2 require 3,000 Mcfh each to convert to natural gas (not considering startup gas for Units 3&4)
 - Gas Burner Design and Installation
 - NFPA compliant gas supply piping system at the boiler

Gas Conversion Impact to Performance

Brown 3

- Capacity and Efficiency Impacts
 - 23.7 MW reduction in full load capacity with no increase in fuel burn rate
 - Boiler efficiency reduction of 3%
 - Unit Net Heat Rate Increase of 390 Btu/kWh
 - Increased turndown
- Impact of Steam Conditions on Turbine
 - Main steam temperature decrease of 52°F
 - Hot reheat steam temperature decrease of 87°F

EW Brown Unit 3		
	Coal	Gas
Target Gross Turbine Generator Load, MW	448.03	448.03
Turbine Derate, MW	0	23.7
Turbine Derate, %	NA	5.3
Maximum Gross Turbine Output, MW	448.03	424.33
Boiler Efficiency, % (HHV)	87.36	84.36
Net Plant Heat Rate, Btu/kWh	10696	11086
Boiler Heat Input, Mbtu/hr	4562.77	4820.68
Coal Flow Rate, ton/hr	202.57	
Natural Gas Flow Rate, kcfm		75.5
Main Steam Outlet Temperature, °F	968	916
Hot Reheat Steam Outlet Temperature, °F	997	910
Economizer Flue Gas Outlet Temperature, °F	746.5	714.8
Air Heater Flue Gas Outlet Temperature, °F	317.2	292.1

Gas Conversion Impact to Performance

Mill Creek 1 and 2

- Capacity and Efficiency Impacts
 - Potential reduction in full load capacity with no increase in fuel burn rate
 - Boiler efficiency reduction
 - Unit Net Heat Rate Increase
 - Increased turndown
- Impact of Steam Conditions on Turbine
 - Main steam temperature decrease
 - Hot reheat steam temperature decrease

Gas Conversion Impacts to Emissions

Brown 3

- Emissions of SO₂ and particulate matter will decrease, permitting the unit to operate without the WFGD or PJFF.
- NOx emission rate exiting boiler will decrease, permitting operation of the SCR at a lower removal efficiency, with less ammonia.
- CO₂ emissions will decrease.
- CO emissions will increase. Potentially requiring CO catalyst, which could be installed in the existing SCR
- MATS will no longer apply
- **NSR – Increased CO and VOC could result in NSR requirements. If generation increases, NOx tons may increase, resulting in NSR requirements.**

EW Brown Unit 3		
	Coal	Gas
CO ₂ , lb/hr	927,437	563,200
CO, lb/Mbtu	*	0.15
NOx, lb/Mbtu	0.04	0.08 - 0.12 ¹
*Baseline emissions were based on an emission factor of 0.5 lb-CO per ton coal burned		
1) Based on natural gas burners with overfire air, no SCR.		

Case No. 2022-00402

Attachment 3 to Response to JI-1 Question No. 1(c)

Page 7 of 8

Gas Conversion Impacts to Emissions

Mill Creek 1 and 2

- Emissions of SO₂ and particulate matter will decrease, permitting the unit to operate without the WFGD or PJFF.
- NOx emission rate exiting boiler will decrease, unclear if this will comply with NAAQS regulations going forward
- CO₂ emissions will decrease.
- CO emissions will increase.
- MATS will no longer apply
- NSR – Increased CO and VOC could result in NSR requirements. If generation increases, NOx tons may increase, resulting in NSR requirements.