

Brandan Burfict

Manager, Environmental Air
Environmental Affairs
O 502-627-2791 | M 502-991-1113
brandan.burfict@lge-ku.com



December 15, 2022

Mr. Matt King
Industrial Permitting Manager
Air Pollution Control District
701 West Ormsby Ave, Suite 303
Louisville, KY 40203

**RE: NGCC Unit 5 Air Permit Application
Louisville Gas & Electric Company – Mill Creek Generating Station; Plant ID: 127**

Dear Mr. King:

Louisville Gas & Electric Company (LG&E) currently operates an electric generation power plant, the Mill Creek Generating Station (Mill Creek), located in Jefferson County, Kentucky. The facility is classified as a major source under the Title V Operating Permit Program and currently operates in accordance with Title V Air Operation Permit No. O-0127-20-V.

LG&E is submitting the enclosed air permit application to obtain a construction permit and amended Title V Operating Permit to include the installation of a new 664 MW (net) natural gas-fired combined cycle (NGCC) electric generating Unit 5. In light of their book life and upcoming new regulatory requirements that would be imposed, the existing Units 1 and 2 coal boilers are also being retired and NGCC Unit 5 is being constructed to replace their capacity.

The NGCC Unit 5 will consist of one natural gas-fired gas combustion turbine, a steam turbine, and one heat recovery steam generator (HRSG) with natural gas-fired duct burners arranged in a one-on-one configuration. NGCC Unit 5 will utilize dry-low-NO_x combustors in the gas turbine and low-NO_x duct burners in the HRSG. It will also be equipped with an oxidation catalyst and Selective Catalytic Reduction as add-on control systems to reduce stack NO_x, CO, hydrocarbons, and organic hazardous air pollutant emissions. The use of a highly efficient combined cycle 1 x 1 gas turbine and HRSG unit will also minimize greenhouse gas emissions by extracting the maximum amount of usable energy from the fuel gas, thus minimizing the amount of natural gas required to be combusted to generate electricity.

The state-of-the-art technology design features as well as the control measures being used for NGCC Unit 5, combined with the emission reductions from the shutdown of the Units 1 and 2 coal boilers, will result in a significant improvement in the air emissions profile for the Mill Creek Generating Station. Following the implementation of the NGCC Project, there will be significant reductions in actual emission for NO_x, SO₂, and particulate matter. The significant decreases in NO_x emissions should contribute to reductions in regional ozone concentrations. In addition, the project is expected to result in net CO₂e emission reductions. Coupled with these significant environmental benefits, the planned project will bring a major new capital investment to the Mill

Mr. Matt King
December 15, 2022

Creek Generating Station and help ensure that it remains a critical asset for the company to meet the energy needs of its customers for several decades.

In recognition of U.S. EPA's current environmental justice policies, LG&E has performed certain environmental justice reviews. LG&E evaluated the Mill Creek Generating Station and the surrounding area using Version 1.0 of the *Climate & Economic Justice Screening Tool*. Mill Creek resides in tract number 21111012104 in Jefferson County. This tract is considered disadvantaged because it meets more than 1 burden threshold and the associated socioeconomic threshold. The area met the threshold for Health (Life Expectancy and Low Income) and Housing (Lack of Indoor Plumbing and Low Income). This project has no significant impacts to the environment and will also result in environmental benefits by facilitating replacement of higher emitting coal-fired generating units at the site. The localized air emissions and traffic reductions resulting from the project should theoretically translate to improved health (life expectancy) outcomes. The combination of indicators for the Housing threshold are not related to LG&E operations. This project will provide economic benefit in the local to the community and reliable, affordable electric service to the LG&E customers generally.


Although currently there are no specific legal requirements mandating environmental justice review as part of the state review process, LG&E opted to perform the above-referenced environmental justice review in order to be both proactive and transparent.

We look forward to working in cooperation with Air Pollution Control District (APCD) personnel to help ensure the timely and successful completion of this permit action. To support the project procurement timeline, LG&E is requesting to obtain the construction permit authorizing the project by **October 1, 2023**.

In follow-up to submittal of the enclosed hard-copy of the application, LG&E will separately email a searchable PDF electronic file of the entire application by email along with the dispersion modeling analysis files used in completing the Strategic Toxic Air Reduction (STAR) Program compliance demonstration analysis. In addition, LG&E will also be providing a copy of the Excel file that contains the emissions calculations presented in the application.

If you or any other APCD staff have any questions or need additional information as you initiate your review of the application, please do not hesitate to contact me at (502) 627-2791 or brandan.burfict@lge-ku.com.

Sincerely,

DocuSigned by:

275A1971A06448A...

Brandon Burfict
Manager, Environmental Air

Enclosure

cc: Mr. Philip Imber, Director, Environmental and Federal Regulatory Compliance, LG&E
Ms. Marlene Zeckner Pardee, Senior Environmental Scientist, LG&E

Mr. Matt King
December 15, 2022

Mr. Jason Wilkerson, Senior Environmental Engineer, LG&E
Mr. Alex Betz, Manager, Production, LG&E Mill Creek Generating Station
Mr. Steven Turner, Vice President Power Production, LG&E and KU Energy
Mr. Paul J. Smith, P.E., Director, Trinity Consultants
Mr. Michael Zimmer, P.E., Principal Consultant, Trinity Consultants

AIR PERMIT APPLICATION New NGCC Combustion Turbine Project



a PPL company

**Louisville Gas & Electric Company
Mill Creek Generating Station**

14460 Dixie Hwy
Louisville, KY 40272



December 15, 2022

Prepared By:

TRINITY CONSULTANTS

1717 Dixie Hwy, Suite 900
Covington, KY 41011
859-341-8100

www.trinityconsultants.com



TABLE OF CONTENTS

| | |
|---|------------|
| 1. APPLICATION SUMMARY | 1-1 |
| 1.1 Purpose of Application | 1-1 |
| 1.2 Project Schedule | 1-2 |
| 1.3 Summary of Application Contents | 1-2 |
| 2. PROJECT DESCRIPTION | 2-4 |
| 2.1 Site Location | 2-4 |
| 2.2 Background on Existing Site Operations and Emission Units | 2-4 |
| 2.3 Proposed New Operations | 2-4 |
| 2.3.1 NGCC Unit 5 (U23/E49a-E49e)..... | 2-5 |
| 2.3.2 Auxiliary Boiler (U24/E50)..... | 2-9 |
| 2.3.3 Emergency Generator with Diesel-Powered Engine (U25/E51)..... | 2-9 |
| 2.3.4 Fuel Gas (Dewpoint) Heater (U26/E52) | 2-10 |
| 2.3.5 Emergency Diesel-Driven Fire Pump Engine (IA4/IE28) | 2-10 |
| 2.3.6 Mechanical Draft Cooling Tower (IA5/IE24) | 2-10 |
| 2.3.7 Lube Oil System with Demister Vents (IA5/IE25)..... | 2-10 |
| 2.3.8 Diesel Storage Tanks (IA5/IE26)..... | 2-10 |
| 2.3.9 HVAC Heaters (Total 10 MMBtu/hr) (IA27) | 2-10 |
| 2.4 Shutdown of Existing Operations | 2-11 |
| 3. EMISSIONS CALCULATION METHODOLOGIES AND SUMMARY | 3-1 |
| 3.1 Unit 5 Gas Turbine with HRSG (U23/E49a-e)..... | 3-1 |
| 3.1.1 GT/DB Emissions from Steady State Operations | 3-1 |
| 3.1.2 GT/DB Emissions from Startup and Shutdown Operations | 3-4 |
| 3.1.3 GT/DB Annual Emissions | 3-5 |
| 3.2 Ancillary Equipment..... | 3-7 |
| 3.2.1 Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52) | 3-7 |
| 3.2.2 Emergency Use Diesel-Fired Engines | 3-7 |
| 3.2.3 Storage Tanks and Organic Losses | 3-7 |
| 3.3 Potential Emissions Summary..... | 3-8 |
| 4. NSR APPLICABILITY ASSESSMENT | 4-1 |
| 4.1 PSD/NA-NSR Applicability Background | 4-1 |
| 4.2 Existing Source Classification | 4-1 |
| 4.2.1 PSD Permitting Program Source Classification | 4-1 |
| 4.2.2 Nonattainment NSR Program Source Classification | 4-2 |
| 4.3 NSR Applicability Analysis Methodology..... | 4-3 |
| 4.3.1 Defining the Project | 4-3 |
| 4.3.2 Existing versus New Emission Units..... | 4-3 |
| 4.3.3 Two-Step Major Modification Determination Process..... | 4-4 |
| 4.4 Components of Project Emission Increases..... | 4-6 |
| 4.4.1 Potential Emissions | 4-6 |
| 4.4.2 Baseline Actual Emissions (BAE)..... | 4-6 |
| 4.4.3 Projected Actual Emissions (PAE) | 4-7 |
| 4.4.4 Additional Associated Emission Unit Increases..... | 4-7 |
| 4.5 Project Emission Increase Evaluation..... | 4-7 |
| 4.6 PSD/NA-NSR Applicability Summary | 4-9 |

| | |
|--|-------------|
| 5. APPLICABLE FEDERAL AND STATE REQUIREMENTS | 5-1 |
| 5.1 New Source Performance Standards | 5-1 |
| 5.1.1 40 CFR 60 Subpart A – General Provisions (Applicable) | 5-1 |
| 5.1.2 NSPS Subpart D – Fossil Fuel-Fired Steam Generators > 250 MMBtu/hr (Not Applicable) | 5-2 |
| 5.1.3 NSPS Subpart Da – Electric Utility Steam Generating Units > 250 MMBtu/hr (Not Applicable) | 5-2 |
| 5.1.4 NSPS Subpart Db – Steam Generating Units > 100 MMBtu/hr (Not Applicable) | 5-3 |
| 5.1.5 NSPS Subpart Dc – Small Steam Generating Units (Applicable) | 5-3 |
| 5.1.6 NSPS Subpart GG – Stationary Gas Turbines (Not Applicable) | 5-4 |
| 5.1.7 NSPS Subpart KKKK – Stationary Combustion Turbines (Applicable) | 5-4 |
| 5.1.8 NSPS Subpart IIII – Stationary Compression Ignition Internal Combustion Engines (Applicable) | 5-6 |
| 5.1.9 NSPS Subpart TTTT – GHG Emissions for Electric Generating Units (Applicable) | 5-8 |
| 5.1.10 NSPS Subpart UUUUa – GHG Emissions from Existing Electric Utility Generating Units (Not Applicable) | 5-9 |
| 5.2 National Emissions Standards for Hazardous Air Pollutants | 5-9 |
| 5.2.1 NESHAP Subpart DDDDD – Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters (Applicable) | 5-9 |
| 5.2.2 NESHAP Subpart ZZZZ – Reciprocating Internal Combustion Engines (Applicable) | 5-11 |
| 5.2.3 NESHAP Subpart YYYYY – Stationary Combustion Turbines (Applicable) | 5-11 |
| 5.2.4 NESHAP Subpart UUUUU – Coal & Oil-Fired Electric Utility Steam Generating Units (Not Applicable) | 5-12 |
| 5.3 Compliance Assurance Monitoring (40 CFR 64) | 5-12 |
| 5.4 Risk Management Plans (40 CFR 68) | 5-13 |
| 5.5 Stratospheric Ozone Protection Regulations (40 CFR 82) | 5-14 |
| 5.6 Interstate Trading Programs | 5-14 |
| 5.6.1 Acid Rain Applicability | 5-14 |
| 5.6.2 Clean Air Interstate Rule/Cross-State Air Pollution Rule | 5-15 |
| 5.7 APCD Air Regulations | 5-17 |
| 5.7.1 APCD Part 1 – General Provisions | 5-17 |
| 5.7.2 APCD Part 2 – Permit Requirements | 5-17 |
| 5.7.3 APCD Part 5 – Standards for Toxic Air Contaminants and Hazardous Air Pollutants | 5-18 |
| 5.7.4 APCD Part 6 – Standards of Performance for Existing Affected Facilities | 5-18 |
| 5.7.5 APCD Part 7 – Standards of Performance for New Affected Facilities | 5-21 |
| 5.8 STAR Program | 5-22 |
| | |
| APPENDIX A. MAPS AND PROCESS FLOW DIAGRAMS | A-1 |
| APPENDIX B. EMISSIONS UNIT INDEX AND CALCULATIONS | B-1 |
| APPENDIX C. AIR PERMIT APPLICATION FORMS | C-1 |
| APPENDIX D. SUGGESTED REVISIONS TO PERMIT | D-1 |

1. APPLICATION SUMMARY

Louisville Gas & Electric Company (LG&E) currently operates an electric generation power plant, the Mill Creek Generating Station (Mill Creek), located in Jefferson County, Kentucky. The facility is classified as a major source under the Title V Operating Permit Program and currently operates in accordance with Title V Air Operation Permit No. O-0127-20-V, with an effective date of July 27, 2020, issued by the Louisville Metro Air Pollution Control District (APCD). This permit authorizes operation of coal boilers (Units 1 through 4); coal, limestone, fly ash, PAC, and gypsum handling and storage operations; emergency equipment; miscellaneous organic liquids tanks; parts washers; cooling towers; general plant fugitive emissions; and numerous insignificant activities.

1.1 Purpose of Application

LG&E is submitting this air permit application to obtain a construction permit and amended Title V Operating Permit to cover the planned installation of a new 664 MW (net) natural gas-fired combined cycle (NGCC) electric generating unit (Unit 5). In light of their book life and upcoming new regulatory requirements that would be imposed, the existing Units 1 and 2 coal boilers are also being retired and the NGCC Unit is being constructed to replace their capacity. The existing Units 3 and 4 coal boilers and the shared associated coal and other material storage and handling operations (except for a small reduction in the footprint of the existing coal storage pile) will be retained and are not being modified by the planned project. LG&E will utilize and optimize the current electrical transmission system in conjunction with completing the NGCC Project.

The new NGCC Unit proposed will consist of one natural gas-fired gas combustion turbine (GT), one steam turbine (ST), and one heat recovery steam generator (HRSG) with natural gas-fired duct burners (DB) arranged in a one-on-one configuration. Ancillary support equipment will also be installed to support the NGCC Unit operations, including one natural gas-fired boiler (Auxiliary Boiler) rated at 99.9 million British thermal units per hour (MMBtu/hr) or less, one pipeline fuel gas (dewpoint) heater rated at 15 MMBtu/hr or less, one 2 megawatts (MW) emergency generator with diesel-fired engine, one 400 horsepower (HP) emergency diesel driven fire pump engine, and one 8-cell mechanical draft cooling tower.

Jefferson County is currently designated as an attainment or unclassified area with respect to the National Ambient Air Quality Standards (NAAQS) for all criteria pollutants except ozone, for which it is classified as a nonattainment area with respect to the 2015 ozone (O₃) standard. The facility is currently classified as an existing major source under both the Prevention of Significant Deterioration (PSD) and nonattainment New Source Review (NSR) permitting programs. Since the new NGCC Unit will be constructed and operated within the existing Mill Creek Generating Station property, it will have the same standard industrial classification (SIC) code as existing operations, and will be under the same common control and/or ownership; hence, the NGCC Project will be considered a modification to an existing major stationary source. Therefore, the applicability of the proposed NGCC Project to the NSR permitting regulations is evaluated.

As documented within this application, the total NGCC Project emission increases, consisting of the sum of the differences of potential emissions from new emission units and the differences between projected actual and baseline actual emissions for existing emission units, is below the NSR major modification thresholds for

all relevant regulated NSR pollutants.¹ Therefore, the project is not subject to PSD or nonattainment NSR permitting requirements. The emission increases are also below 50% of the PSD Significant Emission Rates for all pollutants; therefore, the reasonable possibility recordkeeping requirements under the PSD regulations are also not triggered and there is no need to establish any new synthetic limits on operations or emissions.

Emission units associated with the new NGCC Project will be subject to New Source Performance Standards (NSPS), National Emissions Standards for Hazardous Air Pollutants (NESHAP), and several APCD air regulations. The facility is currently classified as a major source of hazardous air pollutants (HAPs) and will retain this classification following the completion of the NGCC Project.

1.2 Project Schedule

LG&E is targeting for commercial operation of the new NGCC Unit to begin no later than April 1, 2027. Given that the construction and commissioning of the NGCC Unit is expected to last 37 months, the anticipated start of construction will be March 1, 2024. Additional time will be needed for LG&E to finalize contracts with major equipment suppliers for the project ahead of this construction target date and this generally cannot occur until the air construction permit is obtained due to the financial commitments involved. Therefore, to satisfy LG&E's mandate and obligations to provide safe, reliable electrical power to the market, it is important that construction authority for this project be obtained in a timely manner. LG&E will be seeking opportunities to proactively engage with APCD staff and is committed to providing information and/or timely responses to any questions to allow the agency's review and processing of this application and development of a construction permit to proceed as smoothly as possible. LG&E requests to obtain the construction permit by **October 1, 2023**.

1.3 Summary of Application Contents

This application package, consisting of this report, and four appendices is organized as follows:

- ▶ Section 2 provides relevant background information about the Mill Creek Generating Station and information about the proposed new NGCC Unit 5 operations and existing operations that are being shut down.
- ▶ Section 3 discusses the emissions calculation methodologies used to define the potential emissions from the new emission units/ancillary equipment, associated with the NGCC Project, and provides a summary of the total emissions by pollutant.
- ▶ Section 4 presents the methodology used to calculate project emission increases and the NSR applicability analysis.
- ▶ Section 5 provides a summary review of applicable regulatory requirements under state and federal air quality programs impacted by the NGCC Project.
- ▶ Appendix A contains both area and aerial maps that show the location of Mill Creek Generating Station relative to nearby geographic features, site arrangement drawings for the new NGCC Unit within the existing facility, and a process flow diagram for the new emission units.

¹ Relevant regulated NSR pollutants for the NGCC Project are particulate matter (PM), PM 10 microns or less in diameter (PM₁₀), PM 2.5 microns or less in diameter (PM_{2.5}), oxides of nitrogen (NO_x), carbon monoxide (CO), volatile organic compounds (VOC), sulfur dioxide (SO₂), sulfuric acid (H₂SO₄) mists, lead (Pb), and greenhouse gases (GHG).

- ▶ Appendix B provides an inventory of the existing and new proposed emission units at the Mill Creek Generating Station; a derivation of potential emissions from the new emission units associated with the NGCC Project; and the baseline actual emissions for existing emission units that are being shut down.
- ▶ Appendix C provides all the APCD application forms required for processing of this application along with a copy of the acid rain program revision application for the project.
- ▶ Appendix D provides sample suggested edits to the existing Mill Creek Generating Station Title V permit encompassing the regulatory and permitting requirements impacted by the NGCC Project.

2. PROJECT DESCRIPTION

This section describes the proposed NGCC Project and the new emission units that will be installed and operated at the existing Mill Creek Generating Station.

2.1 Site Location

Mill Creek Generating Station sits on approximately 637 acres in southwest Jefferson County, KY, along the Ohio River approximately 16 miles south-southwest of downtown Louisville.

Figure A-1 in Appendix A shows the facility location and the surrounding area on a topographical map. The Universal Transverse Mercator (UTM) coordinates of the Mill Creek Generating Station's center are (approximately) 595.661 kilometers (km) East and 4,212.109 km North (Zone 16, NAD83). Figure A-2 shows an aerial image of the plant denoting the location of existing plant operations and emission units.

2.2 Background on Existing Site Operations and Emission Units

Mill Creek Generating Station, which began operation in 1972, is LG&E's largest coal-fired power plant, with a nameplate generating capacity of 1,717.2 megawatts (MW). The primary emission units at the plant are four (4) base load coal-fired utility boilers (Units 1-4).

- ▶ Unit 1 (E1) is a Combustion Engineering tangentially fired boiler constructed in 1970 with a rated capacity of 3,085 MMBtu/hr, 355.5 MW, using pulverized coal as a primary fuel and natural gas as secondary fuel. Air pollution controls consist of low NO_x burners (LNBS), electrostatic precipitators (ESP), powdered activated carbon (PAC) injection system, dry sorbent injection (DSI) system (and/or liquid additive system), pulse-jet fabric filter (PJFF) baghouse, and wet flue gas desulfurization (WFGD) unit.
- ▶ Unit 2 (E3) is a Combustion Engineering tangentially fired boiler constructed in 1970 with a rated capacity 3,085 MMBtu/hr, 355.5 MW, using pulverized coal as a primary fuel and natural gas as secondary fuel. Air pollution controls consist of LNBS, ESP, PAC injection system, DSI system (and/or liquid additive system), PJFF baghouse, and WFGD unit.
- ▶ Unit 3 (E5) is a Babcock & Wilcox dry bottom, wall-fired boiler constructed in 1973 with a rated capacity of 4,204 MMBtu/hr, 462.6 MW, using pulverized coal as a primary fuel and natural gas as secondary fuel. Air pollution controls consist of LNBS, ESP, Selective Catalytic Reduction (SCR), PAC injection system, DSI system (and/or liquid additive system), PJFF baghouse, and WFGD unit.
- ▶ Unit 4 (E7) is a Babcock & Wilcox dry bottom, wall-fired boiler constructed in 1975 with a rated capacity 5,025 MMBtu/hr, 543.6 MW, using pulverized coal as a primary fuel and natural gas as secondary fuel. Air pollution controls consist of LNBS, ESP, SCR, PAC injection system, DSI system (and/or liquid additive system), PJFF baghouse, and WFGD unit.

2.3 Proposed New Operations

Mill Creek Generating Station's coal-fired Units 1 and 2 are reaching the end of their economic lives and over the last few years, LG&E has started the process of evaluating all available generation options to meet the energy needs of its customers. Based on this evaluation, LG&E plans to construct and operate a new 664 MW (net) natural gas-fired NGCC Unit at the existing Mill Creek Generating Station. The retirement of Units 1 and 2, will reduce the site's gross generation by 711 MW. LG&E has chosen to add a NGCC Unit as a new asset because of its ability to operate as a base loaded unit and because it can be quickly and

efficiently dispatched. New technology allows rapid startups. The NGCC Unit will replace the capacity lost with the retirement of Units 1 and 2.

As part of the NGCC Project, the following new air emissions units will be installed:

- ▶ NG-fired combined cycle power plant with one combustion turbine (GT) and its single-shaft water cooled generator (7HA.03, 501JAC, 9000HL, or similar), one HRSG equipped with NG-fired duct DBs, and one ST arranged in a one-on-one configuration.
- ▶ Auxiliary Boiler using NG and a rated higher heating value (HHV) heat input capacity of 99.9 MMBtu/hr
- ▶ Fuel Gas (Dewpoint) Heater using NG with a heat input capacity of 15 MMBtu/hr
- ▶ 2000 kW (2,682 nominal brake horsepower [bhp]) emergency generator with diesel-fired engine (U.S. EPA Certified Tier 2) and associated diesel storage tank
- ▶ 400 bhp emergency diesel driven fire pump engine (U.S. EPA Certified Tier 3) and associated diesel storage tank
- ▶ Mechanical draft cooling tower (8 Cell)
- ▶ Lube oil system demister vents
- ▶ Ancillary equipment, including raw and demineralized water storage tanks; aqueous ammonia storage and handling equipment; and miscellaneous HVAC heaters

A process flow diagram showing the proposed NGCC Unit operations is provided in Figure A-6 in Appendix A, and each of the proposed new air emission units is discussed in the following subsections. Figure A-3 shows an overlay of the planned location of the new NGCC Unit operations on an existing aerial image of the Mill Creek Generating Station. The same equipment layout location is shown on a facility site diagram in Figure A-4. Finally, Figure A-5 provides a detailed arrangement of the proposed new NGCC Project emission units and associated structures.

LG&E is currently in the process of evaluating and selecting the primary vendor that will provide the core NGCC Unit equipment and a final selection will not be made until farther in the project development process. There are currently three primary vendors being evaluated that are correspondingly referred to in this application as Vendor A, Vendor B, or Vendor C. LG&E has provided a set of minimum equipment specifications and emissions performance guarantees that must be met by each vendor. Because the operating scenarios and potential emissions represented in this permit application encompass the worst-case combination of the data and parameters provided by each vendor for their equipment packages, the regulatory and permit applicability review can be completed without yet knowing which specific vendor will ultimately be selected for the project.

2.3.1 NGCC Unit 5 (U23/E49a-E49e)

As illustrated in Figure A-6 in Appendix A, in a combined-cycle process, ambient air is drawn into the compressor section of the GT through an inlet air filtration system. Inlet evaporative cooling may take place during periods of warm ambient temperatures and low relative humidity to further enhance the overall production capability of the GT. After the evaporative cooler (EC) section, air enters the compressor section where it is compressed and channeled to the fuel/mix combustion section of the GT.

The compressor section of the GT, commonly referred to as the gas generator section, generates emissions from the fuel combustion process. A transition duct within the GT directs the flow of hot gases from the gas generator to the power section of the turbine. Gas generator combustion gases expand through the stages of the power turbine where the thermodynamic energy is converted to mechanical power. This mechanical power is then transmitted through the rotation of the shaft to the generator of the GT, which is directly coupled to the power turbine. The generator takes this rotational power and converts it to electricity.

The hot combustion gases that are produced in the GT are directed into the HRSG through an exhaust transition duct where waste heat is captured and converted into steam energy before the exhaust gases exit the vertical stack. The HRSG duct contains the natural gas-fired DBs, which will be used at times to increase the temperature of the exhaust in the HRSG to enable the production of additional steam on an as-needed basis. This installation will primarily use DBs in the summer months and thus provide supplemental heat input capacity with the goal of ensuring the same MW generation as the winter months.

The steam produced in the HRSG is used in the ST to produce additional electrical power. Once mechanical work from the steam is captured, the steam is exhausted, and condensed in a vacuum within a condenser. The condensate is reused as feed water to the HRSG, creating a closed-loop system.

The GT in conjunction with the DBs is the primary emissions unit for the NGCC Project. The proposed NGCC Unit is designed for continuous operations. The GT will be capable of operating between a nominal minimum emissions compliance load (MECL) and 100-percent load. MECL is defined as the minimum steady-state load at which the combustion turbine can operate at any given ambient condition and maintain compliance with all emission limits.

These base load NGCC systems are almost entirely capable of converting the latent heat from the GT exhaust to steam in the HRSG without additional DB-firing. In their draft project equipment quotes, each vendor only presented a few situations that require operation of the DBs.

With older NGCC power block systems or with simple cycle peaking units, the inclusion of the DBs was necessary to be evaluated/permitted because of their significant contribution of emissions at the combined stack (e.g., CO and NO_x). In contrast, for the proposed installation, each vendor is required to meet a 2 parts per million by volume dry (ppmvd) at 15% O₂ emissions guarantee for CO and NO_x with or without DBs; therefore, it is unnecessary to permit the various operation modes of the DBs separately. These guarantees are further supported by each vendor's commitment to install and operate add-on control devices for CO and NO_x.

The key GT/DB equipment specifications from the equipment quotes provided by the three vendor quotes are as follows:²

- ▶ Maximum short-term heat input capacity up to 4,216 MMBtu/hr HHV total from both GT & DB @ -18°F.
- ▶ Maximum of 4,216 MMBtu/hr HHV from GT by itself
- ▶ Maximum of 296 MMBtu/hr HHV from DBs
- ▶ 4,157 MMBtu/hr maximum simulated heat input capacity taking into account seasonal variation for this baseload operation
- ▶ 640-664 MW (net) power output from combined cycle 1 x 1 configuration at 60 Hz
- ▶ Greater than 63% combine cycle efficiency (lower heating value [LHV])
- ▶ Air cooling for combustors instead of steam cooling
- ▶ 42-75 MW/min GT ramp up
- ▶ Startup time to full load less than 30 min for a hot start
- ▶ Provides super-heated steam greater than 600°C
- ▶ Designed for future hydrogen co-firing

² Please note that the heat inputs and energy generation values are subject to change depending on the final equipment selection.

The operational scenarios used to establish the maximum short-term and annual emissions are discussed in Section 3 of the application.

2.3.1.1 Air Pollution Controls

All vendors will utilize dry-low-NO_x combustors (DLN) in the GT and LNBS in the HRSG. All vendors will utilize oxidation catalysts and SCR as add-on controls to reduce stack NO_x, CO, hydrocarbons (HC), and organic HAP emissions. GHG emissions will be minimized through the use of the highly efficient combined cycle 1 x 1 GT and HRSG unit. A bank of drift eliminators will be installed after the evaporative cooling media to ensure that no water droplets or solids particles from water enter the GT. Therefore, there will be no contribution of PM emissions from the evaporative cooling systems to the generating units.





Dry Low NO_x Combustors. The GT will feature each vendor's latest DLN combustion technology, which can reduce NO_x emissions to approximately 25 ppm, whereas the additional SCR system (described below) is designed to reduce NO_x emissions to less than 2 ppmvd at 15% O₂. The combustor also features low CO emissions at partial load, remaining compliant with permitted levels even at turndown to the MECL.

DLN combustor technology premixes air and a lean fuel mixture prior to injection into the combustion turbine that significantly reduces peak flame temperature and thermal NO_x formation. Conventional combustors are diffusion controlled where fuel and air are injected separately. Combustion occurs locally at stoichiometric interfaces resulting in hot spots that produce high levels of NO_x. In contrast, DLN combustors generally operate in a premixed mode where air and fuel are mixed before entering the combustor. The underlying principle is to supply the combustion zone with a completely homogenous, lean mixture of fuel and air. DLN combustor technology generally consists of hybrid combustion, combining diffusion flame (for low loads) plus DLN flame combustor technology (for high loads). Due to the flame instability limitations of the DLN combustor below approximately 50 percent of rated load, the turbine is typically operated in a conventional diffusion flame mode until the load reaches approximately 50 percent. As a result, NO_x concentrations rise when operating under low load conditions, yet the mass emissions rate at low load is less than base load.³

Oxidation Catalyst. The NGCC Project will install and operate an oxidation catalyst to reduce CO, HC, and organic HAP emissions produced during the combustion process in the flue gas by oxidation.

³ <https://www.epa.gov/system/files/documents/2022-03/combustion-turbine-nox-technology-memo.pdf>

The basic chemical reactions are:





The oxidation catalysts are formulated with precious metals (e.g., platinum group metals) and are coated on flow-through metal monoliths for minimum backpressure and compact design. Multiple catalyst formulations allow the flexibility to target specific conversion requirements, exhaust temperatures, low SO₂ to SO₃ and NO to NO₂ conversions. Oxidation catalysts can provide greater than 90% destruction of CO, VOCs, formaldehyde, and other toxic compounds.⁴ See Section 5.3 of Appendix B for the methodologies used to calculate the control efficiencies used for this NGCC Project.

The catalytic oxidation of available SO₂ to SO₃ in the exhaust gases as it passes through the oxidation catalyst is usually 10 percent. The chosen conversion of SO₂ to SO₃ for a CO catalyst used in LG&E's proposed combined cycle unit is also 10 percent.⁵

SCR System. SCRs are used extensively in power generation applications including coal, oil, and combined cycle power plants. SCR is a post-combustion emission control technique whereby aqueous ammonia is vaporized and injected into the combustion exhaust gases before they pass through a catalyst bed. In the presence of the catalyst, NO₂ and NO (NO_x) react with oxygen and ammonia to produce nitrogen and water.

The basic chemical reactions are:



Small amounts of ammonia that are not consumed in the reaction result in low levels of ammonia stack emissions, known as ammonia slip. Each vendor based their emissions rates assuming no more than 5 ppmvd ammonia slip.⁶

The performance of an SCR system depends primarily on the temperature of the exhaust gas as it passes through the catalyst. Although catalyst formulations have provided a continuum of temperature ranges, these are typically described by three temperature ranges for optimal NO_x reduction. A "normal" catalyst operates well at approximately 650°F, a "mid-range" catalyst operates well between 800 and 900°F, and a "hot" catalyst (generally zeolite based) can operate above a temperature of 1,100°F, although the effectiveness of NO_x removal declines as a function of the exhaust gas temperature. Conventional vanadium/titanium catalysts are commonly used in SCR applications and have an optimal operating temperature in the 600 to 750°F range. Temperatures above 900°F can cause permanent damage to vanadium/titanium catalysts, thus requiring the use of high temperature zeolite catalysts and/or air tempering systems that can reduce exhaust gas temperatures prior to introduction into the catalyst. The application of SCR for the combined cycle plant is more straightforward because the SCR reactor is located

⁴ https://www.jmsec.com/fileadmin/user_upload/pdf/brochures/jmsec_gas_turbine_oxidation_catalyst.pdf

⁵ Page 6-4 of *Estimating Total Sulfuric Acid Emissions from Stationary Power Plants: 2018 Update*. EPRI, Palo Alto, CA: 2018. 3002012398

⁶ Due to the installation of this advanced DLN system on these next generation GTs, ammonia slip is estimated at 5 ppmvd as opposed to 2-3 ppmvd because there will be less molecules of NO and NO₂ to react with NH₃. {See Wien et. al., *Air Emissions Terms, Definitions and General Information*, GE Energy, GER-4249 (08/05)}

downstream of the GT itself, within the tube banks at an appropriate temperature region, near the 600-700 °F range, allowing for the use of “conventional” catalysts.

The catalyst used is typically stacked vertically with gas flow horizontally through the catalyst face. The catalyst has a much smaller pitch due to the limited particulate and plugging concerns and does not deactivate as rapidly due to minimal catalyst poisons in the flue gas.

This process requires additional equipment to store, vaporize, dilute, and mix the reagent prior to being injected into the system through the ammonia injection grid (AIG). The dosing device supplies the vaporized ammonia into the ammonia injection blower system. It controls the quantity of the reduction agent, depending on load and NO_x values. To monitor the amount of ammonia injected, LG&E will install an ammonia flow meter.

Aqueous ammonia (maximum concentration of 19%) will be stored on-site in a storage tank with a capacity of approximately 35,000 gallons. The aqueous ammonia storage tank is a pressure vessel that only vents in the event of an emergency, and thus the tank will not normally vent to the atmosphere.

The catalytic reaction of available SO₂ to SO₃ in the exhaust gases as it passes through the SCR catalyst range between 1 and 3 percent. One vendor recommended the use of a 2 percent conversion. The chosen conversion rate to SO₃ for this installation within the proposed combined cycle unit is 3 percent, which is conservative.⁷

2.3.2 Auxiliary Boiler (U24/E50)

The NG-fired Auxiliary Boiler will be permitted with a maximum heat input capacity of 99.9 MMBtu/hr; however, the prospective equipment vendors will size to suit their design and it is expected that a smaller boiler will ultimately be installed. The combustion system will be LNB with flue gas recirculation (FGR) with a required 10:1 turndown.

The auxiliary boiler will only serve process loads and will consist of the following:

- ▶ HRSG freeze protection (only required with the unit off-line and ambient with potential freezing)
- ▶ Unit starts under warm or cold start conditions. The auxiliary boiler steam will provide sparging steam to the HRSG and condenser as well seal steam for the steam turbine. After the combined cycle unit is up and running auxiliary steam is furnished by the HRSG (cold reheat) and the auxiliary boiler can be taken out of service.

Under the expected dispatch, the Auxiliary Boiler is only expected to operate at 25% utilization or less during periods of time where the NGCC Unit is active. However, LG&E is requesting that it be permitted to allow for a full load continuous operation schedule up to 8,760 hours per year to provide maximum operational flexibility.

2.3.3 Emergency Generator with Diesel-Powered Engine (U25/E51)

The NGCC Project will employ a 2,000 kW emergency generator system that will include a nominal 2,682 bhp compression ignition engine. Ultra-low sulfur diesel (ULSD) fuel with a maximum sulfur content of 0.0015 weight percent (or 15 ppm) will be used in the engine. Potential emissions are based on operating

⁷ Page 6-5 of *Estimating Total Sulfuric Acid Emissions from Stationary Power Plants: 2018 Update*. EPRI, Palo Alto, CA: 2018. 3002012398

500 hr/yr in accordance EPA guidance, although, there are no hourly limits on an emergency engine when operating for emergency purposes.

2.3.4 Fuel Gas (Dewpoint) Heater (U26/E52)

A NG-fired Fuel Gas (Dewpoint) Heater with a maximum heat input of 15 MMBtu/hr will be used to heat the pipeline natural gas that will be introduced to the combustion turbines and duct burners. Although this heater will not be expected to operate continuously, LG&E is requesting that it be permitted to allow for a continuous operation schedule up to 8,760 hours per year.

2.3.5 Emergency Diesel-Driven Fire Pump Engine (IA4/IE28)

The NGCC Project will include a 400 bhp diesel-fired compression ignition engine for emergency purposes to supply energy to the emergency fire pump engine. ULSD fuel will be used in the engine. Potential emissions are based on operating 500 hr/yr in accordance EPA guidance, although, there are no hourly limits on an emergency engine when operating for emergency purposes.

2.3.6 Mechanical Draft Cooling Tower (IA5/IE24)

Steam exiting the steam turbine will be condensed via indirect heat transfer using cooling water provided a mechanical draft, eight-cell, back-to-back counter-flow wet cooling tower. Cooling tower drift will be minimized to 0.001% of the design recirculation rate or less using inherent drift eliminators. The cooling tower qualifies to be classified as an insignificant activity based on its low potential emissions.

2.3.7 Lube Oil System with Demister Vents (IA5/IE25)

The GT and ST will be equipped with an internal lube oil storage and distribution system. A small quantity of the lube oil present in the system will be vaporized due to the high operating temperatures inside the turbine systems, potentially resulting in VOC emissions from the lube oil systems. The GT will be equipped with a demister system to avoid lube oil loss to the atmosphere to the extent possible; however, a small quantity of lube oil will be emitted, as VOC from the lube oil demister vents. This process qualifies to be classified as an IA based on its low potential emissions.

2.3.8 Diesel Storage Tanks (IA5/IE26)

All diesel consumed by the emergency use engines will be ULSD diesel. The diesel driven emergency fire pump engine will have an integrated 440-gallon dual wall tank located within the fire pump enclosure. The standby generator engine will be furnished with a base mounted dual wall tank with a capacity of 4,000 gallons. These storage tanks serving the emergency use engines qualify to be classified as an insignificant activity (IA) based on their low potential emissions.

2.3.9 HVAC Heaters (Total 10 MMBtu/hr) (IA27)

LG&E plans to provision multiple natural gas-fired HVAC units within buildings that support the NGCC Project. The total combined heat input capacity of all small HVAC heaters is assumed to be 10 MMBtu/hr or less. For permitting purposes and to calculate potential emissions, the maximum combined heat input capacity is assumed.

2.4 Shutdown of Existing Operations

Aside from the construction of the new NGCC Unit, LG&E will be shutting down multiple existing emission units at Mill Creek. Table 2-1 lists the existing emission units that will be impacted by the planned project and the proposed date of the permanent shutdown, resulting in project emissions decreases, which are further discussed in Section 4.4.

Table 2-1. List of EUs to be Shutdown with NGCC Project at Mill Creek Generating Station

| Emission Unit | Emission Point | Emission Point Description | Control ID(s) | Control Description | Release ID(s) | Project Impacts |
|----------------------|-----------------------|---|----------------------|------------------------------------|----------------------|-----------------------------|
| U1 | E1 | Unit 1 Boiler (3,085 MMBtu/hr) | C1, C26, C27 | ESP, PAC Injection, DSI, PJFF, FGD | S33 | Shutdown (12/2024) |
| U1 | E2 | Four Coal Silos; Four Coal Mills | C3 | Centrifugal Dust Collector | S5 | Shutdown (12/2024) |
| U2 | E3 | Unit 2 Boiler (3,085 MMBtu/hr) | C4, C27, C28 | ESP, PAC Injection, DSI, PJFF, FGD | S33 | Shutdown (4/2027) |
| U2 | E4 | Four Coal Silos; Four Coal Mills | C4 | Centrifugal Dust Collector | S6 | Shutdown (4/2027) |
| U9 | E16 | Flyash Transfer Bin with Two Separators for Units 1 & 2 | C19 | Baghouse | S17, S24, S25 | Shutdown (4/2027) |
| U16 | E40a-f | Sorbent Storage Silos (two of the six will be retired with MC1 and MC2) | C32a-f | Bin Vent Filters | S35a-f | Shutdown (12/2024) (4/2027) |
| U17 | E41a-f | PAC Storage Silos (two of the six will be retired with MC1 and MC2) | C33a-f | Bin Vent Filters | S36a-f | Shutdown (12/2024) (4/2027) |
| IA5 | IE14a | Cooling Tower for Unit 2 | -- | -- | Fugitive | Shutdown (4/2027) |
| IAz8 | | Emergency Vent for U1 and U2 Boilers | | | Fugitive | Shutdown (4/2027) |

Some existing units will remain operational (with no physical changes or changes to their method of operation) after the construction of the NGCC Project. The construction of the new NGCC Project will either have no impact on the utilization, method of operation, or emissions from these existing units, or in certain cases, will cause a decrease in utilization and emissions. The existing emission units that fall into one of these categories include:

- ▶ Unit 3 and Unit 4 Coal Boilers
- ▶ Raw material storage and handling units
- ▶ Waste/secondary material storage and handling
- ▶ Raw material mixers and crushers
- ▶ Cooling towers for Units 3 and 4
- ▶ Emergency use internal combustion engines
- ▶ NG-fired process heaters
- ▶ Gasoline dispensing and storage tank(s)
- ▶ Diesel dispensing and storage tank(s)
- ▶ Miscellaneous organic liquids tanks

- ▶ Landfill material handling and wind erosion fugitives
- ▶ Paved and unpaved roads

Emissions from these existing emission units are not discussed in Section 3 because these units will be unaffected (physically) by the proposed project.

3. EMISSIONS CALCULATION METHODOLOGIES AND SUMMARY

This section summarizes the emission calculation methodologies for the emission sources that comprise the proposed NGCC Project. Within each emissions unit section, the methods used to calculate emissions are discussed, followed by a summary of the emissions estimates for the specific unit and, in the case of the GT, the mode of operation. The NGCC Project's annual potential emissions for regulated NSR pollutants and HAPs are summarized in Table 3-2. These potential emissions are used as the basis for determining applicability of the project with respect to applicable regulatory requirements, which is discussed subsequently in Sections 4 and 5.

A more detailed set of documented emission calculations is presented in Appendix B of the application for all the new emission units that are part of the NGCC Project, which are listed below. The nomenclature for the emission unit and emission point IDs shown below are placeholders based on the next sequential numbers in the facility's current emission unit inventory and can be finalized by APCD upon its review of the application.

| EU ID/EP ID | Description |
|--------------------|---|
| • U23/E49a-e | EGU Unit 5 Gas Turbine with HRSG/Duct Burners |
| • U24/E50 | Auxiliary Steam Boiler |
| • U25/E51 | 2 MW Diesel Emergency Generator Engine |
| • U26/E52 | Fuel Gas (Dewpoint) Heater |
| • IA4/IE28 | 400 HP Emergency Diesel Driven Fire Pump Engine |
| • IA5/IE24 | Mechanical Draft Cooling Tower (8 Cells) |
| • IA5/IE25 | Lube Oil System with Demister Vents |
| • IA5/IE26 | 4,000 and 440 Gallon Diesel Storage Tanks |
| • IA5/IE27 | HVAC Heaters (Total 10 MMBtu/hr) |

3.1 Unit 5 Gas Turbine with HRSG (U23/E49a-e)

The primary emissions units for the NGCC Project are the NG-fired GT and HRSG, which includes DBs. The following subsections present the maximum hourly emissions during steady-state operations and startup/shutdown (SU/SD) events, as well as the total annual emissions including SU/SD emissions.

3.1.1 GT/DB Emissions from Steady State Operations

Normal or steady-state operation of a GT is characterized as continuous operation at loads generally in the 35 to 100% range (over the range at which emissions compliance is achieved). The GT may be operated at base load (100% operating load for the current ambient conditions) up to 8,760 hours per year with or without duct firing.

Heat input to a gas turbine varies as a function of the fuel (type, composition, and quality), ambient temperature, relative humidity, EC operation, and DB operation. Maximum heat input and maximum emissions rates typically occur at 100 percent load and the minimum design ambient temperature (i.e., -18°F). As explained in more detail in Section 4 of Appendix B, while the GT/DB can achieve a maximum heat input capacity of 4,216 MMBtu/hr (for Vendor A Case 1 for GT only at -18°F and 100% of baseload), the potential emissions used 4,157 MMBtu/hr (or 3.925 MMscf/hr) as the maximum simulated heat input capacity.

LG&E's proposed baseload NGCC Unit is almost entirely capable of converting the latent heat from the GT exhaust to steam in the HRSG without additional DB firing. In their equipment quotes, each prospective vendor only presented a few situations that require operation of the DBs, such as periods of time in the summer months to provide supplemental heat input capacity with the goal of ensuring the same MW generation as the winter months. The maximum heat input capacity from all three vendors was 296 MMBtu/hr (HHV) for the DB.

3.1.1.1 *NO_x, CO, VOC, and PM Emissions*

Similar to the heat input capacity, emissions from a gas turbine are also a function of the fuel (type, composition, and quality), ambient temperature, relative humidity, EC operation, and DB operation, but they additionally are affected by inherent controls, add-on controls, chemical conversions, and other miscellaneous factors. As documented in Sections 4 and 5 in Appendix B, maximum hourly controlled and uncontrolled emissions of NO_x, CO, VOC, PM, PM₁₀, PM_{2.5}, ammonia (NH₃), and formaldehyde for the proposed gas turbine rely on the vendor operational data and LG&E's vendor guarantee requirements for the NGCC Unit, which are listed in Table 3-1. Emissions factors for these pollutants were calculated as the maximum hourly emissions rate divided by 4,157 MMBtu/hr (equivalent to 3.925 MMscf/hr of NG combustion). Annual controlled emissions of NO_x, CO, and VOC used these same maximum simulated heat input capacities times the emissions factor times 8,760 hr/yr.

Table 3-1. GT/HRSG – Basis of Pollutant Emissions Rates

| Pollutant | Emissions Basis |
|-------------------------------------|----------------------------------|
| NO _x | 2 ppmvd @ 15% O ₂ |
| CO | 2 ppmvd @ 15% O ₂ |
| VOC | 1-2 ppmvd @ 15% O ₂ |
| PM ₁₀ /PM _{2.5} | 8-23.3 lb/hr |
| Formaldehyde | 0.091 ppmvd @ 15% O ₂ |
| NH ₃ slip | 5 ppmvd @ 15% O ₂ |

Source: Maximum of Vendor A, B, or C

The gas turbine unit will continue to comply with the presented emission rates irrespective of ambient weather conditions at all loads above MECL. Any emissions resulting from SU/SD operations are described in Section 3.1.2. Information regarding inherent and add-on controls used in the GT/HRSG system were previously explained in Section 2.3.1.

For NO_x, a nominal control efficiency (CE) of 90% for the SCR was selected for purposes of defining a conservatively (high) uncontrolled emission factor. This CE is not constant and not an equipment guarantee as it will normally range between 75% and 91% depending on available nitrogen content and GT combustor design/operation. For CO and VOC (and other organic HAPs), a nominal CE of 90% and 50%, respectively, for an oxidation catalyst was selected for purposes of defining the uncontrolled emission factors.

3.1.1.2 *SO₂ and H₂SO₄ Emissions*

Annual emissions of SO₂ and H₂SO₄ mist were based on a maximum pipeline NG sulfur content and additional factors to account for chemical conversions. For SO₂, all vendors used an expected maximum sulfur content for the pipeline gas of 0.5 grains (gr)/100 standard cubic feet (Cscf). In actuality, based on actual measurements of the pipeline gas consumed by Mill Creek Generating Station, the highest sulfur

measured in the last 5 years was only 0.019 gr/Cscf. The SO₂ emissions are nonetheless based on a sulfur content of 0.5 gr/Cscf and 100% conversion from sulfur to SO₂. In reality, the total SO₂ emissions will be less due to the fact that some SO₂ further converts to SO₃, which can be converted further to H₂SO₄, (NH₄)₂SO₄, and/or (NH₄)HSO₄. For simplicity, the potential emissions of SO₂ do not account for these further reductions and thus the emission estimates are conservative.

The conversion of SO₃ to H₂SO₄ mist and condensable PM (sulfates and nitrates) is influenced by the sulfur content in the pipeline NG, ambient temperature, relative humidity, EC operation, DB operation, oxidation over the CO catalyst, oxidation within the SCR, available moisture, ammonia slip concentration, acid dew point, and other factors. The hourly conversion used in the potential emissions calculations for permitting purposes conservatively assumes a 10% conversion in the GT/DB plus 3% conversion from the SCR plus 10% from CO catalyst (i.e., 23% total), consistent with the approach of the following citation, "*Estimating Total Sulfuric Acid Emissions from Stationary Power Plants: 2018 Update*. EPRI, Palo Alto, CA: 2018. 3002012398, Pages 6-4 & 6-5 ", where the total conversion to H₂SO₄ mist assumes 10% conversion for GT/DB + 3% for SCR + 10% for CO catalyst.

3.1.1.3 Formaldehyde and HAP Emissions

Controlled formaldehyde emissions are calculated based on an emissions guarantee of 91 parts per billion by volume, dry (ppbvd) @15% O₂, which is also equivalent to the applicable standard in NESHAP Subpart YYYYY, 40 CFR §63.6100. This concentration was then converted to a pound per MMBtu emissions factor based on Reference Method (RM) Method 19 determination of the dry F factor (Fd) used for natural gas combustion. LG&E chose to use Vendor A's derived Fd at ~8638 dscf/MMBtu, which was derived from RM 19 equations 19-13 through 19.15. The uncontrolled emissions factor for formaldehyde was obtained from Table 3.1-3 of the U.S. EPA's AP-42 Chapter 3, Section 3.1 *Stationary Gas Turbines*.⁸ As a result, the estimated control efficiency for formaldehyde is 68%.

The GT's uncontrolled emission factors for HAPs other than acetaldehyde were also based on Table 3.1-3 of AP-42 as well. The background document supporting this chapter provided controlled emissions factors when using a CO catalyst for acetaldehyde, acrolein, and benzene.⁹ See Section 5.3.3 of Appendix B for additional details and for the derivation of control efficiencies.

Even though the DB will be used sparingly over the summer months and because there is no restriction on its use, LG&E also provides the standard uncontrolled emissions factors obtained from Tables 1.4-2, 1.4-3, and 1.4-4 of the U.S. EPA's AP-42 Chapter 1, Section 1.4 *Natural Gas Combustion*.¹⁰ A 50 percent control efficiency from the oxidation catalyst was applied to calculate the controlled emission factors for the organic HAPs. See Section 5.3.4 of Appendix B for additional details.

For pollutants where there was overlap between the Sections 1.4 and 3.1 of AP-42, the highest emissions factor was used to derive the potential emissions from the GT/DB system. As shown in Section 3 of Appendix B, using the DB's uncontrolled emission factor for hexane at 1.8 lb/MMscf to estimate the GT/DB's annual emissions results in an annual potential to emit of 15.47 tons per year (tpy) compared with the next highest HAP at 3.95 tpy for formaldehyde, which is an expected pollutant from this type of installation.

⁸ <https://www.epa.gov/sites/default/files/2020-10/documents/c03s01.pdf>

⁹ <https://www.epa.gov/sites/default/files/2020-10/documents/b03s01.pdf>

¹⁰ <https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s04.pdf>

3.1.1.4 GHG Emissions

GHG emissions are estimated based on proposed equipment specifications as provided by the prospective vendors and the default emission factors in the U.S. EPA's Mandatory Greenhouse Reporting Rule (40 CFR 98, Subpart C, Tables C-1 and C-2 for natural gas). According to 40 CFR §52.21(b)(49)(ii), GHG emissions for PSD applicability must show carbon dioxide equivalent (CO₂e) emissions calculated by multiplying the mass of each of the GHGs by the gas's associated global warming potential (GWP), which are specified in Table A-1 to Subpart A of 40 CFR Part 98.

3.1.2 GT/DB Emissions from Startup and Shutdown Operations

For the proposed NGCC Unit, startup will be defined as the period between the commencement of ignition and when the combined-cycle unit reaches emissions compliance (i.e., 2.0 ppmvd CO and NO_x at 15% O₂ at the stack).

The NGCC Unit equipment package from each of the prospective vendors each has its own unique features that allow each NGCC Unit to quickly achieve emissions compliance during a cold, warm, or hot start event. The following provides the underlying basis for each vendor's pound per event emission estimates.

- ▶ Cold starts (CS) are preceded by over 72 hours of shutdown.
 - Expected maximum annual CS events = 5 events/yr over a 40 to 70 minutes ramp up time
- ▶ Warm start (WS) or "non-cold startup" are preceded by a shutdown between 8 and 72 hours. A value of 48 hours is used.
 - Expected maximum annual WS events = 45 events/yr over a 30 to 60 minutes ramp up time
- ▶ Hot starts (HS) are defined as taking place within 8 hours of the previous shutdown.
 - Expected maximum annual HS events = 100 events/yr over a 21 to 35 minutes ramp up time
- ▶ Shutdowns (SD) occur for 12-21 min and the total number of these events is the sum of all cold, warm, and hot SUs.
 - Expected maximum annual SD events = 150 events/yr over 12 to 21 minutes until emissions cease

These assumptions were provided by each vendor, and they are neither guaranteed, nor are they intended to be included in the permit as emissions limits or operational restrictions. While the SU/SD assumptions provide valuable information, from an air permitting perspective, it is more important to focus on the total mass of emissions per event.

NO_x, VOC, CO, and PM emissions vary during SU/SD events; however, emissions of other pollutants do not vary substantively during these events (compared to those during normal steady-state operations). Therefore, only emissions of NO_x, VOC, CO, and PM are separately defined for SU/SD events. The total emissions for each event are provided in Sections 4.1 through 4.3 in Appendix B. As shown in Section 5.5.1 of Appendix B, the emissions factors in pounds per event for the regulated NSR pollutants are based on the highest vendor-provided lb/event. As an example, as documented there, using these methodologies, the total emissions from NO_x estimated for 150 SU/SD events in a year adds an additional 19.5 tpy to the NGCC Project potential emissions.

This methodology of using the maximum of each vendor's individual CS, WS, HS, and SD event emissions value for each pollutant adds an additional level of conservativeness.

3.1.3 GT/DB Annual Emissions

Tables in Sections 4.1 to 4.3 in Appendix B, provide maximum hourly pollutant emissions rates for the GT/HRSRG unit based on three different loads and three different ambient temperatures, including EC and DB operation. Also provided are the outliers with the highest emissions rate. In all cases, the partial loads resulted in lower hourly emissions rates. A summary of the cases provided by each vendor that were evaluated for defining potential emissions is as follows.

- ▶ Vendor A
 - GT loads at 30%, 32.3%, 33.3%, 36.1%, 41.5%, 63.9%, 74.3%, 75%, and 100%
 - Inlet air temperatures of -18, 15, 45, 57, 90, and 106°F
 - Relative humidity (RH) of 40, 50, 55, 60, and 70
 - Ambient pressure of 14.257 pounds per square inch absolute (psia)
 - Evaporative Cooler (EC) on at 90-106°F and 40-50% RH
 - DB on at 90-106°F and 40-50% RH
 - 1 x 1 Combined Cycle Operation Only
 - No ability to by-pass controls

- ▶ Vendor B
 - GT loads at 100%
 - Inlet air temperatures of -18, 15, 45, 57, 59, 90, and 106°F
 - Ambient pressure of 14.245 psia
 - EC on at 59-106°F and 40-60% RH
 - DB on at 90°F and 50% RH
 - 1 x 1 Combined Cycle Operation Only
 - No ability to by-pass controls

- ▶ Vendor C
 - GT loads at 35%, 75%, and 100%
 - Inlet air temperatures of -18, 15, 45, 57, 90, and 106°F
 - Ambient pressure of 14.225 psia
 - EC on at 90-106°F and 40-50% RH
 - DB on at 90°F and 50% RH
 - 1 x 1 Combined Cycle Operation Only
 - No ability to by-pass controls

Given the range and breadth of the cases presented, there are numerous ways to derive the annual potential emissions for the GT. As shown in Section 4.4 of Appendix B, four different simulated annual operating profiles were evaluated for defining potential emissions:

- ▶ Profile 1 calculates the annual emissions using 8,760 hours at the highest hourly emissions rate at the average ambient temperature. In every case, DBs will not be necessary to generate the rated output.
- ▶ Profile 2A calculates the annual emissions with 2,000 hr/yr of operation at 15°F, 4,760 hr/yr at 57°F, and 2,000 hr/yr at 90°F. The DBs and EC only kick in during the summer months. Although it artificially elevates the potential emission rate, for simplicity and conservatism, the total hours do not subtract periods of non-operation between a shutdown and a startup, nor do the total hours exclude the total time of GT operation during the events.

- ▶ Profile 2B is the same as 2A except 127 hours of time for SU/SD events is subtracted. Again, this case does not subtract periods of non-operation between a shutdown and a startup.¹¹
- ▶ Profile 3 is the maximum hourly emissions rate for any case multiplied by 8,760 hr/yr.

As shown in Sections 4.5 and 4.6 of Appendix B, in reviewing the calculated annual emissions for the worst-case operating profiles, LG&E has chosen to represent the potential emissions for the GT/DB based on Profile 2A. Profile 3 is not used because it is not practically realistic and could never occur in practice. While Profile 2A is also extremely conservative, in that it does not subtract for SU/SD hours (which is done in Profile 2B), the differences are not significant. Profile 2A, which considers the differences for cold and hot seasons, also predicts slightly higher potential emissions than the baseload case at the average ambient temperature. Thus, it is conservative but reasonable to use annual emissions for Profile 2A to define the potential to emit (PTE).

Based on the defined PTE values (tpy), the equivalent hourly average emission rates (lb/hr) for each pollutant can be calculated. An emission factor in terms of lb/MMBtu can then be calculated based on the vendor-provided heat input associated with the case for which the PTE value is derived. See Section 4.4 of Appendix B, which provides the underlying heat input rate.

For example, steady-state stack exhaust emissions and the emissions factor of NO_x are calculated as follows.

$$\text{Profile 2A NO}_x \text{ (lb/hr)} = 136.8 \text{ tpy} \times 2,000 \text{ lb/ton} / 8,760 \text{ hr/yr} = 31.23 \text{ lb/hr for Vendor B (at 3,850 MMBtu/hr and 3,636 MMscf/hr)}$$

$$\text{NO}_x \text{ Emission Factor (lb/MMBtu)} = 31.23 \text{ lb/hr} / 3,850 \text{ MMBtu/hr} = 0.00811 \text{ lb/MMBtu}$$

$$\text{NO}_x \text{ Emission Factor (lb/MMscf)} = 31.23 \text{ lb/hr} / 3.636 \text{ MMscf/hr} = \mathbf{8.589 \text{ lb/MMscf}}$$

$$\text{Yet, Maximum Natural Gas Fuel Consumption is for Vendor A} = 4,157 \text{ MMBtu/hr (maximum for any pollutant)} / 1,059 \text{ MMBtu/MMscf} = 3.925 \text{ MMscf/hr}$$

$$\text{NO}_x \text{ (lb/hr)} = \mathbf{8.589 \text{ lb/MMscf}} \times 3.925 \text{ MMscf/hr} = 33.71 \text{ lb/hr}$$

Regarding the SU/SD events, each vendor provided NO_x, CO, VOC, and PM/PM₁₀/PM_{2.5} emissions over each event based on the anticipated maximum number of events that might happen over 12 months. As explained above, using the average of the range for all three vendors, these events would span a total of 127 hours per year. And, if the time in between these events was accounted for in the calculations, the GT/DB would not be operating (or emitting) for 3,447 hr/yr (i.e., 5 cold SU x 72 average hours down + 45 warm SU x 48 average hours down + 100 hot SU x 8 average hours down). Thus, basing the potential emissions on 8,760 hr/yr of operation and then additionally adding the emissions from the SU/SD events yields a conservatively high emission rate. However, this approach is done specifically to avoid the need to establish enforceable individual operating limits around the frequency or duration of SU/SD events in the permit.

Annual potential emissions based on the methodologies described for both the GT/DB and SU/SD events are shown in Section 5.7 in Appendix B.

¹¹ 127 SU/SD hrs = (5 cold SU events × average of 40 & 70 min cold SU + 45 warm SU events × average of 30 & 60 min warm SU + 100 hot SU events × average of 21 & 35 min hot SU + 150 SD events × average of 12 & 21 min SD) × 60 min/hr

3.2 Ancillary Equipment

There are several emissions units that are part of the NGCC Project and support the operation of the GT. Descriptions of the emissions calculations for the ancillary equipment are provided in the following subsections.

3.2.1 Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52)

Potential emissions from the Auxiliary Boiler and Fuel Gas (Dewpoint) Heater are estimated based on LG&E's vendor requirements, pipeline natural gas specifications, and published AP-42 emissions factors. Annual potential emissions for the Auxiliary Boiler and the Fuel Gas (Dewpoint) Heater are documented in Sections 6.3 and 7.3 of Appendix B, respectively.

3.2.2 Emergency Use Diesel-Fired Engines

The emergency diesel-fired fire water pump engine (IA4/IE28) and the emergency diesel-fired engine for the planned emergency generator engine (U25/E51) will meet the emissions requirements specified in Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40 CFR Part 60, Subpart IIII). Emissions of regulated NSR pollutants from the engines are based on either 40 CFR Part 60, Subpart IIII emissions limits (which points to U.S. EPA Tier 2 emissions limits for the generator), and certified emissions data from a representative manufacturer (CAT for the emergency generator engine and John Deere for the emergency fire water pump engine), or AP-42 emissions factors for criteria pollutants and HAPs.

Annual potential emissions based on these methodologies for the emergency generator are shown in Section 10.3 and annual potential emissions for the emergency fire water pump engine are shown in Section 11.3 in Appendix B. The emergency fire pump engine qualifies to be classified as an insignificant activity based on its low potential emissions. LG&E presumes that APCD will add the fire pump engine to Insignificant Activity Group IA4 and an ID of IE28 is proposed.

3.2.3 Storage Tanks and Organic Losses

A 4,000-gallon, dual walled, above ground, ULSD fuel storage tank will be located in the base of the emergency generator engine. In addition, a 440-gallon, fire-rated, above ground, ULSD fuel storage tank will be used for the emergency fire water pump engine. The two ULSD fuel storage tanks are considered sources of VOC emissions.

Standing and working losses of VOCs were calculated for both diesel storage tanks using TankESP[®], which calculates working and breathing losses using the most current version of AP-42 Section 7.1. – *Organic Liquid Storage Tanks*.¹² Annual potential VOC emissions from the 4,000-gallon and 440-gallon diesel tanks are estimated to be 1.98 and 0.27 lb/yr, respectively (see Section 13.2 in Appendix B).

Another potential source of VOC emissions is the lube oil system used for the GT and ST. The GT and the ST will include a lubricating oil sump with a system capacity of approximately 10,000 gallons. The CT and ST will also be equipped with lubricating oil vents, which include electrostatic precipitators/demisters for lubricating oil mist control. Use of low-volatility/low-VOC oil and a low consumption rate of lubricating oil in the CT and ST will result in insignificant/negligible VOC emissions from storage of the lubricating oils. The working losses conservatively assume that all lube oil consumed/replaced will evaporate and contribute to

¹² <https://www.trinityconsultants.com/software/tanks/tankesp>

VOC emissions. Annual potential VOC emissions from the lube oil demister vents are shown in Section 12.2 of Appendix B.

3.3 Potential Emissions Summary

A summary of the calculated potential emissions for the NGCC Project is provided in Table 3-2. Detailed emission calculations including emission factors and references are provided in Appendix B of the permit application report.

Table 3-2. NGCC Project – Total Potential Emissions from New Emission Units

| Pollutant | Potential to Emit (tpy) |
|--------------------------------|------------------------------------|
| PM | 104.0 |
| PM ₁₀ | 102.9 |
| PM _{2.5} | 102.0 |
| NO _x | 199.9 |
| CO | 161.4 |
| VOC | 51.6 |
| SO ₂ | 25.3 |
| H ₂ SO ₄ | 8.7 |
| Lead | 0.0089 |
| CO ₂ e | 2,214,149 |
| Hexane (HAP) | 16.4 |
| Formaldehyde (HAP) | 4.0 |
| Total HAPs | 26.0 |
| NH ₃ | 122.8 |

4. NSR APPLICABILITY ASSESSMENT

This section addresses the methodology used to define the emissions changes from the proposed NGCC Project and assesses applicability of the NSR permitting regulations.

4.1 PSD/NA-NSR Applicability Background

The NSR program was designed to protect public health and welfare from the effects of air pollution and to preserve and/or improve air quality throughout the nation. The NSR program requires certain stationary sources of air pollution to obtain air pollution permits prior to beginning construction. Construction of new sources with emissions above statutory thresholds, and modifications of existing sources emitting above those thresholds or that increase emissions of regulated NSR pollutants by more than the major modification thresholds specified in the NSR regulations are subject to NSR permitting requirements.

The major source NSR regulations encompass two distinct programs that each have unique requirements for new or modified sources. The applicability of these two programs depends on the area's attainment status with respect to the NAAQS. The PSD program, based on requirements in Part C of Title I of the Clean Air Act (CAA), applies to pollutants for which the area is not exceeding the NAAQS (areas designated as attainment or unclassifiable) and to regulated NSR pollutants for which there are no NAAQS. The nonattainment NSR (NA-NSR) program, based on Part D of Title I of the CAA, applies to pollutants for which the area is not meeting the NAAQS (areas designated as nonattainment).

Mill Creek Generating Station is located in Jefferson County, Kentucky, which is currently designated by the U.S. EPA as an unclassified/attainment area for all criteria pollutants, except ozone. For ozone, Jefferson County is designated as a marginal nonattainment with respect to the 8-hour ozone NAAQS promulgated in 2015.¹³ It is located in the portion of Jefferson County that was redesignated as a maintenance area for the 2010 SO₂ NAAQS on September 8, 2020.¹⁴ As such, both PSD and NA-NSR permitting requirements are potentially applicable to the proposed project.

4.2 Existing Source Classification

4.2.1 PSD Permitting Program Source Classification

APCD has a State Implementation Plan (SIP)-approved PSD program encompassed in Regulation 2.05. This regulation adopts the July 15, 2017 edition of the federal PSD regulations at 40 CFR §52.21 by reference with exceptions shown in Section 1 of Regulation 2.05.

The PSD permitting program requirements apply to the construction of any new *major stationary source* (as defined in 40 §CFR 52.21(b)(1)) **or** any project at an existing major stationary source in an area designated as attainment or unclassifiable that is a major modification. A stationary source is a major source if the potential to emit for a specific pollutant equals or exceeds the major source threshold for *regulated NSR*

¹³ <https://www.ecfr.gov/current/title-40/chapter-I/subchapter-C/part-81/subpart-C/section-81.318> and https://www3.epa.gov/airquality/greenbook/anayo_ky.html

¹⁴ <https://www.federalregister.gov/documents/2020/08/06/2020-15598/air-plan-approval-and-designation-of-areas-kentucky-redesignation-of-the-jefferson-county-2010>

pollutants.¹⁵ The regulated NSR pollutants of relevance to the existing Mill Creek Generating Station operations and the NGCC Project are NO_x, CO, SO₂, PM, PM₁₀, PM_{2.5}, VOC, lead, and H₂SO₄ mists.

For projects involving increases in GHG emissions, the mechanism for triggering PSD review is different from other regulated NSR pollutants. For a project to trigger PSD review for GHGs, GHGs must first become *subject to regulation* to be treated as a regulated NSR pollutant that can fall under the PSD requirements.¹⁶ A physical change or change in the method of operation at a facility that results in an emissions increase of a non-GHG pollutant exceeding the significance thresholds **and** an emissions increase of GHG exceeding 75,000 tpy CO_{2e} (for the project alone and on a net basis considering contemporaneous emissions increases and decreases) would make the GHG emissions increase from the project subject to regulation and would require PSD review for the GHG emissions from the new units associated with the proposed project.¹⁷

The threshold for defining a facility as a major stationary source under the PSD permitting program is 250 tpy of any regulated NSR pollutant unless the facility belongs to one of 28 specially named source categories (List of 28), in which case the major stationary source threshold is 100 tpy.^{18,19} Existing operations at Mill Creek Generating Station, classified under SIC Code 4911, "Electric Services", include "fossil fuel-fired steam electric plants," which is a named category on the List of 28. As such, the major source threshold for the PSD program is 100 tpy. The potential emissions of at least one regulated NSR pollutant currently exceeds 100 tpy; therefore, Mill Creek Generating Station is classified as an existing major stationary source under the PSD program.

4.2.2 Nonattainment NSR Program Source Classification

APCD has a Board-approved nonattainment NSR program that is contained in Regulation 2.04, which was last updated on March 16, 2022.²⁰ Pursuant to Paragraph 2.1 of Regulation 2.04, NA-NSR applies to any new major stationary source or major modification that is major for the pollutant for which the area is designated nonattainment under section 107(d)(1)(A)(i) of the CAA, if the stationary source or modification would locate anywhere in the designated nonattainment area. Different pollutants, including individual precursors, are not summed to determine applicability of a major stationary source or major modification.

For Jefferson County, the major stationary source threshold for all nonattainment pollutants (and their precursors) is 100 tpy.²¹ Since Jefferson County currently is only designated nonattainment for ozone, emissions of its defined precursors, NO_x **or** VOC, must be compared to the 100-tpy threshold. Other pollutants are covered under the PSD program.

¹⁵ *Regulated NSR Pollutant* defined in Regulation 2.05, Section 1, and 40 CFR §52.21(b)(50)

¹⁶ "Subject to regulation" is defined in 40 CFR §52.21(b)(49).

¹⁷ 40 CFR §52.21(b)(49)(iv)

¹⁸ 40 CFR 52.21(b)(1)(i)(a)

¹⁹ Being a List of 28 source says nothing about whether a facility is classified as a minor or major source under PSD or whether it is subject to PSD permitting requirements. Being on the List of 28 imparts no particular regulatory requirements or permitting obligations. It only defines what the major source threshold is for a facility in an attainment area.

²⁰ <https://louisvilleky.gov/air-pollution-control-district/document/regulation-204-version-8>

²¹ There are no specially defined source categories under the Nonattainment NSR program as there are under the PSD program, being excluded from which would result in a 250 tpy major source threshold.

Similar to the rationale provided in the PSD section, potential emissions of NO_x and VOC currently exceed 100 tpy; therefore, Mill Creek Generating Station is classified as an existing major stationary source under the NA-NSR program.

Therefore, with respect to the NA-NSR permitting program, NA-NSR requirements could potentially apply to the NGCC Project for emissions of both NO_x and VOC. VOC which is regulated as a precursor to ozone is only potentially subject to NA-NSR requirements. However, NO_x, which is both subject to a dedicated NAAQS (for NO₂) and is regulated as a precursor to ozone, is potentially subject to both PSD and NA-NSR requirements.

4.3 NSR Applicability Analysis Methodology

4.3.1 Defining the Project

The proposed NGCC Project involves the new installation and operation of the new NGCC Unit to replace the capacity leaving with the shutting down the Mill Creek Units 1 and 2 boilers. The existing Units 3 and 4 boilers and the shared material storage and handling operations will be retained and are not being modified by the planned project. However, there will be attributable emissions decreases from certain coal handling operations due to reduction on overall coal usage with the shutdown of Units 1 and 2. No other emission units will have any emissions increases or decreases caused by the NGCC Project. The existing electric generation and transmission assets supporting Units 1 and 2 will remain in place; however, certain modifications/enhancements will be made to accommodate the NGCC Unit.

Since the new Unit 5 Gas Turbine with HRSG and its auxiliary support operations will be under the same common control and ownership, have the same SIC code, and be constructed and operated within the same property boundary, construction of NGCC Project is a modification to an existing major stationary source.

4.3.2 Existing versus New Emission Units

For purposes of calculating project-related emissions increases (labeled herein as project emissions increase or PEI), different calculation methodologies are used for existing and new units; therefore, it is important to clarify whether a source affected by a proposed project is considered a new or existing emission units.

40 CFR §52.21(b)(7) defines emission units as any part of a stationary source that emits or would have the potential to emit any regulated NSR pollutant and includes an *electric utility steam generating unit* (defined in 40 CFR §52.21(b)(31)). Similar definitions exist within Regulation 2.04. For purposes of this section, there are two types of emissions units:

*(i) A **new emissions unit** is any emissions unit that is (or will be) newly constructed and that has existed for less than 2 years from the date such emissions unit first operated.*

*(ii) An **existing emissions unit** is any emissions unit that does not meet the requirements in paragraph (b)(7)(i) of this section. A replacement unit, as defined in paragraph (b)(33) of this section, is an existing emissions unit.*

The GT/DB, Auxiliary Boiler, Fuel Gas (Dewpoint) Heater, Cooling Tower, Emergency Engines, HVAC Units, Storage Tanks, and Demister Vents that are proposed with the NGCC Project are all considered new emissions units.

The Units 1 and 2 coal-fired boilers being shut down, along with their material handling, storage, and transfer operations (which will have an attributable reduction in utilization and emissions), qualify as existing units since they have been in operation for more than two years.

4.3.3 Two-Step Major Modification Determination Process

As Mill Creek Generating Station is classified as an existing major stationary source for PSD and NA-NSR, if the proposed project meets the definition of a *major modification* (specific to each regulated NSR pollutant), then the full PSD and NA-NSR permitting requirements apply for that pollutant. *Major modification* is defined at 40 CFR §52.21(b)(1) for PSD and paragraph 1.5 of Regulation 2.04 for NA-NSR:

"Major Modification" means any physical change in or change in the method of operation of a major stationary source that would result in a significant emission increase [Step 1] ... of a regulated NSR pollutant ... and a significant net emissions increase of that pollutant [Step 2] ... [Step 1 & Step 2 added]

Certain exemptions to the major modification definition exist that, if applicable, means a project does not require an emission increase assessment. The proposed project does not qualify for any of the established exemptions.

For NA-NSR and pursuant to paragraph 1.27 of Regulation 2.04, *significant emissions increase* means, for a regulated NSR pollutant, an increase in emissions that is *significant* (as defined in paragraph 1.10 of Regulation 2.04) for that pollutant. For PSD and pursuant to 40 CFR 52.21(b)(40), *significant emissions increase* means, for a regulated NSR pollutant, an increase in emissions that is *significant* (as defined in 40 CFR §52.21(b)(23)) for that pollutant.

For those pollutants with a *significant emission increases*, the net creditable emission increases and decreases over the contemporaneous period [as defined in 40 CFR §52.21(b)(3) and Paragraph 1.6 of Regulation 2.04] are estimated and the *net emissions increase* is calculated for comparison with the *significant* thresholds (as defined in 40 CFR §52.21(b)(23) and paragraph 1.10 of Regulation 2.04).

Net emissions increase (NEI) is defined by 40 CFR §52.21(b)(3) for PSD, and has similar language in paragraphs 1.6 and 2.2 of Regulation 2.04 for NA-NSR, as:

"Net Emissions Increase" means, with respect to any regulated NSR pollutant ... the amount by which the sum of the following exceeds zero:

- (i) *The increase in emissions ... as calculated pursuant to 40 CFR §52.21(a)(2)(iv). [for existing units, calculated by actual-to-projected actual²² or actual-to-potential; for new units, calculated by actual-to-potential]^{23, 24}*
- (ii) *Any other increases and decreases in actual emissions...that are contemporaneous with the particular change and are otherwise creditable. Baseline emissions for calculating increases and decreases...shall be determined as provided...*

Step 1 is commonly referred to as the “project emission increases (PEI)” analysis as it accounts only for emissions related to the proposed project itself. If the emission increases estimated per Step 1 exceed the major modification thresholds, then the applicant may move to Step 2, commonly referred to as the 5-year netting analysis. The netting analysis includes all projects in the contemporaneous period for which a creditable emission increases or decreases occurred. If the resulting net emission increases exceed the major modification threshold, then NSR permitting requirements apply.

Historically, Step 1 emissions would not have accounted for proposed equipment shutdowns planned, requiring instead that such emission decreases be accounted for as part of the Step 2 analysis, along with any additional contemporaneous increases and decreases. However, in 2020, EPA promulgated the “Project Emissions Accounting” clarification, establishing that the Step 1 emissions can include decreases “provided they are part of a single project” and affirmed that a project can include a combination of new and existing units (i.e., hybrid).²⁵

APCD has accepted and codified the EPA promulgated the “Project Emissions Accounting” clarification. APCD’s PSD requirements in 40 CFR §52.21(a)(2)(iv)(g) includes the “sum of the difference” for all applicability tests, and the NA-NSR requirements have the same language at paragraph 2.2.7 of Regulation 2.04. As the proposed NGCC Project is being added and Units 1 and 2 coal-fired boiler operations are being shut down, LG&E included the emission decreases from these shutdowns in the Step 1 analyses. As is shown in the subsequent paragraphs, because the project emissions increases calculated in Step 1 are less than the major modification thresholds for all regulated NSR pollutants, an evaluation of the net emissions increase (i.e., Step 2) was not required and PSD and NA-NSR permitting requirements do not apply to this project. However, it is worth noting that if a Step 2 netting analysis was conducted, the applicability determination would be exactly the same.

²² 40 CFR §52.21(a)(2)(iv)(c), Actual-to-projected-actual applicability test for projects that only involve existing emissions units, states: A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the difference between the projected actual emissions ... and the baseline actual emissions ... equals or exceeds the significant amount for that pollutant ...

²³ 40 CFR §52.21(a)(2)(iv)(d), Actual-to-potential test for projects that only involve construction of new emissions units, states: A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the difference between the potential to emit ... and the baseline actual emissions ... equals or exceeds the significant amount for that pollutant ...

²⁴ 40 CFR §52.21(a)(2)(iv)(f), Hybrid test for projects that involve multiple types of emission units. A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the emissions increases for each emissions unit, using the methods specified in subparts (a)(2)(iv)(c) and (d) of this paragraph as applicable ... equals or exceeds the significant amount for that pollutant ...

²⁵ Federal Register Volume 85, No. 227, *Prevention of Significant Deterioration (PSD) and Nonattainment New Source Review (NNSR): Project Emissions Accounting*, Final Rule, pp. 74890-74909, published November 24, 2020. Quotation per p. 74893.

4.4 Components of Project Emission Increases

To calculate the project emissions increase, the difference between a future emission level (either potential emissions or projected-actual-emissions) and the baseline actual emissions must each be calculated. These components of the emission increase calculation formula are defined in the following sections.

4.4.1 Potential Emissions

For new emission units, the calculated project emissions increase is simply set to the future annual potential emission rate of the unit considering inherent physical and operational constraints on the production capacity of the equipment and any federally enforceable emissions/operating limitations, where applicable.

4.4.2 Baseline Actual Emissions (BAE)

For existing emission units being modified or affected, to determine the emission increases associated with the proposed project, baseline actual emissions are first defined. *Baseline Actual Emissions* (BAE) are defined in 40 CFR §52.21(b)(48) or by paragraph 1.35 of Regulation 2.04:

For an existing electric utility steam generating unit, baseline actual emissions means the average rate, in tons per year, at which the emissions unit actually emitted the pollutant during any consecutive 24-month period selected by the owner or operator within the 5-year period immediately preceding either the date the owner or operator begins actual construction of the project. The Reviewing authority shall allow the use of a different time period upon a determination that it is more representative of normal source operation...

For a new emission unit covered in the project scope, the BAE are set to zero. For an *emission unit* that “has existed for less than two (2) years from the date the unit first operated”,²⁶ the baseline emissions levels are set equal to “the unit’s potential to emit.”²⁷

The baseline period can be selected on a pollutant-by-pollutant basis, but for a given pollutant, only one baseline period can be used across all new, modified, and associated emission units in the project scope. The baseline period selection process typically involves a review of historical production and emissions data over the previous 5 years at an existing electric utility steam generating unit to identify a historically representative period of 24-month rolling average production/annual emissions.

Since commercial operation for the Mill Creek Generating Station NGCC Unit is targeted for April 1, 2027, and 37 months are allocated for construction and commissioning, the presumed start of on-site construction is **March 1, 2024**. The 5-year period immediately preceding this date begins on March 1, 2019. Thus, for the NGCC Project the earliest baseline period available to select for each pollutant is the 24-month period ending February 2021 (i.e., March 2019 to February 2021).

The selected baseline period used for each pollutant along with documentation of the BAE (and thus the equivalent emission reductions for the project) are provided in Appendix B in Section 14 for Unit 1 & 2 Boilers, Section 15 for Coal Bunkers, Section 16 for Coal Handling, Section 17 for Flyash Transfer Bin, Section 18 for Sorbent and PAC Silos, and Section 19 for Unit 2 Cooling Tower.

²⁶ *Emission Unit* definition in 40 CFR §52.21(b)(7).

²⁷ 40 CFR §52.21(b)(48)(iii) and Section 1.35.3 of Regulation 2.04

4.4.3 Projected Actual Emissions (PAE)

Projected Actual Emissions (PAE) are defined by 40 CFR §52.21(b)(41)(i) and Paragraph 1.28.1 of Regulation 2.04:

"Projected actual emissions" means the maximum annual rate, in tons per year, at which an existing emissions unit is projected to emit a regulated NSR pollutant in any one of the 5 years (12-month period) following the date the unit resumes regular operation after the project, or in any one of the 10 years following that date, if the project involves increasing the emissions unit's design capacity or its potential to emit that regulated NSR pollutant and full utilization of the unit would result in a significant emissions increase or a significant net emissions increase at the major stationary source.

For units in which the proposed projects would not change the potential to emit or the design capacity, an applicant sets the PAE for the following five years after authorization of the proposed project(s).

In determining PAE, pursuant to 40 CFR §52.21(b)(41)(ii)(a) and Paragraph 1.28.2.1 of Regulation 2.04, the source:

Shall consider all relevant information, including but not limited to, historical operational data, the company's own representations, the company's expected business activity and the company's highest projections of business activity, the company's filings with {the State or Federal regulatory authorities, and compliance plans under the approved State Implementation Plan}...

For unmodified, associated units, future emissions are calculated by the same actual-to-projected actual procedure as other existing emissions units.

4.4.4 Additional Associated Emission Unit Increases

In addition to the emission increases from new or modified units, emission increases from associated emission units that may realize an increase in emissions due to a project must be included in the assessment of the project emissions increases.

4.5 Project Emission Increase Evaluation

As stated above, the NGCC Project will constitute a modification to an existing major stationary source, and involves new emissions units and existing emissions units. The procedure for calculating (before beginning actual construction) whether a significant emissions increase (i.e., the first step of the process) will occur depends upon the type of emissions units being modified. Pursuant to 40 CFR §52.21(a)(2)(iv)(f)-(g) and Paragraph 2.2.6-7 of Regulation 2.04,

*(f) **Hybrid test for projects that involve multiple types of emissions units.** A significant emissions increase of a regulated NSR pollutant is projected to occur if the sum of the difference for all emissions units, using the method specified in paragraphs (a)(2)(iv)(c) and (d) of this section as applicable with respect to each emissions unit, equals or exceeds the significant amount for that pollutant (as defined in paragraph (b)(23) of this section).*

(g) The "sum of the difference" as used in paragraphs (c), (d) and (f) of this section shall include both increases and decreases in emissions calculated in accordance with those paragraphs.

Paragraph (c) of 40 CFR §52.21(a)(2)(iv) references the **actual-to-projected-actual applicability test** for projects that only involve existing emissions units. A “significant emissions increase” of a regulated NSR pollutant is projected to occur if the sum of the difference between the PAE and the BAE for each existing emissions unit, equals or exceeds the significant amount for that pollutant.

Whereas (d) of 40 CFR §52.21(a)(2)(iv) references the **actual-to-potential test** for projects that only involve construction of a new emissions unit(s).

Therefore, for hybrid projects that involve existing and new emission units, such is the case with the NGCC Project, an actual-to-projected actual applicability test is used for the existing units and an actual-to-potential test is used for the new units. The sum of emission increases from these tests for all affected units associated with the project is the total project emissions increase (PEI) assessed against the significance thresholds in Step 1.

$$\text{PEI} = \text{Sum of differences of New EUs (PAE}_i - \text{BAE}_i) + \text{Sum of differences of Existing EUs (PAE}_j - \text{BAE}_j) + \text{Sum of differences of Unmodified EUs (PAE}_k - \text{BAE}_k)$$

For a new emissions unit, $\text{PAE}_i = \text{PTE}$, and BAE is usually 0.0 tpy. For example, as shown in Section 2 in Appendix B, the “sum of the differences” for NO_x emissions from the GT/DB, a new emission unit, are as follow:

$$\text{PAE}_{\text{U23/E49}} = \text{PTE}_{\text{U23/E49}} = 167.2 \text{ tpy}$$

$$\text{BAE}_{\text{U23/E49}} = 0 \text{ tpy}$$

$$\text{PEI}_{\text{U23/E49}} = 167.2 \text{ tpy PAE} - 0 \text{ tpy BAE} = 167.2 \text{ tpy for NO}_x$$

For modified emissions units, PAE_i is the forecast of each emission unit’s future actual emissions.²⁸ With the NGCC Project, there will be existing emissions units that are shut down or modified. For example, for the Unit 1 Coal Boiler, $\text{PAE}_{\text{U1/E1}}$ will be 0.0 tpy of NO_x since the projected actual emissions for a unit being permanently shut down are 0 tpy. The BAE for each of the existing emissions units (e.g., Unit 1, Unit 2, etc.) are documented in Sections 14 through 19 of Appendix B.

For example, the “sum of the differences” for NO_x emissions from the existing Unit 1 coal-fired boiler are as follow:

$$\text{PAE}_{\text{U1/E1}} = 0.0 \text{ tpy}$$

$$\text{BAE}_{\text{U1/E1}} = 2,251 \text{ tpy is the 2-year average actual emissions in the baseline period (March 2019 through February 2021)}$$

$$\text{PEI}_{\text{U1/E1}} = 0.0 \text{ tpy PAE} - 2,251 \text{ tpy BAE} = -2,251 \text{ tpy for NO}_x$$

Unmodified existing emission units located upstream or downstream of new or modified emissions units in the project scope are addressed in the calculation of an emissions increase for the project if these unmodified units will experience a change in actual annual throughput/utilization due to the operation of the proposed new/modified units. This type of upstream/downstream emission unit is commonly referred to as an “associated” emission unit. For example, Coal Handling Equipment (U21) will not be modified as part of the project, but activity will be reduced in conjunction with shutdown of Units 1 and 2 Boilers. As a result,

²⁸ In a letter from Scott Pruitt, EPA Administrator to EPA Regional Administrators (December 7, 2017), when a source performs a pre-project NSR applicability analysis in accordance with the procedure in the regulations, and follow the applicable recordkeeping and notification requirements, the source has met the pre-project source obligations. Unless there is clear error (e.g., source applies an incorrect SER), the projected actual emissions are not second-guessed. (https://www.epa.gov/sites/default/files/2017-12/documents/nsr_policy_memo.12.7.17.pdf)

there will be an emission decrease from these coal handling units associated with the project. The emission decrease is set to the BAE attributable to coal usage in the baseline period for the Unit 1 and 2 Boilers, as documented in Section 16 of Appendix B.

4.6 PSD/NA-NSR Applicability Summary

A detailed table documenting the potential emissions from new emission units on a unit-by-unit basis, the baseline actual emissions from shutdown and associated emission units on a unit-by-unit basis, and the overall calculated project emissions increase is provided in Section 2 of Appendix B. A summary showing the comparison of the project emission increases compared to the PSD and NA-NSR major modification thresholds are shown in Tables 4-1 and 4-2, respectively.

Table 4-1. NGCC Project Emissions Increases Compared with PSD Significant Emission Rates

| Pollutant ¹ | "Step 1" Project Emissions Increase (tpy) | PSD Significant Emission Rate ² (tpy) | Project Triggers PSD Review? (Yes/No) |
|--------------------------------|---|--|---------------------------------------|
| PM | -254 | 25 | No |
| PM ₁₀ | -248 | 15 | No |
| PM _{2.5} | -223 | 10 | No |
| NO _x | -4,036 | 40 | No |
| CO | -174 | 100 | No |
| SO ₂ | -1,118 | 40 | No |
| H ₂ SO ₄ | -0.2 | 7 | No |
| Lead | -0.024 | 0.6 | No |
| GHGs (as CO ₂ e) | -836,545 | 75,000 ³ | No |

¹ Only those regulated NSR pollutants for which the project emissions increase could potentially exceed the SER are listed.

² Per 40 CFR §52.21(b)(40), which points to (b)(23), where significant means, in reference to an *emissions increase* of a source to emit any of the following pollutants, a rate of emissions that would equal or exceed any of the following rates. Note, O₃: 40 tpy of VOC emissions **or** 40 tpy of NO_x emissions
PM_{2.5}: 10 tpy of direct PM_{2.5} emissions; 40 tpy of SO₂ emissions; **or** 40 tpy of NO_x emissions unless demonstrated not to be a PM_{2.5} precursor under paragraph (b)(50).

³ CO₂e (GHG Pollutants) only become subject to regulation and potentially applicable to PSD if another regulated NSR pollutant triggers PSD.

Table 4-2. NGCC Project Emissions Increases Compared with NA-NSR Major Modification Thresholds

| Pollutant¹ | "Step 1" Project Emissions Increase (tpy) | NA-NSR Major Modification Threshold² (tpy) | Project Triggers NA-NSR Review? (Yes/No) |
|------------------------------|--|--|---|
| Ozone | | | No |
| NO _x | -4,036 | 40 | |
| VOC | 11 | 40 | |

¹ Jefferson County is nonattainment for the 8-hour Ozone NAAQS promulgated in 2015.

² Per Paragraph 1.27, which points to 1.10.1 of Regulation 2.04, where *significant* means, in reference to an *emissions increase* of a source to emit any of the following pollutants, a rate of emissions that would equal or exceed any of the following rates, where
Ozone: 40 tpy of VOC emissions **or** 40 tpy of NO_x emissions

As shown in Tables 4-1 and 4-2, the proposed NGCC Project is not a major modification under either the PSD or NA-NSR permitting programs, and thus do not trigger permitting requirements of these programs.

In accordance with paragraph 7.6 of Regulation 2.04, projects that **do not** constitute a PSD major modification when calculated using the BAE to PAE methodology, but which have a "reasonable possibility" to result in a significant emissions increase, are subject to additional recordkeeping and reporting requirements including the requirement to calculate and maintain a record of annual emissions, in tons per year on a calendar year basis for at least 5 years following resumption of regular operations after the modification (or 10 years if the project increases the design capacity or potential to emit of a regulated NSR pollutant). Reasonable possibility is defined as either: 1) where the difference between BAE and PAE is greater than 50% of the significance level for the regulated pollutant; or 2) where the difference between BAE and PAE prior to subtraction of the emissions excluded from PAE through the could have accommodated exclusion is greater than 50% of the significance level for the regulated pollutant. For the proposed NGCC Project, the emissions increase of all pollutants except VOC are below zero. For VOC, while there is a calculated project emissions increase (11 tpy), the amount is well below 50% of the SER and therefore, the NGCC Project is not subject to the reasonable possibility recordkeeping and reporting requirements of Section 7 of Regulation 2.04.

5. APPLICABLE FEDERAL AND STATE REQUIREMENTS

Emission units constructed as part of the proposed NGCC Project will be subject to certain federal and APCD air quality regulations. This section of the application summarizes the air permitting requirements and the key air quality regulations that will apply to emission units constructed as part of the NGCC Project. Specifically, applicability to NSPS, pollutant- and category-specific NESHAP, Compliance Assurance Monitoring (CAM), Title V operating permit regulations, Acid Rain Program (ARP), Cross-State Air Pollution Rule (CSAPR), and APCD-specific regulations are addressed.

In Appendix C, Form AP-100H identifies regulatory requirements for the NGCC Project. As an optional supplement to the application, to assist in APCD's review of the application and development of a Construction Permit and revised Title V permit, an edited version of the existing Title V permit for Mill Creek Generating Station showing new and modified permit revisions that would encompass the proposed project is provided in Appendix D.

5.1 New Source Performance Standards

Section 111 of the CAA, Standards of Performance of New Stationary Sources, requires EPA to establish federal emissions standards for source categories that cause or contribute significantly to air pollution. EPA is required to establish standards based on the best systems of emission reductions from technologies that have been adequately demonstrated, taking into account the cost of such technology and any other non-air quality, health, and environmental impact and energy requirements. These standards apply to sources that have been constructed or modified since the proposal of the standard. Since December 23, 1971, EPA has promulgated more than 75 standards. The NSPS are codified in 40 CFR 60.

Any source subject to an NSPS is also subject to the general provisions of NSPS Subpart A, except as noted. A review of all NSPS that could potentially be applicable to any of the new emission units associated with the NGCC Project is presented in this section. The list of category-specific NSPS that will apply to the emission units for the NGCC Project are as follows:

- ▶ 40 CFR 60 Subpart Dc – Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units – Applies to the Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52)
- ▶ 40 CFR 60 Subpart KKKK – Standards of Performance for Stationary Combustion Turbines – Applies to Gas Turbine with HRSG (U23/E49)
- ▶ 40 CFR 60 Subpart TTTT – Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units – Applies to Gas Turbine with HRSG (U23/E49)
- ▶ 40 CFR 60 Subpart IIII – Stationary Compression Ignition Combustion Engines – Applies to the 2 MW Diesel Emergency Generator Engine (U25/E51) and the Emergency Diesel Driven Fire Pump Engine (IA4/IE28)

5.1.1 40 CFR 60 Subpart A – General Provisions (Applicable)

All affected sources subject to source-specific NSPS are subject to the general provisions of NSPS Subpart A unless specifically excluded by the source-specific NSPS. Subpart A requires initial notification, performance testing, recordkeeping and monitoring, provides reference methods, and mandates general control device requirements for all other subparts as applicable.

5.1.2 NSPS Subpart D – Fossil Fuel-Fired Steam Generators > 250 MMBtu/hr (Not Applicable)

40 CFR 60 *Subpart D – Standards of Performance for Fossil-Fuel-Fired Steam Generators* (NSPS D), applies to fossil fuel-fired steam generating units with heat input capacities greater than 250 MMBtu/hr that have been constructed or modified since August 17, 1971.²⁹ The rule defines a fossil fuel-fired steam generating unit as:³⁰

A furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

The GT and HRSG with NG-fired DBs (U23/E49) will not be subject to NSPS D because:

- ▶ The GT is not classified as a steam generating unit under this regulation and
- ▶ The HRSG with NG-fired DBs will be subject to NSPS Subpart KKKK instead and as such, are not subject to NSPS D.³¹

The Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52) are each implicitly not subject since their heat input capacity is less than 250 MMBtu/hr.

5.1.3 NSPS Subpart Da – Electric Utility Steam Generating Units > 250 MMBtu/hr (Not Applicable)

40 CFR *Subpart Da – Standards of Performance for Electric Utility Steam Generating Units* (NSPS Da), provides standards of performance for electric utility steam generating units with heat input capacities greater than 250 MMBtu/hr of fossil fuel (alone or in combination with any other fuel) for which construction, modification, or reconstruction commenced after September 18, 1978.³² The term “steam generating unit” is defined under this regulation as:³³

For units constructed, reconstructed, or modified after May 3, 2011, steam generating unit means any furnace, boiler, or other device used for combusting fuel for the purpose of producing steam (including fossil-fuel-fired steam generators associated with combined cycle gas turbines...

The GT and HRSG with NG-fired DBs (U23/E49) will not be subject to NSPS Subpart Da because:

- ▶ The GT is not classified as a steam generating unit under this regulation and
- ▶ The HRSG with NG-fired DBs will be subject to NSPS Subpart KKKK instead and as such, are not subject to NSPS Subpart Da.³⁴

The Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52) are each implicitly not subject since their heat input capacity is less than 250 MMBtu/hr.

²⁹ 40 CFR §60.40

³⁰ 40 CFR §60.41

³¹ 40 CFR §60.40(e)

³² 40 CFR §60.40Da(a)

³³ 40 CFR §60.41Da

³⁴ 40 CFR §60.40Da(e)

5.1.4 NSPS Subpart Db – Steam Generating Units > 100 MMBtu/hr (Not Applicable)

40 CFR 60 *Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units* (NSPS Db), provides standards of performance for steam generating units with capacities greater than 100 MMBtu/hr for which construction, modification, or reconstruction commenced after June 19, 1984.³⁵ The term “steam generating unit” is defined under this regulation as:³⁶

Steam generating unit means a device that combusts any fuel or byproduct/waste and produces steam or heats water or heats any heat transfer medium. This term includes any municipal-type solid waste incinerator with a heat recovery steam generating unit or any steam generating unit that combusts fuel and is part of a cogeneration system or a combined cycle system. This term does not include process heaters as they are defined in this subpart.

The GT and HRSG with NG-fired DBs (U23/E49) will not be subject to NSPS Subpart Db, because:

- ▶ The GT is not classified as a steam generating unit under this regulation and
- ▶ HRSGs with NG-fired DBs will be subject to NSPS Subpart KKKK instead and as such, are not subject to NSPS Subpart Db.³⁷

The Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52) are each implicitly not subject to NSPS Db since their heat input capacity does not exceed 100 MMBtu/hr.

5.1.5 NSPS Subpart Dc – Small Steam Generating Units (Applicable)

40 CFR 60 *Subpart Dc – Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units* (NSPS Dc), provides standards of performance for each steam generating unit for which construction, modification, or reconstruction commenced after June 9, 1989, and that the maximum design heat input capacity of 100 MMBtu/hr or less, but greater than or equal to 10 MMBtu/hr.³⁸ The term “steam generating unit” is defined under this regulation as:³⁹

Steam generating unit means a device that combusts any fuel and produces steam or heats water or heats any heat transfer medium. This term does not include process heaters as defined in this subpart.

The GT and HRSG with NG-fired DBs (U23/E49) will not be subject to NSPS Subpart Dc because its heat capacity is well above the applicability threshold.

However, both the new NG-fired Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52), meet the definition of a steam generating unit and fall within the applicable heat input capacity range, and

³⁵ 40 CFR §60.40b(a)

³⁶ 40 CFR §60.41b

³⁷ 40 CFR §60.40b(i)

³⁸ 40 CFR §60.40c(a)

³⁹ 40 CFR §60.41c

each is an affected facility after the applicability date.⁴⁰ Units subject to NSPS Subpart Dc that fire natural gas do not have to meet any applicable emission limits, testing, or monitoring requirements under this subpart, except for the requirement to monitor natural gas consumption on a monthly basis. Initial notifications of the dates of construction commencement, anticipated startup, actual startup, in addition to the design heat input capacity and the identification of fuels to be combusted must be submitted to the APCD.

5.1.6 NSPS Subpart GG – Stationary Gas Turbines (Not Applicable)

40 CFR 60 *Subpart GG – Standards of Performance for Stationary Gas Turbines* (NSPS GG), applies to all stationary gas turbines with a heat input at peak load equal to or greater than 10 MMBtu/hr, based on the lower heating value of the fuel fired, that are constructed, modified, or reconstructed after October 3, 1977.⁴¹

The GT and HRSG with NG-fired DBs (U23/E49) will be a stationary gas turbine with a heat input above the threshold and constructed after the applicability date. However, pursuant to 40 CFR §60.4305(b), stationary combustion turbines regulated under NSPS KKKK are exempt from the requirements of NSPS GG. Therefore, NSPS GG does not apply.

5.1.7 NSPS Subpart KKKK – Stationary Combustion Turbines (Applicable)

40 CFR 60 *Subpart KKKK – Standards of Performance for Stationary Combustion Turbines* (NSPS KKKK) establishes emissions limits for a combustion turbine (all references to GT are synonymous with a combustion turbine) and associated HRSG or DBs that commenced construction, modification, or reconstruction after February 18, 2005, and have a heat input from the GT at peak load equal to greater than 10.7 gigajoules (10 MMBtu/hr) based on the HHV of the fuel. HRSGs with DBs regulated under NSPS KKKK are exempt from the requirements of NSPS D, Da, Db, and Dc. Also, because the GT is subject to NSPS KKKK, it is exempt from NSPS GG.

The affected facility under NSPS KKKK is a stationary combustion turbine, which is defined by 40 CFR §60.4420 as:

“all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and subcomponents comprising any simple cycle stationary combustion turbine, any regenerative/ recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self-propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.”

The GT and HRSG with NG-fired DBs (U23/E49) will be a combustion turbine with a heat input above the threshold and constructed after the applicability date and thus will be subject to NSPS KKKK. NSPS KKKK specifies emissions limitations, monitoring, reporting, and recordkeeping requirements for NO_x and SO₂.

⁴⁰ The Fuel Gas (Dewpoint) Heater is equipped with a water/glycol bath (i.e., the heat transfer medium) that indirectly heats the pipeline gas stream, which makes it subject to NSPS Dc.

⁴¹ 40 CFR §60.330

5.1.7.1 Emissions Limits

For a new GT firing natural gas with a rating greater than 850 MMBtu/hr, the NO_x emission standard is 15 ppm at 15% O₂ or 0.43 lb/megawatt hour (MWh) gross energy output.⁴² NSPS KKKK also includes, for units greater than 30 MW output, a NO_x limit of 96 ppm at 15% O₂ or 4.7 lb/MWh gross output for turbine operation at ambient temperatures less than 0°F and turbine operation at loads less than 75% of peak load.⁴³ Compliance with the NO_x emission limit is determined on a 30-unit operating day rolling average basis.⁴⁴

SO₂ emissions into the atmosphere from GTs located in the continental U.S. are limited to 0.9 lb/MWh gross output (or 110 nanograms per Joule (ng/J)), **or** the units must not burn any fuel with total potential sulfur emissions in excess of 0.060 lb SO₂/MMBtu heat input.⁴⁵

As documented in detail in Section 5 of Appendix B, LG&E's GT/DB will have NO_x and SO₂ emissions well below the NSPS KKKK emissions standards and will comply with the applicable monitoring, reporting, and performance test requirements of NSPS KKKK.

5.1.7.2 Monitoring and Testing Requirements

Pursuant to 40 CFR §60.4333(a), the combustion turbine, air pollution control equipment, and monitoring equipment will be maintained in a manner that is consistent with good air pollution control practices for minimizing emissions. This requirement applies at all times including during startup, shutdown, and malfunction.

5.1.7.2.1 NO_x Compliance Demonstration Requirements

The GT will not use either water or steam injection; therefore, the continuous compliance requirements at 40 CFR §60.4340 apply. Pursuant to 40 CFR §60.4340(b)(1), LG&E will install, calibrate, maintain, and operate a continuous emission monitoring system (CEMS) as described in 40 CFR §§ 60.4335(b) and 60.4345. LG&E will certify according to 40 CFR Part 75 Appendix A to demonstrate ongoing compliance with the NSPS KKKK NO_x emission limits. Sources demonstrating compliance with the NO_x emission limit via CEMS are not subject to the requirement to perform initial and annual NO_x stack tests.⁴⁶ Initial compliance with the NO_x emission limit will be demonstrated by comparing the arithmetic average of the NO_x emissions measurements taken during the initial relative accuracy test audit (RATA) required pursuant to 40 CFR §60.4405 to the NO_x emission limit under NSPS KKKK.⁴⁷

5.1.7.2.2 SO₂ Compliance Demonstration Requirements

For compliance with the SO₂ emission limit, facilities are required to perform regular determinations of the total sulfur content of the combustion fuel and to conduct initial and annual compliance demonstrations. The total sulfur content of gaseous fuel combusted in the combustion turbine must be determined and recorded once per operating day or using a custom schedule as approved by APCD;⁴⁸ however, LG&E elects

⁴² 40 CFR §60.4320(a) and Table 1

⁴³ Ibid.

⁴⁴ 40 CFR §60.4350(h), 40 CFR §60.4380(b)(1)

⁴⁵ 40 CFR §60.4330(a)(1) or (a)(2), respectively

⁴⁶ 40 CFR 60.4340(a)

⁴⁷ 40 CFR 60.4405(c)

⁴⁸ 40 CFR 60.4370(b) and (c)

to opt out of this provision of the rule by using a fuel that is demonstrated not to exceed potential sulfur emissions of 0.060 lb/MMBtu SO₂.⁴⁹ This demonstration can be made using one of the following methods:

- ▶ By using a purchase contract specifying that the fuel sulfur content for the natural gas is less than or equal to 20 gr/Cscf of sulfur and results in potential emissions not exceeding 0.060 lb/MMBtu; or
- ▶ By using representative fuel sampling data meeting the requirements of 40 CFR 75, Appendix D, Sections 2.3.1.4 or 2.3.2.4 which show that the sulfur content of the fuel does not exceed 0.060 lb SO₂/MMBtu heat input.

As shown in the attached permit mark up, LG&E will accept the fuel sulfur limitation shown in 40 CFR §60.4330(a)(2) of 20 gr/Cscf of sulfur or less.

Pursuant to 40 CFR §60.4365(a), the fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifies that the total sulfur content for natural gas used at Mill Creek Generating Station is less than 20 gr/Cscf.

5.1.8 NSPS Subpart IIII – Stationary Compression Ignition Internal Combustion Engines (Applicable)

40 CFR 60 *Subpart IIII - Standards of Performance for Stationary Compressions Ignition Internal Combustion Engines* (NSPS IIII) applies to owners or operators of stationary compression ignition (CI) internal combustion engines (ICE) manufactured after April 1, 2006 that are not fire pump engines, and fire pump engines manufactured after July 1, 2006 that commence construction after July 11, 2005.

5.1.8.1 Emergency Fire Pump Engine (IA4/IE28)

The NGCC Project is provisioned to have a nominal 400 hp fire pump engine that will combust ULSD. The date of manufacture for the emergency fire pump engine and date of construction will occur after the dates specified above; therefore, the emergency fire pump engine will be subject to the provisions of NSPS IIII.

Since the proposed emergency fire pump engine will have a power rating of 400 hp and a displacement of less than 30 liters per cylinder, the emergency fire pump engine must comply with the emission standards in Table 4 of NSPS IIII for all pollutants [§60.4205(c)]. Specifically, the emergency fire pump engine must meet the following emissions standards for non-methane hydrocarbons (NMHC)+NO_x and PM:⁵⁰

- ▶ 3.0 grams per horsepower-hour (g/hp-hr) of NMHC+NO_x, and
- ▶ 0.15 g/hp-hr of PM.

As documented in the emissions calculations provided in Appendix B, the proposed emergency fire pump engine will meet these emissions limits.

As provided in 40 CFR §60.4211(c), to demonstrate compliance with these emission standards, LG&E will purchase an emergency fire pump engine certified to the emission limits listed in Table 4 of NSPS IIII or more stringent, and will install and configure the engine according to the manufacturer's specifications. No performance testing is required.

⁴⁹ 40 CFR 60.4365

⁵⁰ NSPS IIII does not establish CO emission limits for fire pump engines manufactured after 2008 for engines at this size.

Effective October 1, 2010, only diesel fuel that meets the requirements set forth in 40 CFR §1090.305 may be used in accordance with 40 CFR §60.4207(b). This regulation states that the sulfur content must remain less than or equal to 15 ppm, and either the cetane index must be at least 40, or the aromatic content must be less than or equal to 35 volume percent.

Under NSPS IIII, LG&E will monitor emergency fire pump engine hours of operation using a non-resettable hour meter and records per §60.4214(b) will be maintained. No other monitoring is required.

Although the emergency fire pump engine is subject to NSPS IIII, based on its potential emissions, it qualifies to be designated as an insignificant activity. LG&E has therefore presumed that it will be included in the existing IA4 IA grouping and has been given a proposed Emission Point designation of IE28.

5.1.8.2 Emergency Generator Engine (U25/E51)

The NGCC Project is provisioned to have a 2 MW rated emergency generator engine and will be a 2021 model year or later unit. Since the diesel fired engine (2,682 hp) serving the generator will be used for emergency purposes and cylinder displacement is less than 10 liters/cylinder, the engine will be subject to the emission limits in 40 CFR §§60.4205(b) and 60.4202(a)(2) and the fuel specifications of 40 CFR §60.4207.

Per 40 CFR §60.4205(b),

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

Per 40 CFR §60.4202(a)(2),

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.

(2) For engines with a rated power greater than or equal to 37 KW (50 HP), the Tier 2 or Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105 beginning in model year 2007.

Starting with Model Year 2006, a new engine with a rated power greater than or equal to 130 kW but less than or equal to 560 kW, must meet the Tier 3 standard in Table 3 to Appendix I as specified in 40 CFR Part 1039. As the emergency generator's rated power is greater than 560 kW, it must meet the Tier 2 standards in Table 2 to Appendix I.⁵¹

Table 2 to Appendix I - Tier 2 Emission Standards contain the following applicable emission limits:

- ▶ 6.4 grams per kilowatt hour (g/kW-hr) (equivalent to 4.8 g/hp-hr) of NMHC+ NO_x,

⁵¹ <https://www.ecfr.gov/current/title-40/part-1039#Appendix-I-to-Part-1039>

- ▶ 3.5 g/kW-hr (equivalent to 2.6 g/hp-hr) of CO, and
- ▶ 0.20 g/kW-hr (equivalent to 0.1 g/hp-hr) of PM.

Pursuant to 40 CFR §1039.105(b)(1) through (3), smoke from the engine may not exceed the following standards.

1. 20 percent during acceleration mode;
2. 15 percent during lugging mode; and
3. 50 percent during peaks in either the acceleration or lugging mode.

As provided in 40 CFR §60.4211(c), to demonstrate compliance with these emission standards, LG&E will purchase an emergency generator certified to the emission limits listed 40 CFR §60.4205(b) or more stringent, and will install and configure the engines according to the manufacturer's specifications. No performance testing is required.

LG&E will use diesel fuel that meets the requirements of 40 CFR §1090.305 for nonroad diesel fuel in accordance with 40 CFR §60.4207(b). This regulation states that the sulfur content must remain less than or equal to 15 ppm, and either the cetane index must be at least 40, or the aromatic content must be less than or equal to 35 volume percent.

Under NSPS IIII, LG&E will monitor hours of operation of the emergency generators using non-resettable hour meters and records per 40 CFR §60.4214(b) will be maintained. No other monitoring is required.

5.1.9 NSPS Subpart TTTT – GHG Emissions for Electric Generating Units (Applicable)

40 CFR 60 *Subpart TTTT – Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units* (NSPS TTTT) is applicable to any steam generating unit, integrated gasification combined-cycle, or stationary GT that commenced construction after January 8, 2014, or commenced modification or reconstruction after June 18, 2014, that:

- ▶ Has a base load rating greater than 250 MMBtu/hr of fossil fuel.
- ▶ Serves a generator(s) capable of selling greater than 25 MW of electricity to a utility power distribution system.

Given that the proposed GT and HRSG with NG-fired DBs (U23/E49) meets all three applicability criteria under 40 CFR §60.5509(a) and do not meet any of the exemption criteria under 40 CFR §60.5509(b), this emission unit will be subject to the provisions of NSPS TTTT.

Note that the NGCC Project is considered a base load natural gas-fired unit. By definition, such a unit must (1) combust more than 90 percent natural gas on a heat input basis on a 12-operating-month rolling average basis and (2) supply more than (i) its design efficiency or 50 percent, whichever is less, (ii) times its potential electric output as net-electric sales on both a 12-operating-month and a three-year rolling average basis.

The GT and DB will be subject to the following key requirements under NSPS TTTT:

- ▶ Per 40 CFR §60.5520(a), emissions of CO₂ must be limited to 1,000 lb/MWh of gross energy output and 1,030 lb/MWh of net energy output.

- ▶ Per 40 CFR §60.5520(d), as long as the GT is only permitted to burn uniform fuels that result in a consistent emission rate of 160 lb CO₂/MMBtu or less, it is not subject to any monitoring or reporting requirements under this subpart. LG&E is only required to maintain purchase records for permitted fuels.
- ▶ Per 40 CFR §60.5550, LG&E must submit a notification of the date of construction and actual date of initial startup of the NGCC Unit.

5.1.10 NSPS Subpart UUUUa – GHG Emissions from Existing Electric Utility Generating Units (Not Applicable)

40 CFR 60 *Subpart UUUUa – Emission Guidelines for Greenhouse Gas Emissions From Existing Electric Utility Generating Units* (NSPS UUUUa), is applicable to steam generating units that commence construction on or before January 8, 2014. NSPS UUUUa is not applicable to the NGCC Project because it will commence construction after the applicability date, in addition to being an EGU that is subject to NSPS TTTT, which is excluded from being a designated facility per 40 CFR §60.5780a(a)(1). Moreover, pursuant to 40 CFR §60.5780a(a)(3), a stationary combustion turbine that meets the definition of a simple cycle stationary combustion turbine, a combined cycle stationary combustion turbine, or a combined heat and power combustion turbine is excluded from being a designated facility as well.

5.2 National Emissions Standards for Hazardous Air Pollutants

NESHAP, located in 40 CFR 61 and 40 CFR 63, have been promulgated for designated pollutants and source categories that emit HAP to the atmosphere. A facility that is a major source of HAP is defined as having potential emissions of greater than 25 tpy of total HAP and/or 10 tpy of any individual HAP. Facilities with a potential to emit HAP at an amount less than that which is defined as a major source are otherwise considered an area source. For major HAP sources, allowable emissions limits are established (under 40 CFR 63) on the basis of a maximum achievable control technology (MACT) determination for the particular major source type or category. The NESHAP under 40 CFR 63 apply to sources in specifically regulated industrial source categories (Clean Air Act Section 112(d)) or on a case-by-case basis (Section 112(g)) for facilities not regulated as a specific industrial source type.

Even after the shutdown of the Units 1 and 2 coal-fired boilers, the Mill Creek Generating Station will remain a major source for individual HAP and total HAPs.

Any source subject to a NESHAP is also subject to the general provisions of 40 CFR Subpart A, except as noted. A review of all NESHAP that could potentially be applicable to any of the new emission units associated with the NGCC Project is presented in this section. The list of NESHAP that will apply to the emission units for the NGCC Project are as follows:

- ▶ 40 CFR 63 Subpart DDDDD – NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters – Applies to Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52)
- ▶ 40 CFR 63 Subpart ZZZZ – NESHAP for Stationary Reciprocating Internal Combustion Engines – Applies to 2 MW Diesel Emergency Generator Engine (U25/E51) and 400 hp Emergency Diesel Driven Fire Pump Engine (IA4/IE28)
- ▶ 40 CFR 63 Subpart YYYY – NESHAP for Combustion Turbines – Applies to Unit 12 GT/HRSG (U23/E49)

5.2.1 NESHAP Subpart DDDDD – Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters (Applicable)

40 CFR 63 *Subpart DDDD – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters* (Boiler MACT) applies to industrial, commercial, or

institutional boilers or process heaters, as defined in 40 CFR §63.7575 that are located at, or are part of, a major source of HAP, except as specified in 40 CFR §63.7491. Boiler MACT applies to each new, reconstructed, or existing affected source, where the affected source includes the collection of all existing industrial, commercial, and institutional boilers and process heaters within an applicable subcategory defined in 40 CFR §63.7575 and each new or reconstructed industrial, commercial, or institutional boiler or process heater.

The Auxiliary Boiler (U24/E50) that will be installed as part of the NGCC Project is an industrial boiler (99.9 MMBtu/hr) and will be located at a major HAP source. It will thus be subject to Boiler MACT. The Fuel Gas (Dewpoint) Heater (U26/E52), which is equipped with burners with a heat input capacity of 15 MMBtu/hr, is classified as a process heater and thus will also be subject to Boiler MACT. As these combustion units are designed to use natural gas as the sole fuel for combustion, they will be categorized as "units designed to burn gas 1 fuels" per 40 CFR §63.7499.

LG&E plans to provide multiple natural gas-fired HVAC units within buildings that are associated with the NGCC Project. The specific make and model will not be known until farther along in the project development phase. The total combined heat input capacity of all these small HVAC heaters can be presumed to be 10 MMBtu/hr or less and this maximum value has been used to define the total potential emissions of all the HVAC heaters. Any installation defined as a hot water heater will not be subject to Boiler MACT.⁵² None of the small HVAC units are expected to be affected sources for Boiler MACT.

Pursuant to 40 CFR §63.7500(a), the Auxiliary Boiler (U24/E50) and Fuel Gas (Dewpoint) Heater (U26/E52) must comply with the emission limits and work practice standards presented in Tables 1 through 3 of the Boiler MACT and the operating limitations found in Table 4. Table 1 specifies emissions limitations for new boilers, but this table only includes emissions limitations for units designed to burn solid, liquid, and gaseous fuels defined under the "gas 2" fuel category. As the two new applicable units are considered "units designed to burn gas 1 fuels", they are not subject to any emissions standards. However, these units are subject to a limited number of work practice standards detailed in Table 3 of the Boiler MACT. These include the requirement to conduct periodic tune-ups where the frequency of the tune-up is dependent on the heat input capacity of the boiler and the presence of a continuous oxygen trim system that maintains an optimum air-to-fuel ratio.

- ▶ Per 40 CFR §63.7500, LG&E must conduct a tune-up of the Auxiliary Boiler and Fuel Gas (Dewpoint) Heater annually as specified in 40 CFR §63.7540(a)(10), unless the unit has a continuous oxygen trim system that maintains an optimum air to fuel ratio. The first tune-up must be no later than 13 months after the initial startup of each boiler, per 40 CFR §63.7515(d).
- ▶ Per 40 CFR §63.7530(f), LG&E must submit a notification of compliance status containing the results of the initial compliance demonstration according to the requirements in 40 CFR §63.7545(e).
- ▶ Per 40 CFR §63.7540(b), LG&E must report any instances it did not meet the tune-up requirements and reported according to the requirements of 40 CFR §63.7550.
- ▶ Per 40 CFR §63.7545, LG&E must submit an initial notification no later than 15 days after the actual date of startup.
- ▶ Per 40 CFR §63.7550, LG&E must submit a compliance report annually.

⁵² Hot water heater means, a closed vessel with a capacity of no more than 120 U.S. gallons in which water is heated by combustion of gaseous, liquid, or biomass/bio-based solid fuel and is withdrawn for use external to the vessel. Hot water boilers (i.e., not generating steam) combusting gaseous, liquid, or biomass fuel with a heat input capacity of less than 1.6 million Btu per hour are included in this definition. The 120 U.S. gallon capacity threshold to be considered a hot water heater is independent of the 1.6 MMBtu/hr heat input capacity threshold for hot water boilers. Hot water heater also means a tankless unit that provides on demand hot water.

- ▶ Per 40 CFR §63.7555, LG&E must keep records of each notification and report submitted for 5 years following the date of each occurrence.

LG&E has documented the relevant Boiler MACT provisions on Form AP-100H in Appendix C.

5.2.2 NESHAP Subpart ZZZZ – Reciprocating Internal Combustion Engines (Applicable)

40 CFR 63 *Subpart ZZZZ – NESHAP for Stationary Reciprocating Internal Combustion Engines* (RICE MACT) regulates HAPs emitted from stationary reciprocating internal combustion engines (RICE) located at major and area source of HAP emissions. The NGCC Project includes two stationary RICE: 1) 2 MW Diesel Emergency Generator (U25/E51) and 2) 400 hp Diesel Driven Fire Pump (IA4/EI28).

Pursuant to 40 CFR §63.6590(c)(6), a new emergency use stationary RICE with a site rating of less than or equal to 500 brake horsepower located at a major source of HAPs (e.g., 400 hp Emergency Diesel Driven Fire Pump engine), must meet the requirements of RICE MACT by meeting the requirements of NSPS IIII for compression ignition engines. No further requirements apply for such engines under this part. Therefore, the emergency use 400 hp Diesel Driven Fire Pump engine will demonstrate compliance with RICE MACT by demonstrating compliance with NSPS IIII.

For the 2 MW Diesel Emergency Generator Engine, pursuant to 40 CFR §63.6590(b)(1) and (b)(1)(i), LG&E does not have to meet the requirements of RICE MACT and of 40 CFR 63, Subpart A except for the initial notification requirements of 40 CFR §63.6645(f).

5.2.3 NESHAP Subpart YYYYY – Stationary Combustion Turbines (Applicable)

40 CFR 63 *Subpart YYYYY – National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines* (NESHAP YYYYY) establishes emissions and operating limitations for HAP from existing, reconstructed, or new stationary combustion turbines (herein referenced as the GT), located at major stationary sources of HAP. The Mill Creek Generating Station will continue to be classified as a major stationary source of HAP after the NGCC Project. The proposed GT and HRSG with NG-fired DBs (U23/E49) meets the definition of an affected source under NESHAP YYYYY and therefore will be subject to this regulation.⁵³ Note that the DBs and waste heat recovery units (even if part of a GT) are explicitly identified as not subject to this rule because they are considered steam generating units and, potentially, subject to other Part 63 standards.

NESHAP YYYYY requirements for GT are dependent on the type of combustion system used- lean premix or diffusion combustion system. A lean premix combustion system operates with a lower flame temperature compared to a diffusion combustion system, resulting in lower NO_x emissions. Each of the prospective vendors LG&E is currently evaluating that will provide the GT will use the DLN combustor technology. As a result, and the proposed GT is considered a lean premix natural gas-fired stationary combustion turbine as defined in 40 CFR §63.6175.

The GT will be subject to the following key requirements under NESHAP Subpart YYYYY. All applicable provisions under NESHAP YYYYY are documented on Form AP-100H in Appendix C.

⁵³ There was a stay for NESHAP Subpart YYYYY in 2004 on all requirements, except for an initial notification; however, this stay was lifted on March 9, 2022. <https://www.federalregister.gov/documents/2022/03/09/2022-04848/national-emission-standards-for-hazardous-air-pollutants-stationary-combustion-turbines-amendments>

- ▶ Per 40 CFR §§63.6095 and 63.6145, LG&E must submit an initial notification not later than 120 days after becoming subject to this subpart.
- ▶ Per 40 CFR §63.6100 and Table 1 of NESHAP YYYY, LG&E must limit the concentration of formaldehyde to 91 ppbv or less at 15% O₂, except during turbine startup.
- ▶ Per 40 CFR §63.6110, LG&E must conduct an initial performance test within 180 days after startup of the turbines for formaldehyde.
- ▶ Per 40 CFR §63.6115, LG&E must conduct annual performance tests.
- ▶ Per 40 CFR §63.6125, LG&E must monitor on a continuous basis the oxidation catalyst inlet temperature.
- ▶ Per 40 CFR §63.6135, LG&E must conduct all parametric monitoring at all times the GT is operating, except for monitor malfunctions, associated repairs, and required quality assurance or quality control activities.
- ▶ Per 40 CFR §63.6145, LG&E must submit an initial notification no later than 120 days after startup, a notification of intent prior to conducting the initial performance test, and a notification of compliance status for the formaldehyde emission limit.
- ▶ Per 40 CFR §63.6150, LG&E must submit a semiannual compliance report according to Table 6 of the subpart.
- ▶ Per 40 CFR §63.6155, LG&E must keep a copy of each notification, performance test, records of startup events, and records of deviations for 5 years, per 63.6160.

5.2.4 NESHAP Subpart UUUUU – Coal & Oil-Fired Electric Utility Steam Generating Units (Not Applicable)

40 CFR 63 Subpart UUUUU - *National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units* is referenced to in short as the Mercury and Air Toxics Standards (MATS) and, applies to electric utility steam generating units (EGUs) that combust coal or oil.⁵⁴ Pursuant to 40 CFR 63.9983(a), any unit designated as a major source stationary combustion turbine subject to NESHAP YYYY is not subject to MATS. Moreover, the proposed GT and HRSG with NG-fired DBs (U23/E49) does not have the capability of firing oil. As such, it is not an affected source for MATS and will not be subject to the MATS rule.

5.3 Compliance Assurance Monitoring (40 CFR 64)

The Compliance Assurance Monitoring (CAM) regulations apply to pollutant-specific emission units at a major source under the Title V operating permit program that satisfy the following criteria as detailed in 40 CFR §64.2(a):

- ▶ The unit is subject to an emission limitation or standard for the applicable regulated air pollutant (or a surrogate thereof), other than an emission limitation or standard that is exempt under §64.2(b);
- ▶ The unit uses a control device to achieve compliance with any such limitation or standard; and
- ▶ The unit has potential pre-control device emissions of the applicable regulated air pollutant that are equal to or greater than 100 percent of the amount, in tons per year, required for a source to be classified as a major source.

Title V permit applicants must prepare and submit a CAM Plan for subject units as part of Title V permit applications. The CAM Plans are intended to document the methods that will be followed to provide an on-going and reasonable assurance of compliance with emission limits. For a subject unit using a control device whose post-controlled emissions exceed the major source threshold (referred to as large pollutant-specific

⁵⁴ 40 CFR 63.9980

emission units [PSEU] in the rule), a CAM plan is required to be submitted with the initial Title V air operation permit application. For a subject unit whose post-control emissions are less than the major source threshold, a CAM plan does not have to be submitted until the first Title V air operation permit renewal application.

The proposed GT and HRSG with NG-fired DBs (U23/E49) will potentially be subject to CAM requirements as it operates a control train system for NO_x, CO, and formaldehyde. NO_x is limited to 15 ppmvd at 15% O₂ pursuant to 40 CFR §60.4320 & Table 1 of NSPS KKKK. To meet these limits, LG&E is requiring each prospective combustion turbine vendor to guarantee a maximum NO_x emission rate of no more than 2 ppmvd at 15% O₂. The pre-controlled and post-controlled potential to emit will be above 100 tpy. LG&E will install, operate, and maintain a NO_x CEMS to ensure continuous compliance. The unit meets the second two CAM applicability criteria; however, since the applicable NO_x emissions standard is from NSPS KKKK, a CAA Section 112 standard that was promulgated after November 15, 1990, the emission limit is exempt from CAM pursuant to 40 CFR §64.2(b)(1)(i). Therefore, NO_x from the GT and DB are not subject to CAM requirements.

The GT and HRSG with NG-fired DBs is not subject to an emission limitation or standard for CO (or a surrogate thereof) under any applicable regulation, nor is any synthetic limit on CO emissions expected or warranted as part of the NGCC Project permit action; therefore, CAM does not apply for CO.

Formaldehyde from the GT and HRSG with NG-fired DBs is limited to 91 ppmvd at 15% O₂ pursuant to 40 CFR §63.6100 and Table 1, Item 1, of NESHAP YYYY. LG&E is requiring each vendor to meet the same emissions limit as NESHAP YYYY. Although the post-controlled value will be lower than 10 tpy, the pre-controlled emissions are estimated to be above 10 tpy. Therefore, the unit meets the second two CAM applicability criteria. However, since the applicable formaldehyde emissions standard is from NESHAP YYYY, a CAA Section 112 standard that was promulgated after November 15, 1990, the emission limit is exempt from CAM pursuant to 40 CFR §64.2(b)(1)(i). Therefore, formaldehyde emissions from the GT are not subject to CAM requirements.

The proposed new Mechanical Draft Cooling Tower (IA5/IE24) will be equipped with inherent drift eliminators, which are not considered a control device. Further, regardless of this designation, the drift eliminators are not needed to meet any applicable PM emission standard and thus CAM is not applicable.

None of the other emission units associated with the NGCC Project are equipped with a control device and thus are implicitly not subject to CAM.

5.4 Risk Management Plans (40 CFR 68)

Subpart B of 40 CFR 68 (RMP Rule) outlines requirements for risk management prevention plans pursuant to Section 112(r) of the CAA. Applicability of the subpart is determined based on the type and quantity of chemicals stored at a facility. Mill Creek Generating Station stores anhydrous ammonia at levels that exceed the threshold quantity of 10,000 pounds and thus the RMP Rule currently applies. Anhydrous ammonia is currently supplied to the SCR for Units 3 and 4.

The facility is and will also continue to be subject to the General Duty Clause under the CAA Section 112(r)(1), which states:

The owners and operators of stationary sources producing, processing, handling or storing such substances [i.e., a chemical in 40 CFR part 68 or any other extremely hazardous substance] have a

general duty [in the same manner and to the same extent as the general duty clause in the Occupational Safety and Health Act (OSHA)] to identify hazards which may result from (such) releases using appropriate hazard assessment techniques, to design and maintain a safe facility taking such steps as are necessary to prevent releases, and to minimize the consequences of accidental releases which do occur.

The NGCC Project will use aqueous ammonia at a concentration of no more than 19%, which is not regulated under the RMP program. Thus, the installation of the NGCC Project will not affect the plant's current regulated status under the RMP Rule.

5.5 Stratospheric Ozone Protection Regulations (40 CFR 82)

The requirements originating from Title VI of the CAA, entitled *Protection of Stratospheric Ozone*, are contained in 40 CFR 82. Subparts A, B, and F of 40 CFR 82 are potentially applicable to the facility. In particular, 40 CFR 82 Subpart F, *Recycling and Emissions Reduction*, potentially applies if the facility operates, maintains, repairs, services, or disposes of appliances that utilize Class I, Class II, or non-exempt substitute refrigerants.⁵⁵ Subpart F generally requires persons completing the repairs, service, or disposal to be properly certified. It is expected that all repairs, service, and disposal of ozone depleting substances from such equipment (air conditioners, refrigerators, etc.) at the facility will be completed by a certified technician. LG&E will continue to comply with 40 CFR 82 Subpart F. The applicable provisions under 40 CFR 82 are already contained in the plant's existing Title V permit and the NGCC Project will not necessitate a change to these provisions.

5.6 Interstate Trading Programs

Starting with the Acid Rain Program mandated by the 1990 Clean Air Act Amendments, EPA has developed several market-based "cap and trade" regulatory programs. All market-based regulatory programs are overseen by EPA's Clean Air Markets Division (CAMD) and are referred to as CAMD regulations. The programs that are potentially applicable to LG&E are:

- ▶ Acid Rain Program (ARP) (1990 – ongoing)
- ▶ Clean Air Interstate Rule (CAIR) (2009 – 2014)
- ▶ Cross-State Air Pollution Rule (CSAPR) (2015 – ongoing)

5.6.1 Acid Rain Applicability

To reduce acid rain in the United States and Canada, Title IV (40 CFR 72 *et seq.*) of the CAA Amendments of 1990 established the ARP to substantially reduce SO₂ and NO_x emissions from electric utility plants. APCD incorporates the ARP by reference per Regulation 6.47. Affected units are specifically listed in Tables 1 and 2 of 40 CFR 73.10 under Phase I and Phase II of the program. Upon Phase III implementation, the ARP in general applies to fossil fuel-fired combustion sources that drive generators for the purposes of generating electricity for sale. The proposed combustion turbine will be a utility unit subject to the ARP. The facility is subject to the requirements of 40 CFR 72 (permits), 40 CFR 73 (SO₂), and 40 CFR 75 (monitoring) but the turbine will not be subject to the NO_x provisions (40 CFR 76) of the ARP regulations because the proposed turbine does not have the capability to burn coal. LG&E is required to apply for the required ARP permit at least two years prior to commencing operation of the proposed turbine.⁵⁶ Under 40 CFR 75 of the ARP,

⁵⁵ 40 CFR 82.150

⁵⁶ 40 CFR 72.30(b)(2)(ii); Regulation 6.47

LG&E is required to operate various CEMS for their coal-fired assets.⁵⁷ Further, the ARP requires the facility to possess SO₂ allowances for each ton of SO₂ emitted. The ARP also requires initial certification of the monitors within 90 days of commencement of commercial operation, quarterly reports, and an annual compliance certification.

5.6.2 Clean Air Interstate Rule/Cross-State Air Pollution Rule

The CAIR, 40 CFR 96, called for reductions in SO₂ and NO_x by utilizing an emissions trading program. More broadly, 40 CFR 96 also includes a forerunner to CAIR, the NO_x SIP Call / NO_x Budget program, and the name of 40 CFR 96 (NO_x Budget Trading Program for State Implementation Plans) still reflects the origins in regulating only NO_x.

A December 2008 court decision kept the requirements of CAIR in place temporarily but directed EPA to issue a new rule to implement CAA requirements concerning the transport of air pollution across state boundaries. On July 6, 2011, the U.S. EPA finalized the Cross-State Air Pollution Rule (CSAPR). On December 30, 2011, CSAPR was stayed prior to implementation. On April 29, 2014, the U.S. Supreme Court issued an opinion reversing an August 21, 2012, D.C. Circuit decision that had vacated CSAPR. Following the remand of the case to the D.C. Circuit, EPA requested that the court lift the CSAPR stay and toll the CSAPR compliance deadlines by three years. On October 23, 2014, the D.C. Circuit granted EPA's request. CSAPR Phase I implementation is now in place and replaces requirements under EPA's 2005 Clean Air Interstate Rule. Therefore, the CAIR section of the permit is irrelevant now that CSAPR has replaced CAIR. Upon reviewing the existing Title V permit for Mill Creek Generating Station, APCD already removed all CAIR requirements.

Units 1 through 4 are subject to the requirements for the CSAPR NO_x Annual Trading Program, CSAPR NO_x Ozone Season Trading Program, and CSAPR SO₂ Trading Program.

The current permit was issued after the 2016 CSAPR update that established CSAPR NO_x Ozone Season Group 2 Trading Program requirements in 40 CFR 97 Subpart EEEEE for a subset of CSAPR-affected states (including Kentucky). These requirements were incorporated into the Kentucky SIP in 401 KAR 51:250. Furthermore, US EPA finalized the Revised CSAPR Update on March 15, 2021, which is intended to resolve outstanding interstate pollution transport obligations for 21 states (including Kentucky) for the 2008 ozone NAAQS. The Revised CSAPR Update establishes CSAPR NO_x Ozone Season Group 3 Trading Program requirements in 40 CFR 97 Subpart GGGGG. Thus, the CSAPR NO_x Ozone Season Group 3 Trading Program requirements in 40 CFR 97 Subpart GGGGG are the current requirements regulating ozone season NO_x emissions at the Mill Creek Generating Station.

CSAPR applicability is similar but distinct from ARP, with applicability criteria and definitions per 40 CFR §97.402.⁵⁸ The CSAPR NO_x Ozone Season Group 3 Trading Program regulates stationary, fossil-fuel-fired boilers and *stationery, fossil-fuel-fired combustion turbines* serving, at any time, on or after January 1, 2005, a generator with a nameplate capacity exceeding 25 MWe and producing power for sale.⁵⁹

⁵⁷ While not subject to ARP NO_x provisions per Part 76, Part 75 monitoring requirements for NO_x apply as referenced by CSAPR.

⁵⁸ CSAPR applicability and definitions are repeated in four separate subparts of 40 CFR 97, but each has identical definitions and applicability requirements. Subpart AAAAA (5A), which is for the NO_x Annual program, is used in this discussion.

⁵⁹ 40 CFR §97.1004(a)(1) Applicability

LG&E’s proposed combustion turbine will be an affected source under this regulation, and must comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR §§ 97.1030 through 97.1035. LG&E is required to monitor emissions of SO₂, NO_x, and maintain sufficient allowances under CSAPR for its operations. Monitoring requirements for NO_x mass emissions and individual unit heat input, including all systems required to monitor NO_x emission rate, NO_x concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, typically tie back to ARP requirements per 40 CFR Part 75.⁶⁰

Regarding SO₂ emissions, Unit 5 GT/HRSG (U23/E49) will qualify as a fossil-fuel-fired *combustion turbine* as defined in 40 CFR §97.602 of the CSAPR SO₂ Group 1 Trading Program. As a CSAPR SO₂ Group 1 unit, LG&E is required to comply with the monitoring, recordkeeping, and reporting requirements 40 CFR 97 Subpart CCCC and Subparts F and G of Part 75.⁶¹ Pursuant to 40 CFR §75.11(d), LG&E can measure and record SO₂ emissions by one of three methods other than a SO₂ CEMS, which is the current method for the existing coal-fired boilers. LG&E is selecting the method shown in 40 CFR §75.11(d)(2) for the combustion turbine, where LG&E will provide other information satisfactory to the Administrator using the applicable procedures specified in Appendix D to 40 CFR Part 75. This appendix includes methods for default SO₂ emission rates (0.0006 lb/MMBtu), fuel flowmeters, gross calorific values, and calculated heat inputs to avoid the installation of SO₂ CEMS and flue gas flowrate monitoring.

To accommodate the NGCC Project, the Title V permit will need to be modified to include the following information in Table 5-1. These changes are reflected in the suggested permit provided in Appendix D.

Table 5-1. Edits to Attachment F Section I of Mill Creek Generating Station’s Title V Permit

| Unit ID: Unit 5, non-peaking natural gas-fired combustion turbine with natural gas-fired duct burners | | | | | |
|---|---|--|--|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, Subpart B (for SO ₂ monitoring) and 40 CFR part 75, Subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil- fired units pursuant to 40 CFR part 75, Appendix D | Excepted monitoring system requirements for gas- and oil- fired peaking units pursuant to 40 CFR part 75, Appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, Subpart E |
| SO ₂ | | X | | | |
| NO _x | X | | | | |
| Heat Input | | X | | | |

⁶⁰ 40 CFR §97.1029(a)(1) Requirements for installation, certification, and data accounting

⁶¹ 40 CFR §97.630 General monitoring, recordkeeping, and reporting requirements

5.7 APCD Air Regulations

In addition to federal air regulations, APCD establishes regulations applicable at the emission unit level (source specific) and at the facility level for stationary sources. The rules also contain requirements related to the need for construction and/or operating permits. The following sections discuss the APCD regulations of relevance for the NGCC Project permit action.

5.7.1 APCD Part 1 – General Provisions

5.7.1.1 Regulation 1.01 – General Provisions

This regulation describes the general application of District regulations and emission standards. LG&E will abide by all appropriate regulations and emission standards as determined by the APCD.

5.7.2 APCD Part 2 – Permit Requirements

5.7.2.1 Regulation 2.03 – Authorization to Construct or Operate

Apart from the exemptions established by Regulation 2.02, changes made pursuant to Section 5.8 of Regulation 2.16 (i.e., “Operational Flexibility”), and projects limited to the construction or reconstruction of air pollution control equipment, a facility must obtain a permit to authorize construction of an affected facility in accordance with Regulation 2.03. Applications for permits to construct must contain the elements identified by Section 4 of Regulation 2.03 and must be made on forms authorized by the APCD. This application report and its appendices, which include the required forms, constitutes the construction permit application required by Regulation 2.03 as well as the operating permit revision application required under Regulation 2.16 for the Mill Creek Generating Station.

5.7.2.2 Regulation 2.04 – Construction or Modification of Major Sources In or Impacting Upon Non-Attainment Areas (Emission Offset Requirements)

Regulation 2.04 is addressed in Section 4 of this application report.

5.7.2.3 Regulation 2.05 – Prevention of Significant Deterioration of Air Quality

Regulation 2.05 is addressed in Section 4 of this application report.

5.7.2.4 Regulation 2.16 – Title V Permits

Mill Creek Generating Station is a major Title V source and will continue to be a major source following completion of the proposed project. LG&E requests that the terms and conditions of the construction permit resulting from this application be incorporated into the facility’s Title V operating permit as a permit revision. Furthermore, following the completion of the project (including the decommissioning of the existing facility boilers), LG&E requests the terms and conditions associated with the operation of Units 1 and 2 (and supporting equipment) be removed from the facility’s Title V operating permit in conjunction with commercial operation of the NGCC Unit. LG&E will notify the APCD when the existing operations associated with the NGCC Project are taken out of service.

5.7.3 APCD Part 5 – Standards for Toxic Air Contaminants and Hazardous Air Pollutants

5.7.3.1 Regulation 5.01 – General Provisions

This regulation applies to the owner or operator of any process equipment that emits or may emit a toxic air contaminant or hazardous air pollutant or for which a toxic air contaminant or hazardous air pollutant emission standard or other requirement is prescribed in a Part 5 regulation. A new or modified process or process equipment shall comply with all applicable emission standards upon commencing operation. LG&E will comply with all appropriate Part 5 regulations upon commencing startup of the new NGCC Unit operations.

5.7.3.2 Regulation 5.02 – Adoption of NESHAP

This regulation adopts particular NESHAP regulations that are listed in 40 CFR Parts 61 and 63. LG&E will comply with this District regulation by meeting the requirements of all NESHAP regulations that were discussed in Section 5.2 of this application.

5.7.3.3 Regulation 5.21 – Environmental Acceptability of Toxic Air Contaminants

The purpose of this regulation is to establish the criteria for determining the environmental acceptability of emissions of toxic air contaminants. This regulation sets the appropriate levels of risk that can be associated with toxic air contaminants at a new or modified process/facility. The APCD has developed the Strategic Toxic Air Reduction (STAR) Program to help reduce the levels of harmful contaminants in ambient air. LG&E has performed a full-scale STAR dispersion modeling analysis in order to demonstrate compliance with Regulation 5.21 and the STAR program. The analysis is presented in Section 5.8 of this application.

5.7.4 APCD Part 6 – Standards of Performance for Existing Affected Facilities

Per Regulation 6.01, Section 1 Applicability, unless specifically exempted in Regulation 2.03, Regulation 6 applies to any affected facility not permitted under Regulation 7, Standards of Performance for New Affected Facilities. Moreover, all affected facilities under this regulation must have permits issued pursuant to Regulation 2.

5.7.4.1 Regulation 6.42 - Reasonably Available Control Technology Requirements for Major VOC- and NO_x-Emitting Facilities

This regulation establishes the requirements for Reasonably Available Control Technology (RACT) determination, demonstration, and compliance for VOC and NO_x emitting facilities for new or renewed operating permits.

Pursuant to Section 1.2, NO_x emissions from all NO_x -emitting facilities located at all major NO_x-emitting sources except for those NO_x-emitting facilities that have been or would be subject to NO_x review pursuant to 40 CFR Section 52.21 and Regulation 2.05 PSD after November 15, 1990, or to review under 40 CFR Part 51 Appendix S and Regulation 2.04 NA-NSR Review after November 15, 1992. As shown above in Section 4 of this application, the Mill Creek Generating Station is a major NO_x-emitting facility and the NGCC Project is not subject to full PSD or NA-NSR review.

Pursuant to Section 1.3.2, facilities that are used for emergency purposes only are exempt from the requirements to establish RACT requirements. Thus, a RACT determination for the emergency generator engine, fire pump engine, and their dedicated diesel fuel tanks is not required.

Pursuant to Section 4.3.1, each applicant for a *revised* operating permit shall be required to propose RACT emission-limiting standards and RACT emission control technology to be imposed by the revised operating permit, taking into account the recommendations set forth in any applicable Control Techniques Guidelines (CTG), Alternative Control Techniques (ACT) Document, or other EPA guidance for the facility. The operating permit application shall include a schedule for implementing the recommended RACT measures as expeditiously as practicable.

5.7.4.1.1 Proposed NO_x RACT for Unit 5 GT/HRSG

As described in Section 5.1.7 of this application, LG&E is requiring each vendor to meet a NO_x limit of 15 ppm at 15% O₂ to ensure continuous compliance with NSPS KKKK. This limit is proposed to be the RACT emission-limiting standard and represents the emission level that satisfies RACT requirements. Moreover, as documented in Section 2.3.1.1, all vendors being considered will utilize dry-low-NO_x combustors in the GT and LNBS in the HRSG. LG&E will install and operate oxidation catalysts and SCR as add-on controls to reduce stack NO_x, CO, HC, and organic HAP emissions. Operation of an SCR to ensure compliance with the proposed NO_x RACT limit, is a reasonable and available control technology for this type of base-load NGCC Unit that is subject to NSPS KKKK.

As represented throughout this application, LG&E is committed to meeting the NO_x RACT limit by installing and operating an SCR upon startup of commercial operation at the Mill Creek Generating Station. LG&E will demonstrate continuous compliance with this limit on a 30-unit operating day rolling average basis using data collected by the NO_x CEMS, as discussed in Section 5.1.7.

Pursuant to 40 CFR §60.4333(a), the combustion turbine, air pollution control equipment, and monitoring equipment will be maintained in a manner that is consistent with good air pollution control practices for minimizing emissions. This requirement applies at all times including during startup, shutdown, and malfunction.

Initial compliance with the NO_x emission limit will be demonstrated by comparing the arithmetic average of the NO_x emissions measurements taken during the initial RATA required pursuant to 40 CFR §60.4405 to the NO_x emission limit under NSPS KKKK.

No further requirements are necessary outside of NSPS KKKK to be added to the revised permit to amend the NO_x RACT Plan. Please see similar references to NSPS KKKK that were added to Cane Run's Title V Permit No. O-0126-20-V, effective May 5, 2020, for U15 (Natural Gas-fired Combined Cycle Unit [EGU7]).

5.7.4.1.2 Proposed NO_x RACT Auxiliary Boiler and Fuel Gas (Dewpoint) Heater

As described in Section 2.3.2 above and in Section 6.3 of Appendix B, LG&E is requiring the vendor of the new 99.9 MMBtu/hr Auxiliary Boiler to equip the unit with LNBS and FGR to meet a 30 ppmv at 3% O₂ NO_x limit. The same specification requirement is being applied for the new Fuel Gas (Dewpoint) Heater. This translates into an NO_x emissions factor of 38.56 lb/MMscf or 0.0364 lb/MMBtu.

In March 1994, EPA published "Alternative Control Techniques Document – NO_x Emissions from Industrial/Commercial/Institutional (ICI) Boilers" (EPA-453/R-94-022).⁶² Table 6-7 of this document summarizes EPA's NO_x control cost effectiveness determinations for natural gas-fired boilers, including various control technology options for a slightly larger-sized gas-fired packaged watertube boiler. Each

⁶² https://www3.epa.gov/airquality/ctg_act/199403_nox_epa453_r-94-022_ici_boilers.pdf

option is presented with its corresponding controlled NO_x level: water injection and oxygen trim (0.06 lb/MMBtu for 150 MMBtu/hr unit; 0.08 lb/MMBtu for 250 MMBtu/hr unit), low NO_x burners (0.09 lb/MMBtu for 150 MMBtu/hr unit; 0.12 lb/MMBtu for 250 MMBtu/hr unit), low NO_x burners and FGR (0.07 lb/MMBtu for 150 MMBtu/hr unit; 0.10 lb/MMBtu for 250 MMBtu/hr unit), and SCR (0.03 lb/MMBtu for 150 MMBtu/hr unit; 0.04 lb/MMBtu for 250 MMBtu/hr unit). With the exception of the SCR-controlled unit rated at 150 MMBtu/hr, LG&E's proposed vendor specification for the new boilers – a NO_x exhaust concentration of 30 ppmv @ 3% O₂ (0.04 lb/MMBtu) – meets the performance of the best-controlled 150 MMBtu/hr and 250 MMBtu/hr gas-fired packaged watertube boiler represented by Table 6-7 of EPA's ACT document.

According to a separate EPA document published on July 30, 1993 and entitled "Fuel Switching to Meet the Reasonably Available Control Technology Requirements for Nitrogen Oxides", typical NO_x controls associated with RACT determinations "have involved modifications to combustion equipment, such as installation of low NO_x burners." Moreover, the EPA policy established by the 1993 document "allows States to adopt rules that permit utilities to control NO_x emissions by switching to cleaner fuels during the summertime ozone season." Even though LG&E's Mill Creek Generating Station is regulated as a utility, the proposed Auxiliary Boiler and Fuel Gas (Dewpoint) Heater are not affected units under the CSAPR NO_x Annual Trading Program or CSAPR NO_x Ozone Season Trading Program. Even so, these boilers will be equipped with LNBs/FGRs, which will reduce NO_x as an ozone precursor over the entire year, and especially during the ozone season.

To satisfy RACT requirements for NO_x emissions under Regulation 6.42, LG&E proposes a limit of 0.04 lb/MMBtu for the Auxiliary Boiler and Fuel Gas (Dewpoint) Heater. Compliance with this limit will be achieved by using natural gas, implementing LNBs and potentially FGR systems, and following manufacturer's recommended procedures regarding the operation and maintenance of each unit. LG&E will demonstrate compliance with this limit by tracking the fuel usage on a monthly basis.

Please see similar requirements that were added to Cane Run's Title V Permit No. O-0126-20-V, effective May 5, 2020, for U16 (Natural Gas-fired Auxiliary Boiler) and U17 (fuel gas dew point heater).

5.7.4.1.3 Proposed VOC RACT for Unit 5 GT/HRSG

As described in Section 3.1.1.1 of this application, LG&E is requiring each vendor to meet a VOC limit of 1 to 2 ppm at 15% O₂. Moreover, as described in Section 5.2.3 of this application, pursuant to 40 CFR §63.6100 and Table 1 of NESHAP YYYY, LG&E must limit the concentration of formaldehyde, which is a VOC, to 91 ppbvd or less at 15% O₂, except during turbine startup.

To ensure continuous compliance with NESHAP YYYY and LG&E's vendor requirement, the NGCC Unit proposed for this site includes an oxidation catalyst system as an add-on control device. NSPS KKKK requires an annual performance test for formaldehyde and continuous monitoring of the oxidation catalyst inlet temperature.

Upon reviewing the available SIP Board Orders published on APCD's website, the most recent proposed VOC RACT, as applicable for a combustion system, required the implementation of good combustion and operating practices to include design considerations, such as, 1) Selection of efficient burners; 2) Implementation of combustion controls to optimize efficiency; and 3) Use of insulation media to minimize heat losses.⁶³ That particular Board Order called, *American Synthetic Rubber Company / NO_x RACT*,

⁶³ <https://louisvilleky.gov/air-pollution-control-district/document/20211117-amended-agreed-board-order-asrc-ract-am2>

Amendment 2, dated November 17, 2021, also includes references to tune-up requirements of 40 CFR §63.7540(a)(10) on an annual basis and includes a list of annual preventative maintenance steps.

LG&E is requesting that APCD consider including a similar VOC RACT requirement to implement good combustion and operating practices, as well as a reference to operating limitations, monitoring, and recordkeeping already contained within the NESHAP YYYY.

5.7.4.1.4 Proposed VOC RACT Auxiliary Boiler and Fuel Gas (Dewpoint) Heater

LG&E did not specify any requirement for limiting the VOC emissions from the Auxiliary Boiler or Fuel Gas (Dewpoint) Heater beyond the level specified in published AP-42 emissions factors.

LG&E requests that APCD consider the same applicable VOC RACT (good combustion and operating practices) from the SIP Board Order called, *American Synthetic Rubber Company / NOx RACT, Amendment 2*, dated November 17, 2021, be applied to the Auxiliary Boiler or Fuel Gas (Dewpoint) Heater.

5.7.5 APCD Part 7 – Standards of Performance for New Affected Facilities

5.7.5.1 *Regulation 7.01 – General Provisions*

This regulation establishes general requirements for any affected facility the construction, modification, or reconstruction of which is commenced on or after the effective date of an applicable standard of performance in Regulation 7. The NGCC Project will be comprised of newly constructed equipment. As such, this equipment will meet all applicable requirements set forth in Regulation 7.

5.7.5.2 *Regulation 7.02 – Adoption of Federal NSPS*

This regulation adopts particular NSPS regulations that are listed in 40 CFR Part 60. LG&E will comply with this District regulation by meeting the requirements of all NSPS regulations that were discussed in Section 5.1 of this application.

5.7.5.3 *Regulation 7.06 – New Indirect Heat Exchangers*

This regulation establishes requirements for new indirect heat exchangers. Both the auxiliary boiler and the fuel gas (dewpoint) heater will be subject to the requirements of this regulation.

Regulation 7.06 applies to indirect heat exchangers, meaning equipment used for the combustion of fuel in which energy is transferred through a medium that does not contact the products of combustion, with individual heat input capacities of more than 1 MMBtu/hr that are constructed, modified or reconstructed after August 17, 1971. LG&E's proposed Auxiliary Boiler and Fuel Gas (Dewpoint) Heater meet each of these criteria; therefore, PM and SO₂ emission standards established by Sections 4 and 5 of Regulation 7.06, respectively, will apply to the new units.

Section 4 of Regulation 7.06 establishes opacity standards and heat input-based PM emission limits. The applicable PM emission limit is determined based on the total heat input capacity for all the affected facilities at the source at the time of construction of the new units. A different heat input-based PM allowable emission rate applies depending on whether the total heat input capacity for the facility is less than 10 MMBtu/hr, between 10 MMBtu/hr and 250 MMBtu/hr, or above 250 MMBtu/hr. For sources with a total heat input capacity greater than 250 MMBtu/hr such as the Mill Creek Generating Station, Section 4.1.2 of Regulation 7.06 establishes a PM emissions limit of 0.10 lb/MMBtu actual heat input.

Section 4.2 establishes a 20% opacity limit with certain exceptions. The proposed Auxiliary Boiler and Fuel Gas (Dewpoint) Heater will be subject to these limits. The potential PM emission factor from combusting natural gas in the new heat exchangers is orders of magnitude lower than the allowable PM emission rate, so LG&E will be implicitly in compliance with these emission limits when burning natural gas.

Section 5 of Regulation 7.06 establishes SO₂ emissions standards. Specifically, for the combustion of gaseous fuels in sources with a total heat input capacity greater than 250 MMBtu/hr, Section 5.1.2 establishes an SO₂ limit of 0.8 lb/MMBtu actual heat input. Again, the potential SO₂ emission factor from combusting natural gas in the Mill Creek Generating Station's Regulation 7.06 affected units is orders of magnitude lower than the allowable SO₂ emission rate, so LG&E will be implicitly in compliance with these emission limits when burning natural gas.

5.7.5.4 Regulation 7.08 – New Process Operations

This regulation establishes emissions limitations from new process operations, unless those emissions are otherwise regulated under another part of Regulation 7. PM emissions from the cooling tower will be regulated under this generally applicable regulation.

5.7.5.5 Regulation 7.09 – New Process Gas Streams

This regulation establishes emissions limitations for hydrogen sulfide, SO₂, and CO from new process gas streams (defined as gas stream emitted from any process), unless those emissions are otherwise regulated under another part of Regulation 7.

The SO₂ standard under Regulation 7.09 (28.63 grains/100 dscf) is less stringent than the standard under NSPS KKKK (0.06 lb/MMBtu). According to Regulation 7.02, Section 5, the combustion turbines are not subject to the SO₂ standard under Regulation 7.09. Also, the combustion process in the turbines is greater than 1,300°F for 0.5 second. Therefore, there is no monitoring, record keeping, and reporting requirements with respect to the CO standard under Regulation 7.09. The combustion turbine is not a quantifiable source of hydrogen sulfide emissions.

5.7.5.6 Regulation 7.12 – Standards of Performance for New Storage Vessels for VOC

Regulation 7.12 contains provisions to limit VOC emissions from storage tanks. The diesel storage tanks associated with the emergency generator and fire pump engines are affected facilities for Regulation 7.12; however, because the true vapor pressure of the VOCs that will be stored are not equal to or greater than 1.5 psia, there are no applicable emissions limits or operational restrictions.

5.7.5.7 Regulation 7.25 – Standards of Performance for New Sources Using Volatile Organic Compounds

Regulation 7.25 applies to each affected facility not elsewhere regulated in Regulation 7 for VOCs. An affected facility must use VOCs and have a VOC PTE of greater than 5 tpy. The combustion turbine lube oil system does use VOCs, however, VOC emissions from the lube oil demister vents are less than 5 tpy. Thus, the requirement to implement best available control technologies (BACT) does not apply under this regulation.

5.8 STAR Program

The proposed project will be subject to the Louisville STAR requirements (Regulation 5.01) for all regulated toxic air contaminants (TAC) that will be emitted at Mill Creek Generating Station. As demonstrated herein,

the proposed NGCC Project, in conjunction with the existing emission units, will comply with all STAR requirements for all TAC emitted at the facility following the completion of the proposed project.

5.8.1.1 De Minimis Source Documentations

To determine which emissions units will need to be evaluated under the requirements of the STAR program, it is important to determine which emission units meet the *de minimis* source criteria identified in APCD Regulation 5.21, Section 2 and thus will be exempt from further action under the STAR program.

The existing units with the potential to emit toxic air contaminants above *de minimis* levels that will remain at the facility include two coal-fired boilers (EGU Unit 3 [U3] and EGU Unit 4 [U4]), fly-ash storage and handling equipment, and the landfill operations. As documented in the existing Title V permit (O-0127-20-V), a STAR Environmental Acceptability (EA) Demonstration including each of these existing emission units was most recently approved by APCD on January 21, 2016. The remaining existing emission units qualify for *de minimis* exemption from STAR requirements.

Section 3 of this application report provides a full list of emission generating units that will be installed as part of the NGCC Project. From this list, the cooling tower and the lube oil system will not have quantifiable emissions of toxic air pollutants and will not be considered as part of this analysis. Emissions from all natural-gas fired combustion equipment, pursuant to Regulation 5.21 Section 2.7, are considered *de minimis*; therefore, all natural-gas fired combustion equipment will be exempt from the requirements of the STAR program. Regulation 5.11 Section 2.3 declares that items that are listed as insignificant activities in Title V permits also meet the *de minimis* source criteria. LG&E expects that the diesel storage tanks and fire pump engine will be listed as insignificant activities and will thus meet the *de minimis* source criteria.

The only new emission generating unit remaining that is part of the NGCC Project that will be subject to the requirements of the STAR program will be the diesel-fired emergency generator engine (unless APCD determines that this unit is an insignificant activity as defined in Regulation 2.16). Full documentation of a pollutant-by-pollutant *de minimis* determination is included in the following paragraph, based upon an operating restriction of 500 hours per year.

APCD Regulation 5.21 Section 2 states that emissions from a process are *de minimis* if the allowed emissions of a TAC from the process or process equipment are equal to or less than *de minimis* values calculated using the Benchmark Ambient Concentration (BAC) for the TAC. Annual emissions from the proposed diesel generator are shown in Table 5-2 and are further detailed in Section 9 of Appendix B. The corresponding BAC-based *de minimis* emission levels for each TAC are also included in Table 5-2. As shown in this table, all TACs with the exception of diesel particulate have annual emissions below the individual process *de minimis* emission rates. Therefore, TAC emissions (with the exception of diesel particulate) from the emergency generator are below *de minimis* thresholds.

5.8.1.2 Tier 4 Methodology

The methodology and findings of a Tier 4 modeling analysis conducted are presented in this section. This analysis demonstrates LG&E's compliance with the STAR program BAC standards for diesel particulate.

5.8.1.2.1 Dispersion Model

For this modeling analysis, the U.S. EPA's AMS/EPA Regulatory Model (AERMOD) (v22112) was selected to determine maximum off-property concentrations. AERMOD is a refined dispersion model that is widely used and accepted in the air quality community for this type of modeling application and has been approved for use in STAR Tier 4 modeling by APCD.

5.8.1.2.2 Emissions Source Data

Diesel particulate emissions from the emergency generator were the only emissions that were modeled as part of this Tier 4 methodology analysis. Table 5-3, below, summarizes the diesel particulate emission rate and stack parameters for the emergency generator stack. The modeled emission rate for diesel particulate emissions (lb/yr) is based on the maximum annual particulate emissions as calculated (as documented in Section 9 of Appendix B), which are based on manufacturer emissions data for a similar engine.

Table 5-2. Generator TAC Potential Emissions and De Minimis Thresholds

| Pollutant | CAS # | HAP? | TAC? | Emission Factor (lb/Mgal) | Uncontrolled Emissions (lb/yr) | De Minimis Threshold (lb/yr) | Below De Minimis ? |
|---------------------------|--------------|-------------|-------------|----------------------------------|---------------------------------------|-------------------------------------|---------------------------|
| Acetaldehyde | 75-07-0 | Y | Y | 3.45E-03 | 0.237 | 216.00 | Y |
| Acrolein | 107-02-8 | Y | Y | 1.08E-03 | 0.074 | 9.60 | Y |
| Benzene | 71-43-2 | Y | Y | 1.06E-01 | 7.284 | 216.00 | Y |
| Formaldehyde | 50-00-0 | Y | Y | 1.08E-02 | 0.741 | 36.96 | Y |
| Naphthalene | 91-20-3 | Y | Y | 1.78E-02 | 1.220 | 13.92 | Y |
| PAH | -- | Y | | 2.91E-02 | 1.990 | | |
| Toluene | 108-88-3 | Y | Y | 3.85E-02 | 2.638 | 2,400,000 | Y |
| Xylenes | 1330-20-7 | Y | Y | 2.64E-02 | 1.812 | 48,000 | Y |
| Acenaphthylene | 208-96-8 | Y | N | 1.26E-03 | 0.087 | -- | -- |
| Acenaphthene | 83-32-9 | Y | N | 6.41E-04 | 0.044 | -- | -- |
| Fluorene | 86-73-7 | Y | N | 1.75E-03 | 0.120 | -- | -- |
| Phenanthrene | 85-01-8 | Y | N | 5.59E-03 | 0.383 | -- | -- |
| Anthracene | 120-12-7 | Y | N | 1.69E-04 | 0.012 | -- | -- |
| Fluoranthene | 206-44-0 | Y | N | 5.52E-04 | 0.038 | -- | -- |
| Pyrene | 129-00-0 | Y | N | 5.08E-04 | 0.035 | -- | -- |
| Benzo(a)anthracene | 56-55-3 | Y | Y | 8.52E-05 | 0.006 | 4.37 | Y |
| Chrysene | 218-01-9 | Y | Y | 2.10E-04 | 0.014 | 43.68 | Y |
| Benzo(b)fluoranthene | 205-99-2 | Y | Y | 1.52E-04 | 0.010 | 4.37 | Y |
| Benzo(k)fluoranthene | 207-08-9 | Y | Y | 2.99E-05 | 0.002 | 4.37 | Y |
| Benzo(a)pyrene | 50-32-8 | Y | Y | 6.16E-04 | 0.042 | 0.44 | Y |
| Indeno (1,2,3-cd)pyrene | 193-39-5 | Y | Y | 5.67E-05 | 0.004 | 4.37 | Y |
| Dibenz(a,h)anthracene | 53-70-3 | Y | Y | 4.74E-05 | 0.003 | 0.40 | Y |
| Benzo(g,h,i)perylene | 191-24-2 | Y | N | 7.62E-05 | 0.005 | -- | -- |
| Diesel particulate matter | -- | N | Y | 1.73E+00 | 118.258 | 1.58 | N |

Table 5-3. Generator Engine Stack Parameters

| Model ID | Description | DPM Annual Emission Rate (lb/yr) | Stack Height (ft) | Stack Temperature (°F) | Exit Velocity (ft/s) | Diameter (ft) |
|-----------------|----------------------------|---|--------------------------|-------------------------------|-----------------------------|----------------------|
| EGENGINE | Emergency Generator Engine | 118.258 | 16.00 | 900 | 152.79 | 1.50 |

5.8.1.2.3 Building Downwash

The U.S. EPA's Building Profile Input Program (BPIP) (04274) was utilized to determine building downwash parameters for the modeling analysis. Table 5-4 below contains a summary of the heights of each of the tanks and buildings that will be located at the Mill Creek Generating Station. These tanks and buildings are structures that could potentially result in plume downwash from the generator engine stack.

Table 5-4. Building Heights

| Model ID | Description | Building Height (ft) |
|-----------------|--|-----------------------------|
| STEAMBLD | Steam Turbine Building | 85.0 |
| FIREWATR | Fire Water Tank | 54.0 |
| DEMINTNK | Demin Water Storage Tank | 45.0 |
| WASTTANK | Wastewater Tank | 27.0 |
| COOLTWER | Cooling Tower | 55.0 |
| ADMIN | Administration Building | 15.0 |
| GASCOMP | Gas Compressor Building | 33.0 |
| STARTENC | Start Enclosure | 16.0 |
| BATTENC | Battery Enclosure | 16.0 |
| CTS01-08 | Cooling Tower Cell #1-#8 Stack | 55.0 |
| CHEMBLDG | Circulating Water Chemical Feed Building | 15.0 |
| AUXBLDG | Auxiliary Boiler Building | 36.0 |
| FEEDPUMP | Boiler Feed Pump Electrical Building | 18.0 |
| NITROTNK | Nitrogen Storage Tank | 10.0 |
| WWPUMP | Wastewater Pump Skid | 12.0 |
| PDCBLDG | PDC Building | 16.0 |
| PEEC | Single Shaft PEEC | 16.0 |
| TURBPENT | Turbine Building Penthouse | 145.0 |
| TURBANC | Ancillary Turbine Structure | 48.2 |
| EMERGENC | Emergency Generator Enclosure | 15.0 |
| SAMPPAN | Sample Panel | 12.0 |
| CYCLE | Cycle Chemical Feed | 16.0 |
| GASTURBF | Gas Turbine Inlet Filter | 55.0 |
| CIRCPUMP | Circ Water Pumps | 12.0 |
| GASYARD | Gas Yard | 15.0 |
| GSUTRANS | GSU Transformer | 45.0 |
| AMMCONT | Ammonia Flow Control | 10.0 |
| DUCTSKID | Duct Burner Skid | 12.0 |
| RECIRCP | HRSG Recirculation Pump Enclosure | 12.0 |
| CEMSSH | CEMS Shelter | 12.0 |
| UNITAUX | Unit Auxiliary Transformers | 15.0 |
| PUMPHS | Pump Enclosure | 12.0 |
| AMMOUNLO | Ammonia Unloading/Storage/Forwarding | 20.0 |
| CO2TANK | CO2 Storage Tank | 10.0 |
| SPAREGSU | Spare GSU Transformer | 35.0 |

5.8.1.2.4 Receptor Grids and Terrain

Multiple modeling grids were used in order to provide a detailed mapping of ground-level, off-property concentrations in areas immediately surrounding the Mill Creek Generating Station property. The first grid extends from the facility center out to 3 km and includes receptors at 100 m spacing. The second grid is from 3 km out to 5 km and includes receptors at 250 m spacing. The fourth grid is from 5 km out to 10 km and includes receptors at 500 m spacing. The fifth grid is from 10 km out to 20 km and includes receptors

at 1,000 m spacing. The final grid is from 20 km to 50 km and includes receptors at 2,000 m spacing. Additionally, receptors were placed along the property line of the facility at a 50-meter density.

Since terrain elevations are of interest in this project due to the facility’s location near the Ohio River, digital elevation data for the Louisville area were obtained from the USGS and imported into the modeling runs for each receptor location. Stack and building elevations were based on an estimated facility-grade level for the NGCC Unit.

5.8.1.2.5 Meteorological Data

The five most recent years of valid meteorological data available from APCD from the nearest representative National Weather Service (NWS) stations are utilized in the analysis. 2015-2019 surface data from the NWS station at the Louisville International Airport-Standiford Field in Louisville, Kentucky (NWS Station No. 93821) are combined with corresponding years of atmospheric sounding data from Wilmington, Ohio (NWS Station No. 13841) in order to generate the model-ready meteorological data files. These meteorological data files were obtained from the APCD website.⁶⁴

5.8.1.2.6 Modeling Results

Table 5-5 summarizes the results of the LG&E Tier 4 STAR modeling analysis for all public receptors. The maximum ground-level, off-property public receptor concentration for emissions of diesel particulate (in micrograms per cubic meter [$\mu\text{g}/\text{m}^3$]) associated with emergency generator operation is listed for an average of the five modeled years. These values are divided by the BAC for diesel particulate ($0.0033 \mu\text{g}/\text{m}^3$) to calculate the carcinogenic risk (R_c) associated with the emergency generator emissions. This value is less than 1.0, which is the environmental acceptability goal (EAG) for individual processes as defined in APCD Regulation 5.21 Section 3.1.

Additionally, diesel particulate has a noncarcinogenic benchmark ambient concentration (BAC_{NC}) of $5.00 \mu\text{g}/\text{m}^3$ with an annual averaging period. Given the BAC_c is much more stringent than the BAC_{NC} , compliance with the carcinogenic value also indicates compliance with the noncarcinogenic value and as such the BAC_{NC} was not evaluated against in this modeling analysis.

Table 5-5. Tier 4 STAR Modeling Results

| Model ID | Averaging Period | BAC _c Diesel Particulate ($\mu\text{g}/\text{m}^3$) | Maximum Impact ($\mu\text{g}/\text{m}^3$) | UTM East ² (m) | UTM North ² (m) | R _c |
|----------|---------------------|---|---|---------------------------------|----------------------------------|----------------|
| EGENGINE | Period ¹ | 0.0033 | 0.00244 | 596,364 | 4,212,024 | 0.74 |

¹ Evaluated maximum modeled arithmetic mean of the five year modeling period for comparison against the Carcinogenic Benchmark Ambient Concentration (BAC_c).

² UTM coordinates are in NAD83 Zone 16.

⁶⁴ Meteorological Data for Dispersion Modeling, <https://louisvilleky.gov/government/air-pollution-control-district/meteorological-data-dispersion-modeling>

As indicated in the current Title V permit (O-0127-20-V), the January 21, 2016 EA Demonstration was based on SCREEN3 dispersion modeling. To determine the facility-wide cumulative risk, the "worst-case" modeled impact for each source was determined using the SCREEN3 dispersion model and then these impacts were added together. SCREEN3 determined the "worst-case" impact irrespective of receptor direction from the modeled sources.

To demonstrate compliance with the facility-wide cumulative carcinogenic risk goals (shown in Table 5-6), the facility-wide R_c from the January 2016 EA demonstration was added to the R_c calculated for the proposed generator engine. This approach is conservative because the maximum modeled impact location for the emergency generator engine is unlikely to occur at the same receptor location as all of the previously modeled sources. As shown in in Table 5-6, the calculated post-project carcinogenic risk from all process/process equipment (P/PE) will meet all applicable EA goals.

Table 5-6. Facility-wide Cumulative Risk Analysis


| Process Equipment | Applicable TACs | EAG_c Risk | Existing Facility¹ R_c | NGCC Project R_c | Total Applicable R_c | Below EAG_c? |
|---------------------------|------------------------|-----------------------------|--|-----------------------------------|---------------------------------------|-------------------------------|
| Individual P/PE | DPM | 1.0 | -- | 0.74 | 0.74 | Yes |
| All P/PE | All TACs | 7.5 | 4.16 | 0.74 | 4.90 | Yes |
| All New and Modified P/PE | All TACs | 3.8 | -- | 0.74 | 0.74 | Yes |






¹ Facility-wide carcinogenic risk (4.16) was taken from most recent STAR EA demonstration submitted to APCD January 21, 2016 as documented in the current Title V permit (O-0127-20-V). This risk value conservatively includes risk associated with EGU Unit 1 (U-1) and EGU Unit 2 (U-2), which will be shutdown as part of the NGCC project.

All dispersion modeling files will be provided to APCD in electronic format in conjunction with the submittal of this permit application. Model and processor input, output, and data files will also be provided. Spreadsheets tabulating source parameters, emissions, and other input data sets can also be provided upon request.


APPENDIX A. MAPS AND PROCESS FLOW DIAGRAMS

- ▶ Figure A-1 Area Map of Mill Creek Generating Station
- ▶ Figure A-2 Aerial Map of Mill Creek Generating Station Showing Arrangement of Existing Operations
- ▶ Figure A-3 Site Arrangement Drawing of New NGCC Unit Equipment (Aerial Map Overlay)
- ▶ Figure A-4 Site Arrangement Drawing of New NGCC Unit Equipment
- ▶ Figure A-5 Site Arrangement Drawing of New NGCC Unit Structures and Equipment
- ▶ Figure A-6 NGCC Project Equipment Process Flow Diagram



| | | | | |
|--|--|---|--|---|
|  <p>LGE KU PPL companies</p> | | <p>Figure A-1. Area Map for Mill Creek Generating Station in Louisville, KY</p> | |  |
| <p>LG&E-KU Louisville, KY</p> | | <p>CRS: UTM Zone 16 / NAD83 Datum</p> | | |
| <p>Scale: 0 2 4 km</p>  | | <p>Legend Facility</p>  | | |
| <p>Project No: 221801.0123</p> | | <p> 1717 Dixie Highway, Ste. 900 Covington, KY 41011</p> | | |


| Revisions | |
|-----------|------------------------------------|
| A | Project: 10358480 INITIAL ISSUE |
| Drawn: | EDC 12/06/2022 |
| Checked: | MAW 12/06/2022 |
| Appd.: | |



SITE PLAN
SCALE: 1" = 300'-0"

Figure A-3 Site Arrangement Drawing of New NGCC Unit Operations (Aerial Map Overlay)

NOT TO BE USED FOR CONSTRUCTION



| | | |
|---|---------------------------------------|--------------------------|
| Location and Title: MILL CREEK | LG& KU Generation Services | Drawn: ZAP |
| Scale: 1" = 300'-0" | Contract No. PPL companies | Checked: MAW |
| Engineering discipline: CIVIL | Drawing type: PLAN | Approved: - |
| Title: COMBINED CYCLE GENERATION PROGRAM MILL CREEK UNIT 5 SITE PLAN | | Released for: REVIEW |
| Originator: HDR ENGINEERING, INC | Job or Project No. 10358480 | Drawing No. 5GA-C1000 |
| | | Rev. No. A |


C:\pwworking\hadr\10358480\10358480-5GA-C1000.dwg Plot: 12/8/2022 10:36:07 AM ECHURCH

Revisions

| | | |
|---|-------------------|-------------|
| A | Project: | 10343340 |
| | ISSUED FOR REPORT | 07 OCT 2022 |
| | Dwn: | SDK |
| | Chkd: | |
| | Appd: | |




Figure A-4 Site Arrangement Drawing of New NGCC Unit Operations




SITE PLAN
 SCALE: 1" = 300'-0"
 300 0 300 600 900

NOT TO BE USED FOR CONSTRUCTION



| | | | | | |
|--|----------------------|---------------------------|-------------------|---------------------|---------------|
| Location and Title: MILL CREEK | Scale: None | Contract No.: | LG& KU | Generation Services | Drawn: AAK |
| Engineering discipline: CIVIL | Discipline: CIVIL | Company: PPL companies | | | Checked: |
| MILL CREEK SITE ARRANGEMENT SINGLE UNIT BUILD | | | | | Approved: |
| Originator: HDR, INC. | Job or Project No.: | 10343340 | Drawing No.: | 0GA-C1001 | Rev.: |
| | | | | | A |

A
B
C
D
E




- 1 GAS TURBINE (GT)
- 2 HEAT RECOVERY STEAM GENERATOR (HRSG)
- 3 STEAM TURBINE BUILDING
- 4 HRSG STACK
- 5 ADMINISTRATION/CONTROL BUILDING
- 6 GAS YARD
- 7 GAS COMPRESSOR BUILDING
- 8 CIRC WATER PUMPS
- 9 EMERGENCY GENERATOR
- 10 DEMIN WATER STORAGE TANK
- 11 PLANT PARKING
- 12 GSU TRANSFORMER
- 13 BATTERY ENCLOSURE
- 14 COOLING TOWER
- 15 EXCITATION/STATIC START ENCLOSURE
- 16 AMMONIA FLOW CONTROL
- 17 DUCT BURNER SKID
- 18 UNIT AUX TRANSFORMERS
- 19 SERVICE/FIRE WATER STORAGE TANK
- 20 FIRE PROTECTION PUMP HOUSE
- 21 CEMS SHELTER
- 22 WASTE WATER TANK
- 23 CIRC. WATER CHEMICAL FEED BUILDING
- 24 AUXILIARY BOILER BUILDING
- 25 HRSG RECIRCULATION PUMPS
- 26 BOILER FEED PUMP/ELECTRICAL BUILDING
- 27 DEMIN FORWARDING PUMPS
- 28 WASTE WATER PUMP SKID
- 29 SERVICE WATER PUMP SKID
- 30 AMMONIA UNLOADING/STORAGE/FORWARDING
- 31 SINGLE SHAFT PEECC
- 32 CO2 BULK STORAGE TANK
- 33 NITROGEN STORAGE TANK
- 34 HRSG BLOWDOWN TANK/PIT
- 35 MEDIUM VOLTAGE PDC
- 36 SPARE GSU TRANSFORMER
- 37 OIL/WATER SEPARATOR
- 38 HRSG BLOWDOWN SUMP
- 39 SAMPLE PANEL
- 40 CYCLE CHEMICAL FEED

Revisions


| | | |
|---|----------------|-------------|
| A | Project: | 10343340 |
| | Initial Issue: | 07 OCT 2022 |
| | Dwn: | SDK |
| | Chkd: | |
| | Appd: | |

Figure A-5 Site Arrangement Drawing of New NGCC Unit Structures and Equipment





SITE PLAN
 SCALE: 1" = 300'-0"
 300 0 300 600 900

NOT TO BE USED FOR CONSTRUCTION



| | | | | |
|--|--------------------------------|---------------------------|---------------------|------------------------------|
| Location and Title: MILL CREEK | Scale: - | Contract No. - | Revision: - | Drawn: L&K |
| Engineering discipline: CIVIL | Discipline: PPL companies | Company: PPL companies | Generation Services | Checked: - |
| MILL CREEK GENERAL ARRANGEMENT SINGLE UNIT NGCC | | | Approved: - | Released for: INFORMATION |
| Originator: HDR, INC. | Job or Project No. 10343340 | Drawing No. OGA-C1101 | Rev. A | Released for: INFORMATION |

Figure A-6 Process Flow Diagram for New Emission Units Associated with NGCC Project



Process Flow Diagram for New NGCC Project Emission Units
L&E
 Mill Creek Station

Emission Unit and Emission Point IDs are shown in green.
 Control Device IDs are shown in maroon.
 Release Point IDs are shown in blue.

| Flow Legend | |
|-------------|---------------------------|
| | Process Flow |
| | Gaseous or Emissions Flow |

| | |
|---|--|
| Revised: December 13, 2022 | |
| Project # 221801.0123 | |
| 1717 Dixie Hwy, Ste. 900 Covington, KY 41011 | |

APPENDIX B. EMISSIONS UNIT INDEX AND CALCULATIONS

An inventory of existing and new emission units at the Mill Creek Generating Station is provided in this appendix along with documentation showing the methodology for defining potential emissions from the new emission units associated with the NGCC Project (as reflected on the APCD application forms provided in Appendix C) and the baseline actual emissions for existing emission units that are being shut down. The appendix is split up into the following 19 sections:

1. Mill Creek Generating Station Emission Unit Index
2. Project Emissions Increases Summary Table

Potential Emissions from New NGCC Project Emission Units

3. Potential Emissions Summary for New NGCC Project Emission Units
4. Potential Emissions for Gas Turbine/Duct Burners Based on Prospective Vendor Data
5. Unit 5 Gas Turbine with HRSG/Duct Burners - Emission Calculations
6. Auxiliary Steam Boiler - Emissions Calculations
7. Fuel Gas (Dewpoint) Preheater - Emissions Calculations
8. Mechanical Draft Cooling Tower – Emissions Calculations
9. Diesel-Fired Emergency Generator Engine - Emissions Calculations
10. Diesel-Fired Emergency Fire Pump Engine - Emissions Calculations *[Insignificant Activity]*
11. HVAC Heaters – Emissions Calculations *[Insignificant Activity]*
12. Lube Oil Demister Vents - Emission Calculations *[Insignificant Activity]*
13. Diesel Storage Tanks – Emissions Calculations *[Insignificant Activity]*

Baseline Actual Emissions from Existing Emission Units Being Shut Down

14. Mill Creek Unit 1 and 2 Boilers - Emission Reductions from Shutdowns
15. Mill Creek Unit 1 and 2 Coal Bunkers – Emission Reductions from Shutdowns
16. Mill Creek Unit 1 and 2 Coal Bunkers - Emission Reductions from Shutdowns
17. Mill Creek Unit 1 and 2 Flyash Transfer Bin – Emission Reductions from Shutdowns
18. Mill Creek Unit 1 and 2 Sorbent and PAC Silos - Emission Reductions from Shutdowns
19. Mill Creek Unit 2 Cooling Tower - Emission Reductions from Shutdown

1. Mill Creek Generating Station Emission Unit Index

- > The following table provides an index of existing emission units at the Mill Creek Generating Station along with new emission units being installed as part of the proposed NGCC Project. Existing units being shutdown are highlighted in red font. Other than units being shutdown, there are no changes being made to other existing units at the plant as part of the NGCC Project.
- > The emission unit ID nomenclature listed for the new emission units (shown in green font) are placeholders, to be finalized by APCD upon issuance of construction permit and revised Title V operating permit.

| Emission Unit | Emission Point | Emission Unit Description | Emission Point Description | Control ID(s) | Control Description | Release ID(s) | Project Impacts |
|---------------|----------------|---------------------------------|---|--------------------|---|---------------|---------------------|
| U1 | E1 | EGU Unit 1 | Unit 1 Boiler (3,085 MMBtu/hr) | C1, C26, C27 | ESP, PAC Injection, DSI, PJFF, | S33 | Shutdown (12/2024) |
| U1 | E2 | EGU Unit 1 | Four Coal Silos; Four Coal Mills | C3 | Centrifugal Dust Collector | S5 | Shutdown (12/2024) |
| U2 | E3 | EGU Unit 2 | Unit 2 Boiler (3,085 MMBtu/hr) | C4, C27, C28 | ESP, PAC Injection, DSI, PJFF, | S33 | Shutdown (4/2027) |
| U2 | E4 | EGU Unit 2 | Four Coal Silos; Four Coal Mills | C6 | Centrifugal Dust Collector | S6 | Shutdown (4/2027) |
| U3 | E5 | EGU Unit 3 | Unit 3 Boiler (4,204 MMBtu/hr) | C7, C22, C29, C39 | ESP, SCR, PAC Injection, DSI, PJFF, FGD | S4 | Existing Unaffected |
| U3 | E6 | EGU Unit 3 | Four Coal Silos; Four Coal Mills | C9 | Centrifugal Dust Collector | S7 | Existing Unaffected |
| U4 | E7 | EGU Unit 4 | Unit 4 Boiler (5,025 MMBtu/hr) | C10, C23, C30, C31 | ESP, SCR, PAC Injection, DSI, PJFF, FGD | S34 | Existing Unaffected |
| U4 | E8 | EGU Unit 4 | Five Coal Silos; Five Coal Mills | C12 | Centrifugal Dust Collector | S8 | Existing Unaffected |
| U8 | E13 | Fly Ash Storage & Handling | Flyash Silos A & B | C15a, C16 | Cartridge Dust Collector; Baghouse | S13, S14 | Existing Unaffected |
| U8 | E31 | Fly Ash Storage & Handling | Silos A & B Dry Truck Load-Outs | C37, C38 | Air Slider Filter; Loading Spout Filter | S43, S43 | Existing Unaffected |
| U8 | E32 | Fly Ash Storage & Handling | Silos A & B Railcar Load-Outs | C24a, C25a | Cartridge Filter Dust Collectors (2) | S22, S23 | Existing Unaffected |
| U8 | E33 | Fly Ash Storage & Handling | Silos A & B Wet Truck Load-Outs | -- | -- | Fugitive | Existing Unaffected |
| U9 | E16 | Fly Ash Transfer Bins | Flyash Transfer Bin with Two Separators for Units 1 & 2 | C19 | Baghouse | S17, S24, S25 | Shutdown (4/2027) |
| U9 | E17 | Fly Ash Transfer Bins | Flyash Transfer Bin with Two Separators for Unit 3 | C20 | Baghouse | S18, S26, S27 | Existing Unaffected |
| U9 | E18 | Fly Ash Transfer Bins | Flyash Transfer Bin with Two Separators for Unit 4 | C21 | Baghouse | S19, S28, S29 | Existing Unaffected |
| U12 | E24 | Limestone Processing Operations | Barge Unloading Operation (Limestone) | -- | -- | Fugitive | Existing Unaffected |
| U12 | E25 | Limestone Processing Operations | Transfer Point from Conveyor to Storage Pile | -- | -- | Fugitive | Existing Unaffected |
| U12 | E26 | Limestone Processing Operations | Belt Conveyor LA and Transfer to Belt Conveyor LB | -- | -- | Fugitive | Existing Unaffected |
| U12 | E27 | Limestone Processing Operations | Belt Conveyor LB and Transfer to Storage Pile | -- | -- | Fugitive | Existing Unaffected |
| U12 | E28 | Limestone Processing Operations | Three Limestone Crushers | -- | -- | Fugitive | Existing Unaffected |
| U14 | E38 | Cooling Tower | Cooling Tower for Unit 4 | -- | -- | Fugitive | Existing Unaffected |
| U15 | E39a | Haul Roads | Paved Road Particulate Emissions | -- | -- | Fugitive | Existing Unaffected |
| U15 | E39b | Haul Roads | Unpaved Road Particulate Emissions | -- | -- | Fugitive | Existing Unaffected |
| U16 | E40a-b | Sorbent Storage Silos | Two of Six Sorbent Silos for Dry Sorbent or Trona | C32a-b | Bin Vent Filters | S35a-b | Shutdown (4/2027) |
| U16 | E40c-f | Sorbent Storage Silos | Four of Six Sorbent Silos for Dry Sorbent or Trona | C32c-f | Bin Vent Filters | S35c-f | Existing Unaffected |
| U17 | E41a-b | PAC Storage Silos | Two of Six PAC Silos for PAC Injection System | C33a-b | Bin Vent Filters | S36a-b | Shutdown (4/2027) |
| U17 | E41c-f | PAC Storage Silos | Four of Six PAC Silos for PAC Injection System | C33c-f | Bin Vent Filters | S36c-f | Existing Unaffected |
| U18 | E42 | Fly Ash Storage Silos | One or More Flyash Silo for PJFF Units | C34 | Bin Vent Filters | S37 | Existing Unaffected |
| U20 | E44a | Gypsum Pelletizing Plant | Load Hopper for Gypsum Receiving | C36 | Baghouse | S39 | Existing Unaffected |
| U20 | E44b | Gypsum Pelletizing Plant | Conveyor (Hopper to Dispersion Dryer) | C36 | Baghouse | S39 | Existing Unaffected |
| U20 | E44c | Gypsum Pelletizing Plant | Allgaier Dispersion Dryer | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44d | Gypsum Pelletizing Plant | Pneumatic Conveyor with Cyclone (BH to Load Hopper) | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44e | Gypsum Pelletizing Plant | Mixer Load Hopper | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44f | Gypsum Pelletizing Plant | Rotary Airlock Conveyor (Mixer Hopper to Pin Mixer) | -- | -- | Fugitive | Existing Unaffected |

| Emission Unit | Emission Point | Emission Unit Description | Emission Point Description | Control ID(s) | Control Description | Release ID(s) | Imber Project Impacts |
|---------------|----------------|----------------------------------|--|---------------|-------------------------|---------------|-----------------------|
| U20 | E44g | Gypsum Pelletizing Plant | Pin or Plow Mixer with Lingo Sulfonate Storage Tank | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44h | Gypsum Pelletizing Plant | Belt Conveyor (Pin Mixer to Disc Pelletizer) | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44i | Gypsum Pelletizing Plant | DISC Pelletizer | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44j | Gypsum Pelletizing Plant | Belt Conveyor (Disc Pelletizer to Fluid Bed Dryer) | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44k | Gypsum Pelletizing Plant | Allgaier Vibrating Fluid Bed Dryer | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44l | Gypsum Pelletizing Plant | Mogensen Sizer/Screenner | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44m | Gypsum Pelletizing Plant | Belt Conveyor (Screenner to Product Pile) | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44n | Gypsum Pelletizing Plant | Hammer Mill | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44o | Gypsum Pelletizing Plant | Limestone Silo with Integrated Bin Vent Filters | -- | -- | Fugitive | Existing Unaffected |
| U20 | E44p | Gypsum Pelletizing Plant | De-Dust System with Tanks, Conveyors, Mixer, Elevators | -- | -- | Fugitive | Existing Unaffected |
| U20 | E45 | Gypsum Pelletizing Plant | NG Direct-Fired Heater for Dispersion Dryer (42 | -- | -- | S40 | Existing Unaffected |
| U20 | E46 | Gypsum Pelletizing Plant | NG Direct-Fired Heater for Fluid Bed Dryer (42 MMBtu/hr) | -- | -- | S41 | Existing Unaffected |
| U21 | E47a | Coal Handling | Barge Unloading Operation (Coal) | -- | -- | Fugitive | Existing* |
| U21 | E47b | Coal Handling | Railcar Unloading (Coal) | -- | -- | Fugitive | Existing* |
| U21 | E47c | Coal Handling | Coal Radial Stacker | -- | -- | Fugitive | Existing* |
| U21 | E47d | Coal Handling | Two Coal Crushers | -- | -- | Fugitive | Existing* |
| U21 | E47e1-16 | Coal Handling | Coal Belt Conveyors | -- | -- | Fugitive | Existing* |
| U21 | E47f | Coal Handling | Coal Storage Pile (Drop Point Emission) | -- | -- | Fugitive | Existing* |
| U21 | E47g | Coal Handling | Fuel Additive Facility (2 Silos; Hopper; Mix Tank; Heater) | -- | -- | Fugitive | Existing Unaffected |
| U22 | E48a | Landfill | Landfill Haul Roads | -- | -- | Fugitive | Existing Unaffected |
| U22 | E48b | Landfill | Landfill Drop Points | -- | -- | Fugitive | Existing Unaffected |
| U22 | E48c | Landfill | Landfill Wind Erosion Emissions | -- | -- | Fugitive | Existing Unaffected |
| U23 | E49a | EGU Unit 5 Gas Turbine with HRSG | Natural Gas Firing in GT & DB | C43, C44 | Oxidation Catalyst; SCR | S49 | New (4/2027) |
| U23 | E49b | EGU Unit 5 Gas Turbine with HRSG | Cold Startup Events | -- | -- | S49 | New (4/2027) |
| U23 | E49c | EGU Unit 5 Gas Turbine with HRSG | Warm Startup Events | -- | -- | S49 | New (4/2027) |
| U23 | E49d | EGU Unit 5 Gas Turbine with HRSG | Hot Startup Events | -- | -- | S49 | New (4/2027) |
| U23 | E49e | EGU Unit 5 Gas Turbine with HRSG | Shutdown Events | -- | -- | S49 | New (4/2027) |
| U24 | E50 | Auxiliary Steam Boiler | Natural Gas Combustion w/ LNB & FGR | -- | -- | S50 | New (4/2027) |
| U25 | E51 | 2 MW Diesel Emergency Generator | Diesel Fuel Combustion | -- | -- | S51 | New (4/2027) |
| U26 | E52 | Fuel Gas (Dewpoint) Heater | NG Fuel Combustion (15 MMBtu/hr) | -- | -- | S52 | New (4/2027) |
| IA1 | E20 | Gasoline Storage Tank | Stage I Gasoline Refueling Station with 3,000 Gallon Tank | -- | -- | Fugitive | Existing Unaffected |
| IA2 | IE1-8 | Parts Washers | Eight Parts Washers Equipped with Secondary Reservoirs | -- | -- | Fugitive | Existing Unaffected |
| IA3 | E36 | Emergency Generators | Turning Gear Diesel Generator (800 hp) | -- | -- | Fugitive | Existing Unaffected |
| IA3 | E37 | Emergency Generators | FGD Quench Water System Diesel Generator (800 hp) | -- | -- | Fugitive | Existing Unaffected |
| IA3 | IE24 | Emergency Generators | NG Fired Emergency Generator (105 hp) | -- | -- | Fugitive | Existing Unaffected |
| IA4 | IE9 | Fire Pump Engines | Diesel Fire Pump Engine (157 hp) | -- | -- | Fugitive | Existing Unaffected |
| IA4 | IE10 | Fire Pump Engines | Diesel Fire Pump Engine (183 hp) | -- | -- | Fugitive | Existing Unaffected |
| IA4 | IE28 | 400 HP Diesel Driven Fire Pump | Diesel Fuel Combustion | -- | -- | S53 | New (4/2027) |
| IA5 | IE11 | Other Insignificant Activities | 17 Lubricating Oil Tanks (400 - 20,000 gal capacities) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE12 | Other Insignificant Activities | 1,000 Gallon #1 Fuel Oil Tank | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE13 | Other Insignificant Activities | Portable Kerosene Storage Tank (< 500 gal) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE14a | Other Insignificant Activities | Cooling Tower for Unit 2 | -- | -- | Fugitive | Shutdown (4/2027) |

| Emission Unit | Emission Point | Emission Unit Description | Emission Point Description | Control ID(s) | Control Description | Release ID(s) | Imber Project Impacts |
|---------------|----------------|------------------------------------|---|---------------|--|---------------|-----------------------|
| IA5 | IE14b | Other Insignificant Activities | Cooling Tower for Unit 3 | | | Fugitive | Existing Unaffected |
| IA5 | IE15 | Other Insignificant Activities | Gypsum Handling Equipment | -- | -- | Fugitive | Existing Unaffected |
| IA5 | | Other Insignificant Activities | Portable Gypsum Dewatering Systems | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE17 | Other Insignificant Activities | Bottom/Fly Ash Storage Silo with Bin Vent Filter (IE17) | C40 | Bin Vent Filter | S30 | Existing Unaffected |
| IA5 | IE18 | Other Insignificant Activities | Bottom/Fly Ash Storage Silo with Bin Vent Filter (IE18) | C31 | Bin Vent Filter | S31 | Existing Unaffected |
| IA5 | IE19 | Other Insignificant Activities | Pug Mill Mixers (IE19) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE20 | Other Insignificant Activities | Pug Mill Mixers (IE20) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE21 | Other Insignificant Activities | Pug Mill Mixers (IE21) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE22 | Other Insignificant Activities | Pug Mill Mixers (IE22) | -- | -- | Fugitive | Existing Unaffected |
| IA5 | IE23 | Other Insignificant Activities | Process Water System (PWS) | C42a, C42b | Bin Vent Filters for Hydrated Lime Silos | S32a, S32b | Existing Unaffected |
| IA5 | IE24 | Other Insignificant Activities | Mechanical Draft Cooling Tower (8 Cells) for NGCC | -- | -- | Fugitive | New (4/2027) |
| IA5 | IE25 | Other Insignificant Activities | Lube Oil Storage Tanks with Demister Vents | -- | -- | Fugitive | New (4/2027) |
| IA5 | IE26 | Other Insignificant Activities | Diesel Storage Tanks for NGCC Units (1@ 4,000 gal 1@ 440 gal) | -- | -- | Fugitive | New (4/2027) |
| IA5 | IE27 | Other Insignificant Activities | HVAC Heaters (Total 10 MMBtu/hr) | -- | -- | Fugitive | New (4/2027) |
| IAz1 | | Unlabeled Insignificant Activities | Minor NG Combustion Sources < 10 MMBtu/hr | -- | -- | Fugitive | Existing Unaffected |
| IAz2 | | Unlabeled Insignificant Activities | Emergency Relief Vents for Boiler Steam Supply | -- | -- | Fugitive | Existing Unaffected |
| IAz3 | | Unlabeled Insignificant Activities | Lab Exhaust Systems | -- | -- | Fugitive | Existing Unaffected |
| IAz4 | | Unlabeled Insignificant Activities | Ash Pond with Wet Storage | -- | -- | Fugitive | Existing Unaffected |
| IAz5 | | Unlabeled Insignificant Activities | Stack Piles (Coal, Limestone, Gypsum) | -- | -- | Fugitive | Existing Unaffected |
| IAz6 | | Unlabeled Insignificant Activities | Turbine Oil Reservoir Vapor Extractor | -- | -- | Fugitive | Existing Unaffected |
| IAz7 | | Unlabeled Insignificant Activities | Hydrogen Seal Oil Tank Vent | -- | -- | Fugitive | Existing Unaffected |
| IAz8 | | Unlabeled Insignificant Activities | Emergency Vent for U1 and U2 Boilers | | | Fugitive | Shutdown (4/2027) |

* Coal handling equipment (U21) will not be modified as part of the project, but activity will be reduced in conjunction with shutdown of Units 1 and 2 boilers. As a result, there will be an emissions decrease.

2. Project Emissions Increases Summary Table

> The table below tallies the emission increases associated with the proposed NGCC Project for all relevant regulated NSR pollutants and compares them to the PSD/NSR major modification thresholds. Values shown for new emission units are their potential emissions, taking into account inherent and proposed operating limitations and control device configurations. Values shown for the existing emission units being shutdown as part of the project have zero projected actual emissions minus their baseline actual emissions calculated in accordance with 40 CFR 52.21(b)(48)(i) and Reg 2.04, Paragraph 1.35. Project emission increases are calculated pursuant to 40 CFR 52.21(a)(2)(iv)(f) and Reg 2.04, Paragraph 2.26.

| Emission Unit ID | Description | PM (tpy) | PM ₁₀ (tpy) | PM _{2.5} (tpy) | NO _x (tpy) | CO (tpy) | VOC (tpy) | SO ₂ (tpy) | H ₂ SO ₄ (tpy) | Lead (tpy) | CO ₂ e (tpy) |
|---------------------------|---|---------------|------------------------|-------------------------|-----------------------|---------------|--------------|-----------------------|--------------------------------------|-----------------|-------------------------|
| New Emission Units | | | | | | | | | | | |
| U23/E49a | EGU Unit 5 Gas Turbine with HRSG | 100.10 | 100.10 | 100.10 | 167.17 | 135.90 | 47.82 | 24.54 | 8.64 | 0.01 | 2,149,207 |
| U24/E50 | Auxiliary Steam Boiler | 1.43 | 1.43 | 1.43 | 15.93 | 16.16 | 2.27 | 0.59 | 0.045 | 2.07E-04 | 51,238 |
| U25/E51 | 2 MW Diesel Emergency Generator | 0.059 | 0.059 | 0.059 | 9.70 | 0.80 | 0.21 | 0.007 | | | 768 |
| U26/E52 | Fuel Gas (Dewpoint) Heater | 0.22 | 0.22 | 0.22 | 2.39 | 4.90 | 0.34 | 0.089 | 0.007 | 3.10E-05 | 7,693 |
| IA4/IE28 | 400 HP Diesel Driven Fire Pump | 0.022 | 0.022 | 0.022 | 0.58 | 0.18 | 0.02 | 0.001 | | | 115 |
| IA5/IE24 | Mechanical Draft Cooling Tower (8 Cells) for NGCC | 2.06 | 0.97 | 0.0042 | | | | | | | |
| IA5/IE25 | Lube Oil Storage Tanks with Demister Vents | | | | | | 0.66 | | | | |
| IA5/IE26 | Diesel Storage Tanks for NGCC Units (1@ 4,000 gal 1@ 440 gal) | | | | | | 0.0011 | | | | |
| IA5/IE27 | HVAC Heaters (Total 10 MMBtu/hr) | 0.14 | 0.14 | 0.14 | 4.14 | 3.47 | 0.23 | 0.059 | 0.005 | 2.07E-05 | 5,129 |
| Subtotal | | 104.03 | 102.94 | 101.98 | 199.90 | 161.42 | 51.56 | 25.28 | 8.70 | 8.85E-03 | 2,214,149 |

Emission Decreases from Units Being Shutdown with Project

| | | | | | | | | | | | |
|-----------------|---|---------------|---------------|---------------|---------------|-------------|--------------|---------------|-------------|--------------|-------------------|
| U1/E1 | Unit 1 Boiler (3,085 MMBtu/hr) | -194.4 | -191.6 | -178.0 | -2,251 | -180.8 | -21.6 | -551.8 | -8.0 | -0.02 | -1,641,022 |
| U1/E2 | EGU Unit 1 - Four Coal Silos; Four Coal Mills | -0.0047 | -0.0022 | -0.0003 | | | | | | | |
| U2/E3 | Unit 2 Boiler (3,085 MMBtu/hr) | -160.5 | -158.1 | -146.3 | -1,985 | -154.4 | -18.5 | -591.5 | -0.9 | -0.01 | -1,409,672 |
| U2/E4 | EGU Unit 2 - Four Coal Silos; Four Coal Mills | -0.0041 | -0.0019 | -0.0003 | | | | | | | |
| U9/E16 | Flyash Transfer Bin with Two Separators for Units 1 & 2 | -0.3643 | -0.1276 | -0.1276 | | | | | | | |
| U16/E40a-b | Sorbent Storage Silos - Two of Six Sorbent Silos | -0.0126 | -0.0126 | -0.0126 | | | | | | | |
| U17/E41a-b | PAC Storage Silos - Two of Six PAC Silos for PAC Injectio | -0.0004 | -0.0004 | -0.0004 | | | | | | | |
| IA5/IE14a | Other Insignificant Activities - Cooling Tower for Unit 2 | -0.0315 | -0.0226 | -6.9E-05 | | | | | | | |
| Subtotal | | -355.3 | -349.8 | -324.4 | -4,236 | -335 | -40.1 | -1,143 | -8.9 | -0.03 | -3,050,694 |

Emission Decreases from Existing Unmodified Emission Units

| | | | | | | | | | | | |
|-----------------|--|--------------|--------------|--------------|--|--|--|--|--|--|--|
| U21/E47 | Coal Handling Operations (for Unit 1 Boiler) | -1.70 | -0.81 | -0.12 | | | | | | | |
| U21/E47 | Coal Handling Operations (for Unit 2 Boiler) | -1.46 | -0.69 | -0.10 | | | | | | | |
| Subtotal | | -3.16 | -1.49 | -0.23 | | | | | | | |

Emissions Increase Summary

| | | | | | | | | | | |
|--------------------------------------|-------------|-------------|-------------|---------------|-------------|-----------|---------------|-------------|---------------|-----------------|
| Project Emission Increases | -254 | -248 | -223 | -4,036 | -174 | 11 | -1,118 | -0.2 | -0.024 | -836,545 |
| PSD/NSR Major Modification Threshold | 25 | 15 | 10 | 40 | 100 | 40 | 40 | 7 | 0.6 | 75,000 |
| Trigger PSD/NSR? | No | No | No | No | No | No | No | No | No | No |

3. Potential Emissions Summary for New NGCC Project Emission Units

> The table below tallies the potential to emit for all new emission units associated with the proposed NGCC Project for all relevant regulated air pollutants.

| Emission Unit ID | Description | PM (tpy) | PM ₁₀ (tpy) | PM _{2.5} (tpy) | NO _x (tpy) | CO (tpy) | VOC (tpy) | SO ₂ (tpy) | H ₂ SO ₄ (tpy) | Lead (tpy) | CO ₂ e (tpy) |
|---------------------------|---|----------|------------------------|-------------------------|-----------------------|----------|-----------|-----------------------|--------------------------------------|------------|-------------------------|
| New Emission Units | | | | | | | | | | | |
| U23/E49a | EGU Unit 5 Gas Turbine with HRSG | 100.10 | 100.10 | 100.10 | 167.17 | 135.90 | 47.82 | 24.54 | 8.64 | 0.01 | 2,149,207 |
| U24/E50 | Auxiliary Steam Boiler | 1.43 | 1.43 | 1.43 | 15.93 | 16.16 | 2.27 | 0.59 | 0.045 | 2.1E-04 | 51,238 |
| U25/E51 | 2 MW Diesel Emergency Generator | 0.059 | 0.059 | 0.059 | 9.70 | 0.80 | 0.21 | 0.007 | | | 768 |
| U26/E52 | Fuel Gas (Dewpoint) Heater | 0.22 | 0.22 | 0.22 | 2.39 | 4.90 | 0.34 | 0.089 | 0.007 | 3.1E-05 | 7,693 |
| IA4/IE28 | 400 HP Diesel Driven Fire Pump | 0.022 | 0.022 | 0.022 | 0.58 | 0.18 | 0.02 | 0.001 | | | 115 |
| IA5/IE24 | Mechanical Draft Cooling Tower (8 Cells) for NGCC | 2.06 | 0.97 | 0.0042 | | | | | | | |
| IA5/IE25 | Lube Oil Storage Tanks with Demister Vents | | | | | | 0.66 | | | | |
| IA5/IE26 | Diesel Storage Tanks for NGCC Units (1@ 4,000 gal 1@ 440 gal) | | | | | | 0.0011 | | | | |
| IA5/IE27 | HVAC Heaters (Total 10 MMBtu/hr) | 0.14 | 0.14 | 0.14 | 4.14 | 3.47 | 0.23 | 0.059 | 0.005 | 2.07E-05 | 5,129 |
| Subtotal | | 104.03 | 102.94 | 101.98 | 199.90 | 161.42 | 51.56 | 25.28 | 8.70 | 8.9E-03 | 2,214,149 |

| Emission Unit ID | Description | Acetalde- Formalde | | | | | | | Total HAP (tpy) | |
|---------------------------|---|--------------------|------------|--------------|--------------|---------------|---------------|--------------|-----------------|---------------|
| | | NH3 (tpy) | hyde (tpy) | - hyde (tpy) | Hexane (tpy) | Toluene (tpy) | Xylenes (tpy) | Nickel (tpy) | | Mercury (tpy) |
| New Emission Units | | | | | | | | | | |
| U23/E49a | EGU Unit 5 Gas Turbine with HRSG | 122.76 | 3.09 | 3.95 | 15.47 | 1.14 | 0.56 | 3.61E-02 | 4.47E-03 | 25.00 |
| U24/E50 | Auxiliary Steam Boiler | | | 3.1E-02 | 0.74 | 1.4E-03 | | 8.68E-04 | 1.07E-04 | 0.78 |
| U25/E51 | 2 MW Diesel Emergency Generator | | 1.2E-04 | 3.7E-04 | | 1.3E-03 | 9.1E-04 | | | 8.0E-03 |
| U26/E52 | Fuel Gas (Dewpoint) Heater | | | 4.7E-03 | 0.112 | 2.1E-04 | | 1.30E-04 | 1.61E-05 | 0.12 |
| IA4/IE28 | 400 HP Diesel Driven Fire Pump | | 5.4E-04 | 8.3E-04 | | 2.9E-04 | 2.0E-04 | | | 2.8E-03 |
| IA5/IE24 | Mechanical Draft Cooling Tower (8 Cells) for NGCC | | | | | | | | | |
| IA5/IE25 | Lube Oil Storage Tanks with Demister Vents | | | | | | | | | |
| IA5/IE26 | Diesel Storage Tanks for NGCC Units (1@ 4,000 gal 1@ 440 gal) | | | | | | | | | |
| IA5/IE27 | HVAC Heaters (Total 10 MMBtu/hr) | | | 3.1E-03 | 7.4E-02 | 1.4E-04 | | 8.7E-05 | 1.1E-05 | 0.078 |
| Subtotal | | 122.76 | 3.09 | 3.99 | 16.40 | 1.14 | 0.56 | 0.04 | 4.6E-03 | 25.98 |

4. Potential Emissions for Gas Turbine/Duct Burners Based on Prospective Vendor Data

- > LG&E is choosing between three vendors for the new 640-664 MW (net) natural gas combined cycle electric generating plant (herein labeled as NGCC). Sections 4 and 5 provide the derivation of the emission factors, heat input, and potential emissions. The NGCC system will consist of one power block with one NG-fired gas turbine (GT) and its single-shaft water cooled generator, one heat recovery steam generator (HRSG) with NG-fired duct burners (DB), and one steam turbine generator (STG) arranged in a one-on-one configuration. The GT will be either a 1x1 7HA.03, 501JAC, 1x1 9000HL, or similar unit, all of which are the largest and most efficient turbines currently in the market.
- > Each vendor provided emissions data for a number of cases that bracket the range of possible operating conditions such as the coldest/hottest day, a representative winter day at 15°F, average temperature day at 57°F, and representative summer day at 90°F. The following shows the highest emissions profile at 15, 57, and 90°F, as well as the outlier cases, with the highest hourly emissions rate by pollutant. If the DB is also operational and providing additional heat input, such as during the summer cases, it is shown as well in the load description. Not shown are 75% or minimum load situations because in every one of those low load cases, the hourly emissions rate is less than the corresponding 100% load case. Another variation that occurred in the summer months was the possible operation of an evaporative cooler (EC).

4.1 Vendor A: Calculated Stack Emission Rates for GT/DB

| Case | Ambient Temp. (°F) | Load (%) | Load Description | NO _x (lb/hr) | CO (lb/hr) | VOC (lb/hr) | Total PM (lb/hr) | SO ₂ (lb/hr) | H ₂ SO ₄ [*] (lb/hr) | NH ₃ (lb/hr) | CO ₂ (lb/hr) |
|-----------|-----------------------|-------------|---------------------|----------------------------|---------------|----------------|---------------------|----------------------------|--|----------------------------|----------------------------|
| 4 | 15 | 100 | GT | 30.6 | 18.6 | 5.3 | 18.0 | 7.1 | 4.8 | 28.3 | 548,000 |
| 10 | 57 | 100 | GT | 30.0 | 18.3 | 5.2 | 17.9 | 7.0 | 4.7 | 27.8 | 537,000 |
| 13 | 90 | 100 | GT + EC + DB | 30.6 | 18.6 | 10.7 | 19.4 | 7.1 | 5.1 | 28.3 | 547,000 |
| 17 | 106 | 100 | GT + EC + DB | 29.8 | 18.2 | 10.4 | 19.7 | 6.9 | 5.0 | 27.6 | 534,000 |
| 1 | -18 | 100 | GT | 30.7 | 18.7 | 5.3 | 18.0 | 7.1 | 4.8 | 28.4 | 549,000 |
| Max of 20 | | Varies | | 30.7 | 18.7 | 10.7 | 19.7 | 7.1 | 5.1 | 28.4 | 549,000 |

* When asked by LG&E to provide emissions for H₂SO₄, only Vendor A provided data. H₂SO₄ is generated from the following simplified chemical conversion: Fuel-based sulfur => SO₂ => SO₃ => H₂SO₄. SO₃ is generated in the combustion process and varies depending on both the chosen oxidation catalyst and SCR catalyst. Vendor A's overly conservative conversion rates for SO₃ generation resulted in H₂SO₄ hourly emissions being 70% of SO₂. As shown in Section 5.3.1, LG&E used a more realistic, yet conservative, conversion rate.

Startup/Shutdown Events

| | | | | | | | | |
|--|--------|--------|-------|-------|---|---|---|---|
| 5 cold start events (total pounds) | 2,100 | 1,550 | 500 | 160 | - | - | - | - |
| 45 warm start events (total pounds) | 11,700 | 10,350 | 3,825 | 1,215 | - | - | - | - |
| 100 hot start events (total pounds) | 13,500 | 20,000 | 8,000 | 1,400 | - | - | - | - |
| 150 shutdown start events (total pounds) | 6,000 | 26,250 | 9,000 | 750 | - | - | - | - |
| Sum of all Events (total tons) | 16.7 | 29.1 | 10.7 | 1.8 | - | - | - | - |

Sample Calculations:

Total Emissions from SUSD Events: NO_x (tpy) = (2,100 lb for C-SU + 11,700 lb for W-SU + 13,500 lb for H-SU + 6,000 lb for Shutdowns) / 2,000 lb/ton = 16.7 tpy

4.2 Vendor B: Calculated Stack Emission Rates for GT/DB

Imber

| Case | Ambient Temp. (°F) | Load (%) | Load Description | NO _x (lb/hr) | CO (lb/hr) | VOC (lb/hr) | Total PM (lb/hr) | SO ₂ (lb/hr) | H ₂ SO ₄ (lb/hr) | NH ₃ (lb/hr) | CO ₂ (lb/hr) |
|-----------|-----------------------|-------------|---------------------|----------------------------|---------------|----------------|---------------------|----------------------------|---|----------------------------|----------------------------|
| 16 | 15 | 100 | GT | 31.0 | 19.0 | 5.3 | 19.9 | - | - | - | - |
| 12 | 57 | 100 | GT | 31.0 | 19.0 | 5.4 | 20.1 | - | - | - | - |
| 5 | 90 | 100 | GT + EC + DB | 32.0 | 19.0 | 10.9 | 23.3 | - | - | - | - |
| Max of 11 | | Varies | | 32.0 | 19.0 | 10.9 | 23.3 | - | - | - | - |

Startup/Shutdown Events

| | | | | | | | | | | | |
|--|--|--|--|--------|-------------|-------------|-------|---|---|---|---|
| 5 cold start events (total pounds) | | | | 360 | 2,665 | 675 | 150 | - | - | - | - |
| 45 warm start events (total pounds) | | | | 2,925 | 21,420 | 5,445 | 1,125 | - | - | - | - |
| 100 hot start events (total pounds) | | | | 5,500 | 30,300 | 9,100 | 1,500 | - | - | - | - |
| 150 shutdown start events (total pounds) | | | | 11,700 | 29,250 | 17,700 | 750 | - | - | - | - |
| Sum of all Events (total tons) | | | | 10.2 | 41.8 | 16.5 | 1.8 | - | - | - | - |

4.3 Vendor C: Calculated Stack Emission Rates for GT/DB

| Case | Ambient Temp. (°F) | Load (%) | Load Description | NO _x (lb/hr) | CO (lb/hr) | VOC (lb/hr) | Total PM (lb/hr) | SO ₂ (lb/hr) | H ₂ SO ₄ (lb/hr) | NH ₃ (lb/hr) | CO ₂ (lb/hr) |
|-----------|-----------------------|-------------|---------------------|----------------------------|---------------|----------------|---------------------|----------------------------|---|----------------------------|----------------------------|
| 15 | 15 | 100 | GT | 30.1 | 18.3 | 5.3 | 14.9 | - | - | 27.9 | - |
| 9 | 57 | 100 | GT | 28.8 | 17.5 | 5.0 | 14.1 | - | - | 26.6 | - |
| 21 | 90 | 100 | GT + EC + DB | 29.6 | 18.0 | 10.3 | 16.4 | - | - | 27.4 | - |
| 18 | -18 | 100 | GT + EC | 30.2 | 18.4 | 5.3 | 14.9 | - | - | 28.0 | - |
| Max of 21 | | Varies | | 29.6 | 18 | 10.3 | 16.4 | - | - | 27.4 | - |

Startup/Shutdown Events

| | | | | | | | | | | | |
|--|--|--|--|-------|--------|-------|-----|---|---|---|---|
| 5 cold start events (total pounds) | | | | 540 | 3,790 | 350 | 33 | - | - | - | - |
| 45 warm start events (total pounds) | | | | 2,655 | 12,825 | 2,025 | 216 | - | - | - | - |
| 100 hot start events (total pounds) | | | | 5,900 | 28,500 | 4,500 | 480 | - | - | - | - |
| 150 shutdown start events (total pounds) | | | | 6,900 | 36,600 | 7,350 | 600 | - | - | - | - |
| Sum of all Events (total tons) | | | | 8.0 | 40.9 | 7.1 | 0.7 | - | - | - | - |

4.4 Comparison of Annual Emissions by Operating Scenario and Vendor

> The following represents the annual emissions by operating scenario:

- 1) Profile 1 calculates the annual emissions using 8,760 hours at the highest hourly emissions rate at the average ambient temperature. In every case, DBs will not be necessary to generate the rated output.
- 2) Profile 2A calculates the annual emissions with 2,000 hr/yr of operation at 15°F, 4,760 hr/yr at 57°F, and 2,000 hr/yr at 90°F. The DBs and EC only kick in during the summer months. Although it artificially elevates the potential emission rate, for simplicity and conservatism, the total hours do not subtract periods of non-operation between a shutdown and a startup, nor do the total hours exclude the total time of GT operation during the events.
- 3) Profile 2B is the same as 2A except 127 hours of time for SUSD events is subtracted. Again, this case does not subtract periods of non-operation between a shutdown and a startup. Where, 127 hrs = (5 C-SU events * average of 40 & 70 min C-SU + 45 W-SU events * average of 30 & 60 min W-SU + 100 H-SU events * average of 21 & 35 min H-SU + 150 SD events * average of 12 & 21 min SD) * 60 mn/hr
- 4) Profile 3 is the maximum hourly emissions rate for any case multiplied by 8,760 hr/yr.

| Emissions Profile | Underlying Heat Input (MMBtu/hr) | NO _x (tpy) | CO (tpy) | VOC (tpy) | Total PM (tpy) | SO ₂ (tpy) | H ₂ SO ₄ (tpy) | NH ₃ (tpy) | CO ₂ (tpy) |
|---|----------------------------------|-----------------------|----------|-----------|----------------|-----------------------|--------------------------------------|-----------------------|-----------------------|
| Profile 1: 8,760 hr/yr at 57 °F | | | | | | | | | |
| Vendor A (GT only) | 4,124 | 131.4 | 80.2 | 22.8 | 78.4 | 30.7 | 20.6 | 121.8 | 2,352,060 |
| Vendor B (GT only) | 3,858 | 135.8 | 83.2 | 23.7 | 88.0 | | | | |
| Vendor C (GT only) | 3,751 | 126.1 | 76.7 | 21.9 | 61.8 | | | 116.5 | |
| Profile 2A: 2,000 hr/yr at 15 °F, 4,760 hr/yr at 57 °F, and 2,000 hr/yr at 90 °F | | | | | | | | | |
| Vendor A (GT + EC + DB) | 4,157 | 132.6 | 80.8 | 28.4 | 80.0 | 30.9 | 21.1 | 122.8 | 2,373,060 |
| Vendor B (GT + EC + DB) | 3,850 | 136.8 | 83.2 | 29.1 | 91.0 | | | | |
| Vendor C (GT + EC + DB) | 3,817 | 128.2 | 78.0 | 27.5 | 64.9 | | | 118.6 | |
| Profile 2B: 2,000 hr/yr at 15 °F, 4,633 hr/yr at 57 °F, and 2,000 hr/yr at 90 °F | | | | | | | | | |
| Vendor A (GT + EC + DB) | 4,097 | 130.7 | 79.6 | 28.0 | 78.9 | 30.4 | 20.8 | 121.0 | 2,338,961 |
| Vendor B (GT + EC + DB) | 3,794 | 134.8 | 82.0 | 28.7 | 89.8 | | | | |
| Vendor C (GT + EC + DB) | 3,762 | 126.4 | 76.8 | 27.2 | 64.0 | | | 116.9 | |
| Profile 3: 8,760 hr/yr at maximum hourly emissions for all operating scenarios | | | | | | | | | |
| Vendor A (GT + EC + DB) | 4,216 | 134.5 | 81.9 | 46.9 | 86.3 | 31.1 | 22.3 | 124.4 | 2,404,620 |
| Vendor B (GT + EC + DB) | 3,854 | 140.2 | 83.2 | 47.7 | 102.1 | | | | |
| Vendor C (GT + EC + DB) | 3,942 | 129.6 | 78.8 | 45.1 | 71.8 | | | 120.0 | |

Sample Calculations:

For Profile 1, Vendor A: NO_x (tpy) = 30.0 lb/hr (for 57F, Case 10) x 8,760 hr/yr / 2,000 lb/ton = 131.4 tpy

For Profile 2A, Vendor B: NO_x (tpy) = (31.0 lb/hr @15F x 2,000 hr/yr + 31.0 lb/hr @57F x 4,760 hr/yr + 32.0 lb/hr @90F x 2,000 hr/yr) / 2,000 lb/ton = 136.8 tpy

4.5 Defined PTE on a Seasonal Basis Determined Using Max Hourly Emission Rates by Vendor

> In reviewing the calculated annual emissions for the worst case operating scenarios presented in Section 4.4, LG&E has chosen to represent the potential emissions for the GT/DB based on Profile 2A. Profile 3 is not used because it is not practically realistic and could never occur in practice. While Profile 2A is also conservative, in that it does not subtract for SUSL hours (which is done in Profile 2B), the differences are not significant. Profile 2A, which considers the differences for cold and hot seasons, also predicts slightly higher potential emissions than the baseload case at the average ambient temperature. Thus, it is conservative but reasonable to use emissions for Profile 2A to define the PTE.

| Selected Emissions Profile | NO _x (tpy) | CO (tpy) | VOC (tpy) | Total PM (tpy) | SO ₂ (tpy) | H ₂ SO ₄ (tpy) | NH ₃ (tpy) | CO ₂ (tpy) |
|--|--------------------------|-------------|--------------|-------------------|--------------------------|---|--------------------------|--------------------------|
| Profile 1: 8,760 hr/yr at 57 °F Maximum by Vendor (tpy) | 135.8 | 83.2 | 23.7 | 88.0 | 30.7 | 20.6 | 121.8 | 2,352,060 |
| Profile 2A: 2,000 hr/yr at 15 °F, 4,760 hr/yr at 57 °F, and 2,000 hr/yr at 90 °F Maximum by Vendor (tpy) | 136.8 | 83.2 | 29.1 | 91.0 | 30.9 | 21.1 | 122.8 | 2,373,060 |
| Worst case GT PTE (Profile 2A) | | | | | | | | |
| Maximum by Vendor (tpy) of Profile 1 or 2A | 136.8 | 83.2 | 29.1 | 91.0 | 30.9 | 21.1 | 122.8 | 2,373,060 |
| Maximum by Pollutant from SUSL Events (tpy) | 16.7 | 41.8 | 16.5 | 1.8 | 0 | 0 | 0 | 0 |

4.6 Derivation of Emission Factors Based on Hourly Average Emission Rate

- > Based on the defined PTE values (tpy), the equivalent hourly average emission rate (lb/hr) can be calculated. An emission factor in terms of lb/MMBtu can then be calculated based on the vendor-provided heat input associated with the case for which the PTE value is derived. See Section 4.4, which provides the underlying heat input rate.
- > Emission factors in terms of lb/MMscf of gas fired are calculated based on the nominal average heating value of natural gas received at the Mill Creek Generating Station of 1,059 Btu/scf.

| Selected Emissions Profile | NO _x | CO | VOC | Total PM | SO ₂ | H ₂ SO ₄ | NH ₃ | CO ₂ |
|---|-----------------|---------|---------|----------|-----------------|--------------------------------|-----------------|-----------------|
| Steady-State Stack Exhaust Emissions (lb/hr) | | | | | | | | |
| Equivalent hourly emissions rate (Annual emissions for 2A in tpy x 2000 lb/ton / 8,760 hours) | 31.23 | 19.00 | 6.63 | 20.78 | 7.05 | 4.81 | 28.03 | 541,795 |
| Heat Input (MMBtu/hr, HHV) | | | | | | | | |
| Weighted vendor-provided heat inputs (HHV) (highest is 4,157 MMBtu/hr for Vendor A) | 3,850 | 3,850 | 3,850 | 3,850 | 4,157 | 4,157 | 4,157 | 4,157 |
| Natural Gas Fuel Consumption (MMscf/hr) | | | | | | | | |
| Steady State = Heat Input (MMBtu/yr, HHV) / NG HHV (Btu/scf) / 8,760 hr/yr | 3.636 | 3.636 | 3.636 | 3.636 | 3.925 | 3.925 | 3.925 | 3.925 |
| Steady-State Stack Emission Factor (lb/MMBtu, HHV) | | | | | | | | |
| Emission factor associated with gas combustion during steady-state operation of GT + DB | 0.00811 | 0.00493 | 0.00172 | 0.00540 | 0.00169 | 0.00116 | 0.00674 | 130.34 |
| Steady-State Emission Factor (lb/MMscf, HHV) | | | | | | | | |
| Emission factor converted to lb/MMscf based on average gas HV of 1,059 Btu/scf | 8.589 | 5.226 | 1.824 | 5.717 | 1.795 | 1.226 | 7.141 | 138,031 |

Sample Calculations:

Steady-State Stack Exhaust Emissions: NO_x (lb/hr) = 136.8 tpy x 2,000 lb/ton / 8,760 hr/yr = 31.23 lb/hr

Maximum Natural Gas Fuel Consumption = 4,157 MMBtu/hr (maximum for any pollutant) / 1,059 MMBtu/MMscf = 3.925 MMscf/hr

NO_x Emission Factor (lb/MMBtu) = 31.23 lb/hr / 3,850 MMBtu/hr = 0.00811 lb/Mmbtu

NO_x Emission Factor (lb/MMscf) = 31.23 lb/hr / 3.636 MMscf/hr = 8.589 lb/MMscf

5. Unit 5 Gas Turbine with HRSG/Duct Burners - Emission Calculations

> Emission factors and control efficiencies for the pollutants represented on the forms for the new GT/DB along with calculated potential emissions are documented in this section.

5.1 Description and Nomenclature

> The new emission unit identification and associated process IDs proposed to be assigned within the State and Local Emissions Inventory System (SLEIS) for the GT/DB are shown below. Both the GT and DB fire natural gas solely and Process ID 1 includes the natural gas fired in the GT and DB because both are exhausted through the same add-on control devices before exiting the stack. Process IDs 2 through 5 encompass possible startup and shutdown operating events, consistent with conventional approaches for representing emissions from combustion turbines.

| GT/DB Emission Unit and Emission Point IDs and Descriptions | SLEIS Process ID# |
|---|-------------------|
| U23 - EGU Unit 5 Gas Turbine with HRSG | |
| E49a - Natural Gas Firing in GT & DB | 1 |
| E49b - Cold Startup Events | 2 |
| E49c - Warm Startup Events | 3 |
| E49d - Hot Startup Events | 4 |
| E49e - Shutdown Events | 5 |

5.2 Capacity and Fuel Information for E49a - Natural Gas Firing in GT & DB

> The following provides the capacity information for the GT/DB, as well as other relevant information used in the emissions estimates.

| | | |
|---|-----------------------|---|
| Natural Gas Higher Heating Value (HHV) at MC | 1,059 Btu/scf | Average for Mill Creek Generating Station Inlet Gas |
| Natural Gas HHV used for AP-42 1.4 & 3-1 | 1,020 Btu/scf | |
| Maximum operating hours/yr used in permitting | 8,760 hr/yr | LG&E did not take any reductions for time between events. |
| Total hours estimate for summer season | 2,000 hr/yr | |
| Total hours estimate for fall and spring | 4,760 hr/yr | |
| Total hours estimate for winter season | 2,000 hr/yr | |
| Maximum operating hours/yr accounting for SUSD events | 5,314 hr/yr | Although not used in calculations, this is the actual estimate of operating hours IF LG&E excluded time for every SUSD event and time in between events |
| Maximum Short-term Heat Input Capacity (for information only; not used in the calculations) | 4,216 MMBtu/hr | Max of three vendors out of all cases (Vendor A, Case 1 = GT only at -18°F and 100% of baseload) |
| Maximum Short-term Fuel Consumption (for information only; not used in the calculations) | 3.981 MMscf/hr | = 4,216 MMBtu/hr / 1,059 Btu/scf |
| Maximum Simulated Heat Input Capacity Used for Emission Calculations | 4,157 MMBtu/hr | Weighted vendor-provided heat inputs (HHV) (highest is 4,157 MMBtu/hr for Vendor A), see Section 4.6. |
| Maximum Simulated Fuel Consumption | 3.925 MMscf/hr | = 4,157 MMBtu/hr / 1,059 Btu/scf |
| Maximum Simulated Fuel Consumption | 34,385 MMscf/yr | = 8,760 hr/yr * 3.925 MMscf/hr |
| SCC Code: | 20100201 | Electric Generation (2-01), Turbine (2-01-002-01) |
| SCC Units: | | Million Cubic Feet Natural Gas Burned (MMscf) |

5.3 Derivation and Documentation of Steady-State Operation Emission Factors

5.3.1 NSR-Regulated Pollutants

> Controlled emission factors (EFs) for all NSR-regulated pollutants have been calculated as described in Section 4 for the worst-case annual operating profile out of the four scenarios described therein. Any deviations from the vendor estimates are noted below. Lead emissions are addressed in the HAP subsection below.

NO_x

| | | |
|--|------------------------------|--|
| Concentration in stack exhaust after SCR | 2 ppmvd @ 15% O ₂ | LG&E's vendor guarantee requirement for NGCC |
| Controlled Emission Factor | 8.589 lb/MMscf | See Section 4.6 for derivation |
| Controlled Emission Rate | 33.71 lb/hr | = 8.589 lb/MMscf x 3.925 MMscf/hr |
| Control Efficiency (not guaranteed) | 90 % | Nominal value for a SCR selected for purposes of defining an uncontrolled emission factor. Ranges between 75% and 91% depending on available nitrogen content and GT combustor design/operation. |
| Uncontrolled Emission Factor | 85.892 lb/MMscf | = 8.589 lb/MMscf / (100% - 90%) |

CO

| | | |
|---|------------------------------|--|
| Concentration in stack exhaust after oxidation catalyst | 2 ppmvd @ 15% O ₂ | LG&E's vendor guarantee requirement for GT |
| Controlled Emission Factor | 5.226 lb/MMscf | See Section 4.6 for derivation |
| Controlled Emission Rate | 20.51 lb/hr | = 5.226 lb/MMscf x 3.925 MMscf/hr |
| Control Efficiency (not guaranteed) | 90 % | Nominal value for an oxidation catalyst |
| Uncontrolled Emission Factor | 52.259 lb/MMscf | = 5.226 lb/MMscf / (100% - 90%) |

VOC

| | | |
|--|---------------------------------|--|
| Concentration in Stack Exhaust | 1.23 ppmvd @ 15% O ₂ | LG&E's vendor guarantee requirement for GT |
| Controlled Emission Factor | 1.824 lb/MMscf | See Section 4.6 for derivation |
| Controlled Emission Rate | 7.16 lb/hr | = 1.824 lb/MMscf x 3.925 MMscf/hr |
| Control Efficiency (not guaranteed) | 50 % | Based on expected VOM control efficiency from catalytic oxidation. |
| Uncontrolled Emission Factor | 3.649 lb/MMscf | = 1.824 lb/MMscf / (100% - 50%) |

SO₂

> All vendors were told that the pipeline tariff is based on a sulfur content on 0.5 gr/100 scf (Cscf), and the highest sulfur measured in the last 4 years was 0.019 gr/Cscf. The following estimate is based solely on a maximum sulfur input of 0.5 gr/Cscf and 100% conversion from S to SO₂. In reality, the SO₂ should be reduced by the amount of SO₂ converted to SO₃, which can be converted further to H₂SO₄, (NH₄)₂SO₄, and/or (NH₄)HSO₄. For simplicity, the following methodology does not account for these further reductions and thus the emission estimates are conservative.

| | | |
|--|-----------------|---|
| Max sulfur content for pipeline gas | 0.5 lb/Cscf | |
| Max actual sulfur content for pipeline gas in last 4 yrs | 0.019 lb/Cscf | <i>Cited for informational purposes only.</i> |
| Molecular Weight of S | 32.07 lb/lbmol | |
| Molecular Weight of SO ₂ | 64.07 lb/lbmol | |
| Uncontrolled Emission Rate | 5.60 lb/hr | = 0.5 lb/Cscf x 10,000 Cscf/MMscf / 7,000 gr/lb / 1,059 x 4,157 MMBtu/hr x 64.07 lb /lbmol SO ₂ / 32.07 lb/lbmol S x 1 lbmol SO ₂ /1 lbmol S x 100% |
| Uncontrolled Emission Factor | 1.427 lb/MMscf | = 5.60 lb/hr / 3.925 MMscf/hr |
| Uncontrolled En | 0.0013 lb/MMBtu | = 5.60 lb/hr / 4,157 MMBtu/hr |

H₂SO₄**Imber**

- > Within the combustion process, SO₂ can be further oxidized into SO₃, which then can be converted further to H₂SO₄, (NH₄)₂SO₄, and/or (NH₄)HSO₄. This conversion is influenced by the sulfur content in the fuel, ambient temperature/relative humidity, evaporative cooling operation, duct burner operation, oxidation over the oxidation catalyst, oxidation within the SCR, available moisture, ammonia slip concentration, acid dew point, etc. The estimates below are based on the following citation, "Pages 6-4 & 6-5 of Estimating Total Sulfuric Acid Emissions from Stationary Power Plants: 2018 Update. EPRI, Palo Alto, CA: 2018. 3002012398", where the total conversion assumes 10% conversion for GT/DB + 3% for SCR + 10% for oxidation catalyst.

| | | |
|---|----------------|--|
| Molecular Weight of SO ₃ | 80.06 lb/lbmol | |
| Estimated SO ₂ to SO ₃ Conversion Rate | 23% | 10% conversion in GT/DB + 3% for SCR + 10% conversion across catalyst |
| Estimated SO ₃ to H ₂ SO ₄ Conversion Rate | 100% | Conservative assumption |
| Molecular Weight of H ₂ SO ₄ | 98.08 lb/lbmol | |
| Uncontrolled Emission Rate of H ₂ SO ₄ | 1.97 lb/hr | = 5.60 lb/hr SO ₂ * 23% SO ₂ to SO ₃ * 80.06 lb/lbmol SO ₃ / 64.07 lb/lbmol SO ₂ * 1 lbmole SO ₃ / 1 lbmole SO ₂ * 100% SO ₃ to H ₂ SO ₄ * 98.08 lb/lbmol H ₂ SO ₄ / 80.06 lb/lbmol SO ₃ * 1 lbmol H ₂ SO ₄ / 1 lbmol SO ₃ |
| Uncontrolled Emission Factor of H ₂ SO ₄ | 0.503 lb/MMscf | = 1.97 lb/hr / 3.925 MMscf/hr |

PM/PM₁₀/PM_{2.5}

- > Steady-state generation of PM should be negligible from this NGCC system. For example, one prospective GT/DB vendor stated the following in their documentation, "PM-10 emissions from natural gas combustion are essentially zero (no emissions from the combustion process itself). The reported levels in the gathered data are due to non-combustion factors, which include test sampling and construction debris." When LG&E asked each vendor to provide PM estimates, all vendors provided overly conservative estimates of PM (not guarantees). Given the presence of the oxidation catalyst system, formation of condensable PM (CPM) and sub-micron filterable PM is a possibility under certain conditions. One pathway is the sulfate formation from H₂SO₄, (NH₄)₂SO₄, and/or (NH₄)HSO₄, as well as the nitrate formation in the form of NH₄NO₃. However, the PM emissions from these pathways are still expected to be low. Regardless, given uncertainties, LG&E conservatively used the information provided by the vendors for defining PM emissions. In all cases, all PM can be assumed to be less than 2.5 μm in mean diameter (i.e., PM = PM₁₀ = PM_{2.5}).

| | | |
|------------------------------|-----------------|-----------------------------------|
| Uncontrolled Emission Factor | 5.717 lb/MMscf | See Section 4.6 for derivation |
| Uncontrolled Emission Factor | 0.0054 lb/MMBtu | = 5.717 lb/MMscf / 1,059 Btu/scf |
| Uncontrolled Emission Rate | 22.44 lb/hr | = 5.717 lb/MMscf x 3.925 MMscf/hr |

Greenhouse Gases

- > Emission factors for CO₂ are based on Subpart C of EPA's Mandatory Greenhouse Gas Reporting Rule (MRR, 40 CFR 98 Subpart C Table C-1). AP-42 emission factors in Section 3.1 have been used for the CH₄ and N₂O emission factors.
- > The global warming multiplying factors for CH₄ and N₂O are those specified in 40 CFR 98 Subpart A. These are used to calculate the overall CO₂e emissions.

CO₂

| | | |
|------------------------------|------------------|--|
| Uncontrolled Emission Factor | 116.98 lb/MMBtu | 40 CFR 98, Subpart C, Table C-1; converted from 53.06 kg/MMBtu to lb/MMBtu |
| Uncontrolled Emission Factor | 123,879 lb/MMscf | = 116.98 lb/MMBtu * 1,059 MMBtu/MMscf |
| Uncontrolled Emission Rate | 486,246 lb/hr | = 123,879 lb/MMscf x 3.925 MMscf/hr |

CH₄

| | | |
|------------------------------|-----------------|---|
| Uncontrolled Emission Factor | 0.0086 lb/MMBtu | AP-42 Section 3.1 Stationary Gas Turbines, Table 3.1-2a |
| | 8.772 lb/MMscf | = 0.0086 lb/MMBtu x 1,020 MMBtu/MMscf per AP-42 |

N₂O

| | | |
|------------------------------|-----------------|---|
| Uncontrolled Emission Factor | 0.0030 lb/MMBtu | AP-42 Section 3.1 Stationary Gas Turbines, Table 3.1-2a |
| | 3.060 lb/MMscf | = 0.0030 lb/MMBtu x 1,020 MMBtu/MMscf per AP-42 |

CO₂e

Global Warming Potentials of GHGs per 40 CFR 98 Subpart A, Table A-1.

| | |
|------------------|-----|
| CO ₂ | 1 |
| CH ₄ | 25 |
| N ₂ O | 298 |

| | | |
|------------------------------|------------------|--|
| Uncontrolled Emission Factor | 125,010 lb/MMscf | (CO ₂ EF) + (CH ₄ EF x CH ₄ GWP) + (N ₂ O EF x N ₂ O GWP) |
|------------------------------|------------------|--|

5.3.2 Ammonia (from Ammonia Slip in SCR)

NH₃

| | | |
|--------------------------------|------------------------------|--|
| Concentration in stack exhaust | 5 ppmvd @ 15% O ₂ | LG&E's vendor guarantee requirement for NGCC |
| Uncontrolled Emission Factor | 7.141 lb/MMscf | See Section 4.6 for derivation |
| Uncontrolled Emission Rate | 28.03 lb/hr | = 7.141 lb/MMscf x 3.925 MMscf/hr |

Imber

5.3.3 Hazardous Air Pollutants for GT

Formaldehyde

| | | |
|--------------------------------|----------------------------------|---|
| Concentration in stack exhaust | 0.091 ppmvd @ 15% O ₂ | LG&E's vendor guarantee requirement per 40 CFR §63.6100 and Table 1 of NESHAP YYYY |
| Molecular weight of HCHO | 30.031 lb/lbmol | |
| Oxygen based F-Factor | 8.638 dscf/MMBtu | RM Method 19 determination of Fd factor for natural gas combustion can use a default value of 8,710, or use equations 19-13 through 19.15. LG&E chose to use Vendor A's derived Fd at ~8638 dscf/MMBtu. |
| Uncontrolled Emission Rate | 0.90 lb/hr | = 1.0 atm STD x 30.031 lb/lbmol HCHO / 0.7302 ft ³ -atm/lbmol-°R / 527.67°R STD x 0.091 ppmvd @ 15% O ₂ / 1E6 x 8,638.0 dscf/MMBtu x (20.9/(20.9-15)) x 4,157 MMBtu/hr |
| Uncontrolled Emission Factor | 0.230 lb/MMscf | = 0.90 lb/hr / 3.925 MMscf/hr |

> Other than for formaldehyde (described above), emission factors for organic and metallic HAP emissions from natural gas-fired turbines published in AP-42, Section 3.1 are used to estimate potential emissions.

| Pollutant | CAS No. | GT | | Oxidation | GT After | GT After | Basis | Note |
|-----------------|-----------|-------------------------|-------------------------|--|----------------------------------|----------------------------------|------------------------------|------|
| | | Uncontrld EF (lb/MMBtu) | Uncontrld EF (lb/MMscf) | Catalyst Control Efficiency ⁴ (%) | Oxidation Catalyst EF (lb/MMBtu) | Oxidation Catalyst EF (lb/MMscf) | | |
| 1,3-Butadiene | 106-99-0 | 4.3E-07 | 4.386E-04 | 50% | 2.2E-07 | 2.2E-04 | AP-42 Table 3.1 | 2 |
| Acetaldehyde | 75-07-0 | 3.5E-04 | 3.590E-01 | 50% | 1.8E-04 | 1.8E-01 | AP-42 Table 3.1 & 3-4 of BID | 1, 2 |
| Acrolein | 107-02-8 | 6.4E-06 | 6.528E-03 | 43% | 3.6E-06 | 3.7E-03 | AP-42 Table 3.1 & 3-4 of BID | 1 |
| Benzene | 71-43-2 | 1.2E-05 | 1.224E-02 | 73% | 3.3E-06 | 3.3E-03 | AP-42 Table 3.1 & 3-4 of BID | 1 |
| Ethylbenzene | 100-41-4 | 3.2E-05 | 3.264E-02 | 50% | 1.6E-05 | 1.6E-02 | AP-42 Table 3.1 | 2 |
| Formaldehyde | 50-00-0 | 7.1E-04 | 7.242E-01 | 68% | 2.3E-04 | 2.3E-01 | LG&E Requirement | 2, 3 |
| Naphthalene | 91-20-3 | 1.3E-06 | 1.326E-03 | 50% | 6.5E-07 | 6.6E-04 | AP-42 Table 3.1 | 2 |
| PAH | | 2.2E-06 | 2.244E-03 | 50% | 1.1E-06 | 1.1E-03 | AP-42 Table 3.1 | 2 |
| Propylene Oxide | 75-56-9 | 2.9E-05 | 2.958E-02 | 50% | 1.5E-05 | 1.5E-02 | AP-42 Table 3.1 | 2 |
| Toluene | 108-88-3 | 1.3E-04 | 1.326E-01 | 50% | 6.5E-05 | 6.6E-02 | AP-42 Table 3.1 | 2 |
| Xylenes | 1330-20-7 | 6.4E-05 | 6.528E-02 | 50% | 3.2E-05 | 3.3E-02 | AP-42 Table 3.1 | 2 |

1. Controlled emission factors (Oxidation Catalyst) for Acetaldehyde, Acrolein and Benzene are obtained from U.S. EPA's Emission Factor Documentation for AP-42 Section 3.1 Stationary Gas Turbines.

2. Emission factors for 1,3- Butadiene, Acetaldehyde, Ethylbenzene, Propylene Oxide, Toluene, Xylenes, Naphthalene and PAH are obtained from AP-42 Chapter 3.1, Table 3.1-3 (Stationary Gas Turbines, April, 2000). A control efficiency of 50% was applied to these uncontrolled emission factors based on expected VOM control efficiency from catalytic oxidation.

3. See LG&E requirement above for formaldehyde that sets the GT post-oxidation catalyst EF.

4. The control efficiencies are estimates and should not be construed as guarantees.

5.3.4 Hazardous Air Pollutants for DB

> Emission factors from DBs are obtained from AP-42, Chapter 1.4, Table 1.4-2, 1.4-3, 1.4-4 (Emission Factors for Natural Gas Fired External Combustion Sources, July, 1998). Polycyclic aromatic hydrocarbons were omitted from the DB emission factor list since they are accounted for with the GT.

| Pollutant | CAS No. | DB | DB | Oxidation | DB After | DB After | Basis | Note |
|-----------------|------------|-------------------------------|-------------------------------|---|--|--|-------------------|---------|
| | | Uncontrld EF (lb/MMBtu) | Uncontrld EF (lb/MMscf) | Catalyst Control Efficiency ⁵ (%) | Oxidation Catalyst EF (lb/MMBtu) | Oxidation Catalyst EF (lb/MMscf) | | |
| Benzene | 71-43-2 | 2.1E-06 | 2.1E-03 | 50% | 1.0E-06 | 1.1E-03 | AP-42 Table 1.4-3 | 1, 2, 4 |
| Dichlorobenzene | 25321-22-6 | 1.2E-06 | 1.2E-03 | 50% | 5.9E-07 | 6.0E-04 | AP-42 Table 1.4-3 | 1, 2 |
| Formaldehyde | 50-00-0 | | | | | | | 3 |
| Naphthalene | 91-20-3 | 6.0E-07 | 6.1E-04 | 50% | 3.0E-07 | 3.1E-04 | AP-42 Table 1.4-3 | 1, 2, 4 |
| Hexane | 110-54-3 | 1.8E-03 | 1.8E+00 | 50% | 8.8E-04 | 9.0E-01 | AP-42 Table 1.4-3 | 1, 2 |
| Toluene | 108-88-3 | 3.3E-06 | 3.4E-03 | 50% | 1.7E-06 | 1.7E-03 | AP-42 Table 1.4-3 | 1, 2, 4 |
| Arsenic | 7440-38-2 | 2.0E-07 | 2.0E-04 | | 2.0E-07 | 2.0E-04 | AP-42 Table 1.4-4 | 1 |
| Beryllium | 7440-41-7 | 1.2E-08 | 1.2E-05 | | 1.2E-08 | 1.2E-05 | AP-42 Table 1.4-4 | 1 |
| Cadmium | 7440-43-9 | 1.1E-06 | 1.1E-03 | | 1.1E-06 | 1.1E-03 | AP-42 Table 1.4-4 | 1 |
| Chromium | 7440-47-3 | 1.4E-06 | 1.4E-03 | | 1.4E-06 | 1.4E-03 | AP-42 Table 1.4-4 | 1 |
| Cobalt | 7440-48-4 | 8.2E-08 | 8.4E-05 | | 8.2E-08 | 8.4E-05 | AP-42 Table 1.4-4 | 1 |
| Lead | 7439-92-1 | 4.9E-07 | 5.0E-04 | | 4.9E-07 | 5.0E-04 | AP-42 Table 1.4-4 | 1 |
| Manganese | 7439-96-5 | 3.7E-07 | 3.8E-04 | | 3.7E-07 | 3.8E-04 | AP-42 Table 1.4-4 | 1 |
| Mercury | 7439-97-6 | 2.5E-07 | 2.6E-04 | | 2.5E-07 | 2.6E-04 | AP-42 Table 1.4-4 | 1 |
| Nickel | 7440-02-0 | 2.1E-06 | 2.1E-03 | | 2.1E-06 | 2.1E-03 | AP-42 Table 1.4-4 | 1 |
| Selenium | 7782-49-2 | 2.4E-08 | 2.4E-05 | | 2.4E-08 | 2.4E-05 | AP-42 Table 1.4-4 | 1 |

1. Emission factors are obtained from AP-42, Chapter 1.4, Table 1.4-2, 1.4-3, 1.4-4 (Emission Factors for Natural Gas Fired External Combustion Sources, July, 1998).

2. A control efficiency of 50% was applied to these uncontrolled emission factors based on expected VOM control efficiency from catalytic oxidation.

3. See LG&E requirement for formaldehyde produced in the GT, as it applies to the entire NGCC.

4. Not used in PTE analysis because GT EF is higher than DB.

5. The control efficiencies are estimates and should not be construed as guarantees.

5.4 NGCC Potential Emissions Summary - Steady State Operations

Imber

- > The following represents the potential emissions assuming the GT+DB combust natural gas at 4,157 MMBtu/hr heat input for 8,760 hours per year, which is not possible given the range of shutdowns and startups that can occur during a particular year. However, to be conservative and to avoid any restriction on the hours of "normal" or steady state operations, this approach is used. Also, the size of the NG-fired DBs are ≤ 296 MMBtu/hr, yet if there was an EF that had a greater lb/MMscf for DB operation, it was used in the PTE, which also adds conservatism to the estimated PTE values.
- > The EFs used for HAPs represent the higher of GT or DB emission factors, even though it is unrealistic for a DB to be operational outside of brief summertime events. Thus, the HAP potential emission values are very conservative.

Process ID 1: Steady-State Operation with or without DBs

| | Uncontrolled EF | | Uncontrolled Emissions | | ~Control Efficiency | Controlled Emissions | |
|-----------------------------|-----------------|--------------------------|------------------------|-----------|---------------------|----------------------|-----------|
| | (lb/MMscf) | Basis | (lb/hr) | (tpy) | | (lb/hr) | (tpy) |
| Regulated Pollutants | | | | | | | |
| NOX | 85.892 | LG&E Requirement | 337.1 | 1476.7 | 90% | 33.7 | 147.7 |
| CO | 52.259 | LG&E Requirement | 205.1 | 898.4 | 90% | 20.5 | 89.8 |
| VOC | 3.649 | LG&E Requirement | 14.32 | 62.7 | 50% | 7.16 | 31.4 |
| PM | 5.717 | Vendor Estimate | 22.4 | 98.3 | | 22.4 | 98.3 |
| PM10 | 5.717 | Vendor Estimate | 22.4 | 98.3 | | 22.4 | 98.3 |
| PM2.5 | 5.717 | Vendor Estimate | 22.4 | 98.3 | | 22.4 | 98.3 |
| SO2 | 1.427 | Pipeline spec conversion | 5.60 | 24.5 | | 5.60 | 24.5 |
| H2SO4 | 0.503 | Pipeline spec conversion | 1.97 | 8.6 | | 1.97 | 8.6 |
| NH3 | 7.141 | LG&E Requirement | 28.0 | 122.8 | | 28.0 | 122.8 |
| CO2e | 125,010 | 40 CFR 98, Table C-1 | 490,686 | 2,149,207 | | 490,686 | 2,149,207 |

| CAS No. | Uncontrolled EF | | Uncontrolled Emissions | | ~Control Efficiency | Controlled Emissions | | |
|---------------------------------|-----------------|----------|------------------------------|----------|---------------------|----------------------|----------|----------|
| | (lb/MMscf) | Basis | (lb/hr) | (tpy) | | (lb/hr) | (tpy) | |
| Hazardous Air Pollutants | | | | | | | | |
| 1,3-Butadiene | 106-99-0 | 4.39E-04 | AP-42 Table 3.1 | 0.002 | 0.008 | 50% | 0.001 | 0.004 |
| Acetaldehyde | 75-07-0 | 3.59E-01 | AP-42 Table 3.1 & 3-4 of BID | 1.409 | 6.173 | 50% | 0.705 | 3.086 |
| Acrolein | 107-02-8 | 6.53E-03 | AP-42 Table 3.1 & 3-4 of BID | 0.026 | 0.112 | 43% | 0.014 | 0.063 |
| Benzene | 71-43-2 | 1.22E-02 | AP-42 Table 3.1 & 3-4 of BID | 0.048 | 0.210 | 73% | 0.013 | 0.057 |
| Dichlorobenzene | 25321-22-6 | 1.20E-03 | AP-42 Table 1.4-3 | 0.005 | 0.021 | 50% | 0.002 | 0.010 |
| Ethylbenzene | 100-41-4 | 3.26E-02 | AP-42 Table 3.1 | 0.128 | 0.561 | 50% | 0.064 | 0.281 |
| Formaldehyde | 50-00-0 | 7.24E-01 | LG&E Requirement | 2.843 | 12.451 | 68% | 0.902 | 3.951 |
| Hexane | 110-54-3 | 1.80E+00 | AP-42 Table 1.4-3 | 7.065 | 30.946 | 50% | 3.533 | 15.473 |
| Naphthalene | 91-20-3 | 1.33E-03 | AP-42 Table 3.1 | 0.005 | 0.023 | 50% | 0.003 | 0.011 |
| Propylene Oxide | 75-56-9 | 2.96E-02 | AP-42 Table 3.1 | 0.116 | 0.509 | 50% | 0.058 | 0.254 |
| Toluene | 108-88-3 | 1.33E-01 | AP-42 Table 3.1 | 0.520 | 2.28 | 50% | 0.260 | 1.14 |
| Xylenes | 1330-20-7 | 6.53E-02 | AP-42 Table 3.1 | 0.256 | 1.12 | 50% | 0.128 | 0.56 |
| Arsenic | 7440-38-2 | 2.00E-04 | AP-42 Table 1.4-4 | 7.85E-04 | 3.44E-03 | 0% | 7.85E-04 | 3.44E-03 |
| Beryllium | 7440-41-7 | 1.20E-05 | AP-42 Table 1.4-4 | 4.71E-05 | 2.06E-04 | 0% | 4.71E-05 | 2.06E-04 |
| Cadmium | 7440-43-9 | 1.10E-03 | AP-42 Table 1.4-4 | 4.32E-03 | 1.89E-02 | 0% | 4.32E-03 | 1.89E-02 |
| Chromium | 7440-47-3 | 1.40E-03 | AP-42 Table 1.4-4 | 5.50E-03 | 2.41E-02 | 0% | 5.50E-03 | 2.41E-02 |
| Cobalt | 7440-48-4 | 8.40E-05 | AP-42 Table 1.4-4 | 3.30E-04 | 1.44E-03 | 0% | 3.30E-04 | 1.44E-03 |
| Lead | 7439-92-1 | 5.00E-04 | AP-42 Table 1.4-4 | 1.96E-03 | 8.60E-03 | 0% | 1.96E-03 | 8.60E-03 |
| Manganese | 7439-96-5 | 3.80E-04 | AP-42 Table 1.4-4 | 1.49E-03 | 6.53E-03 | 0% | 1.49E-03 | 6.53E-03 |
| Mercury | 7439-97-6 | 2.60E-04 | AP-42 Table 1.4-4 | 1.02E-03 | 4.47E-03 | 0% | 1.02E-03 | 4.47E-03 |
| Nickel | 7440-02-0 | 2.10E-03 | AP-42 Table 1.4-4 | 8.24E-03 | 3.61E-02 | 0% | 8.24E-03 | 3.61E-02 |
| Selenium | 7782-49-2 | 2.40E-05 | AP-42 Table 1.4-4 | 9.42E-05 | 4.13E-04 | 0% | 9.42E-05 | 4.13E-04 |
| Total HAP | | 3.171 | | 12.447 | 54.519 | | 5.707 | 24.997 |

5.5 Capacity and Underlying Assumptions for E49b thru E49e Cold, Warm, Hot, and Shutdown Events Imber

> The following are estimates provided by each vendor:

Time in between event and SD

> Cold starts are preceded by over 72 hours of shutdown.

Maximum Annual Cold Start Events 5 events/yr 40-70 min/C-SU >72 hr of SD

> Warm start cool down duration ranges from >8 to <72 hours after shutdown. Assume 48 hours.

Maximum Annual Warm Start Events 45 events/yr 30-60 min/W-SU 8-72 hr of SD

> Hot starts are defined as taking place within 8 hours of the previous shutdown.

Maximum Annual Hot Start Events 100 events/yr 21-35 min/H-SU 0-8 hr of SD

> Shutdowns will occur for 12-21 min and the total number of events is the sum of all cold, warm, and hot startups.

Maximum Annual Shutdown Events 150 events/yr 12-21 min/SD

> There is not an SCC code for turbine SUSD events; therefore, LG&E used the generic not classified category for industrial processes on an "each" basis.

SCC Code: 39999993 Misc. Industrial Processes (3-99), Others Not Classified (3-99-999-93)

SCC Units: Each Event (i.e., "lb per event")

5.5.1 Startup and Shutdown Event Emission Factors

> The EFs presented below for emissions of NSR-regulated pollutants from startup and shutdown events are based on the highest vendor-provided lb/event.

| Event Type | NO _x EF (lb/event) | CO EF (lb/event) | VOC EF (lb/event) | PM/PM ₁₀ / PM _{2.5} EF |
|------------|----------------------------------|---------------------|----------------------|---|
| | | | | (lb/event) |
| Cold Start | 420 | 758 | 135 | 32 |
| Warm Start | 260 | 476 | 121 | 27 |
| Hot Start | 135 | 303 | 91 | 15 |
| Shutdown | 78 | 244 | 118 | 5 |

5.6 GT Cold, Warm, & Hot Startups, and Shutdown Potential Emissions Summary

> The following potential emissions represent the maximum pounds per SUSD event by pollutant.

| Pollutant | Uncontrolled EF | | Uncontrolled Emissions | | Control Efficiency | Controlled Emissions | |
|------------------------------------|-----------------|--------------|------------------------|-------|--------------------|----------------------|-------|
| | (lb/event) | Basis | (lb/yr) | (tpy) | | (lb/yr) | (tpy) |
| Process ID 2: Cold Startups | | | | | | | |
| NOX | 420 | Vendor A Max | 2,100 | 1.05 | N/A | 2,100 | 1.05 |
| CO | 758 | Vendor C Max | 3,790 | 1.90 | N/A | 3,790 | 1.90 |
| VOC | 135 | Vendor B Max | 675 | 0.34 | N/A | 675 | 0.34 |
| PM | 32 | Vendor A Max | 160 | 0.08 | N/A | 160 | 0.08 |
| PM10 | 32 | Vendor A Max | 160 | 0.08 | N/A | 160 | 0.08 |
| PM2.5 | 32 | Vendor A Max | 160 | 0.08 | N/A | 160 | 0.08 |
| Process ID 3: Warm Startups | | | | | | | |
| NOX | 260 | Vendor A Max | 11,700 | 5.85 | N/A | 11,700 | 5.85 |
| CO | 476 | Vendor B Max | 21,420 | 10.7 | N/A | 21,420 | 10.7 |
| VOC | 121 | Vendor B Max | 5,445 | 2.72 | N/A | 5,445 | 2.72 |
| PM | 27 | Vendor A Max | 1,215 | 0.61 | N/A | 1,215 | 0.61 |
| PM10 | 27 | Vendor A Max | 1,215 | 0.61 | N/A | 1,215 | 0.61 |
| PM2.5 | 27 | Vendor A Max | 1,215 | 0.61 | N/A | 1,215 | 0.61 |
| Process ID 4: Hot Startups | | | | | | | |
| NOX | 135 | Vendor A Max | 13,500 | 6.75 | N/A | 13,500 | 6.75 |
| CO | 303 | Vendor B Max | 30,300 | 15.2 | N/A | 30,300 | 15.2 |
| VOC | 91 | Vendor B Max | 9,100 | 4.55 | N/A | 9,100 | 4.55 |
| PM | 15 | Vendor B Max | 1,500 | 0.75 | N/A | 1,500 | 0.75 |
| PM10 | 15 | Vendor B Max | 1,500 | 0.75 | N/A | 1,500 | 0.75 |
| PM2.5 | 15 | Vendor B Max | 1,500 | 0.75 | N/A | 1,500 | 0.75 |
| Process ID 5: Shutdowns | | | | | | | |
| NOX | 78 | Vendor B Max | 11,700 | 5.85 | N/A | 11,700 | 5.85 |
| CO | 244 | Vendor C Max | 36,600 | 18.3 | N/A | 36,600 | 18.3 |
| VOC | 118 | Vendor B Max | 17,700 | 8.9 | N/A | 17,700 | 8.85 |
| PM | 5 | Vendor B Max | 750 | 0.38 | N/A | 750 | 0.38 |
| PM10 | 5 | Vendor B Max | 750 | 0.38 | N/A | 750 | 0.38 |
| PM2.5 | 5 | Vendor B Max | 750 | 0.38 | N/A | 750 | 0.38 |

5.7 NGCC Overall Combined PTE Summary - Steady State Operations + SUSD Events

- > The table below summarizes the PTE from all Process IDs. The total emissions from the NGCC include 8,760 hours at "normal" or steady state operations plus (not minus) the total hours and emissions of SUSD events while the GT is emitting.
- > The calculation of PTE is conservative since the hours in which SUSD events are occurring are not subtracted from the total steady state operational hours (8,760 hr/yr). In reality, based on the SUSD assumptions, there could be as much as 127 hours of SUSD conditions each year.
- > Additionally, if the GT/DB experienced all 150 events, there would be no emissions for up to 3,447 hr/yr if one accounted for the downtime in-between SUSD events (i.e., 5 C-SU * 72 avg hrs down + 45 W-SU * 48 avg hrs down + 100 H-SU * 8 avg hrs down).
- > Combined Process ID potential emissions are only shown for NO_x, CO, VOC, and PM/PM₁₀/PM_{2.5} since these are the only pollutants for which incremental emissions during SUSD events are quantified. Potential emissions for other pollutants and HAPs are as shown in Section 5.4.

| Pollutant | PTE (tpy) |
|------------------|----------------------|
| NOX | 167.2 |
| CO | 135.9 |
| VOC | 47.8 |
| PM | 100.1 |
| PM10 | 100.1 |
| PM2.5 | 100.1 |

6. Auxiliary Steam Boiler - Emissions Calculations

> A new auxiliary steam boiler will be installed as part of the NGCC project. Potential emissions for the auxiliary steam boiler are documented in this section.

6.1 Auxiliary Boiler Nomenclature and Specifications

> Proposed nomenclature for the new Aux Boiler associated with the NGCC Plant:

| | |
|-----------------|---|
| Emission Unit: | U24 - Auxiliary Steam Boiler |
| Emission Point: | E50 - Natural Gas Combustion w/ LNB & FGR |
| Control Device: | -- -- |
| Stack ID: | S50 |

> LG&E plans to provision a NG-fired auxiliary boiler for the NGCC project. While construction of the GT/DB is targeted to commence in March 2024, because the construction timeline for the Aux Boiler is much shorter, it may not start construction until later in the construction phase. As such, the specific make and model for the Aux Boiler will not be known until farther on in the project development. However, LG&E plans to procure a boiler with a maximum heat input capacity of 99.9 MMBtu/hr or less and the boiler will be equipped with low-NOX burners with a flue gas recirculation system. For permitting purposes and to calculate potential emissions, this maximum heat input capacity is assumed.

| | |
|-----------------|--|
| SCC Code | 10200602 |
| SCC Description | External Combustion Boilers - Industrial (1-02) - Natural Gas (1-02-006) - 10-100 Million Btu/hr (1-02-006-02) |
| SCC Units | Million Cubic Feet Natural Gas Burned |

> Although the Aux Boiler will only operate periodically to assist with warm or cold startups of the gas turbine (U23) and to provide freeze protection during winter downtime hours, potential emissions are calculated based on 8,760 hr/yr of operation for simplicity and conservatism.

| | | |
|--|-------------------------------|---|
| Max Annual Operating Hours | 8,760 hr/yr | |
| Heat Input Capacity | 99.9 MMBtu/hr | |
| Gross Steam Generation | 82,745 lb/hr | |
| Net Steam Generation | 69,645 lb/hr | |
| NG Heating Value | 1,059 Btu/scf | Average for Mill Creek Generating Station Inlet Gas |
| Max Gas Firing Rate at Average HHV | 0.0943 MMscf/hr | 99.9 MMBtu/hr / 1,059 MMBtu/MMscf = 0.0943 MMscf/hr |
| NG HHV used for AP-42 1.4 Emission Factors | 1,020 Btu/scf | |

6.2 Derivation and Documentation of Emission Factors

6.2.1 Constants and Conversion Factors

| | | |
|---|---|---|
| Molar Volume (at STP) | 385.5 scf/lbmol | = 528 °R / 1 atm x 0.7302 cf-atm/(lbmol-°R) |
| Atomic Weight of Sulfur | 32.07 lb/lbmol | |
| Molecular Weight of NO ₂ | 46.01 lb NO ₂ /lbmol | |
| Molecular Weight of CO | 28.01 lb CO/lbmol | |
| Molecular Weight of SO ₂ | 64.07 lb SO ₂ /lbmol | |
| Molecular Weight of H ₂ SO ₄ | 98.079 lb H ₂ SO ₄ /lbmol | |
| F-Factor for natural gas combustion from 40 CFR 60, Appendix A (Method 19) | 8,710 dscf/MMBtu | |
| Concentration of Sulfur in Natural Gas | 0.5 gr/Ccf | Assumed max sulfur content for Mill Creek inlet natural gas |
| Estimated SO ₂ to SO ₃ Conversion Rate | 5 % | |
| Estimated SO ₃ to H ₂ SO ₄ Conversion Rate | 100 % | |

6.2.2 Prospective Vendor Data

| Pollutant | CAS # | Concentration (ppmv @ 3% O ₂) | Concentration (ppmv @ 0% O ₂) | Emission Factor Basis |
|-----------|------------|--|--|--|
| NOx | na | 30 | 35 | LG&E requirement for boiler with Low NOx Burners (LNB) and Flue Gas Recirculation (FGR) firing at high fire (100% load); exhaust expressed at 3% oxygen concentration, corrected to 0% oxygen concentration by multiplying by 20.9% / (20.9% - 3%) |
| CO | 00630-08-0 | 50 | 58 | LG&E requirement at 3% oxygen concentration, corrected to 0% oxygen concentration by multiplying by 20.9% / (20.9% - 3%) |

6.2.3 Regulated NSR Pollutant Emission Factors

| Pollutant | CAS # | Emission Factor (lb/MMBtu) | Emission Factor (lb/MMscf) | Emission Factor Basis |
|--------------------------------|------------|----------------------------------|----------------------------------|--|
| NOx | 10102-44-0 | 0.0364 | 38.557 | LG&E requirement (Vendor Guarantee) 35 lbmol NO ₂ /10 ⁶ lbmol air x 46.01 lb NO ₂ /lbmol / 385.5 scf/lbmol x 8,710 dscf/MMBtu x 1,059 MMBtu/MMscf = 38.557 lb/MMscf |
| CO | 00630-08-0 | 0.0369 | 39.121 | LG&E requirement (Vendor Guarantee) 58 lbmol CO/10 ⁶ lbmol air x 28.01 lb CO/lbmol / 385.5 scf/lbmol x 8,710 dscf/MMBtu x 1,059 MMBtu/MMscf = 39.121 lb/MMscf |
| VOC | na | 0.0054 | 5.5 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM/PM10/PM2.5-Filt | | 0.0019 | 1.90 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM-Condensable | | 0.0015 | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database |
| PM/PM10/PM2.5 Total | | 0.0034 | 3.47 | AP-42 Table 1.4-2 + EPA Speciate Database |
| SO ₂ | 07446-09-5 | 0.0013 | 1.427 | 0.5 gr/Ccf / 7,000 gr/lb x 64.07 lb SO ₂ /lbmol / 32.07 lb S/lbmol x 10,000 Ccf/MMscf = 1.427 lb/MMscf |
| H ₂ SO ₄ | 7664-93-9 | 1.03E-04 | 0.109 | 5% conversion of SO ₂ to SO ₃ and 100% conversion of SO ₃ to H ₂ SO ₄ 1.427 lb SO ₂ /MMscf x 5% x 100% x 98.079 lb H ₂ SO ₄ /lbmol / 64.07 lb SO ₂ /lbmol = 0.109 lb/MMscf |
| Lead | | 4.90E-07 | 0.0005 | AP-42, Section 1.4, Table 1.4-2 |
| CO ₂ | | 116.98 | 123,879 | 40 CFR 98, Subpart C, Table C-1; converted from 53.06 kg/MMBtu |
| CH ₄ | | 0.0022 | 2.335 | 40 CFR 98, Subpart C, Table C-2; converted from 0.001 kg/MMBtu |
| N ₂ O | | 0.0002 | 0.233 | 40 CFR 98, Subpart C, Table C-2; converted from 0.0001 kg/MMBtu |
| CO ₂ e | | 117.10 | 124,007 | = CO ₂ EF x CO ₂ GWP + CH ₄ EF x CH ₄ GWP + N ₂ O EF x N ₂ O GWP |

6.2.4 Hazardous Air Pollutants

> Emission factors for HAPs are obtained from AP-42, Chapter 1.4, Table 1.4-3 and 1.4-4 (Emission Factors for Natural Gas Fired External

| Pollutant | Emission Factor (lb/MMscf) |
|-----------|----------------------------------|
|-----------|----------------------------------|

Speciated Organic Compounds (AP-42, Table 1.4-3)

| | |
|-----------------|---------|
| Benzene | 2.1E-03 |
| Dichlorobenzene | 1.2E-03 |
| Formaldehyde | 7.5E-02 |
| Hexane | 1.8E+00 |
| Naphthalene | 6.1E-04 |
| Toluene | 3.4E-03 |

Metals (AP-42, Table 1.4-4)

| | |
|------------------|--------------|
| Arsenic | 2.0E-04 |
| Cadmium | 1.1E-03 |
| Chromium | 1.4E-03 |
| Manganese | 3.8E-04 |
| Mercury | 2.6E-04 |
| Nickel | 2.1E-03 |
| Total HAP | 1.888 |

6.3 Aux Boiler Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|---------------------------------|-----------------|---|---------------------|----------|
| | (lb/MMscf) | Basis | (lb/hr) | (tpy) |
| NO _x | 38.557 | LG&E Requirement | 3.637 | 15.93 |
| CO | 39.121 | LG&E Requirement | 3.690 | 16.16 |
| VOC | 5.5 | AP-42 Table 1.4-2 | 0.519 | 2.27 |
| PM/PM10/PM2.5-Filt | 1.9 | AP-42 Table 1.4-2 | 0.179 | 0.79 |
| PM-Condensable | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database | 0.148 | 0.65 |
| PM/PM10/PM2.5 Total | 3.47 | AP-42 Table 1.4-2 | 0.327 | 1.43 |
| SO ₂ | 1.43 | Pipeline spec conversion | 0.135 | 0.59 |
| H ₂ SO ₄ | 0.109 | Pipeline spec conversion | 0.010 | 0.05 |
| Lead | 0.0005 | AP-42, Table 1.4-2 | 4.72E-05 | 2.07E-04 |
| CO ₂ e | 124,007 | 40 CFR 98, Table C-1 | 11,698 | 51,238 |
| Hazardous Air Pollutants | 1.888 | Sum of HAPs | 0.178 | 0.78 |
| Benzene | 2.1E-03 | AP-42, Table 1.4-3 | 1.98E-04 | 8.68E-04 |
| Dichlorobenzene | 1.2E-03 | AP-42, Table 1.4-3 | 1.13E-04 | 4.96E-04 |
| Formaldehyde | 7.5E-02 | AP-42, Table 1.4-3 | 7.08E-03 | 3.10E-02 |
| Hexane | 1.8E+00 | AP-42, Table 1.4-3 | 0.170 | 0.744 |
| Naphthalene | 6.1E-04 | AP-42, Table 1.4-3 | 5.75E-05 | 2.52E-04 |
| Toluene | 3.4E-03 | AP-42, Table 1.4-3 | 3.21E-04 | 1.40E-03 |
| Arsenic | 2.0E-04 | AP-42, Table 1.4-4 | 1.89E-05 | 8.26E-05 |
| Cadmium | 1.1E-03 | AP-42, Table 1.4-4 | 1.04E-04 | 4.55E-04 |
| Chromium | 1.4E-03 | AP-42, Table 1.4-4 | 1.32E-04 | 5.78E-04 |
| Manganese | 3.8E-04 | AP-42, Table 1.4-4 | 3.58E-05 | 1.57E-04 |
| Mercury | 2.6E-04 | AP-42, Table 1.4-4 | 2.45E-05 | 1.07E-04 |
| Nickel | 2.1E-03 | AP-42, Table 1.4-4 | 1.98E-04 | 8.68E-04 |

Sample Calculations:

$$\text{NO}_x \text{ (lb/hr)} = 38.557 \text{ lb/MMscf} \times 0.0943 \text{ MMscf/hr} = 3.637 \text{ lb/hr NO}_x$$

$$\text{NO}_x \text{ (tpy)} = 3.637 \text{ lb/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 15.93 \text{ tpy NO}_x$$

7. Fuel Gas (Dewpoint) Preheater - Emissions Calculations

- > A new fuel gas preheater will be installed as part of the NGCC project to provide supplemental heating when needed to the incoming natural gas feed stream. Potential emissions for the preheater are documented in this section.

7.1 Preheater Nomenclature and Specifications

- > Proposed nomenclature for the new fuel gas (dewpoint) preheater associated with the NGCC Plant:

| | |
|-----------------|---|
| Emission Unit: | U26 - Fuel Gas (Dewpoint) Heater |
| Emission Point: | E52 - NG Fuel Combustion (15 MMBtu/hr) |
| Control Device: | -- -- |
| Stack ID: | S52 |

- > LG&E plans to provision a natural-gas fired preheater for the NGCC project. The specific make and model are will not be known until farther along in the project development phase. However, the maximum heat input capacity will be 15 MMBtu/hr or less and the preheater will be equipped with LNBS or LNBS with FGR. For permitting purposes and to calculate potential emissions, this maximum heat input capacity is assumed.

| | | |
|--|---|---|
| SCC Code | 39990003 | |
| SCC Description | Industrial Processes - Miscellaneous Manufacturing Industries (3-99) - Miscellaneous Manufacturing Industries (3-99-900) - Natural Gas: Process Heaters (3-99-900-03) | |
| SCC Units | Million Cubic Feet Natural Gas Burned | |
| Max Annual Operating Hours | 8,760 hr/yr | |
| Heat Input Capacity | 15 MMBtu/hr | |
| NG Heating Value | 1,059 Btu/scf | Average for Mill Creek Generating Station Inlet Gas |
| Max Gas Firing Rate at Average HHV | 0.0142 MMscf/hr | 15 MMBtu/hr / 1,059 MMBtu/MMscf = 0.0142 MMscf/hr |
| NG HHV used for AP-42 1.4 Emission Factors | 1,020 Btu/scf | |

7.2 Derivation and Documentation of Emission Factors

7.2.1 Constants and Conversion Factors

| Parameter | Value | Units | Basis |
|---|--------|--|---|
| Molar Volume (at STP) | 385.5 | scf/lbmol | = 528 °R / 1 atm x 0.7302 cf-atm/(lbmol-°R) |
| Atomic Weight of Sulfur | 32.07 | lb/lbmol | |
| Molecular Weight of NO ₂ | 46.01 | lb NO ₂ /lbmol | |
| Molecular Weight of CO | 28.01 | lb CO/lbmol | |
| Molecular Weight of SO ₂ | 64.07 | lb SO ₂ /lbmol | |
| Molecular Weight of H ₂ SO ₄ | 98.079 | lb H ₂ SO ₄ /lbmol | |
| F-Factor for natural gas combustion from 40 CFR 60, Appendix A (Method 19) | 8,710 | dscf/MMBtu | |
| Concentration of Sulfur in Natural Gas | 0.5 | gr/Ccf | Assumed max sulfur content for Mill Creek inlet natural gas |
| Estimated SO ₂ to SO ₃ Conversion Rate | 5 | % | |
| Estimated SO ₃ to H ₂ SO ₄ Conversion Rate | 100 | % | |

7.2.2 Prospective Vendor Data

| Pollutant | CAS # | Concentration (ppmv @ 3% O ₂) | Concentration (ppmv @ 0% O ₂) | Emission Factor Basis |
|-----------------|------------|--|--|---|
| NO _x | na | 30 | 35 | LG&E requirement for boiler at high fire (100% load); exhaust expressed at 3% oxygen concentration, corrected to 0% oxygen concentration by multiplying by 20.9% / (20.9% - 3%) |
| CO | 00630-08-0 | 101 | 118 | LG&E requirement at 100% load at 3% oxygen concentration, corrected to 0% oxygen concentration by multiplying by 20.9% / (20.9% - 3%) |

7.2.3 NSR-Regulated Pollutant Emission Factors

| Pollutant | CAS # | Emission Factor (lb/MMBtu) | Emission Factor (lb/MMscf) | Emission Factor Basis |
|--------------------------------|------------|----------------------------------|----------------------------------|--|
| NO _x | 10102-44-0 | 0.0364 | 38.557 | LG&E's Vendor requirement 35 lbmol NO ₂ /10 ⁶ lbmol air x 46.01 lb NO ₂ /lbmol / 385.5 scf/lbmol x 8,710 dscf/MMBtu x 1,059 MMBtu/MMscf = 38.557 lb/MMscf |
| CO | 00630-08-0 | 0.0746 | 79.025 | LG&E's Vendor requirement 118 lbmol CO/10 ⁶ lbmol air x 28.01 lb CO/lbmol / 385.5 scf/lbmol x 8,710 dscf/MMBtu x 1,059 MMBtu/MMscf = 79.025 lb/MMscf |
| VOC | na | 0.005 | 5.5 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM/PM10/PM2.5-Filt | | 0.0019 | 1.90 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM-Condensable | | 0.0015 | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database |
| PM/PM10/PM2.5 Total | | 0.0034 | 3.47 | AP-42 Table 1.4-2 + EPA Speciate Database |
| SO ₂ | 07446-09-5 | 0.0013 | 1.427 | 0.5 gr/Ccf / 7,000 gr/lb x 64.07 lb SO ₂ /lbmol / 32.07 lb S/lbmol x 10,000 |
| H ₂ SO ₄ | 7664-93-9 | 1.03E-04 | 0.109 | 5% conversion of SO ₂ to SO ₃ and 100% conversion of SO ₃ to H ₂ SO ₄ 1.427 lb SO ₂ /MMscf x 5% x 100% x 98.079 lb H ₂ SO ₄ /lbmol / 64.07 lb SO ₂ /lbmol = 0.109 lb/MMscf |
| Lead | | 4.72E-07 | 0.0005 | AP-42, Section 1.4, Table 1.4-2 |
| CO ₂ | | 116.98 | 123,879 | 40 CFR 98, Subpart C, Table C-1; converted from 53.06 kg/MMBtu |
| CH ₄ | | 0.0022 | 2.33 | 40 CFR 98, Subpart C, Table C-2; converted from 0.001 kg/MMBtu |
| N ₂ O | | 0.0002 | 0.233 | 40 CFR 98, Subpart C, Table C-2; converted from 0.0001 kg/MMBtu |
| CO _{2e} | | 117.10 | 124,007 | = CO ₂ EF x CO ₂ GWP + CH ₄ EF x CH ₄ GWP + N ₂ O EF x N ₂ O GWP |

7.2.4 Hazardous Air Pollutants

> Emission factors for HAPs are obtained from AP-42, Chapter 1.4, Table 1.4-3 and 1.4-4 (Emission Factors for Natural Gas Fired External

| Pollutant | Emission Factor (lb/MMscf) |
|---|-------------------------------|
| Speciated Organic Compounds (AP-42, Table 1.4-3) | |
| Benzene | 2.1E-03 |
| Dichlorobenzene | 1.2E-03 |
| Formaldehyde | 7.5E-02 |
| Hexane | 1.8E+00 |
| Naphthalene | 6.1E-04 |
| Toluene | 3.4E-03 |
| Metals (AP-42, Table 1.4-4) | |
| Arsenic | 2.0E-04 |
| Cadmium | 1.1E-03 |
| Chromium | 1.4E-03 |
| Manganese | 3.8E-04 |
| Mercury | 2.6E-04 |
| Nickel | 2.1E-03 |
| Total HAP | 1.888 |

7.3 Preheater Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|---------------------------------|-----------------|---|---------------------|----------|
| | (lb/MMscf) | Basis | (lb/hr) | (tpy) |
| NO _x | 38.557 | LG&E Requirement | 0.546 | 2.392 |
| CO | 79.025 | LG&E Requirement | 1.119 | 4.903 |
| VOC | 5.5 | AP-42 Table 1.4-2 | 0.078 | 0.341 |
| PM/PM10/PM2.5-Filt | 1.9 | AP-42 Table 1.4-2 | 0.027 | 0.118 |
| PM-Condensable | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database | 0.022 | 0.097 |
| PM/PM10/PM2.5 Total | 3.47 | AP-42 Table 1.4-2 | 0.049 | 0.215 |
| SO ₂ | 1.43 | Pipeline spec conversion | 0.020 | 0.089 |
| H ₂ SO ₄ | 0.109 | Pipeline spec conversion | 1.55E-03 | 6.78E-03 |
| Lead | 0.0005 | AP-42, Table 1.4-2 | 7.08E-06 | 3.10E-05 |
| CO _{2e} | 124,007 | 40 CFR 98, Table C-1 | 1,756 | 7,693 |
| Hazardous Air Pollutants | 1.888 | Sum of HAPs | 0.027 | 0.117 |
| Benzene | 2.1E-03 | AP-42, Table 1.4-3 | 2.97E-05 | 1.30E-04 |
| Dichlorobenzene | 1.2E-03 | AP-42, Table 1.4-3 | 1.70E-05 | 7.44E-05 |
| Formaldehyde | 7.5E-02 | AP-42, Table 1.4-3 | 1.06E-03 | 4.65E-03 |
| Hexane | 1.8E+00 | AP-42, Table 1.4-3 | 2.55E-02 | 1.12E-01 |
| Naphthalene | 6.1E-04 | AP-42, Table 1.4-3 | 8.64E-06 | 3.78E-05 |
| Toluene | 3.4E-03 | AP-42, Table 1.4-3 | 4.82E-05 | 2.11E-04 |
| Arsenic | 2.0E-04 | AP-42, Table 1.4-4 | 2.83E-06 | 1.24E-05 |
| Cadmium | 1.1E-03 | AP-42, Table 1.4-4 | 1.56E-05 | 6.82E-05 |
| Chromium | 1.4E-03 | AP-42, Table 1.4-4 | 1.98E-05 | 8.69E-05 |
| Manganese | 3.8E-04 | AP-42, Table 1.4-4 | 5.38E-06 | 2.36E-05 |
| Mercury | 2.6E-04 | AP-42, Table 1.4-4 | 3.68E-06 | 1.61E-05 |
| Nickel | 2.1E-03 | AP-42, Table 1.4-4 | 2.97E-05 | 1.30E-04 |

Sample Calculations:

$$\text{NO}_x \text{ (lb/hr)} = 38.557 \text{ lb/MMscf} \times 0.0142 \text{ MMscf/hr} = 0.546 \text{ lb/hr NO}_x$$

$$\text{NO}_x \text{ (tpy)} = 0.546 \text{ lb/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 2.39 \text{ tpy NO}_x$$

8. Mechanical Draft Cooling Tower - Emissions Calculations

- > The NGCC Plant will be served by one re-circulating counterflow wet linear mechanical draft cooling tower. Potential emissions for the cooling tower are documented in this section.

8.1 Cooling Tower Nomenclature and Specifications

- > Proposed nomenclature for the new cooling tower associated with the NGCC plant:

| | |
|-----------------|---|
| Emission Unit | IA5 - Other Insignificant Activities |
| Emission Point | IE24 - Mechanical Draft Cooling Tower (8 Cells) for NGCC |
| Control Device | --- |
| Stack ID | Fugitive |
| SCC Code | 38500101 |
| SCC Description | Industrial Processes - Cooling Tower (3-85) - Process Cooling (3-85-001) - Mechanical Draft (3-85-001-01) |
| SCC Units | Million Gallons Cooling Water Throughput |

8.2 Methodology for Defining Potential PM Emissions from Cooling Tower

8.2.1 PM Emission Factor

- > As the water flows down through a cooling tower, the draft air picks up water droplets that can be emitted from the top of the tower (i.e., "drift loss"). Drift loss is minimized through the use of mist eliminators. Particulate matter emissions can result due to the presence of dissolved solids in the cooling tower water droplets that are released from the tower. As the cooling tower droplets disperse in the atmosphere, the liquid water evaporates, leaving behind solid particles in the form of particulate matter.
- > Particulate matter emissions from cooling towers are estimated using the procedures of AP-42 Section 13.4 (1/1995 edition), in which PM emissions are estimated as a function of the tower flow capacity, drift loss, and total dissolved solids (TDS) in the cooling tower recirculating water.

- > Cooling Tower Design Parameters:

| | | |
|---|--------------|--|
| Max Annual Operating Hours | 8,760 hr/yr | |
| Circulating Water Flow Rate | 95,000 gpm | |
| | 5.7 MMgal/hr | 95,000 gpm x 60 min/hr / 1E6 gal/MMgal = 5.7 |
| Total Dissolved Solids (TDS) of Recirculating Water | 990 ppm | |
| Drift Percentage for Cooling Tower Mist Eliminator | 0.001 % | |
| Density of Circulating Water | 8.34 lb/gal | |

PM emission factor based on AP42 13.4 methodology:

$$\text{PM Factor} = 1.0\text{E-}05 \text{ gal drift/gal flow} \times 8.34 \text{ lb/gal} \times 990 \text{ ppm} =$$

| |
|-----------------|
| 0.0826 lb/MMgal |
|-----------------|

8.2.2 PM₁₀ and PM_{2.5} Emission Factors

Imber

- > PM₁₀ and PM_{2.5} emission factors are derived from the PM emission factor calculated above using the methodology presented in "Calculating Realistic PM₁₀ Emissions from Cooling Towers" by Joe Reisman and Gordon Frisbie, Environmental Progress, Volume 21, Issue 2 (April 20, 2004).
- > The aerodynamic diameter of a particle resulting from drift was calculated over a target droplet size distribution presented in the table below, taken from the source cited above. By interpolating on the calculated aerodynamic particle diameter, the corresponding mass percentage smaller than PM_{2.5} and PM₁₀ can be derived.

| Droplet Diameter Size ¹ (μm) | EPRI % Mass Smaller ¹ (%) | Droplet Volume (μm^3) | Droplet Mass (μg) | Particle Mass (Solids) (μg) | Solid Particle Volume (μm^3) | Solid Particle Diameter (μm) | Aerodyn. Particle Diameter (μm) |
|---|---|---------------------------------------|-----------------------------------|---|--|--|---|
| 10 | 0 | 524 | 5.24E-04 | 5.18E-07 | 0.24 | 0.77 | 1.1 |
| 20 | 0.196 | 4,189 | 4.19E-03 | 4.15E-06 | 1.88 | 1.53 | 2.3 |
| 22.0 | 0.202 | 5,571 | 5.57E-03 | 5.52E-06 | 2.51 | 1.69 | 2.5 |
| 30 | 0.226 | 14,137 | 0.01 | 1.40E-05 | 6.36 | 2.30 | 3.4 |
| 40 | 0.514 | 33,510 | 0.03 | 3.32E-05 | 15.08 | 3.07 | 4.5 |
| 50 | 1.816 | 65,450 | 0.07 | 6.48E-05 | 29.45 | 3.83 | 5.7 |
| 60 | 5.702 | 113,097 | 0.11 | 1.12E-04 | 50.89 | 4.60 | 6.8 |
| 70 | 21.348 | 179,594 | 0.18 | 1.78E-04 | 80.82 | 5.36 | 8.0 |
| 88.0 | 46.937 | 356,576 | 0.36 | 3.53E-04 | 160.46 | 6.74 | 10.0 |
| 90 | 49.812 | 381,704 | 0.38 | 3.78E-04 | 171.77 | 6.90 | 10.2 |
| 110 | 70.509 | 696,910 | 0.70 | 6.90E-04 | 314 | 8.43 | 12.5 |
| 130 | 82.023 | 1,150,347 | 1.15 | 1.14E-03 | 518 | 9.96 | 14.8 |
| 150 | 88.012 | 1,767,146 | 1.77 | 1.75E-03 | 795 | 11.49 | 17.0 |
| 180 | 91.032 | 3,053,628 | 3.05 | 3.02E-03 | 1,374 | 13.79 | 20.5 |
| 210 | 92.468 | 4,849,048 | 4.85 | 4.80E-03 | 2,182 | 16.09 | 23.9 |
| 240 | 94.091 | 7,238,229 | 7.24 | 7.17E-03 | 3,257 | 18.39 | 27.3 |
| 270 | 94.689 | 10,305,995 | 10.31 | 1.02E-02 | 4,638 | 20.69 | 30.7 |
| 300 | 96.288 | 14,137,167 | 14.14 | 1.40E-02 | 6,362 | 22.99 | 34.1 |
| 350 | 97.011 | 22,449,298 | 22.45 | 2.22E-02 | 10,102 | 26.82 | 39.8 |
| 400 | 98.340 | 33,510,322 | 33.51 | 3.32E-02 | 15,080 | 30.65 | 45.5 |
| 450 | 99.071 | 47,712,938 | 47.71 | 4.72E-02 | 21,471 | 34.48 | 51.1 |
| 500 | 99.071 | 65,449,847 | 65.45 | 6.48E-02 | 29,452 | 38.32 | 56.8 |
| 600 | 100 | 113,097,336 | 113.10 | 1.12E-01 | 50,894 | 45.98 | 68.2 |

Bold highlights indicate interpolated values to determine PM₁₀ and PM_{2.5} size fractions.

¹ Based on drift droplet size distribution testing from EPRI test facility published in the Reisman and Frisbie paper.

8.2.3 Summary of PM Emission Factors

Estimated PM₁₀/PM Ratio 0.469 EPRI ratio of mass smaller than PM₁₀ (based on interpolation in table above)
 Estimated PM_{2.5}/PM Ratio 2.02E-03 EPRI ratio of mass smaller than PM_{2.5} (based on interpolation in table above)

| Pollutant | Emission Factor (lb/MMgal) | Basis |
|-------------------|-------------------------------|---|
| PM | 0.0826 | = 8.34 lb/gal x 990 ppm x 0.0010 drift % |
| PM ₁₀ | 0.0388 | = 0.0826 lb PM/MMgal circulating water x 0.469 Estimated PM ₁₀ /PM Ratio |
| PM _{2.5} | 1.668E-04 | = 0.0826 lb PM/MMgal circulating water x 2.02E-03 Estimated PM _{2.5} /PM Ratio |

8.3 Cooling Tower Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|-------------------|-----------------|--|---------------------|----------|
| | (lb/MMgal) | Basis | (lb/hr) | (tpy) |
| PM | 0.083 | 990 ppm TDS in recirculating water and 0.001% drift | 0.471 | 2.06 |
| PM ₁₀ | 0.039 | EPRI PM ₁₀ /PM ratio | 0.221 | 0.97 |
| PM _{2.5} | 1.668E-04 | EPRI PM _{2.5} /PM ratio | 9.51E-04 | 4.16E-03 |

Sample Calculations:

$$\text{PM (lb/hr)} = 0.083 \text{ lb/MMgal} \times 5.7 \text{ MMgal/hr} = 0.471 \text{ lb/hr PM}$$

$$\text{PM (tpy)} = 0.471 \text{ lb/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 2.06 \text{ tpy PM}$$

9. Diesel-Fired Emergency Generator Engine - Emissions Calculations

> A new diesel-fired emergency generator will be installed as part of the NGCC project to supply power in the event of a power outage. Potential emissions for the emergency generator are documented in this section.

9.1 Emergency Generator Nomenclature and Specifications

> Proposed nomenclature for the new Emergency Generator associated with the NGCC Plant:

Emission Unit: **U25 - 2 MW Diesel Emergency Generator**
 Emission Point: E51 - Diesel Fuel Combustion
 Control Device: - - -
 Stack ID: S51

> LG&E plans to provision a diesel-fired emergency generator for the NGCC project. The specific make and model will not be known until farther on in the project phase. However, the maximum engine rating will be 2 MW or less. For permitting purposes and to calculate potential emissions, this maximum rating is assumed.

| | | |
|-------------------------------------|--|--|
| SCC Code | 20200102 | |
| SCC Description | Internal Combustion Engines - Industrial (2-02) - Distillate Oil (Diesel) (2-02-001) - Reciprocating (2-02-001-02) | |
| SCC Units | 1000 Gallons Distillate Oil (Diesel) Burned | |
| Generator Rating | 2,000 kW | Maximum required generator power output |
| Engine Rating | 2,682 bhp | Converted |
| Annual Operating Hours | 500 hr/yr | The PTE of emergency generators may be based on 500 operating hours annually per EPA guidance. |
| Diesel Heating Value: | 137.03 MMBtu/Mgal | Assume heating value of 137,030 Btu/gallon for diesel fuel based on AP-42, Table 3.4-1, Footnote 'a', i.e., 19300 Btu/lb * 7.1 lb/gallon = 137,000 Btu/gallon |
| Avg Brake-Specific Fuel Consumption | 7,000 Btu/hp-hr | AP-42, Chapter 3.3 Gasoline and Diesel Industrial Engines, Table 3.3-1 Footnote a |
| Maximum Fuel Consumption | 0.137 Mgal/hr | = 2,682 bhp x 7,000 Btu/hp-hr / 1E6 Btu/MMBtu / 137.03 MMBtu/Mgal |

9.2 Derivation and Documentation of Emission Factors

> While the exact make and model of the emergency engine is not known, it is assumed that the engine will be compliant with the Tier 2 emission standards for generator output greater than 560 kW. Used a manufacturer datasheet for a similarly sized Tier 2 engine provides the emission factors for NO_x, VOC, CO, and PM/PM₁₀/PM_{2.5}. Engine will be a CAT 3516C Diesel GenSet with a 3516C, ATAAC, V-16,4-Stroke Water-Cooled Diesel or similar. Emission factors for NSR-regulated pollutants not included in the manufacturer's emissions data are from AP-42, Section 3.4 Large Stationary Diesel and All Stationary Dual-Fuel Engines (for other criteria pollutants and HAP), and 40 CFR 98, Subpart C, Table C-2 (for non-CO₂ greenhouse gases).

NO_x

| | | |
|--|-----------------|--|
| Emission factor for NO _x : | 6.56 g/hp-hr | Manufacturer Emissions Datasheet |
| NO _x emission factor in terms of SCC units: | 283.110 lb/Mgal | = 6.56 g/hp-hr x 2,682 bhp / 0.137 Mgal/hr / 453.593 gm/lb |

VOC

| | | |
|--|---------------|--|
| Emission factor for VOC: | 0.14 g/hp-hr | Manufacturer Emissions Datasheet |
| VOC emission factor in terms of SCC units: | 6.042 lb/Mgal | = 0.14 g/hp-hr x 2,682 bhp / 0.137 Mgal/hr / 453.593 gm/lb |

CO

| | | |
|---|----------------|--|
| Emission factor for CO: | 0.54 g/hp-hr | Manufacturer Emissions Datasheet |
| CO emission factor in terms of SCC units: | 23.305 lb/Mgal | = 0.54 g/hp-hr x 2,682 bhp / 0.137 Mgal/hr / 453.593 gm/lb |

PM/PM₁₀/PM_{2.5}

Emission factor for PM/PM₁₀/PM_{2.5}: 0.04 g/hp-hr Manufacturer Emissions Datasheet
 PM/PM₁₀/PM_{2.5} emission factor in terms of SCC units: 1.726 lb/Mgal = 0.04 g/hp-hr x 2,682 bhp / 0.137 Mgal/hr / 453.593 gm/lb

SO₂

> To take into account the lower sulfur content of the diesel fuel burned, and for purposes of representing SO₂ emissions from the engine, the factor in AP-42 Table 3.4-1 (Large Stationary Diesel Engines, 10/1996 edition) is used as shown below. This factor expresses SO₂ as a function of sulfur content. As required under NSPS Subpart IIII, ultra low sulfur diesel (ULSD) must be used in the new emergency generator engine.

AP-42 Factor for SO₂ based on sulfur content: 1.01 S lb/MMBtu AP-42 Table 3.4-1 (S is sulfur content in %)
 Sulfur Content: 0.0015 % Based on maximum sulfur content in ULSD of 15 ppm
 SO₂ emission factor (lb/MMBtu): 1.52E-03 lb/MMBtu = 1.01 EF x 0.0015%, sulfur
 SO₂ emission factor in terms of SCC units: 0.208 lb/Mgal = 1.52E-03 lb/MMBtu x 137 MMBtu/Mgal

Greenhouse Gases

> CO₂, CH₄ and N₂O emissions for diesel fuel combustion are estimated using the Distillate Fuel Oil No. 2 emission factors published in 40 CFR 98, Subpart C, Table C-1 & 2. CO_{2e} emissions for diesel fuel combustion are estimated using the global warming potentials published in 40 CFR 98, Subpart A, Table A-1.

Global Warming Potentials of GHGs per 40 CFR 98 Subpart A, Table A-1.

| | |
|------------------|-----|
| CO ₂ | 1 |
| CH ₄ | 25 |
| N ₂ O | 298 |

| Pollutant | Emission Factor (kg/MMBtu) | Equivalent Factor (lb/Mgal) | |
|------------------|----------------------------|-----------------------------|--|
| CO ₂ | 73.96 | 22,343 | 40 CFR 98, Subpart C, Table C-1; Distillate Fuel Oil No. 2 |
| CH ₄ | 3.00E-03 | 0.906 | 40 CFR 98, Subpart C, Table C-2; Distillate Fuel Oil No. 2 |
| N ₂ O | 6.00E-04 | 0.181 | 40 CFR 98, Subpart C, Table C-2; Distillate Fuel Oil No. 2 |
| CO _{2e} | 74.21 | 22,420 | = CO ₂ EF x CO ₂ GWP + CH ₄ EF x CH ₄ GWP + N ₂ O EF x N ₂ O GWP |

9.2.1 Hazardous Air Pollutants

Imber

- > Emission factors for organic HAP compounds expected to be emitted are based on emission factors in AP-42 Table 3.4-3 and 3.4-4 (10/96 Edition). Emission factors are converted from lb/MMBtu as provided in AP-42 to lb/Mgal as applicable to the SCC designation.
- > Pollutants listed below designated as Toxic Air Contaminants (TACs) under Jefferson County's STAR Regulation (Reg 5.01) are indicated as such and are compared with their De Minimis Thresholds calculated using the Benchmark Ambient Concentration (BAC) for the TAC.
- > The emission factor shown for diesel particulate matter is the engine's PM emission factor pulled from the manufacturer emissions data sheet. Diesel particulate is included in this list because it is regulated as a TAC under Reg 5.01.
- > TAC emissions from the engine are below de minimis for all TACs except diesel particulate. For diesel particulate, a modeling analysis was completed to demonstrate that offsite impacts comply with BAC standards. Refer to Section 5.7 in the Application Report.

| Pollutant | CAS # | HAP? | TAC? | Emission Factor (lb/MMBtu) | Emission Factor (lb/Mgal) | Uncontrld Emissions (lb/yr) | Minimis Threshold (lb/yr) | Below De Minimis ? |
|---------------------------|-----------|------|------|----------------------------|---------------------------|-----------------------------|---------------------------|--------------------|
| Acetaldehyde | 75-07-0 | Y | Y | 2.52E-05 | 3.45E-03 | 0.237 | 216.00 | Y |
| Acrolein | 107-02-8 | Y | Y | 7.88E-06 | 1.08E-03 | 0.074 | 9.60 | Y |
| Benzene | 71-43-2 | Y | Y | 7.76E-04 | 1.06E-01 | 7.284 | 216.00 | Y |
| Formaldehyde | 50-00-0 | Y | Y | 7.89E-05 | 1.08E-02 | 0.741 | 36.96 | Y |
| Naphthalene | 91-20-3 | Y | Y | 1.30E-04 | 1.78E-02 | 1.220 | 13.92 | Y |
| PAH | -- | Y | | 2.12E-04 | 2.91E-02 | 1.990 | | |
| Toluene | 108-88-3 | Y | Y | 2.81E-04 | 3.85E-02 | 2.638 | 2,400,000 | Y |
| Xylenes | 1330-20-7 | Y | Y | 1.93E-04 | 2.64E-02 | 1.812 | 48,000 | Y |
| Acenaphthylene | 208-96-8 | Y | N | 9.23E-06 | 1.26E-03 | 0.087 | -- | -- |
| Acenaphthene | 83-32-9 | Y | N | 4.68E-06 | 6.41E-04 | 0.044 | -- | -- |
| Fluorene | 86-73-7 | Y | N | 1.28E-05 | 1.75E-03 | 0.120 | -- | -- |
| Phenanthrene | 85-01-8 | Y | N | 4.08E-05 | 5.59E-03 | 0.383 | -- | -- |
| Anthracene | 120-12-7 | Y | N | 1.23E-06 | 1.69E-04 | 0.012 | -- | -- |
| Fluoranthene | 206-44-0 | Y | N | 4.03E-06 | 5.52E-04 | 0.038 | -- | -- |
| Pyrene | 129-00-0 | Y | N | 3.71E-06 | 5.08E-04 | 0.035 | -- | -- |
| Benzo(a)anthracene | 56-55-3 | Y | Y | 6.22E-07 | 8.52E-05 | 0.006 | 4.37 | Y |
| Chrysene | 218-01-9 | Y | Y | 1.53E-06 | 2.10E-04 | 0.014 | 43.68 | Y |
| Benzo(b)fluoranthene | 205-99-2 | Y | Y | 1.11E-06 | 1.52E-04 | 0.010 | 4.37 | Y |
| Benzo(k)fluoranthene | 207-08-9 | Y | Y | 2.18E-07 | 2.99E-05 | 0.002 | 4.37 | Y |
| Benzo(a)pyrene | 50-32-8 | Y | Y | 4.50E-06 | 6.16E-04 | 0.042 | 0.44 | Y |
| Indeno (1,2,3-cd)pyrene | 193-39-5 | Y | Y | 4.14E-07 | 5.67E-05 | 0.004 | 4.37 | Y |
| Dibenz(a,h)anthracene | 53-70-3 | Y | Y | 3.46E-07 | 4.74E-05 | 0.003 | 0.40 | Y |
| Benzo(g,h,i)perylene | 191-24-2 | Y | N | 5.56E-07 | 7.62E-05 | 0.005 | -- | -- |
| Diesel particulate matter | -- | N | Y | 1.26E-02 | 1.73E+00 | 118.258 | 1.58 | N |

9.3 Emergency Generator Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|---------------------------------|-----------------|--|---------------------|----------|
| | (lb/Mgal) | Basis | (lb/hr) | (tpy) |
| NOx | 283.110 | Manufacturer Emissions Datasheet | 38.789 | 9.70 |
| CO | 23.305 | Manufacturer Emissions Datasheet | 3.193 | 0.80 |
| VOC | 6.042 | Manufacturer Emissions Datasheet | 0.828 | 0.207 |
| PM/PM10/PM2.5 | 1.726 | Manufacturer Emissions Datasheet | 0.237 | 0.059 |
| SO2 | 0.208 | AP-42 Table 3.4-1 (S is sulfur content in %) | 0.028 | 0.007 |
| CO2e | 22,420 | 40 CFR 98, Subpart C | 3,072 | 767.93 |
| <i>Hazardous Air Pollutants</i> | | | | |
| Acetaldehyde | 0.0035 | AP-42 Table 3.4-3 | 4.73E-04 | 1.18E-04 |
| Acrolein | 0.0011 | AP-42 Table 3.4-3 | 1.48E-04 | 3.70E-05 |
| Benzene | 0.106 | AP-42 Table 3.4-3 | 1.46E-02 | 3.64E-03 |
| Formaldehyde | 0.011 | AP-42 Table 3.4-3 | 1.48E-03 | 3.70E-04 |
| Naphthalene | 0.018 | AP-42 Table 3.4-4 | 2.44E-03 | 6.10E-04 |
| PAH | 0.029 | AP-42 Table 3.4-4 | 3.98E-03 | 9.95E-04 |
| Toluene | 0.039 | AP-42 Table 3.4-3 | 5.28E-03 | 1.32E-03 |
| Xylenes | 0.026 | AP-42 Table 3.4-3 | 3.62E-03 | 9.06E-04 |
| Total HAP | 0.233 | AP-42 Table 3.4-3 | 3.20E-02 | 8.00E-03 |

Sample Calculations:

NOx (lb/hr) = 283.110 lb/Mgal x 0.137 Mgal/hr = 38.789 lb/hr NOx

NOx (tpy) = 38.789 lb/hr x 500 hr/yr / 2,000 lb/ton = 9.70 tpy NOx

Cat® 3516C Diesel Generator Sets



Image shown may not reflect actual configuration

| | |
|------------------------|--------------|
| Bore – mm (in) | 170 (6.69) |
| Stroke – mm (in) | 190 (7.48) |
| Displacement – L (in³) | 69 (4210.64) |
| Compression Ratio | 14.7:1 |
| Aspiration | TA |
| Fuel System | EUI |
| Governor Type | ADEM™ A3 |

| Standby 60 Hz ekW (kVA) | Mission Critical 60 Hz ekW (kVA) | Prime 60 Hz ekW (kVA) | Continuous 60 Hz ekW (kVA) | Emissions Performance |
|----------------------------|-------------------------------------|--------------------------|-------------------------------|---|
| 2000 (2500) | 2000 (2500) | 1825 (2281) | 1650 (2063) | U.S. EPA Stationary Emergency Use Only (Tier 2) |

Features

Cat® Diesel Engine

- Meets U.S. EPA Stationary Emergency Use Only (Tier 2) emission standards
- Reliable performance proven in thousands of applications worldwide

Generator Set Package

- Accepts 100% block load in one step and meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

Alternators

- Superior motor starting capability minimizes need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

Cooling System

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- Tested to ensure proper generator set cooling

EMCP 4 Control Panels

- User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements

Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

Worldwide Product Support

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region

LEHE1376-08

Page 1 of 4

3516C Diesel Generator Sets
Electric Power



Package Performance

| Performance | Standby | Mission Critical | Prime | Continuous |
|---|------------------|------------------|------------------|------------------|
| Frequency | 60 Hz | 60 Hz | 60 Hz | 60 Hz |
| Gen set power rating with fan | 2000 ekW | 2000 ekW | 1825 ekW | 1650 ekW |
| Gen set power rating with fan @ 0.8 power factor | 2500 kVA | 2500 kVA | 2281 kVA | 2063 kVA |
| Emissions | EPA ESE (TIER 2) | EPA ESE (TIER 2) | EPA ESE (TIER 2) | EPA ESE (TIER 2) |
| Performance number | EM1896-03 | EM1897-03 | DM8264-06 | DM8265-05 |
| Fuel Consumption | | | | |
| 100% load with fan – L/hr (gal/hr) | 505.8 (133.6) | 505.8 (133.6) | 465.6 (123.0) | 427.9 (113.0) |
| 75% load with fan – L/hr (gal/hr) | 393.9 (104.1) | 393.9 (104.1) | 366.7 (96.9) | 338.3 (89.4) |
| 50% load with fan – L/hr (gal/hr) | 284.2 (75.1) | 284.2 (75.1) | 261.3 (69.0) | 238.3 (63.0) |
| 25% load with fan – L/hr (gal/hr) | 164.3 (43.4) | 164.3 (43.4) | 154.2 (40.7) | 144.1 (38.1) |
| Cooling System | | | | |
| Radiator air flow restriction (system) – kPa (in. water) | 0.12 (0.48) | 0.12 (0.48) | 0.12 (0.48) | 0.12 (0.48) |
| Radiator air flow – m ³ /min (cfm) | 2204 (77834) | 2204 (77834) | 2204 (77834) | 2204 (77834) |
| Engine coolant capacity – L (gal) | 233.2 (61.6) | 233.2 (61.6) | 233.2 (61.6) | 233.2 (61.6) |
| Radiator coolant capacity – L (gal) | 180.0 (47.6) | 180.0 (47.6) | 180.0 (47.6) | 180.0 (47.6) |
| Total coolant capacity – L (gal) | 413.2 (109.2) | 413.2 (109.2) | 413.2 (109.2) | 413.2 (109.2) |
| Inlet Air | | | | |
| Combustion air inlet flow rate – m ³ /min (cfm) | 185.5 (6548.9) | 185.5 (6548.9) | 180.0 (6357.6) | 174.3 (6155.8) |
| Exhaust System | | | | |
| Exhaust stack gas temperature – °C (°F) | 400.1 (752.1) | 400.1 (752.1) | 382.8 (721.1) | 370.7 (699.3) |
| Exhaust gas flow rate – m ³ /min (cfm) | 433.1 (15292.8) | 433.1 (15292.8) | 408.1 (14410.4) | 385.3 (13605.7) |
| Exhaust system backpressure (maximum allowable) – kPa (in. water) | 6.7 (27.0) | 6.7 (27.0) | 6.7 (27.0) | 6.7 (27.0) |
| Heat Rejection | | | | |
| Heat rejection to jacket water – kW (Btu/min) | 759 (43150) | 759 (43150) | 715 (40666) | 673 (38277) |
| Heat rejection to exhaust (total) – kW (Btu/min) | 1788 (101696) | 1788 (101696) | 1645 (93554) | 1522 (86577) |
| Heat rejection to aftercooler – kW (Btu/min) | 672 (38240) | 672 (38240) | 612 (34784) | 553 (31421) |
| Heat rejection to atmosphere from engine – kW (Btu/min) | 133 (7564) | 133 (7564) | 127 (7230) | 123 (6983) |
| Heat rejection from alternator – kW (Btu/min) | 96 (5464) | 96 (5464) | 86 (4895) | 76 (4326) |
| Emissions* (Nominal) | | | | |
| NOx mg/Nm ³ (g/hp-h) | 2754.3 (5.46) | 2754.3 (5.46) | 2488.9 (5.05) | 2202.3 (4.37) |
| CO mg/Nm ³ (g/hp-h) | 143.3 (0.30) | 143.3 (0.30) | 129.7 (0.27) | 112.3 (0.24) |
| HC mg/Nm ³ (g/hp-h) | 44.7 (0.11) | 44.7 (0.11) | 55.6 (0.13) | 67.4 (0.16) |
| PM mg/Nm ³ (g/hp-h) | 10.4 (0.03) | 10.4 (0.03) | 10.9 (0.03) | 12.0 (0.03) |
| Emissions* (Potential Site Variation) | | | | |
| NOx mg/Nm ³ (g/hp-h) | 3305.2 (6.56) | 3305.2 (6.56) | 2986.6 (6.06) | 2642.7 (5.24) |
| CO mg/Nm ³ (g/hp-h) | 258.0 (0.54) | 258.0 (0.54) | 233.4 (0.49) | 202.1 (0.43) |
| HC mg/Nm ³ (g/hp-h) | 59.5 (0.14) | 59.5 (0.14) | 73.9 (0.18) | 89.6 (0.22) |
| PM mg/Nm ³ (g/hp-h) | 14.6 (0.04) | 14.6 (0.04) | 15.3 (0.04) | 16.8 (0.04) |

*mg/Nm³ levels are corrected to 5% O₂. Contact your local Cat dealer for further information.

10. Diesel-Fired Emergency Fire Pump Engine - Emissions Calculations

Imber

- > A new diesel-fired emergency fire pump engine will be installed as part of the NGCC project to supply water in the event of a fire and/or power outage. Potential emissions for the emergency fire pump engine are documented in this section.

10.1 Emergency Fire Pump Engine Nomenclature and Specifications

- > Proposed nomenclature for the new Emergency Fire Pump Engine associated with the NGCC Plant:

Emission Unit: **IA4 - 400 HP Diesel Driven Fire Pump**
 Emission Point: IE28 - Diesel Fuel Combustion
 Control Device: ---
 Stack ID: S53

- > LG&E plans to provision a diesel-fired emergency fire pump engine for the NGCC project. The specific make and model will not be known until farther on in the project phase. However, the maximum engine rating will be 400 hp or less. For permitting purposes and to calculate potential emissions, this maximum rating is assumed.

| | | |
|-------------------------------------|--|--|
| SCC Code | 20200102 | |
| SCC Description | Internal Combustion Engines - Industrial (2-02) - Distillate Oil (Diesel) (2-02-001) - Reciprocating (2-02-001-02) | |
| SCC Units | 1000 Gallons Distillate Oil (Diesel) Burned | |
| Engine Rating | 400 bhp | |
| Annual Operating Hours | 500 hr/yr | The PTE of emergency engines may be based on 500 operating hours annually per EPA guidance. |
| Diesel Heating Value: | 137.03 MMBtu/Mgal | Assume heating value of 137,030 Btu/gallon for diesel fuel based on AP-42, Table 3.4-1, Footnote 'a', i.e., 19300 Btu/lb * 7.1 lb/gallon = 137,000 Btu/gallon |
| Avg Brake-Specific Fuel Consumption | 7,000 Btu/hp-hr | AP-42, Chapter 3.3 Gasoline and Diesel Industrial Engines, Table 3.3-1 Footnote a |
| Maximum Fuel Consumption | 0.020 Mgal/hr | = 400 bhp x 7,000 Btu/hp-hr / 1E6 Btu/MMBtu / 137.03 MMBtu/Mgal |

10.2 Derivation and Documentation of Emission Factors

- > While the exact make and model of the fire pump engine is not known, it is assumed that the engine will be compliant with the NSPS IIII Table 4 emission standards for engine ratings greater than 300 HP, but less than 600 HP. A manufacturer datasheet for a similarly sized engine provides the emission factors for NO_x, VOC, CO, and PM/PM₁₀/PM_{2.5}. Emission factors for NSR-regulated pollutants not included in the manufacturer's emissions data are from AP-42, Section 3.3 Gasoline and Diesel Industrial Engines (for other criteria pollutants and HAP), and 40 CFR 98, Subpart C, Table C-2 (for non-CO₂ greenhouse gases).

NO_x

| | | |
|--|-----------------|--|
| Emission factor for NO _x : | 2.61 g/hp-hr | Manufacturer Emissions Datasheet |
| NO _x emission factor in terms of SCC units: | 112.640 lb/Mgal | = 2.61 g/hp-hr x 400 bhp / 0.020 Mgal/hr / 453.593 gm/lb |

VOC

| | | |
|--|---------------|--|
| Emission factor for VOC: | 0.10 g/hp-hr | Manufacturer Emissions Datasheet |
| VOC emission factor in terms of SCC units: | 4.316 lb/Mgal | = 0.10 g/hp-hr x 400 bhp / 0.020 Mgal/hr / 453.593 gm/lb |

CO

| | | |
|---|----------------|--|
| Emission factor for CO: | 0.80 g/hp-hr | Manufacturer Emissions Datasheet |
| CO emission factor in terms of SCC units: | 34.526 lb/Mgal | = 0.80 g/hp-hr x 400 bhp / 0.020 Mgal/hr / 453.593 gm/lb |

PM/PM₁₀/PM_{2.5}

| | | |
|---|---------------|--|
| Emission factor for PM/PM ₁₀ /PM _{2.5} : | 0.10 g/hp-hr | Manufacturer Emissions Datasheet |
| PM/PM ₁₀ /PM _{2.5} emission factor in terms of SCC units: | 4.316 lb/Mgal | = 0.10 g/hp-hr x 400 bhp / 0.020 Mgal/hr / 453.593 gm/lb |

SO₂ **Imber**

> To take into account the lower sulfur content of the diesel fuel burned, and for purposes of representing SO₂ emissions from the engine, the factor in AP-42 Table 3.4-1 (Large Stationary Diesel Engines, 10/1996 edition) is used as shown below. This factor expresses SO₂ as a function of sulfur content. As required under NSPS Subpart IIII, the ultra low sulfur diesel (ULSD) must be used in the new emergency generator engine.

| | | |
|---|-------------------|---|
| AP-42 Factor for SO ₂ based on sulfur content: | 1.01 S lb/MMBtu | AP-42 Table 3.4-1 (S is sulfur content in %) |
| Sulfur Content: | 0.0015 % | Based on maximum sulfur content in ULSD of 15 ppm |
| SO ₂ emission factor (lb/MMBtu): | 1.52E-03 lb/MMBtu | = 1.01 EF x 0.0015%, sulfur |
| SO ₂ emission factor in terms of SCC units: | 0.208 lb/Mgal | = 1.52E-03 lb/MMBtu x 137 MMBtu/Mgal |

Greenhouse Gases

> CO₂, CH₄ and N₂O emissions for diesel fuel combustion are estimated using the Distillate Fuel Oil No. 2 emission factors published in 40 CFR 98, Subpart C, Table C-1 & 2. CO₂e emissions for diesel fuel combustion are estimated using the global warming potentials published in 40 CFR 98, Subpart A, Table A-1.

Global Warming Potentials of GHGs per 40 CFR 98 Subpart A, Table A-1.

| | |
|------------------|-----|
| CO ₂ | 1 |
| CH ₄ | 25 |
| N ₂ O | 298 |

| Pollutant | Emission Factor (kg/MMBtu) | Equivalent Factor (lb/Mgal) | |
|-------------------|----------------------------|-----------------------------|--|
| CO ₂ | 73.96 | 22,343 | 40 CFR 98, Subpart C, Table C-1; Distillate Fuel Oil No. 2 |
| CH ₄ | 3.00E-03 | 0.906 | 40 CFR 98, Subpart C, Table C-2; Distillate Fuel Oil No. 2 |
| N ₂ O | 6.00E-04 | 0.181 | 40 CFR 98, Subpart C, Table C-2; Distillate Fuel Oil No. 2 |
| CO ₂ e | 74.21 | 22,420 | = CO2 EF x CO2 GWP + CH4 EF x CH4 GWP + N2O EF x N2O GWP |

10.2.1 Hazardous Air Pollutants**Imber**

- > Emission factors for organic HAP compounds expected to be emitted are based on emission factors in AP-42 Table 3.4-3 and 3.4-4 (10/96 Edition).
- > Pollutants listed below designated as Toxic Air Contaminants (TACs) under Jefferson County's STAR Regulation (Reg 5.01) are indicated as such
- > The emission factor shown for diesel particulate matter is the engine's PM emission factor pulled from the manufacturer emissions data sheet. Diesel
- > TAC emissions from the engine are below de minimis for all TACs except diesel particulate. For diesel particulate, a modeling analysis was

| Pollutant | CAS # | HAP? | TAC? | Emission Factor (lb/MMBtu) | Emission Factor (lb/Mgal) | Uncontrld Emissions (lb/yr) | De Minimis Threshold (lb/yr) | Below De Minimis ? |
|---------------------------|-----------|------|------|-------------------------------|------------------------------|--------------------------------|---------------------------------|-----------------------|
| 1,3-Butadiene | 106-99-0 | Y | Y | 3.91E-05 | 5.36E-03 | 0.055 | 15.84 | Y |
| Acetaldehyde | 75-07-0 | Y | Y | 7.67E-04 | 1.05E-01 | 1.074 | 216.00 | Y |
| Acrolein | 107-02-8 | Y | Y | 9.25E-05 | 1.27E-02 | 0.130 | 9.60 | Y |
| Benzene | 71-43-2 | Y | Y | 9.33E-04 | 1.28E-01 | 1.306 | 216.00 | Y |
| Formaldehyde | 50-00-0 | Y | Y | 1.18E-03 | 1.62E-01 | 1.652 | 36.96 | Y |
| Naphthalene | 91-20-3 | Y | Y | 8.48E-05 | 1.16E-02 | 0.119 | 13.92 | Y |
| PAH | | Y | | 1.68E-04 | 2.30E-02 | 0.235 | | |
| Toluene | 108-88-3 | Y | Y | 4.09E-04 | 5.60E-02 | 0.573 | 2,400,000 | Y |
| Xylenes | 1330-20-7 | Y | Y | 2.85E-04 | 3.91E-02 | 0.399 | 48,000 | Y |
| Phenanthrene | 85-01-8 | Y | N | 2.94E-05 | 4.03E-03 | 0.041 | -- | -- |
| Fluorene | 86-73-7 | Y | N | 2.92E-05 | 4.00E-03 | 0.041 | -- | -- |
| Acenaphthylene | 208-96-8 | Y | N | 5.06E-06 | 6.93E-04 | 0.007 | -- | -- |
| Acenaphthene | 83-32-9 | Y | N | 1.42E-06 | 1.95E-04 | 0.002 | -- | -- |
| Fluoranthene | 206-44-0 | Y | N | 7.61E-06 | 1.04E-03 | 0.011 | -- | -- |
| Pyrene | 129-00-0 | Y | N | 4.78E-06 | 6.55E-04 | 0.007 | -- | -- |
| Chrysene | 218-01-9 | Y | Y | 3.53E-07 | 4.84E-05 | 0.000 | 43.68 | Y |
| Anthracene | 120-12-7 | Y | N | 1.87E-06 | 2.56E-04 | 0.003 | -- | -- |
| Benzo(b)fluoranthene | 205-99-2 | Y | Y | 9.91E-08 | 1.36E-05 | 0.000 | 4.37 | Y |
| Benzo(a)anthracene | 56-55-3 | Y | Y | 1.68E-06 | 2.30E-04 | 0.002 | 4.37 | Y |
| Benzo(g,h,i)perylene | 191-24-2 | Y | N | 4.89E-07 | 6.70E-05 | 0.001 | -- | -- |
| Indeno (1,2,3-cd)pyrene | 193-39-5 | Y | Y | 3.75E-07 | 5.14E-05 | 0.001 | 4.37 | Y |
| Dibenz(a,h)anthracene | 53-70-3 | Y | Y | 5.83E-07 | 7.99E-05 | 0.001 | 0.40 | Y |
| Benzo(a)pyrene | 50-32-8 | Y | Y | 1.88E-07 | 2.58E-05 | 0.000 | 0.44 | Y |
| Benzo(k)fluoranthene | 207-08-9 | Y | Y | 1.55E-07 | 2.12E-05 | 0.000 | 4.37 | Y |
| Diesel particulate matter | -- | N | Y | 3.15E-02 | 4.32E+00 | 44.092 | 1.58 | N |

10.3 Emergency Fire Pump Engine Potential Emissions Summary

Imber

| Pollutant | Emission Factor | | Potential Emissions | |
|---------------------------------|-----------------|--|---------------------|----------|
| | (lb/Mgal) | Basis | (lb/hr) | (tpy) |
| NOx | 112.640 | Manufacturer Emissions Datasheet | 2.302 | 0.575 |
| CO | 34.526 | Manufacturer Emissions Datasheet | 0.705 | 0.176 |
| VOC | 4.316 | Manufacturer Emissions Datasheet | 0.088 | 0.022 |
| PM/PM10/PM2.5 | 4.316 | Manufacturer Emissions Datasheet | 0.088 | 0.022 |
| SO2 | 0.208 | AP-42 Table 3.4-1 (S is sulfur content in %) | 0.004 | 0.001 |
| CO2e | 22,420 | 40 CFR 98, Subpart C | 458 | 114.529 |
| <i>Hazardous Air Pollutants</i> | | | | |
| 1,3-Butadiene | 0.005 | AP-42 Table 3.3-2 | 1.09E-04 | 2.74E-05 |
| Acetaldehyde | 0.105 | AP-42 Table 3.3-2 | 2.15E-03 | 5.37E-04 |
| Acrolein | 0.013 | AP-42 Table 3.3-2 | 2.59E-04 | 6.48E-05 |
| Benzene | 0.128 | AP-42 Table 3.3-2 | 2.61E-03 | 6.53E-04 |
| Formaldehyde | 0.162 | AP-42 Table 3.3-2 | 3.30E-03 | 8.26E-04 |
| Naphthalene | 0.012 | AP-42 Table 3.3-2 | 2.37E-04 | 5.94E-05 |
| PAH | 0.023 | AP-42 Table 3.3-2 | 4.71E-04 | 1.18E-04 |
| Toluene | 0.056 | AP-42 Table 3.3-2 | 1.15E-03 | 2.86E-04 |
| Xylenes | 0.039 | AP-42 Table 3.3-2 | 7.98E-04 | 2.00E-04 |
| Total HAP | 0.542 | AP-42 Table 3.3-2 | 1.11E-02 | 2.77E-03 |

Sample Calculations:

$$\text{NOx (lb/hr)} = 112.640 \text{ lb/Mgal} \times 0.020 \text{ Mgal/hr} = 2.302 \text{ lb/hr NOx}$$

$$\text{NOx (tpy)} = 2.302 \text{ lb/hr} \times 500 \text{ hr/yr} / 2,000 \text{ lb/ton} = 0.575 \text{ tpy NOx}$$



Rating Specific Emissions Data

Nameplate Rating Information

| | |
|-----------------------|--------------------|
| Clarke Model | JW6H-UFAD80 |
| Power Rating (BHP/kW) | 400/298 |
| Certified Speed (RPM) | 2100 |

Refer to **Rating Data** section on page 2 for emissions output values

Rating Specific Emissions Data - John Deere Power Systems





Rating Data

| | | |
|----------------------|----------------------------------|---------|
| Rating | 6090HFC47B | |
| Certified Power(kW) | 298 | |
| Rated Speed | 2100 | |
| Vehicle Model Number | OEM (Clarke Fire Pump-Emergency) | |
| Units | g/kW-hr | g/hp-hr |
| NO _x | 3.50 | 2.61 |
| HC | 0.14 | 0.10 |
| NO _x + HC | N/A | N/A |
| P _m | 0.14 | 0.10 |
| CO | 1.1 | 0.8 |

Certificate Data

| | | |
|------------------------|----------------------------------|--|
| Engine Model Year | 2022 | |
| EPA Family Name | NJDXL09.0114 | |
| EPA JD Name | 450HAB | |
| EPA Certificate Number | NJDXL09.0114-007 | |
| CARB Executive Order | | |
| Parent of Family | 6090HFG84A | |
| Units | g/kW-hr | |
| NO _x | 3.80 | |
| HC | 0.05 | |
| NO _x + HC | N/A | |
| P _m | 0.11 | |
| CO | 0.9 | |

* The emission data listed is measured from a laboratory test engine according to the test procedures of 40 CFR 89 or 40 CFR 1039, as applicable. The test engine is intended to represent nominal production hardware, and we do not guarantee that every production engine will have identical test results. The family parent data represents multiple ratings and this data may have been collected at a different engine speed and load. Emission results may vary due to engine manufacturing tolerances, engine operating conditions, fuels used, or other conditions beyond our control.

This information is property of Deere & Company. It is provided solely for the purpose of obtaining certification or permits of Deere powered equipment. Unauthorized distribution of this information is prohibited.

Emissions Results by Rating run on Apr-05-2022

11. HVAC Heaters - Emissions Calculations

- > LG&E expects to install several HVAC heaters for the new buildings that are associated with the NGCC project to provide heating in winter months as needed. Potential emissions for the HVAC heaters are documented in this section.

11.1 HVAC Heaters Nomenclature and Specifications

- > Proposed nomenclature for the new HVAC heaters associated with the NGCC Plant:

Emission Unit: **IA5 - Other Insignificant Activities**
 Emission Point: IE27 - HVAC Heaters (Total 10 MMBtu/hr)
 Control Device: - - -
 Stack ID: Fugitive

- > LG&E plans to provision multiple natural gas-fired HVAC units within building that support the NGCC project. The specific make and model are TBD. The total combined heat input capacity of all small HVAC heaters is assumed to be 10 MMBtu/hr or less. For permitting purposes and to calculate potential emissions, the maximum combined heat input capacity is assumed.

| | | |
|--|--------------------|---|
| Max Annual Operating Hours | 8,760 hr/yr | |
| Heat Input Capacity | 10 MMBtu/hr | |
| NG Heating Value | 1,059 Btu/scf | Average for Mill Creek Generating Station Inlet Gas |
| Max Gas Firing Rate at Average HHV | 0.0094 MMscf/hr | 10 MMBtu/hr / 1,059 MMBtu/MMscf = 0.0094 MMscf/hr |
| NG HHV used for AP-42 1.4 Emission Factors | 1,020 Btu/scf | |

11.2 Derivation and Documentation of Emission Factors

11.2.1 Constants and Conversion Factors

| Parameter | Value | Units | Basis |
|---|--------|--|---|
| Molar Volume (at STP) | 385.5 | scf/lbmol | = 528 °R / 1 atm x 0.7302 cf-atm/(lbmol-°R) |
| Atomic Weight of Sulfur | 32.07 | lb/lbmol | |
| Molecular Weight of NO ₂ | 46.01 | lb NO ₂ /lbmol | |
| Molecular Weight of CO | 28.01 | lb CO/lbmol | |
| Molecular Weight of SO ₂ | 64.07 | lb SO ₂ /lbmol | |
| Molecular Weight of H ₂ SO ₄ | 98.079 | lb H ₂ SO ₄ /lbmol | |
| F-Factor for natural gas combustion from 40 CFR 60, Appendix A (Method 19) | 8,710 | dscf/MMBtu | |
| Concentration of Sulfur in Natural Gas | 0.5 | gr/Ccf | Assumed max sulfur content for Mill Creek inlet natural gas |
| Estimated SO ₂ to SO ₃ Conversion Rate | 5 | % | |
| Estimated SO ₃ to H ₂ SO ₄ Conversion Rate | 100 | % | |

11.2.2 NSR-Regulated Pollutant Emission Factors

| Pollutant | CAS # | Emission Factor (lb/MMBtu) | Emission Factor (lb/MMscf) | Emission Factor Basis |
|---------------------|------------|-------------------------------|-------------------------------|---|
| NOx | 10102-44-0 | 0.098 | 100 | AP-42 Section 1.4 Table 1.4-1 for Uncontrolled Small Boilers (7/98) |
| CO | 00630-08-0 | 0.082 | 84 | AP-42 Section 1.4 Table 1.4-1 for Uncontrolled Small Boilers (7/98) |
| VOC | na | 0.005 | 5.5 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM/PM10/PM2.5-Filt | | 0.0019 | 1.90 | AP-42 Section 1.4 Table 1.4-2 (7/98) |
| PM-Condensable | | 0.0015 | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database |
| PM/PM10/PM2.5 Total | | 0.0034 | 3.47 | AP-42 Table 1.4-2 + EPA Speciate Database |
| SO2 | 07446-09-5 | 0.0013 | 1.427 | 0.5 gr/Ccf / 7,000 gr/lb x 64.07 lb SO2/lbmol / 32.07 lb S/lbmol x 10,000 |
| H2SO4 | 7664-93-9 | 1.03E-04 | 0.109 | 5% conversion of SO2 to SO3 and 100% conversion of SO3 to H2SO4 1.427 lb SO2/MMscf x 5% x 100% x 98.079 lb H2SO4/lbmol / 64.07 lb SO2/lbmol = 0.109 lb/MMscf |
| Lead | | 4.72E-07 | 0.0005 | AP-42, Section 1.4, Table 1.4-2 |
| CO2 | | 116.98 | 123,879 | 40 CFR 98, Subpart C, Table C-1; converted from 53.06 kg/MMBtu |
| CH4 | | 0.0022 | 2.33 | 40 CFR 98, Subpart C, Table C-2; converted from 0.001 kg/MMBtu |
| N2O | | 0.0002 | 0.233 | 40 CFR 98, Subpart C, Table C-2; converted from 0.0001 kg/MMBtu |
| CO2e | | 117.10 | 124,007 | = CO2 EF x CO2 GWP + CH4 EF x CH4 GWP + N2O EF x N2O GWP |

11.2.3 Hazardous Air Pollutants

> Emission factors for HAPs are obtained from AP-42, Chapter 1.4, Table 1.4-3 and 1.4-4 (Emission Factors for Natural Gas Fired External

| Pollutant | Emission Factor (lb/MMscf) |
|-----------|-------------------------------|
|-----------|-------------------------------|

Speciated Organic Compounds (AP-42, Table 1.4-3)

| | |
|-----------------|---------|
| Benzene | 2.1E-03 |
| Dichlorobenzene | 1.2E-03 |
| Formaldehyde | 7.5E-02 |
| Hexane | 1.8E+00 |
| Naphthalene | 6.1E-04 |
| Toluene | 3.4E-03 |

Metals (AP-42, Table 1.4-4)

| | |
|------------------|--------------|
| Arsenic | 2.0E-04 |
| Cadmium | 1.1E-03 |
| Chromium | 1.4E-03 |
| Manganese | 3.8E-04 |
| Mercury | 2.6E-04 |
| Nickel | 2.1E-03 |
| Total HAP | 1.888 |

11.3 HVAC Heaters Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|---------------------------------|-----------------|---|---------------------|----------|
| | (lb/MMscf) | Basis | (lb/hr) | (tpy) |
| NO _x | 100 | AP-42 Table 1.4-1 | 0.944 | 4.136 |
| CO | 84 | AP-42 Table 1.4-1 | 0.793 | 3.474 |
| VOC | 5.5 | AP-42 Table 1.4-2 | 0.052 | 0.227 |
| PM/PM10/PM2.5-Filt | 1.9 | AP-42 Table 1.4-2 | 0.018 | 0.079 |
| PM-Condensable | 1.57 | AP-42 Table 1.4-2 + EPA Speciate Database | 0.015 | 0.065 |
| PM/PM10/PM2.5 Total | 3.47 | AP-42 Table 1.4-2 | 0.033 | 0.144 |
| SO ₂ | 1.43 | Pipeline spec conversion | 0.013 | 0.059 |
| H ₂ SO ₄ | 0.109 | Pipeline spec conversion | 1.03E-03 | 4.52E-03 |
| Lead | 0.0005 | AP-42, Table 1.4-2 | 4.72E-06 | 2.07E-05 |
| CO _{2e} | 124,007 | 40 CFR 98, Table C-1 | 1,171 | 5,129 |
| Hazardous Air Pollutants | 1.888 | Sum of HAPs | 0.018 | 0.078 |
| Benzene | 2.1E-03 | AP-42, Table 1.4-3 | 1.98E-05 | 8.69E-05 |
| Dichlorobenzene | 1.2E-03 | AP-42, Table 1.4-3 | 1.13E-05 | 4.96E-05 |
| Formaldehyde | 7.5E-02 | AP-42, Table 1.4-3 | 7.08E-04 | 3.10E-03 |
| Hexane | 1.8E+00 | AP-42, Table 1.4-3 | 1.70E-02 | 7.44E-02 |
| Naphthalene | 6.1E-04 | AP-42, Table 1.4-3 | 5.76E-06 | 2.52E-05 |
| Toluene | 3.4E-03 | AP-42, Table 1.4-3 | 3.21E-05 | 1.41E-04 |
| Arsenic | 2.0E-04 | AP-42, Table 1.4-4 | 1.89E-06 | 8.27E-06 |
| Cadmium | 1.1E-03 | AP-42, Table 1.4-4 | 1.04E-05 | 4.55E-05 |
| Chromium | 1.4E-03 | AP-42, Table 1.4-4 | 1.32E-05 | 5.79E-05 |
| Manganese | 3.8E-04 | AP-42, Table 1.4-4 | 3.59E-06 | 1.57E-05 |
| Mercury | 2.6E-04 | AP-42, Table 1.4-4 | 2.46E-06 | 1.08E-05 |
| Nickel | 2.1E-03 | AP-42, Table 1.4-4 | 1.98E-05 | 8.69E-05 |

Sample Calculations:

$$\text{NO}_x \text{ (lb/hr)} = 100 \text{ lb/MMscf} \times 0.0094 \text{ MMscf/hr} = 0.944 \text{ lb/hr NO}_x$$

$$\text{NO}_x \text{ (tpy)} = 0.944 \text{ lb/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 4.136 \text{ tpy NO}_x$$

12. Lube Oil Demister Vents - Emission Calculations

- > LG&E plans to provision multiple lube oil storage tanks for the NGCC project. The storage tanks will be equipped with demister vents which will be a source of fugitive VOC emissions. Potential VOC emissions from the demister vents are documented in this section.

12.1 Lube Oil Demister Vents Nomenclature and Specifications

- > Proposed nomenclature for the new lube oil demister vents associated with the NGCC Plant:

Emission Unit: **IA5 - Other Insignificant Activities**

Emission Point: IE25 - Lube Oil Storage Tanks with Demister Vents

Control Device: - - -

Stack ID: Fugitive

- > The working losses conservatively assume that all lube oil consumed/replaced will evaporate and contribute to VOC emissions. Similar to LG&E's Cane Run NGCC project, at most 110 and 73 gallons per year of lube oil will be added to the GT and STG, respectively.

| | | |
|----------------------------|---------------------|--|
| Max Annual Operating Hours | 8,760 hr/yr | |
| GT Lube Oil Consumption | 0.3 gal/day | Process knowledge |
| | 0.013 gal/hr | Unit Conversion: 0.3 gal/day / 24 hr/day |
| ST Lube Oil Consumption | 0.2 gal/day | Process knowledge |
| | 0.008 gal/hr | Unit Conversion: 0.2 gal/day / 24 hr/day |
| Total Lube Oil Consumption | 0.021 gal/hr | 0.013 gal/day from GT + 0.008 gal/day from ST = 0.021 gal/hr total |

12.2 Lube Oil Demister Vents Potential Emissions Summary

| Pollutant | Emission Factor | | Potential Emissions | |
|-----------|-----------------|------------------|---------------------|-------|
| | (lb/gal) | Basis | (lb/hr) | (tpy) |
| VOC | 7.26 | Lube oil density | 0.151 | 0.662 |

Sample Calculations:

$$\text{VOC (lb/hr)} = 7.26 \text{ lb/gal} \times 0.021 \text{ gal/hr} = 0.151 \text{ lb/hr VOC}$$

$$\text{VOC (tpy)} = 0.151 \text{ lb/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 0.662 \text{ tpy VOC}$$

13. Diesel Storage Tank - Emissions Calculations

- > LG&E plans to provision diesel storage tanks for the NGCC project to supply fuel to the emergency generator engine and fire pump engine. Potential emissions from the diesel storage tanks are documented in this section.

13.1 Diesel Storage Tanks Nomenclature and Specifications

- > This insignificant activity represents emissions from two storage tanks: one associated with the new emergency generator engine and one associated with the new fire pump engine.
- > Proposed nomenclature for the new diesel storage tanks associated with the NGCC Plant:

Emission Unit: **IA5 - Other Insignificant Activities**

Emission Point: IE26 - Diesel Storage Tanks for NGCC Units (1@ 4,000 gal 1@ 440 gal)

Control Device: - - - -

Stack ID: Fugitive

Tank Type: Fixed Roof Tanks

| | | |
|---|------------------------|--|
| Emergency Generator Tank Volume | 4,000 gal | Design specifications |
| Emergency Generator Tank Diameter | 534.76 ft ³ | Unit Conversion: 4000 gal x 7.48 ft ³ /gal |
| Emergency Generator Tank Height | 6.98 ft | Design specifications |
| Emergency Generator Tank Throughput | 13.97 ft | Design specifications |
| Emergency Generator Tank Turnovers | 68,504 gal/yr | Emergency diesel engine annual fuel consumption (based on 500 hr/yr): 0.137 Mgal/hr x 500 operating hrs/yr x 1000 gal/Mgal |
| Emergency Generator Tank True Vapor Pressure | 7.82 gal/hr | Assuming continuous operation (i.e., 8,760 hr/yr) |
| Emergency Generator Tank Bulk Liquid Storage Temperature | 17.1 turnovers/yr | 68,504 gal/yr / 4000 gal = 17.13 turnovers/yr |
| Emergency Generator Tank Average Liquid Surface Temperature | 0.0064 psia | Calculated by TankESP |
| Emergency Generator Tank True Vapor Pressure | 59.00 °F | Calculated by TankESP |
| Emergency Generator Tank Bulk Liquid Storage Temperature | 59.79 °F | Calculated by TankESP |
| Emergency Generator Tank Average Liquid Surface Temperature | | |
| Fire Pump Tank Volume | 440 gal | Design specifications |
| Fire Pump Tank Diameter | 58.82 ft ³ | Unit Conversion: 440 gal x 7.48 ft ³ /gal |
| Fire Pump Tank Height | 3.35 ft | Design specifications |
| Fire Pump Tank Throughput | 6.69 ft | Design specifications |
| Fire Pump Tank Turnovers | 10,217 gal/yr | Fire pump diesel engine annual fuel consumption (based on 500 hr/yr): 0.020 Mgal/hr x 500 operating hrs/yr x 1000 gal/Mgal |
| Fire Pump Tank True Vapor Pressure | 1.17 gal/hr | Assuming continuous operation (i.e., 8,760 hr/yr) |
| Fire Pump Tank Bulk Liquid Storage Temperature | 23.2 turnovers/yr | 10,217 gal/yr / 440 gal = 23.22 turnovers/yr |
| Fire Pump Tank Average Liquid Surface Temperature | 0.0064 psia | Calculated by TankESP |
| Fire Pump Tank True Vapor Pressure | 59.00 °F | Calculated by TankESP |
| Fire Pump Tank Bulk Liquid Storage Temperature | 59.79 °F | Calculated by TankESP |
| Fire Pump Tank Average Liquid Surface Temperature | | |

13.2 Diesel Storage Tanks Potential Emissions Summary

| Storage Tank | Pollutant | Emission Factor | | Annual Standing Losses (lb/yr) | Annual Working Losses (lb/yr) | Potential Emissions | |
|---------------------|---|-----------------|---|--------------------------------|-------------------------------|---------------------|----------|
| | | (lb/gal) | Basis | | | (lb/hr) | (tpy) |
| Emergency Generator | VOC | 2.89E-05 | TankESP analysis using methodology presented in AP-42 Section 7.1 | 0.605 | 1.372 | 2.26E-04 | 9.89E-04 |
| Fire Pump | VOC | 2.66E-05 | TankESP analysis using methodology presented in AP-42 Section 7.1 | 0.067 | 0.205 | 3.10E-05 | 1.36E-04 |
| TankESP: | https://www.trinityconsultants.com/software/tanks/tankesp | | | | | | |

14. Mill Creek Unit 1 and 2 Boilers - Emission Reductions from Shutdowns

- > The project covered by this permit application encompasses the planned installation of a new NGCC combustion turbine system in conjunction with the shutdown of the existing Unit 1 and Unit 2 coal boilers.
- > The new NGCC unit is targeted to commence operation on April 1, 2027 following a 37-month construction and commissioning phase. Accordingly, the anticipated start of construction for the project is **March 1, 2024**.
- > Based on this project schedule, the contemporaneous netting period under the PSD/NSR regulations for the project runs from March 1, 2019 (i.e., 5 years prior to start of construction) up to April 1, 2027 (anticipated date of operation).
- > Since both the Unit 1 and Unit 2 boilers are completely shutting down as part of the project, their creditable contemporaneous emission decreases will be equivalent to their baseline actual emissions.
- > Pursuant to 40 CFR 52.21(b)(48)(i), for any existing electric utility steam generating unit, baseline actual emissions are the average rate in tons per year at which the unit actually emitted a pollutant during any consecutive 24-month period selected by the owner/operator within the 5-year period immediately preceding the time the owner/operator begins actual construction of the project. Thus, for this project, the earliest baseline period available is the 24-month period ending February 2021 (i.e., March 2019 to February 2021).
- > A separate 24-month period may be selected for defining baseline actual emissions for each pollutant. The selected baseline periods and documentation of the baseline actual emissions (and thus the equivalent emission reductions for the project) are provided in the following subsections for each relevant regulated NSR pollutant emitted by the Unit 1 and 2 boilers.

14.1 Unit 1 and 2 Boiler Nomenclature

| | Unit 1 | Unit 2 |
|-----------------------------|------------------------------------|------------------------------------|
| Emission Unit ID: | U1 | U2 |
| Emission Point ID: | E1 | E3 |
| Emission Unit Description: | EGU Unit 1 | EGU Unit 2 |
| Emission Point Description: | Unit 1 Boiler (3,085 MMBtu/hr) | Unit 2 Boiler (3,085 MMBtu/hr) |
| Control Device IDs: | C1, C26, C27 | C4, C27, C28 |
| Control Description: | ESP, PAC Injection, DSI, PJFF, FGD | ESP, PAC Injection, DSI, PJFF, FGD |
| Stack IDs: | S33 | S33 |

14.2 NO_x Baseline Actual Emissions

- > LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of NO_x.
- > Because Units 1 and 2 each have a NO_x CEMS, the baseline actual emissions are known directly from the CEMS data set. The monthly and overall 24-month annual average baseline actual NO_x emissions are shown in the table below.

| Month | Unit 1 | Unit 2 |
|----------------|---|---|
| | NO _x CEMS Emissions (tons) | NO _x CEMS Emissions (tons) |
| 3/2019 | 77.5 | 287.6 |
| 4/2019 | 0.0 | 215.9 |
| 5/2019 | 145.6 | 223.9 |
| 6/2019 | 198.3 | 217.7 |
| 7/2019 | 239.3 | 229.4 |
| 8/2019 | 226.4 | 220.0 |
| 9/2019 | 228.2 | 196.7 |
| 10/2019 | 223.6 | 221.9 |
| 11/2019 | 202.6 | 230.3 |
| 12/2019 | 234.6 | 211.3 |
| 1/2020 | 233.6 | 268.1 |
| 2/2020 | 225.6 | 254.9 |
| 3/2020 | 191.2 | 274.7 |
| 4/2020 | 198.0 | 122.0 |
| 5/2020 | 183.3 | 0.0 |
| 6/2020 | 174.1 | 0.0 |
| 7/2020 | 192.6 | 0.0 |
| 8/2020 | 189.4 | 0.0 |
| 9/2020 | 168.9 | 0.0 |
| 10/2020 | 204.6 | 0.0 |
| 11/2020 | 183.8 | 194.8 |
| 12/2020 | 189.5 | 218.1 |
| 1/2021 | 224.5 | 214.2 |
| 2/2021 | 166.4 | 169.2 |
| 24-month Total | 4,501.4 | 3,970.5 |
| Annual Avg | 2,250.7 | 1,985.3 |

14.3 SO₂ and H₂SO₄ Baseline Actual Emissions

- > LG&E has selected the 24-month period ending September 2022 for defining baseline actual emissions of SO₂.
- > Because Units 1 and 2 each have a SO₂ CEMS, the baseline actual emissions are known directly from the CEMS data set.
- > LG&E has selected the 24-month period ending May 2021 for defining baseline actual emissions of sulfuric acid mist (H₂SO₄).
- > H₂SO₄ emissions are calculated based on an assumed 1% conversion rate and a stack test-derived H₂SO₄ control efficiency. The 1% conversion value is codified in Table A1, Attachment H of Title V Permit O-0127-20-V.
- > The H₂SO₄ control efficiency values used for Units 1 and 2 are 98.7% and 99.8%, respectively, based on stack tests conducted June 4-8, 2015 for Units 1 and 2. These control efficiency values are also mandated for emission calculation purposes in Attachment G of Title V Permit O-0127-20-V.
- > The uncontrolled SO₂ emission values needed for the calculation of H₂SO₄ emissions are determined based on the reference emission factor in AP-42 Section 1.1 (Bituminous and Subbituminous Coal Combustion), Table 1.1-3 of "38S", where S is the coal sulfur content as a percentage. The 38S emission factor includes an implicit assumption that 95% of the sulfur in the coal is converted to SO₂. (S lb sulfur/100 lb coal x 2,000 lb/ton x 64 lb SO₂/32 lb S x 95% = 38 S)

14.3.1 Unit 1 Baseline Actual SO₂ and H₂SO₄ Emissions

> The directly measured monthly emissions of SO₂ from CEMS during the baseline period are tabulated below for Unit 1. Based on the estimated uncontrolled SO₂ emissions (before the FGD), the sulfuric acid mist conversion rate, and sulfuric acid mist control efficiency, the baseline actual H₂SO₄ emissions for Unit 1 are also tabulated below.

| Month | Unit 1 Boiler | | SO ₂ Before FGD Emission Factor | SO ₂ Emissions Before FGD Control | SO ₂ CEMS Emissions | SO ₂ Control Efficiency Achieved | H ₂ SO ₄ Control Efficiency | H ₂ SO ₄ Emissions |
|---------|-------------------|---------------------|--|--|--------------------------------|---|---|--|
| | Coal Usage (tons) | Coal Sulfur Content | (lb/ton) | (tons) | (tons) | (%) | (%) | (tons) |
| 6/2019 | 56,145 | 2.59% | 98.4 | 2,762.9 | 26.7 | 99.04% | 98.7% | 0.55 |
| 7/2019 | 71,216 | 2.60% | 98.8 | 3,518.1 | 45.8 | 98.70% | 98.7% | 0.70 |
| 8/2019 | 68,476 | 2.60% | 98.8 | 3,382.7 | 40.7 | 98.80% | 98.7% | 0.67 |
| 9/2019 | 67,272 | 2.68% | 101.8 | 3,425.5 | 47.5 | 98.61% | 98.7% | 0.68 |
| 10/2019 | 73,422 | 2.79% | 106.0 | 3,892.1 | 54.9 | 98.59% | 98.7% | 0.77 |
| 11/2019 | 64,380 | 2.88% | 109.4 | 3,522.9 | 70.7 | 97.99% | 98.7% | 0.70 |
| 12/2019 | 72,906 | 2.88% | 109.4 | 3,989.4 | 66.4 | 98.34% | 98.7% | 0.79 |
| 1/2020 | 71,262 | 2.85% | 108.3 | 3,858.8 | 78.9 | 97.95% | 98.7% | 0.77 |
| 2/2020 | 66,244 | 2.81% | 106.8 | 3,536.8 | 57.3 | 98.38% | 98.7% | 0.70 |
| 3/2020 | 59,470 | 2.80% | 106.4 | 3,163.8 | 57.1 | 98.20% | 98.7% | 0.63 |
| 4/2020 | 63,995 | 2.78% | 105.6 | 3,380.2 | 45.9 | 98.64% | 98.7% | 0.67 |
| 5/2020 | 63,359 | 2.77% | 105.3 | 3,334.6 | 30.6 | 99.08% | 98.7% | 0.66 |
| 6/2020 | 57,413 | 2.77% | 105.3 | 3,021.6 | 28.4 | 99.06% | 98.7% | 0.60 |
| 7/2020 | 65,451 | 2.79% | 106.0 | 3,469.6 | 33.9 | 99.02% | 98.7% | 0.69 |
| 8/2020 | 64,748 | 2.82% | 107.2 | 3,469.2 | 51.4 | 98.52% | 98.7% | 0.69 |
| 9/2020 | 55,962 | 2.83% | 107.5 | 3,009.1 | 33.7 | 98.88% | 98.7% | 0.60 |
| 10/2020 | 67,634 | 2.84% | 107.9 | 3,649.5 | 46.2 | 98.73% | 98.7% | 0.73 |
| 11/2020 | 62,140 | 2.88% | 109.4 | 3,400.3 | 52.3 | 98.46% | 98.7% | 0.68 |
| 12/2020 | 62,047 | 2.90% | 110.2 | 3,418.8 | 54.3 | 98.41% | 98.7% | 0.68 |
| 1/2021 | 79,509 | 2.90% | 110.2 | 4,380.9 | 87.3 | 98.01% | 98.7% | 0.87 |
| 2/2021 | 58,020 | 2.91% | 110.6 | 3,207.9 | 103.7 | 96.77% | 98.7% | 0.64 |
| 3/2021 | 6,713 | 2.93% | 111.3 | 373.7 | 4.8 | 98.72% | 98.7% | 0.07 |
| 4/2021 | 68,693 | 2.88% | 109.4 | 3,758.9 | 76.9 | 97.95% | 98.7% | 0.75 |
| 5/2021 | 63,321 | 2.94% | 111.7 | 3,537.1 | 28.1 | 99.21% | 98.7% | 0.70 |
| 6/2021 | 3,678 | 2.92% | 111.0 | 204.1 | 1.3 | 99.37% | 98.7% | 0.04 |
| 7/2021 | 50,791 | 2.95% | 112.1 | 2,846.8 | 19.4 | 99.32% | 98.7% | 0.57 |
| 8/2021 | 80,745 | 3.00% | 114.0 | 4,602.5 | 68.8 | 98.50% | 98.7% | 0.92 |
| 9/2021 | 71,741 | 3.11% | 118.2 | 4,239.2 | 50.9 | 98.80% | 98.7% | 0.84 |
| 10/2021 | 38,722 | 3.14% | 119.3 | 2,310.2 | 51.4 | 97.78% | 98.7% | 0.46 |
| 11/2021 | 70,195 | 3.14% | 119.3 | 4,187.8 | 91.1 | 97.82% | 98.7% | 0.83 |
| 12/2021 | 42,904 | 3.13% | 118.9 | 2,551.5 | 35.7 | 98.60% | 98.7% | 0.51 |
| 1/2022 | 59,823 | 3.10% | 117.8 | 3,523.6 | 53.7 | 98.47% | 98.7% | 0.70 |
| 2/2022 | 66,254 | 3.10% | 117.8 | 3,902.4 | 75.8 | 98.06% | 98.7% | 0.78 |
| 3/2022 | 78,861 | 3.10% | 117.8 | 4,644.9 | 75.9 | 98.37% | 98.7% | 0.92 |
| 4/2022 | 81,016 | 3.11% | 118.2 | 4,787.2 | 69.5 | 98.55% | 98.7% | 0.95 |
| 5/2022 | 28,522 | 3.13% | 118.9 | 1,696.2 | 25.0 | 98.53% | 98.7% | 0.34 |
| 6/2022 | 32,774 | 3.16% | 120.1 | 1,967.8 | 25.7 | 98.69% | 98.7% | 0.39 |
| 7/2022 | 8,954 | 3.10% | 117.8 | 527.4 | 5.6 | 98.93% | 98.7% | 0.10 |
| 8/2022 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 9/2022 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |

| | | |
|------------------------------|--------------|------------|
| 24-month Total Ending 5/2021 | | |
| 24-month Total Ending 9/2022 | 1,103.6 | |
| Annual Avg | 551.8 | 8.0 |

Sample Calculations: (for 7/2022)

SO2 Before FGD Emission Factor = $38 \times 3.10 = 117.8$ lb SO2/ton uncontrolled

SO2 Emissions Before FGD Control = $8,954 \text{ tons/mo} \times 117.8 \text{ lb/ton} / 2,000 \text{ lb/ton} = 527.4$ tons SO2/mo

SO2 Control Efficiency Achieved = $1 - (5.6 \text{ tons SO2 controlled} / 527.4 \text{ tons SO2 uncontrolled}) = 98.93\%$

H2SO4 Emissions = $527.4 \text{ uncontrolled SO2 tons/mo} \times 1\% \times 98 \text{ lb H2SO4} / 64 \text{ lb SO2} \times (1 - 98.7\%) = 0.10$ tons H2SO4/mo

SO2 Annual Average Baseline Emissions = $1,103.6 \text{ tons/24-months} / 2 \text{ years/24-month} = 551.8$ tpy SO2

H2SO4 Annual Average Baseline Emissions = $16.0 \text{ tons/24-months} / 2 \text{ years/24-month} = 8.0$ tpy H2SO4

14.3.2 Unit 2 Baseline Actual SO₂ and H₂SO₄ Emissions

> The monthly directly measured emissions of SO₂ from CEMS during the baseline period are tabulated below for Unit 2. Based on the estimated uncontrolled SO₂ emissions (before the FGD), the sulfuric acid mist conversion rate, and sulfuric acid mist control efficiency, the baseline actual H₂SO₄ emissions for Unit 2 are also tabulated below.

| Month | Unit 2 Boiler | | SO ₂ Before FGD Emission Factor | SO ₂ Emissions Before FGD Control | SO ₂ CEMS Emissions | SO ₂ Control Efficiency Achieved | H ₂ SO ₄ Control Efficiency | H ₂ SO ₄ Emissions |
|---------|-------------------|---------------------|--|--|--------------------------------|---|---|--|
| | Coal Usage (tons) | Coal Sulfur Content | (lb/ton) | (tons) | (tons) | | | (tons) |
| 6/2019 | 63,042 | 2.59% | 98.4 | 3,102.3 | 28.0 | 99.10% | 99.8% | 0.10 |
| 7/2019 | 70,568 | 2.60% | 98.8 | 3,486.1 | 43.2 | 98.76% | 99.8% | 0.11 |
| 8/2019 | 67,333 | 2.60% | 98.8 | 3,326.3 | 38.8 | 98.83% | 99.8% | 0.10 |
| 9/2019 | 60,312 | 2.68% | 101.8 | 3,071.1 | 46.4 | 98.49% | 99.8% | 0.09 |
| 10/2019 | 73,925 | 2.79% | 106.0 | 3,918.8 | 54.5 | 98.61% | 99.8% | 0.12 |
| 11/2019 | 72,685 | 2.88% | 109.4 | 3,977.3 | 76.1 | 98.09% | 99.8% | 0.12 |
| 12/2019 | 68,406 | 2.88% | 109.4 | 3,743.2 | 68.5 | 98.17% | 99.8% | 0.11 |
| 1/2020 | 82,174 | 2.85% | 108.3 | 4,449.7 | 90.2 | 97.97% | 99.8% | 0.14 |
| 2/2020 | 75,163 | 2.81% | 106.8 | 4,013.0 | 64.5 | 98.39% | 99.8% | 0.12 |
| 3/2020 | 84,985 | 2.79% | 106.0 | 4,505.1 | 69.1 | 98.47% | 99.8% | 0.14 |
| 4/2020 | 38,436 | 2.78% | 105.6 | 2,030.2 | 33.5 | 98.35% | 99.8% | 0.06 |
| 5/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 6/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 7/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 8/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 9/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 10/2020 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 11/2020 | 66,397 | 2.88% | 109.4 | 3,633.2 | 62.6 | 98.28% | 99.8% | 0.11 |
| 12/2020 | 71,579 | 2.90% | 110.2 | 3,944.0 | 63.1 | 98.40% | 99.8% | 0.12 |
| 1/2021 | 74,209 | 2.91% | 110.6 | 4,103.0 | 88.1 | 97.85% | 99.8% | 0.13 |
| 2/2021 | 58,536 | 2.91% | 110.6 | 3,236.5 | 106.0 | 96.73% | 99.8% | 0.10 |
| 3/2021 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 4/2021 | 56,824 | 2.88% | 109.4 | 3,109.4 | 69.5 | 97.76% | 99.8% | 0.10 |
| 5/2021 | 10,628 | 2.91% | 110.6 | 587.6 | 9.4 | 98.40% | 99.8% | 0.02 |
| 6/2021 | 66,321 | 2.92% | 111.0 | 3,679.5 | 58.1 | 98.42% | 99.8% | 0.11 |
| 7/2021 | 50,791 | 2.92% | 111.0 | 2,817.9 | 39.5 | 98.60% | 99.8% | 0.09 |
| 8/2021 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 9/2021 | 0 | -- | -- | -- | 0.0 | -- | -- | -- |
| 10/2021 | 44,741 | 3.13% | 118.9 | 2,660.7 | 40.6 | 98.48% | 99.8% | 0.08 |
| 11/2021 | 77,707 | 3.14% | 119.3 | 4,636.0 | 98.2 | 97.88% | 99.8% | 0.14 |
| 12/2021 | 62,787 | 3.13% | 118.9 | 3,733.9 | 50.0 | 98.66% | 99.8% | 0.11 |
| 1/2022 | 63,540 | 3.10% | 117.8 | 3,742.5 | 58.2 | 98.45% | 99.8% | 0.11 |
| 2/2022 | 42,818 | 3.10% | 117.8 | 2,522.0 | 55.3 | 97.81% | 99.8% | 0.08 |
| 3/2022 | 78,690 | 3.10% | 117.8 | 4,634.8 | 76.1 | 98.36% | 99.8% | 0.14 |
| 4/2022 | 74,462 | 3.11% | 118.2 | 4,400.0 | 66.5 | 98.49% | 99.8% | 0.13 |
| 5/2022 | 0 | -- | -- | -- | 5.1 | -- | -- | -- |
| 6/2022 | 40,774 | 3.17% | 120.5 | 2,455.8 | 31.5 | 98.72% | 99.8% | 0.08 |
| 7/2022 | 69,453 | 3.10% | 117.8 | 4,090.8 | 62.0 | 98.48% | 99.8% | 0.13 |
| 8/2022 | 84,230 | 3.11% | 118.2 | 4,977.2 | 55.4 | 98.89% | 99.8% | 0.15 |
| 9/2022 | 77,295 | 3.11% | 118.2 | 4,567.4 | 87.9 | 98.08% | 99.8% | 0.14 |

24-month Total Ending 5/2021

24-month Total Ending 9/2022

Annual Avg

1,183.0

591.5

0.9

Sample Calculations: (for 7/2022)

SO2 Before FGD Emission Factor = $38 \times 3.10 = 117.8$ lb SO2/ton uncontrolled

SO2 Emissions Before FGD Control = $69,453 \text{ tons/mo} \times 117.8 \text{ lb/ton} / 2,000 \text{ lb/ton} = 4,090.8$ tons SO2/mo

SO2 Control Efficiency Achieved = $1 - (62.0 \text{ tons SO2 controlled} / 4,090.8 \text{ tons SO2 uncontrolled}) = 98.48\%$

H2SO4 Emissions = $4,090.8 \text{ uncontrolled SO2 tons/mo} \times 1\% \times 98 \text{ lb H2SO4} / 64 \text{ lb SO2} \times (1 - 99.8\%) = 0.13$ tons H2SO4/mo

SO2 Annual Average Baseline Emissions = $1,183.0 \text{ tons/24-months} / 2 \text{ years/24-month} = 591.5$ tpy SO2

H2SO4 Annual Average Baseline Emissions = $1.8 \text{ tons/24-months} / 2 \text{ years/24-month} = 0.9$ tpy H2SO4

14.4 CO Baseline Actual Emissions

> LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of CO.

14.4.1 CO Emission Factors

- > CO emissions from Units 1 and 2 can be attributed to both coal combustion and natural gas combustion. Total emissions are based on the sum of emissions attributable to each fuel.
- > LG&E has historically calculated actual CO emissions associated with coal combustion in Units 1 and 2 for annual emission inventory purposes using the reference emission factor in AP-42 Section 1.1 (Bituminous and Subbituminous Coal Combustion), Table 1.1-3, of 0.5 lb/ton. This emission factor is also mandated in Table A1, Attachment H of Title V Permit O-0127-20-V.
- > LG&E has historically calculated actual CO emissions associated with natural gas combustion in Units 1 and 2 for annual emission inventory purposes using the reference emission factor in AP-42 Section 1.4 (Natural Gas Combustion), Table 1.4-1, of 84 lb/MMscf. This emission factor is also mandated in Table A2, Attachment H of Title V Permit O-0127-20-V.

| | | |
|------------------------|-------------|---|
| CO Coal Combustion EF: | 0.5 lb/ton | AP-42 1.1 (9/98), Table 1.1-3, for any type of pulverized coal dry bottom furnace |
| CO NG Combustion EF: | 84 lb/MMscf | AP-42 1.4, Table 1.4-1, for all large (> 100 MMBtu/yr) wall-fired boilers |

14.4.2 Unit 1 Baseline Actual CO Emissions

> The monthly coal and NG usage rates during the selected baseline period for Unit 1 are shown in the following table. The baseline actual CO emissions are calculated based on the respective coal and NG emission factors as shown.

| Month | Unit 1 Boiler | | NG Usage (Mcf) | CO Emissions from NG (tons) | Total CO Monthly Emissions (tons) |
|----------------|----------------------|-------------------------------------|-------------------|-----------------------------------|--|
| | Coal Usage (tons) | CO Emissions from Coal (tons) | | | |
| 3/2019 | 21,074 | 5.27 | 458 | 0.019 | 5.29 |
| 4/2019 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 5/2019 | 44,409 | 11.10 | 22,541 | 0.947 | 12.05 |
| 6/2019 | 56,145 | 14.04 | 6,005 | 0.252 | 14.29 |
| 7/2019 | 71,216 | 17.80 | 72 | 0.003 | 17.81 |
| 8/2019 | 68,476 | 17.12 | 256 | 0.011 | 17.13 |
| 9/2019 | 67,272 | 16.82 | 1,061 | 0.045 | 16.86 |
| 10/2019 | 73,422 | 18.36 | 193 | 0.008 | 18.36 |
| 11/2019 | 64,380 | 16.10 | 1,925 | 0.081 | 16.18 |
| 12/2019 | 72,906 | 18.23 | 21 | 0.001 | 18.23 |
| 1/2020 | 71,262 | 17.82 | 2,455 | 0.103 | 17.92 |
| 2/2020 | 66,244 | 16.56 | 24 | 0.001 | 16.56 |
| 3/2020 | 59,470 | 14.87 | 6,506 | 0.273 | 15.14 |
| 4/2020 | 63,995 | 16.00 | 3,612 | 0.152 | 16.15 |
| 5/2020 | 63,359 | 15.84 | 128 | 0.005 | 15.85 |
| 6/2020 | 57,413 | 14.35 | 3,550 | 0.149 | 14.50 |
| 7/2020 | 65,451 | 16.36 | 281 | 0.012 | 16.37 |
| 8/2020 | 64,748 | 16.19 | 134 | 0.006 | 16.19 |
| 9/2020 | 55,962 | 13.99 | 929 | 0.039 | 14.03 |
| 10/2020 | 67,634 | 16.91 | 87 | 0.004 | 16.91 |
| 11/2020 | 62,140 | 15.54 | 12 | 0.001 | 15.54 |
| 12/2020 | 62,047 | 15.51 | 5,417 | 0.228 | 15.74 |
| 1/2021 | 79,509 | 19.88 | 0 | 0.000 | 19.88 |
| 2/2021 | 58,020 | 14.51 | 2,489 | 0.105 | 14.61 |
| 24-month Total | 1,436,554 | 359.1 | 58,156 | 2.443 | 361.6 |
| Annual Avg | 718,277 | 179.6 | 29,078 | 1.221 | 180.8 |

Sample Calculations: (for 12/2020)

CO Emissions from Coal = 62,047 tons/mo x 0.5 lb/ton / 2,000 lb/ton = 15.51 tons CO/mo

CO Emissions from NG = 5,417 MCF/mo / 1000 MCF/MMcf x 84 lb/MMscf / 2,000 lb/ton = 0.228 tons CO/mo

Total CO Monthly Emissions = 15.51 + 0.228 = 15.74 tons CO/mo

Annual Average Baseline Emissions = 361.6 tons/24-months / 2 years/24-month = 180.8 tpy CO

14.4.3 Unit 2 Baseline Actual CO Emissions

> The monthly coal and NG usage rates during the selected baseline period for Unit 2 are shown in the following table. The baseline actual CO emissions are calculated based on the respective coal and NG emission factors as shown.

| Month | Unit 2 Boiler | | NG Usage (Mcf) | CO Emissions from NG (tons) | Total CO Monthly Emissions (tons) |
|----------------|----------------------|--|-------------------|--------------------------------------|--|
| | Coal Usage (tons) | CO Emissions from Coal (tons) | | | |
| 3/2019 | 73,058 | 18.26 | 2,489 | 0.105 | 18.37 |
| 4/2019 | 58,035 | 14.51 | 4,367 | 0.183 | 14.69 |
| 5/2019 | 68,309 | 17.08 | 56 | 0.002 | 17.08 |
| 6/2019 | 63,042 | 15.76 | 958 | 0.040 | 15.80 |
| 7/2019 | 70,568 | 17.64 | 163 | 0.007 | 17.65 |
| 8/2019 | 67,333 | 16.83 | 0 | 0.000 | 16.83 |
| 9/2019 | 60,312 | 15.08 | 3,274 | 0.138 | 15.22 |
| 10/2019 | 73,925 | 18.48 | 587 | 0.025 | 18.51 |
| 11/2019 | 72,685 | 18.17 | 111 | 0.005 | 18.18 |
| 12/2019 | 68,406 | 17.10 | 2,004 | 0.084 | 17.19 |
| 1/2020 | 82,174 | 20.54 | 669 | 0.028 | 20.57 |
| 2/2020 | 75,163 | 18.79 | 14 | 0.001 | 18.79 |
| 3/2020 | 84,985 | 21.25 | 319 | 0.013 | 21.26 |
| 4/2020 | 38,436 | 9.61 | 4,810 | 0.202 | 9.81 |
| 5/2020 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 6/2020 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 7/2020 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 8/2020 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 9/2020 | 0 | 0.00 | 0 | 0.000 | 0.00 |
| 10/2020 | 0 | 0.00 | 7,630 | 0.320 | 0.32 |
| 11/2020 | 66,397 | 16.60 | 10,203 | 0.429 | 17.03 |
| 12/2020 | 71,579 | 17.89 | 4,223 | 0.177 | 18.07 |
| 1/2021 | 74,209 | 18.55 | 3,598 | 0.151 | 18.70 |
| 2/2021 | 58,536 | 14.63 | 1,583 | 0.066 | 14.70 |
| 24-month Total | 1,227,152 | 306.8 | 47,058 | 1.976 | 308.8 |
| Annual Avg | 613,576 | 153.4 | 23,529 | 0.988 | 154.4 |

Sample Calculations: (for 12/2020)

CO Emissions from Coal = 71,579 tons/mo x 0.5 lb/ton / 2,000 lb/ton = 17.89 tons CO/mo

CO Emissions from NG = 4,223 MCF/mo / 1000 MCF/MMcf x 84 lb/MMscf / 2,000 lb/ton = 0.177 tons CO/mo

Total CO Monthly Emissions = 17.89 + 0.177 = 18.07 tons CO/mo

Annual Average Baseline Emissions = 308.8 tons/24-months / 2 years/24-month = 154.4 tpy CO

14.5 VOC Baseline Actual Emissions

> LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of VOC.

14.5.1 VOC Emission Factors

- > VOC emissions from Units 1 and 2 can be attributed to both coal combustion and natural gas combustion. Total emissions are based on the sum of emissions attributable to each fuel.
- > LG&E has historically calculated actual VOC emissions associated with coal combustion in Units 1 and 2 for annual emission inventory purposes using the reference emission factor in AP-42 Section 1.1 (Bituminous and Subbituminous Coal Combustion), Table 1.1-19, of 0.06 lb/ton. This emission factor is also mandated in Table A1, Attachment H of Title V Permit O-0127-20-V.
- > LG&E has historically calculated actual VOC emissions associated with natural gas combustion in Units 1 and 2 for annual emission inventory purposes using the reference emission factor in AP-42 Section 1.4 (Natural Gas Combustion), Table 1.4-2, of 5.5 lb/MMscf. This emission factor is also mandated in Table A2, Attachment H of Title V Permit O-0127-20-V.

| | | |
|-------------------------|--------------|---|
| VOC Coal Combustion EF: | 0.06 lb/ton | AP-42 1.1 (9/98), Table 1.1-19, TNMOC for pulverized coal dry bottom furnaces |
| VOC NG Combustion EF: | 5.5 lb/MMscf | AP-42 1.4, Table 1.4-2. |

14.5.2 Unit 1 Baseline Actual VOC Emissions

> The monthly coal and NG usage rates during the selected baseline period for Unit 1 are shown in the following table. The baseline actual VOC emissions are calculated based on the respective coal and NG emission factors as shown.

| Month | Unit 1 Boiler | | NG Usage (Mcf) | VOC Emissions from NG (tons) | Total VOC Monthly Emissions (tons) |
|----------------|----------------------|---|-------------------|---------------------------------------|---|
| | Coal Usage (tons) | VOC Emissions from Coal (tons) | | | |
| 3/2019 | 21,074 | 0.63 | 458 | 0.0013 | 0.63 |
| 4/2019 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 5/2019 | 44,409 | 1.33 | 22,541 | 0.0620 | 1.39 |
| 6/2019 | 56,145 | 1.68 | 6,005 | 0.0165 | 1.70 |
| 7/2019 | 71,216 | 2.14 | 72 | 0.0002 | 2.14 |
| 8/2019 | 68,476 | 2.05 | 256 | 0.0007 | 2.05 |
| 9/2019 | 67,272 | 2.02 | 1,061 | 0.0029 | 2.02 |
| 10/2019 | 73,422 | 2.20 | 193 | 0.0005 | 2.20 |
| 11/2019 | 64,380 | 1.93 | 1,925 | 0.0053 | 1.94 |
| 12/2019 | 72,906 | 2.19 | 21 | 0.0001 | 2.19 |
| 1/2020 | 71,262 | 2.14 | 2,455 | 0.0068 | 2.14 |
| 2/2020 | 66,244 | 1.99 | 24 | 0.0001 | 1.99 |
| 3/2020 | 59,470 | 1.78 | 6,506 | 0.0179 | 1.80 |
| 4/2020 | 63,995 | 1.92 | 3,612 | 0.0099 | 1.93 |
| 5/2020 | 63,359 | 1.90 | 128 | 0.0004 | 1.90 |
| 6/2020 | 57,413 | 1.72 | 3,550 | 0.0098 | 1.73 |
| 7/2020 | 65,451 | 1.96 | 281 | 0.0008 | 1.96 |
| 8/2020 | 64,748 | 1.94 | 134 | 0.0004 | 1.94 |
| 9/2020 | 55,962 | 1.68 | 929 | 0.0026 | 1.68 |
| 10/2020 | 67,634 | 2.03 | 87 | 0.0002 | 2.03 |
| 11/2020 | 62,140 | 1.86 | 12 | 0.0000 | 1.86 |
| 12/2020 | 62,047 | 1.86 | 5,417 | 0.0149 | 1.88 |
| 1/2021 | 79,509 | 2.39 | 0 | 0.0000 | 2.39 |
| 2/2021 | 58,020 | 1.74 | 2,489 | 0.0068 | 1.75 |
| 24-month Total | 1,436,554 | 43.1 | 58,156 | 0.1599 | 43.3 |
| Annual Avg | 718,277 | 21.5 | 29,078 | 0.0800 | 21.6 |

Sample Calculations: (for 12/2020)

VOC Emissions from Coal = 62,047 tons/mo x 0.06 lb/ton / 2,000 lb/ton = 1.86 tons VOC/mo

VOC Emissions from NG = 5,417 MCF/mo / 1000 MCF/MMcf x 5.5 lb/MMscf / 2,000 lb/ton = 0.0149 tons VOC/mo

Total VOC Monthly Emissions = 1.86 + 0.0149 = 1.88 tons VOC/mo

Annual Average Baseline Emissions = 43.3 tons/24-months / 2 years/24-month = 21.6 tpy VOC

14.5.3 Unit 2 Baseline Actual VOC Emissions

> The monthly coal and NG usage rates during the selected baseline period for Unit 2 are shown in the following table. The baseline actual VOC emissions are calculated based on the respective coal and NG emission factors as shown.

| Month | Unit 2 Boiler | | NG Usage (Mcf) | VOC Emissions from NG (tons) | Total VOC Monthly Emissions (tons) |
|----------------|----------------------|---|-------------------|---------------------------------------|---|
| | Coal Usage (tons) | VOC Emissions from Coal (tons) | | | |
| 3/2019 | 73,058 | 2.19 | 2,489 | 0.0068 | 2.20 |
| 4/2019 | 58,035 | 1.74 | 4,367 | 0.0120 | 1.75 |
| 5/2019 | 68,309 | 2.05 | 56 | 0.0002 | 2.05 |
| 6/2019 | 63,042 | 1.89 | 958 | 0.0026 | 1.89 |
| 7/2019 | 70,568 | 2.12 | 163 | 0.0004 | 2.12 |
| 8/2019 | 67,333 | 2.02 | 0 | 0.0000 | 2.02 |
| 9/2019 | 60,312 | 1.81 | 3,274 | 0.0090 | 1.82 |
| 10/2019 | 73,925 | 2.22 | 587 | 0.0016 | 2.22 |
| 11/2019 | 72,685 | 2.18 | 111 | 0.0003 | 2.18 |
| 12/2019 | 68,406 | 2.05 | 2,004 | 0.0055 | 2.06 |
| 1/2020 | 82,174 | 2.47 | 669 | 0.0018 | 2.47 |
| 2/2020 | 75,163 | 2.25 | 14 | 0.0000 | 2.25 |
| 3/2020 | 84,985 | 2.55 | 319 | 0.0009 | 2.55 |
| 4/2020 | 38,436 | 1.15 | 4,810 | 0.0132 | 1.17 |
| 5/2020 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 6/2020 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 7/2020 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 8/2020 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 9/2020 | 0 | 0.00 | 0 | 0.0000 | 0.00 |
| 10/2020 | 0 | 0.00 | 7,630 | 0.0210 | 0.02 |
| 11/2020 | 66,397 | 1.99 | 10,203 | 0.0281 | 2.02 |
| 12/2020 | 71,579 | 2.15 | 4,223 | 0.0116 | 2.16 |
| 1/2021 | 74,209 | 2.23 | 3,598 | 0.0099 | 2.24 |
| 2/2021 | 58,536 | 1.76 | 1,583 | 0.0044 | 1.76 |
| 24-month Total | 1,227,152 | 36.81 | 47,058 | 0.1294 | 36.9 |
| Annual Avg | 613,576 | 18.41 | 23,529 | 0.0647 | 18.5 |

Sample Calculations: (for 12/2020)

VOC Emissions from Coal = 58,536 tons/mo x 0.06 lb/ton / 2,000 lb/ton = 1.76 tons VOC/mo

VOC Emissions from NG = 1,583 MCF/mo / 1000 MCF/MMcf x 5.5 lb/MMscf / 2,000 lb/ton = 0.0044 tons VOC/mo

Total VOC Monthly Emissions = 1.76 + 0.0044 = 1.76 tons VOC/mo

Annual Average Baseline Emissions = 36.9 tons/24-months / 2 years/24-month = 18.5 tpy VOC

14.6 PM/PM10/PM2.5 Baseline Actual Emissions

> LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of PM, PM10, and PM2.5.

14.6.1 PM Emission Factors

- > Because there is a PM CEMS on the shared Unit 1 and 2 stack, the baseline actual emissions for filterable PM are known directly from the CEMS data set. The individual unit PM emissions are assumed to be proportional to the individual heat input rate and the total heat input rate.
- > LG&E has historically calculated actual PM10 and PM2.5 emissions for Units 1 and 2 for annual emission inventory purposes using the cumulative particle size distribution information for coal boilers in AP-42 Section 1.1 (Bituminous and Subbituminous Coal Combustion), Table 1.1-6, combined with the known PM emissions data from the CEMS.
- > Specifically, as shown in AP-42 Table 1.1-6, for a baghouse controlled coal boiler, 92% of cumulative PM filterable mass can be expected to be PM₁₀ and 53% of the cumulative PM filterable mass can be expected to be PM_{2.5}. These same ratios are also mandated in Table A1, Attachment H of Title V Permit O-0127-20-V.
- > Condensable PM emissions from **coal combustion** are estimated based on the emission factor in AP-42 Section 1.1, Table 1.1-6 for pulverized coal boilers with PM control combined with FGD control of 0.02 lb/MMBtu. This emission factor is also mandated in Table A1, Attachment H of Title V Permit O-0127-20-V.
- > Condensable PM emissions from **natural gas combustion** are estimated based on the 2011 NEI EPA emission factor, as mandated in Table A2, Attachment H of Title V Permit O-0127-20-V. Note that this attachment of the permit also specifies a PM-filterable emission factor to use for natural gas combustion. However, since all PM (from both coal and natural gas combustion) are measured by the CEMS, a separate calculation of PM-filterable emissions from natural gas combustion is not performed.

| | | |
|---------------------------------|---------------|---|
| PM10/PM Filterable Size Ratio: | 0.92 | AP-42 1.1 (9/98), Table 1-1-6, Cumulative Mass % for baghouse controlled boiler |
| PM2.5/PM Filterable Size Ratio: | 0.53 | AP-42 1.1 (9/98), Table 1-1-6, Cumulative Mass % for baghouse controlled boiler |
| PM Condensable EF for Coal: | 0.02 lb/MMBtu | AP-42 1.1 (9/98), Table 1-1-5, Coal boiler with PM controls combined with FGD |
| PM Condensable EF for NG: | 0.32 lb/MMcf | 2011 NEI, EPA (See Attachment H, Table A2 of Title V permit) |

14.6.2 Unit 1 Baseline Actual PM/PM10/PM2.5 Emissions

Imber

> The monthly coal and natural gas heat input rates during the selected baseline period for Unit 1 are shown in the following table. The baseline actual PM/PM₁₀/PM_{2.5} emissions are calculated based on the PM CEMS data, the PM₁₀ and PM_{2.5} filterable ratios, and condensable PM emission factors as shown.

| Month | Unit 1 Boiler | | PM | PM | Condens. | Total PM Emissions (tons) | PM ₁₀ | PM _{2.5} |
|----------------|-------------------------|-------------------------|---|---------------------------------------|---------------------|---------------------------|-----------------------------|-----------------------------|
| | Coal Heat Input (MMBtu) | Natural Gas Usage (Mcf) | Filterable Emissions from CEMS (lb/MMBtu) | Filterable Emissions from CEMS (tons) | PM Emissions (tons) | | Filterable Emissions (tons) | Filterable Emissions (tons) |
| 3/2019 | 472,439 | 458 | 0.0041 | 0.96 | 4.72 | 5.68 | 5.61 | 5.23 |
| 4/2019 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 5/2019 | 1,027,220 | 22,541 | 0.0046 | 2.34 | 10.28 | 12.62 | 12.43 | 11.52 |
| 6/2019 | 1,286,599 | 6,005 | 0.0043 | 2.75 | 12.87 | 15.62 | 15.40 | 14.33 |
| 7/2019 | 1,651,254 | 72 | 0.0041 | 3.40 | 16.51 | 19.91 | 19.64 | 18.32 |
| 8/2019 | 1,571,795 | 256 | 0.0041 | 3.25 | 15.72 | 18.97 | 18.71 | 17.44 |
| 9/2019 | 1,550,152 | 1,061 | 0.0043 | 3.34 | 15.50 | 18.84 | 18.57 | 17.27 |
| 10/2019 | 1,643,911 | 193 | 0.0040 | 3.31 | 16.44 | 19.75 | 19.49 | 18.19 |
| 11/2019 | 1,419,736 | 1,925 | 0.0041 | 2.92 | 14.20 | 17.12 | 16.89 | 15.75 |
| 12/2019 | 1,627,665 | 21 | 0.0042 | 3.43 | 16.28 | 19.71 | 19.44 | 18.10 |
| 1/2020 | 1,565,780 | 2,455 | 0.0040 | 3.17 | 15.66 | 18.83 | 18.57 | 17.34 |
| 2/2020 | 1,473,879 | 24 | 0.0041 | 3.00 | 14.74 | 17.74 | 17.50 | 16.33 |
| 3/2020 | 1,241,753 | 6,506 | 0.0047 | 2.93 | 12.42 | 15.35 | 15.11 | 13.97 |
| 4/2020 | 1,424,207 | 3,612 | 0.0043 | 3.06 | 14.24 | 17.30 | 17.06 | 15.86 |
| 5/2020 | 1,391,382 | 128 | 0.0042 | 2.91 | 13.91 | 16.82 | 16.59 | 15.45 |
| 6/2020 | 1,281,102 | 3,550 | 0.0042 | 2.71 | 12.81 | 15.52 | 15.30 | 14.25 |
| 7/2020 | 1,463,518 | 281 | 0.0042 | 3.11 | 14.64 | 17.74 | 17.49 | 16.28 |
| 8/2020 | 1,435,575 | 134 | 0.0044 | 3.14 | 14.36 | 17.49 | 17.24 | 16.02 |
| 9/2020 | 1,257,837 | 929 | 0.0043 | 2.73 | 12.58 | 15.31 | 15.09 | 14.02 |
| 10/2020 | 1,503,443 | 87 | 0.0046 | 3.44 | 15.03 | 18.47 | 18.20 | 16.86 |
| 11/2020 | 1,344,464 | 12 | 0.0044 | 2.95 | 13.44 | 16.39 | 16.15 | 15.01 |
| 12/2020 | 1,354,782 | 5,417 | 0.0043 | 2.90 | 13.55 | 16.45 | 16.22 | 15.09 |
| 1/2021 | 1,690,775 | 0 | 0.0043 | 3.62 | 16.91 | 20.53 | 20.24 | 18.83 |
| 2/2021 | 1,219,193 | 2,489 | 0.0073 | 4.43 | 12.19 | 16.62 | 16.27 | 14.54 |
| 24-month Total | 31,898,457 | 58,156 | | 69.80 | 318.99 | 388.79 | 383.21 | 355.99 |
| Annual Avg | 15,949,228 | 29,078 | 0.0042 | 34.90 | 159.50 | 194.4 | 191.6 | 178.0 |

Sample Calculations: (for 2/2021)

PM-Filterable Emissions = 1,219,193 MMBtu/mo x 0.0073 lb/MMBtu / 2,000 lb/ton = 4.43 tons/mo PM-Filterable

Condensable PM Emissions = 1,219,193 MMBtu/mo x 0.02 lb/MMBtu / 2,000 lb/ton +

2,489 Mcfmo / 1000 Mcf/MMcf x 0.32 lb/MMcf / 2,000 lb/ton = 12.19 tons/mo PM Condensibles

PM Emissions = 4.43 tons PM-Filt/mo + 12.19 tons PM-Cond/mo = 16.62 tons/mo PM

PM10 Emissions = 4.43 tons PM-Filt/mo x 0.92 + 12.19 tons PM-Cond/mo = 16.27 tons/mo PM10

PM2.5 Emissions = 4.43 tons PM-Filt/mo x 0.53 + 12.19 tons PM-Cond/mo = 14.54 tons/mo PM2.5

Annual Average Baseline PM10 Emissions = 383.2 tons/24-months / 2 years/24-month = 191.6 tpy Total PM10

Annual Average Baseline PM2.5 Emissions = 356.0 tons/24-months / 2 years/24-month = 178.0 tpy Total PM2.5

14.6.3 Unit 2 Baseline Actual PM/PM10/PM2.5 Emissions

Imber

> The monthly coal and natural gas heat input rates during the selected baseline period for Unit 2 are shown in the following table. The baseline actual PM/PM₁₀/PM_{2.5} emissions are calculated based on the PM CEMS data, the PM₁₀ and PM_{2.5} filterable ratios, and condensable PM emission factors as shown.

| Month | Unit 2 Boiler | | PM | PM | Condens. | Total PM Emissions (tons) | PM ₁₀ | PM _{2.5} |
|----------------|-------------------------|-------------------------|---|---------------------------------------|---------------------|---------------------------|-----------------------------|-----------------------------|
| | Coal Heat Input (MMBtu) | Natural Gas Usage (Mcf) | Filterable Emissions from CEMS (lb/MMBtu) | Filterable Emissions from CEMS (tons) | PM Emissions (tons) | | Filterable Emissions (tons) | Filterable Emissions (tons) |
| 3/2019 | 1,825,052 | 2,489 | 0.0041 | 3.71 | 18.25 | 21.96 | 21.66 | 20.22 |
| 4/2019 | 1,462,865 | 4,367 | 0.0046 | 3.35 | 14.63 | 17.98 | 17.71 | 16.41 |
| 5/2019 | 1,567,100 | 56 | 0.0045 | 3.49 | 15.67 | 19.16 | 18.88 | 17.52 |
| 6/2019 | 1,420,369 | 958 | 0.0043 | 3.03 | 14.20 | 17.23 | 16.99 | 15.81 |
| 7/2019 | 1,585,589 | 163 | 0.0041 | 3.27 | 15.86 | 19.12 | 18.86 | 17.59 |
| 8/2019 | 1,529,429 | 0 | 0.0041 | 3.17 | 15.29 | 18.46 | 18.21 | 16.97 |
| 9/2019 | 1,368,624 | 3,274 | 0.0043 | 2.95 | 13.69 | 16.64 | 16.40 | 15.25 |
| 10/2019 | 1,635,772 | 587 | 0.0040 | 3.30 | 16.36 | 19.65 | 19.39 | 18.10 |
| 11/2019 | 1,641,799 | 111 | 0.0041 | 3.37 | 16.42 | 19.79 | 19.52 | 18.21 |
| 12/2019 | 1,502,585 | 2,004 | 0.0042 | 3.17 | 15.03 | 18.20 | 17.95 | 16.71 |
| 1/2020 | 1,798,755 | 669 | 0.0040 | 3.64 | 17.99 | 21.63 | 21.33 | 19.92 |
| 2/2020 | 1,668,024 | 14 | 0.0041 | 3.40 | 16.68 | 20.08 | 19.81 | 18.48 |
| 3/2020 | 1,798,399 | 319 | 0.0046 | 4.17 | 17.98 | 22.15 | 21.82 | 20.19 |
| 4/2020 | 853,140 | 4,810 | 0.0043 | 1.84 | 8.53 | 10.37 | 10.22 | 9.51 |
| 5/2020 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 6/2020 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 7/2020 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 8/2020 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 9/2020 | 0 | 0 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 10/2020 | 0 | 7,630 | 0.0000 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 11/2020 | 1,433,755 | 10,203 | 0.0044 | 3.16 | 14.34 | 17.50 | 17.25 | 16.02 |
| 12/2020 | 156,373 | 4,223 | 0.0428 | 3.35 | 1.56 | 4.91 | 4.64 | 3.34 |
| 1/2021 | 1,579,424 | 3,598 | 0.0043 | 3.39 | 15.79 | 19.18 | 18.91 | 17.59 |
| 2/2021 | 1,238,756 | 1,583 | 0.0073 | 4.50 | 12.39 | 16.89 | 16.53 | 14.77 |
| 24-month Total | 26,065,809 | 47,058 | | 60.26 | 260.67 | 320.92 | 316.10 | 292.60 |
| Annual Avg | 13,032,905 | 23,529 | 0.0049 | 30.13 | 130.33 | 160.5 | 158.1 | 146.3 |

Sample Calculations: (for 22021)

PM-Filterable Emissions = 1,238,756 MMBtu/mo x 0.0073 lb/MMBtu / 2,000 lb/ton = 4.50 tons/mo PM-Filterable

Condensable PM Emissions = 1,238,756 MMBtu/mo x 0.02 lb/MMBtu / 2,000 lb/ton +

1,583 Mcf/mo / 1000 Mcf/MMcf x 0.32 lb/MMcf / 2,000 lb/ton = 12.39 tons/mo PM Condensibles

PM Emissions = 4.50 tons PM-Filt/mo + 12.39 tons PM-Cond/mo = 16.89 tons/mo PM

PM10 Emissions = 4.50 tons PM-Filt/mo x 0.92 + 12.39 tons PM-Cond/mo = 16.53 tons/mo PM10

PM2.5 Emissions = 4.50 tons PM-Filt/mo x 0.53 + 12.39 tons PM-Cond/mo = 14.77 tons/mo PM2.5

Annual Average Baseline PM10 Emissions = 316.1 tons/24-months / 2 years/24-month = 158.1 tpy Total PM10

Annual Average Baseline PM2.5 Emissions = 292.6 tons/24-months / 2 years/24-month = 146.3 tpy Total PM2.5

14.7 Lead Baseline Actual Emissions

> LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of lead.

14.7.1 Lead Emission Factors

> Lead emissions from **coal combustion** for Units 1 and 2 calculated for annual emission inventory purposes are based on the emission factor specified in Table A1, Attachment H of Title V Permit O-0127-20-V.

> Lead emissions from **natural gas combustion** for Units 1 and 2 calculated for annual emission inventory purposes are based on the emission factor in AP-42 Section 1.4 (Natural Gas Combustion), Table 1.4-2 of 5E-4 lb/MMscf. This emission factor is also mandated in Table A2, Attachment H of Title V Permit O-0127-20-V.

Lead Coal Combustion EF: **2.25E-06** lb/MMBtu Table A1, Attachment H of Title V permit.

Lead NG Combustion EF: **5.00E-04** lb/MMcf AP-42 1.4, Table 1.4-2

14.7.2 Units 1 and 2 Baseline Actual Lead Emissions

> The monthly coal usage and associated heat input rates, and the natural gas usage rates during the selected baseline period for Unit 1 are shown in the following table. The baseline actual lead emissions are calculated based on the emission factor documented above.

| Month | Unit 1 Boiler | | | | Unit 2 Boiler | | | |
|----------------|----------------------|-------------------------------|-------------------------------|-----------------------------|----------------------|-------------------------------|-------------------------------|-----------------------------|
| | Coal Usage (tons) | Coal Heat Input (MMBtu) | Natural Gas Usage (Mcf) | Lead Emissions (tons) | Coal Usage (tons) | Coal Heat Input (MMBtu) | Natural Gas Usage (Mcf) | Lead Emissions (tons) |
| 3/2019 | 21,074 | 472,439 | 458 | 0.0005 | 73,058 | 1,825,052 | 2,489 | 0.0021 |
| 4/2019 | 0 | 0 | 0 | 0.0000 | 58,035 | 1,462,865 | 4,367 | 0.0016 |
| 5/2019 | 44,409 | 1,027,220 | 22,541 | 0.0012 | 68,309 | 1,567,100 | 56 | 0.0018 |
| 6/2019 | 56,145 | 1,286,599 | 6,005 | 0.0014 | 63,042 | 1,420,369 | 958 | 0.0016 |
| 7/2019 | 71,216 | 1,651,254 | 72 | 0.0019 | 70,568 | 1,585,589 | 163 | 0.0018 |
| 8/2019 | 68,476 | 1,571,795 | 256 | 0.0018 | 67,333 | 1,529,429 | 0 | 0.0017 |
| 9/2019 | 67,272 | 1,550,152 | 1,061 | 0.0017 | 60,312 | 1,368,624 | 3,274 | 0.0015 |
| 10/2019 | 73,422 | 1,643,911 | 193 | 0.0018 | 73,925 | 1,635,772 | 587 | 0.0018 |
| 11/2019 | 64,380 | 1,419,736 | 1,925 | 0.0016 | 72,685 | 1,641,799 | 111 | 0.0018 |
| 12/2019 | 72,906 | 1,627,665 | 21 | 0.0018 | 68,406 | 1,502,585 | 2,004 | 0.0017 |
| 1/2020 | 71,262 | 1,565,780 | 2,455 | 0.0018 | 82,174 | 1,798,755 | 669 | 0.0020 |
| 2/2020 | 66,244 | 1,473,879 | 24 | 0.0017 | 75,163 | 1,668,024 | 14 | 0.0019 |
| 3/2020 | 59,470 | 1,241,753 | 6,506 | 0.0014 | 84,985 | 1,798,399 | 319 | 0.0020 |
| 4/2020 | 63,995 | 1,424,207 | 3,612 | 0.0016 | 38,436 | 853,140 | 4,810 | 0.0010 |
| 5/2020 | 63,359 | 1,391,382 | 128 | 0.0016 | 0 | 0 | 0 | 0.0000 |
| 6/2020 | 57,413 | 1,281,102 | 3,550 | 0.0014 | 0 | 0 | 0 | 0.0000 |
| 7/2020 | 65,451 | 1,463,518 | 281 | 0.0016 | 0 | 0 | 0 | 0.0000 |
| 8/2020 | 64,748 | 1,435,575 | 134 | 0.0016 | 0 | 0 | 0 | 0.0000 |
| 9/2020 | 55,962 | 1,257,837 | 929 | 0.0014 | 0 | 0 | 0 | 0.0000 |
| 10/2020 | 67,634 | 1,503,443 | 87 | 0.0017 | 0 | 0 | 7,630 | 0.0000 |
| 11/2020 | 62,140 | 1,344,464 | 12 | 0.0015 | 66,397 | 1,433,755 | 10,203 | 0.0016 |
| 12/2020 | 62,047 | 1,354,782 | 5,417 | 0.0015 | 71,579 | 156,373 | 4,223 | 0.0002 |
| 1/2021 | 79,509 | 1,690,775 | 0 | 0.0019 | 74,209 | 1,579,424 | 3,598 | 0.0018 |
| 2/2021 | 58,020 | 1,219,193 | 2,489 | 0.0014 | 58,536 | 1,238,756 | 1,583 | 0.0014 |
| 24-month Total | 1,436,554 | 31,898,457 | 58,156 | 0.036 | 1,227,152 | 26,065,809 | 47,058 | 0.029 |
| Annual Avg | 718,277 | 15,949,228 | 29,078 | 0.018 | 613,576 | 13,032,905 | 23,529 | 0.015 |

Sample Calculations: (for 2/2021 for Unit 1)

Unit 1 Lead Emissions = 1,219,193 MMBtu/mo x 2.25E-06 lb/MMBtu / 2,000 lb/ton +

2,489 MCF/mo / 1000 Mcf/MMcf x 5.00E-04 lb/MMcf / 2,000 lb/ton = 0.0014 ton/mo

Annual Average Baseline Emissions = 0.036 tons/24-months / 2 years/24-month = 0.018 tpy lead

14.8 CO₂e Baseline Actual Emissions

> LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of CO₂e.

14.8.1 GHG Emission Factors

- > Because Units 1 and 2 each have a CO₂ CEMS, the baseline actual emissions are known directly from the CEMS data set. The monthly and overall 24-month annual average baseline actual CO₂ emissions are shown in the table below.
- > Emission factors for methane and nitrous oxide from both coal and natural gas combustion are based on Subpart C of EPA's Mandatory Greenhouse Gas Reporting Rule (MRR, 40 CFR 98 Subpart C Table C-2).
- > The global warming multiplying factors for CH₄ and N₂O are those specified in 40 CFR 98 Subpart A.

| | | |
|--|-------------------|--------------------------------|
| Coal CH ₄ Emission Factor: | 1.10E-02 kg/MMBtu | 40 CFR 98 Subpart C, Table C-2 |
| NG CH ₄ Emission Factor: | 1.00E-03 kg/MMBtu | 40 CFR 98 Subpart C, Table C-2 |
| Coal N ₂ O Emission Factor: | 1.60E-03 kg/MMBtu | 40 CFR 98 Subpart C, Table C-2 |
| NG N ₂ O Emission Factor: | 1.00E-04 kg/MMBtu | 40 CFR 98 Subpart C, Table C-2 |

Global warming multiplying factors to calculate CO₂e emissions:

| | | |
|---------------------------|-----|--------------------------------|
| GWP for CO ₂ : | 1 | 40 CFR 98 Subpart A, Table A-1 |
| GWP for CH ₄ : | 25 | 40 CFR 98 Subpart A, Table A-1 |
| GWP for N ₂ O: | 298 | 40 CFR 98 Subpart A, Table A-1 |

14.8.2 Unit 1 Baseline Actual CO₂e Emissions

> The monthly coal and NG heat input rates during the selected baseline period for Unit 1 are shown in the following table. The baseline actual CO₂e emissions are calculated based on the directly measured CO₂ emissions and the calculated CH₄ and N₂O emissions as shown.

| Month | Unit 1 Boiler | | | | | |
|----------------|--|-------------------------------|-----------------------------|--|---|--|
| | Measured CO ₂ Emissions (tons) | Coal Heat Input (MMBtu) | NG Heat Input (MMBtu) | CH ₄ Emissions (tons) | N ₂ O Emissions (tons) | CO ₂ e Emissions (tons) |
| 3/2019 | 48,034 | 472,439 | 488 | 5.7 | 0.8 | 48,425 |
| 4/2019 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 5/2019 | 104,290 | 1,027,220 | 24,006 | 12.5 | 1.8 | 105,142 |
| 6/2019 | 130,776 | 1,286,599 | 6,395 | 15.6 | 2.3 | 131,843 |
| 7/2019 | 167,905 | 1,651,254 | 77 | 20.0 | 2.9 | 169,273 |
| 8/2019 | 159,827 | 1,571,795 | 273 | 19.1 | 2.8 | 161,130 |
| 9/2019 | 157,472 | 1,550,152 | 1,130 | 18.8 | 2.7 | 158,757 |
| 10/2019 | 167,121 | 1,643,911 | 206 | 19.9 | 2.9 | 168,484 |
| 11/2019 | 144,355 | 1,419,736 | 2,050 | 17.2 | 2.5 | 145,532 |
| 12/2019 | 165,360 | 1,627,665 | 22 | 19.7 | 2.9 | 166,709 |
| 1/2020 | 159,199 | 1,565,780 | 2,615 | 19.0 | 2.8 | 160,497 |
| 2/2020 | 149,244 | 1,473,879 | 26 | 17.9 | 2.6 | 150,465 |
| 3/2020 | 126,756 | 1,241,753 | 6,929 | 15.1 | 2.2 | 127,785 |
| 4/2020 | 145,831 | 1,424,207 | 3,847 | 17.3 | 2.5 | 147,012 |
| 5/2020 | 142,749 | 1,391,382 | 136 | 16.9 | 2.5 | 143,902 |
| 6/2020 | 131,308 | 1,281,102 | 3,781 | 15.5 | 2.3 | 132,369 |
| 7/2020 | 150,140 | 1,463,518 | 299 | 17.7 | 2.6 | 151,352 |
| 8/2020 | 147,205 | 1,435,575 | 143 | 17.4 | 2.5 | 148,394 |
| 9/2020 | 129,030 | 1,257,837 | 990 | 15.3 | 2.2 | 130,073 |
| 10/2020 | 153,977 | 1,503,443 | 92 | 18.2 | 2.7 | 155,223 |
| 11/2020 | 137,669 | 1,344,464 | 13 | 16.3 | 2.4 | 138,783 |
| 12/2020 | 138,950 | 1,354,782 | 5,769 | 16.4 | 2.4 | 140,073 |
| 1/2021 | 173,370 | 1,690,775 | 0 | 20.5 | 3.0 | 174,771 |
| 2/2021 | 125,040 | 1,219,193 | 2,651 | 14.8 | 2.2 | 126,051 |
| 24-month Total | 3,255,606 | 31,898,457 | 61,938 | 386.9 | 56.3 | 3,282,045 |
| Annual Avg | 1,627,803 | 15,949,228 | 30,969 | 193.4 | 28.1 | 1,641,022 |

Sample Calculations: (for 12/2020)

CH₄ Emissions = 1,354,782 MMBtu/mo x 1.10E-02 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton +
5,769 MMBtu/mo x 1.00E-03 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton = 16.4 tons/mo CH₄

N₂O Emissions = 1,354,782 MMBtu/mo x 1.60E-03 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton +
5,769 MMBtu/mo x 1.00E-04 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton = 2.4 tons/mo N₂O

CO₂e Emissions = 138,950 tons/mo CO₂ + (16.4 tons/mo CH₄ x 25) + (2.4 tons/mo N₂O x 298) = 140,073 tons/mo CO₂e

Annual Average Baseline Emissions = 3,282,045 tons/24-months / 2 years/24-month = 1,641,022 tpy CO₂e

14.8.3 Unit 2 Baseline Actual CO₂e Emissions

> The monthly coal and NG heat input rates during the selected baseline period for Unit 2 are shown in the following table. The baseline actual CO₂e emissions are calculated based on the directly measured CO₂ emissions and the calculated CH₄ and N₂O emissions as shown.

| Month | Unit 2 Boiler Measured | | | | | |
|----------------|----------------------------------|-------------------------|-----------------------|----------------------------------|-----------------------------------|------------------------------------|
| | CO ₂ Emissions (tons) | Coal Heat Input (MMBtu) | NG Heat Input (MMBtu) | CH ₄ Emissions (tons) | N ₂ O Emissions (tons) | CO ₂ e Emissions (tons) |
| 3/2019 | 185,491 | 1,825,052 | 2,651 | 22.1 | 3.2 | 187,003 |
| 4/2019 | 148,459 | 1,462,865 | 4,651 | 17.7 | 2.6 | 149,672 |
| 5/2019 | 158,484 | 1,567,100 | 60 | 19.0 | 2.8 | 159,783 |
| 6/2019 | 144,195 | 1,420,369 | 1,020 | 17.2 | 2.5 | 145,372 |
| 7/2019 | 161,228 | 1,585,589 | 174 | 19.2 | 2.8 | 162,542 |
| 8/2019 | 155,520 | 1,529,429 | 0 | 18.5 | 2.7 | 156,787 |
| 9/2019 | 139,077 | 1,368,624 | 3,487 | 16.6 | 2.4 | 140,211 |
| 10/2019 | 166,320 | 1,635,772 | 625 | 19.8 | 2.9 | 167,676 |
| 11/2019 | 166,866 | 1,641,799 | 118 | 19.9 | 2.9 | 168,226 |
| 12/2019 | 152,640 | 1,502,585 | 2,134 | 18.2 | 2.7 | 153,886 |
| 1/2020 | 182,842 | 1,798,755 | 712 | 21.8 | 3.2 | 184,333 |
| 2/2020 | 168,830 | 1,668,024 | 15 | 20.2 | 2.9 | 170,212 |
| 3/2020 | 183,695 | 1,798,399 | 340 | 21.8 | 3.2 | 185,185 |
| 4/2020 | 87,467 | 853,140 | 5,122 | 10.4 | 1.5 | 88,174 |
| 5/2020 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 6/2020 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 7/2020 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 8/2020 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 9/2020 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 10/2020 | 0 | 0 | 8,126 | 0.0 | 0.0 | 0 |
| 11/2020 | 147,080 | 1,433,755 | 10,866 | 17.4 | 2.5 | 148,268 |
| 12/2020 | 160,476 | 156,373 | 4,497 | 1.9 | 0.3 | 160,606 |
| 1/2021 | 162,020 | 1,579,424 | 3,832 | 19.2 | 2.8 | 163,329 |
| 2/2021 | 127,052 | 1,238,756 | 1,686 | 15.0 | 2.2 | 128,079 |
| 24-month Total | 2,797,740 | 26,065,809 | 50,116 | 316.1 | 46.0 | 2,819,344 |
| Annual Avg | 1,398,870 | 13,032,905 | 25,058 | 158.1 | 23.0 | 1,409,672 |

Sample Calculations: (for 2/2021)

CH₄ Emissions = 1,238,756 MMBtu/mo x 1.10E-02 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton +
1,686 MMBtu/mo x 1.00E-03 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton = 15.0 tons/mo CH₄

N₂O Emissions = 1,238,756 MMBtu/mo x 1.60E-03 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton +
1,686 MMBtu/mo x 1.00E-04 kg/MMBtu x 2.20462 lb/kg / 2,000 lb/ton = 2.2 tons/mo N₂O

CO₂e Emissions = 127,052 tons/mo CO₂ + (15.0 tons/mo CH₄ x 25) + (2.2 tons/mo N₂O x 298) = 128,079 tons/mo CO₂e

Annual Average Baseline Emissions = 2,819,344 tons/24-months / 2 years/24-month = 1,409,672 tpy CO₂e

15. Mill Creek Unit 1 and 2 Coal Bunkers - Emission Reductions from Shutdowns Imber

- > In conjunction with the shutdown of the Unit 1 and 2 boilers, their associated coal silos and coal mills in the coal bunkers will also shutdown resulting in emission decreases of PM that are quantified in this section.

15.1 Coal Bunkers Emission Unit Nomenclature

- > The coal silos and coal mills associated with the Unit 1 Boiler operation are designated as Emission Point E2 under Emission Unit U1. Similarly, the coal silos and coal mills associated with the Unit 2 Boiler operation are designated as Emission Point E4 under Emission Unit U2.

| Emission Unit | Emission Point | Control Device | Stack ID |
|-----------------|---------------------------------------|---------------------------------|----------|
| U1 - EGU Unit 1 | E2 - Four Coal Silos; Four Coal Mills | C3 - Centrifugal Dust Collector | S5 |
| U2 - EGU Unit 2 | E4 - Four Coal Silos; Four Coal Mills | C6 - Centrifugal Dust Collector | S6 |

15.2 PM/PM10/PM2.5 Baseline Actual Emissions

- > LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of PM, PM10, and PM2.5.

15.2.1 PM Emission Factors

- > LG&E has historically calculated uncontrolled PM, PM10 and PM2.5 emissions for the coal bunkers for annual emission inventory purposes using the methodology in AP-42 Section 13.2.4 (Aggregate Handling and Storage Piles).
- > PM emissions from transfer points in the process are calculated using Equation 1 of 13.2.4 as a function of material moisture content and mean wind speed. LG&E uses a coal moisture content value of 4.5%, which is the mean value specified for coal-fired power plants in Table 13.2.4-1. Since the coal bunker transfer points are enclosed, a reduced wind speed 1.3 mph is used in the calculation. Particle size multipliers specified in Section 13.2.4 of AP-42 are used to define the PM, PM10, and PM2.5 emission rates. The resulting emission factors used are listed below. These same emission factors are also mandated in Table A3, Attachment H of Title V Permit O-0127-20-V.

$$E \text{ (lb/ton)} = 0.0032k * (U/5)^{1.3} / (M/2)^{1.4}$$

where:

| | PM | PM ₁₀ | PM _{2.5} |
|--------------------------------------|----------|------------------|-------------------|
| k: Particle Size Multiplier (lb/VMT) | 0.74 | 0.35 | 0.053 |
| M: Material Moisture Content (%) | 4.5 | 4.5 | 4.5 |
| U: Mean Wind Speed (mph) | 1.3 | 1.3 | 1.3 |
| E: Emission Factor (lb/ton) | 1.32E-04 | 6.25E-05 | 9.46E-06 |

Sample Calculation: (for PM)

$$\text{PM Transfer EF} = 0.0032 \times 0.74 \times (1.3/5)^{1.3} / (4.5/2)^{1.4} = 1.32\text{E-}04 \text{ lb/ton}$$

- > PM emissions from the coal bunkers are routed to a centrifugal dust collector for control. As specified in Table A3, Attachment H of Title V Permit O-0127-20-V, a 90% control efficiency is used for calculating emissions to the atmosphere.

| | PM | PM ₁₀ | PM _{2.5} |
|--|----------|------------------|-------------------|
| Post-Control Emission Factors (lb/ton) | 1.32E-05 | 6.25E-06 | 9.46E-07 |

Sample Calculation: (for PM)

$$\text{Post-Control PM Emission Factor} = 1.32\text{E-}04 \text{ lb/ton} \times (100\% - 90\%) = 1.32\text{E-}05 \text{ lb/ton PM controlled}$$

15.2.2 Unit 1 and 2 Coal Bunker Baseline Actual PM/PM10/PM2.5 Emissions

Imber

> The monthly coal usage rates during the selected baseline period for Units 1 and 2 are shown in the following table. The baseline actual PM/PM₁₀/PM_{2.5} emissions are calculated based on PM, PM₁₀, and PM_{2.5} emission factors as shown.

| Month | Unit 1 Coal Handling Emissions | | | | Unit 2 Coal Handling Emissions | | | |
|----------------|--------------------------------|---------------------|-----------------------------------|-----------------------------------|--------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| | Coal Usage (tons) | PM Filterable | PM10 | PM2.5 | Coal Usage (tons) | PM | PM10 | PM2.5 |
| | | Emissions (tons) | Filterable Emissions (tons) | Filterable Emissions (tons) | | Filterable Emissions (tons) | Filterable Emissions (tons) | Filterable Emissions (tons) |
| 3/2019 | 21,074 | 0.00014 | 0.00007 | 0.00001 | 73,058 | 0.00048 | 0.00023 | 0.00003 |
| 4/2019 | 0 | 0.00000 | 0.00000 | 0.00000 | 58,035 | 0.00038 | 0.00018 | 0.00003 |
| 5/2019 | 44,409 | 0.00029 | 0.00014 | 0.00002 | 68,309 | 0.00045 | 0.00021 | 0.00003 |
| 6/2019 | 56,145 | 0.00037 | 0.00018 | 0.00003 | 63,042 | 0.00042 | 0.00020 | 0.00003 |
| 7/2019 | 71,216 | 0.00047 | 0.00022 | 0.00003 | 70,568 | 0.00047 | 0.00022 | 0.00003 |
| 8/2019 | 68,476 | 0.00045 | 0.00021 | 0.00003 | 67,333 | 0.00044 | 0.00021 | 0.00003 |
| 9/2019 | 67,272 | 0.00044 | 0.00021 | 0.00003 | 60,312 | 0.00040 | 0.00019 | 0.00003 |
| 10/2019 | 73,422 | 0.00048 | 0.00023 | 0.00003 | 73,925 | 0.00049 | 0.00023 | 0.00003 |
| 11/2019 | 64,380 | 0.00043 | 0.00020 | 0.00003 | 72,685 | 0.00048 | 0.00023 | 0.00003 |
| 12/2019 | 72,906 | 0.00048 | 0.00023 | 0.00003 | 68,406 | 0.00045 | 0.00021 | 0.00003 |
| 1/2020 | 71,262 | 0.00047 | 0.00022 | 0.00003 | 82,174 | 0.00054 | 0.00026 | 0.00004 |
| 2/2020 | 66,244 | 0.00044 | 0.00021 | 0.00003 | 75,163 | 0.00050 | 0.00023 | 0.00004 |
| 3/2020 | 59,470 | 0.00039 | 0.00019 | 0.00003 | 84,985 | 0.00056 | 0.00027 | 0.00004 |
| 4/2020 | 63,995 | 0.00042 | 0.00020 | 0.00003 | 38,436 | 0.00025 | 0.00012 | 0.00002 |
| 5/2020 | 63,359 | 0.00042 | 0.00020 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 6/2020 | 57,413 | 0.00038 | 0.00018 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 7/2020 | 65,451 | 0.00043 | 0.00020 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 8/2020 | 64,748 | 0.00043 | 0.00020 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 9/2020 | 55,962 | 0.00037 | 0.00017 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 10/2020 | 67,634 | 0.00045 | 0.00021 | 0.00003 | 0 | 0.00000 | 0.00000 | 0.00000 |
| 11/2020 | 62,140 | 0.00041 | 0.00019 | 0.00003 | 66,397 | 0.00044 | 0.00021 | 0.00003 |
| 12/2020 | 62,047 | 0.00041 | 0.00019 | 0.00003 | 71,579 | 0.00047 | 0.00022 | 0.00003 |
| 1/2021 | 79,509 | 0.00053 | 0.00025 | 0.00004 | 74,209 | 0.00049 | 0.00023 | 0.00004 |
| 2/2021 | 58,020 | 0.00038 | 0.00018 | 0.00003 | 58,536 | 0.00039 | 0.00018 | 0.00003 |
| 24-month Total | 1,436,554 | 0.0095 | 0.0045 | 0.0007 | 1,227,152 | 0.0081 | 0.0038 | 0.0006 |
| Annual Avg | 718,277 | 0.0047 | 0.0022 | 0.0003 | 613,576 | 0.0041 | 0.0019 | 0.0003 |

Sample Calculations: (for 2/2021 for Unit 1 for PM)

Unit 1 Coal Bunker PM Emissions = 58,020 tons x 1.32-E-05 lb/ton / 2,000 lb/ton = 0.00038 tons/mo PM

Annual Average Baseline PM Emissions for Unit 1 Coal Bunker = 0.0095 tons/24-months / 2 years/24-month = 0.0047 tpy PM

16. Mill Creek Unit 1 and 2 Coal Bunkers - Emission Reductions from Shutdowns Imber

- > The shutdown of Unit 1 and 2 boilers as part of the NGCC project will result in emission reductions from the corresponding shutdown of their associated coal handling operations.

16.1 Coal Handling Operations Emission Unit Nomenclature

- > The coal handling operations associated with the coal boilers are covered by Emission Unit 21 (Emission Points E47a-f). While the coal handling operations will remain following the project, their emissions will decrease given the reduction in coal throughput from the shutdown of Units 1 and 2. The emission reductions associated with the shutdown of Units 1 and 2 can be quantified based on the coal throughput attributable to the Unit 1 and 2 boilers during the baseline period.

| Emission Unit | Emission Point | Transfer Enclosure |
|---------------------|--|--------------------|
| U21 - Coal Handling | E47a - Barge Unloading Operation (Coal) | Outdoors |
| U21 - Coal Handling | E47b - Railcar Unloading (Coal) | Outdoors |
| U21 - Coal Handling | E47c - Coal Radial Stacker | Outdoors |
| U21 - Coal Handling | E47d - Two Coal Crushers | Indoor/Enclosed |
| U21 - Coal Handling | E47e1-16 - Coal Belt Conveyors | Indoor/Enclosed |
| U21 - Coal Handling | E47f - Coal Storage Pile (Drop Point Emission) | Outdoors |

16.2 PM/PM10/PM2.5 Baseline Actual Emissions

- > LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of PM, PM10, and PM2.5.

16.2.1 PM Emission Factors

- > LG&E has historically calculated actual PM, PM10, and PM2.5 emissions for the coal handling operations for annual emission inventory purposes using the methodology in AP-42 Section 13.2.4 (Aggregate Handling and Storage Piles).
- > PM emissions from transfer points in the coal handling operations are calculated using Equation 1 of 13.2.4 as a function of material moisture content and mean wind speed. LG&E uses a coal moisture content value of 4.5%, which is the mean value specified for coal-fired power plants in Table 13.2.4-1. A wind speed of 8.4 and 1.3 mph is used for indoor/enclosed and outdoor transfer points, respectively. Particle size multipliers specified in the 13.2.4 of AP-42 are used to define the PM, PM10, and PM2.5 emission rates. The resulting emission factors used for each type of transfer are listed below. These same emission factors are also mandated in Table A3, Attachment H of Title V Permit O-0127-20-V.

$$E \text{ (lb/ton)} = 0.0032k * (U/5)^{1.3} / (M/2)^{1.4}$$

where:

| | PM | PM ₁₀ | PM _{2.5} |
|--------------------------------------|------|------------------|-------------------|
| k: Particle Size Multiplier (lb/VMT) | 0.74 | 0.35 | 0.053 |
| M: Material Moisture Content (%) | 4.5 | 4.5 | 4.5 |

Emission Factors for Outdoor Transfers (E47a, E47b, E47c, and E47f)

| | | | |
|-----------------------------|----------|----------|----------|
| U: Mean Wind Speed (mph) | 8.4 | 8.4 | 8.4 |
| E: Emission Factor (lb/ton) | 1.49E-03 | 7.06E-04 | 1.07E-04 |

Emission Factors for Indoor/Enclosed Transfers (E47d and E47e)

| | | | |
|-----------------------------|----------|----------|----------|
| U: Mean Wind Speed (mph) | 1.3 | 1.3 | 1.3 |
| E: Emission Factor (lb/ton) | 1.32E-04 | 6.25E-05 | 9.46E-06 |

Sample Calculation: (for PM for Outdoor Transfer)

$$\text{PM Outdoor Transfer EF} = 0.0032 \times 0.74 \times (8.4/5)^{1.3} / (4.5/2)^{1.4} = 1.49\text{E-}03 \text{ lb/ton}$$

- > A single consolidated emission factor for each PM size fraction is calculated based on the sum of transfer points. The barge and rail unloading emission factors, which are identical, are only counted once since coal is only received via one of the two methods at a time.

| | PM | PM ₁₀ | PM _{2.5} |
|-----------------------------------|----------|------------------|-------------------|
| Combined Emission Factor (lb/ton) | 4.74E-03 | 2.24E-03 | 3.40E-04 |

Sample Calculation (for PM):

Coal Handling PM EF = 1.49E-03 (barge/rail unloading) + 1.49E-03 (radial stacker) + 1.49E-03 (coal pile) + 1.32E-04 (conveyors) + 1.32E-04 (coal crusher) = 4.74E-03 lb/ton PM

16.2.2 Unit 1 and 2 Coal Handling Operations Baseline Actual PM/PM10/PM2.5 Emissions

- > The monthly coal usage rates during the selected baseline period for Units 1 and 2 are shown in the following table. The baseline actual emissions are calculated based on PM, PM₁₀, and PM_{2.5} emission factors as shown.

| Month | Unit 1 Coal Handling Emissions | | | | Unit 2 Coal Handling Emissions | | | |
|----------------|--------------------------------|--------------------------------------|---|--|--------------------------------|---|---|--|
| | Coal Usage (tons) | PM Filterable Emissions (tons) | PM10 Filterable Emissions (tons) | PM2.5 Filterable Emissions (tons) | Coal Usage (tons) | PM Filterable Emissions (tons) | PM10 Filterable Emissions (tons) | PM2.5 Filterable Emissions (tons) |
| 3/2019 | 21,074 | 0.050 | 0.024 | 0.004 | 73,058 | 0.173 | 0.082 | 0.012 |
| 4/2019 | 0 | 0.000 | 0.000 | 0.000 | 58,035 | 0.138 | 0.065 | 0.010 |
| 5/2019 | 44,409 | 0.105 | 0.050 | 0.008 | 68,309 | 0.162 | 0.077 | 0.012 |
| 6/2019 | 56,145 | 0.133 | 0.063 | 0.010 | 63,042 | 0.150 | 0.071 | 0.011 |
| 7/2019 | 71,216 | 0.169 | 0.080 | 0.012 | 70,568 | 0.167 | 0.079 | 0.012 |
| 8/2019 | 68,476 | 0.162 | 0.077 | 0.012 | 67,333 | 0.160 | 0.076 | 0.011 |
| 9/2019 | 67,272 | 0.160 | 0.075 | 0.011 | 60,312 | 0.143 | 0.068 | 0.010 |
| 10/2019 | 73,422 | 0.174 | 0.082 | 0.012 | 73,925 | 0.175 | 0.083 | 0.013 |
| 11/2019 | 64,380 | 0.153 | 0.072 | 0.011 | 72,685 | 0.172 | 0.082 | 0.012 |
| 12/2019 | 72,906 | 0.173 | 0.082 | 0.012 | 68,406 | 0.162 | 0.077 | 0.012 |
| 1/2020 | 71,262 | 0.169 | 0.080 | 0.012 | 82,174 | 0.195 | 0.092 | 0.014 |
| 2/2020 | 66,244 | 0.157 | 0.074 | 0.011 | 75,163 | 0.178 | 0.084 | 0.013 |
| 3/2020 | 59,470 | 0.141 | 0.067 | 0.010 | 84,985 | 0.202 | 0.095 | 0.014 |
| 4/2020 | 63,995 | 0.152 | 0.072 | 0.011 | 38,436 | 0.091 | 0.043 | 0.007 |
| 5/2020 | 63,359 | 0.150 | 0.071 | 0.011 | 0 | 0.000 | 0.000 | 0.000 |
| 6/2020 | 57,413 | 0.136 | 0.064 | 0.010 | 0 | 0.000 | 0.000 | 0.000 |
| 7/2020 | 65,451 | 0.155 | 0.073 | 0.011 | 0 | 0.000 | 0.000 | 0.000 |
| 8/2020 | 64,748 | 0.154 | 0.073 | 0.011 | 0 | 0.000 | 0.000 | 0.000 |
| 9/2020 | 55,962 | 0.133 | 0.063 | 0.010 | 0 | 0.000 | 0.000 | 0.000 |
| 10/2020 | 67,634 | 0.160 | 0.076 | 0.011 | 0 | 0.000 | 0.000 | 0.000 |
| 11/2020 | 62,140 | 0.147 | 0.070 | 0.011 | 66,397 | 0.158 | 0.075 | 0.011 |
| 12/2020 | 62,047 | 0.147 | 0.070 | 0.011 | 71,579 | 0.170 | 0.080 | 0.012 |
| 1/2021 | 79,509 | 0.189 | 0.089 | 0.014 | 74,209 | 0.176 | 0.083 | 0.013 |
| 2/2021 | 58,020 | 0.138 | 0.065 | 0.010 | 58,536 | 0.139 | 0.066 | 0.010 |
| 24-month Total | 1,436,554 | 3.41 | 1.61 | 0.24 | 1,227,152 | 2.91 | 1.38 | 0.21 |
| Annual Avg | 718,277 | 1.70 | 0.81 | 0.12 | 613,576 | 1.46 | 0.69 | 0.10 |

Sample Calculations: (for 2/2021 for Unit 1 for PM)

Unit 1 Coal Handling PM Emissions = 58,020 tons x 4.74-E-03 lb/ton / 2000 lb/ton = 0.138 tons/mo PM

Annual Average Baseline PM Emissions for Unit 1 Coal Handling = 3.41 tons/24-months / 2 years/24-month = 1.70 tpy PM

17. Mill Creek Unit 1 and 2 Flyash Transfer Bin - Emission Reductions from Shutdowns

- > In conjunction with the shutdown of the Unit 1 and 2 boilers, the Flyash Transfer Bin for Units 1 and 2 will also shutdown resulting in emission decreases of PM that are quantified in this section.

17.1 Flyash Transfer Bin Emission Unit Nomenclature

- > The flyash transfer bin serving the Units 1 and 2 Boilers is designated as Emission Point E16 under Emission Unit U9. While Emission Unit U9 will remain, E16 will be removed as part of the NGCC project.

| Emission Unit | Emission Point | Control Device | Stack ID |
|----------------------------|---|----------------|---------------|
| U9 - Fly Ash Transfer Bins | E16 - Flyash Transfer Bin with Two Separators for Units 1 & 2 | C19 - Baghouse | S17, S24, S25 |

17.2 PM/PM10/PM2.5 Baseline Actual Emissions

- > LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of PM, PM10, and PM2.5.

17.2.1 PM Emission Factors

- > LG&E has historically calculated uncontrolled PM, PM10 and PM2.5 emissions for the flyash transfer bins using representative emission factors in AP-42 Section 11.12 (Concrete Batching), Table 11.12-2 for cement supplement unloading to an elevated silo.
- > To account for the higher moisture content in coal flyash (4.8%) versus cement supplement (1%), the Table 11.12-2 emission factors are multiplied by the moisture content adjustment factor from AP-42 Section 13.2.4 Equation 1 (for aggregate drop points). The resulting uncontrolled emission factors are also what is listed in Table A3 of Attachment H in Title V Permit O-0127-20-V.

$$\text{Moisture Content Adjustment Factor} = (1\%)^{1.4} / (4.8\%)^{1.4} = 0.1112$$

| | PM | PM ₁₀ |
|--|--------|------------------|
| Emission factors from Table 11.12-2 (lb/ton) | 3.14 | 1.1 |
| Adjusted for Coal Flyash Moisture (lb/ton) | 0.3493 | 0.1224 |

Sample Calculation: (for PM)

$$\text{Coal Flyash Transfer EF} = 3.14 \text{ lb/ton for cement unloading} \times 0.1112 \text{ moisture adjustment factor} = 0.3493 \text{ lb/ton PM}$$

- > Because there is not a separate PM_{2.5} emission factor available in AP-42 Table 11.12-2, PM_{2.5} emissions have historically been set equal to PM₁₀ for emission inventory purposes.
- > PM emissions from the flyash transfer bin are routed to a baghouse for PM control. As specified in Table A3, Attachment H of Title V Permit O-0127-20-V, a 98% control efficiency is used for calculating emissions to the atmosphere.

| | PM | PM ₁₀ |
|--|----------|------------------|
| Post-Control Emission Factors (lb/ton) | 6.99E-03 | 2.45E-03 |

Sample Calculation: (for PM)

$$\text{Post-Control PM Emission Factor} = 0.3493 \text{ lb/ton} \times (1 - 0.98) = 6.99\text{E-}03 \text{ lb/ton PM controlled}$$

17.2.2 Unit 1 & 2 Flyash Transfer Bin Baseline Actual PM/PM10/PM2.5 Emissions

Imber

- > The emission factors defined above are multiplied by the flyash throughput rate to define emissions. The amount of flyash generated is calculated as 80% of the total ash content in the coal.
- > The monthly coal usage rates during the selected baseline period for Units 1 and 2 along with ash contents and calculated flyash process rates are shown in the following table. The baseline actual PM/PM₁₀/PM_{2.5} emissions are calculated based on PM and PM₁₀ emission factors as shown.

| Month | Unit 1 Coal | Unit 1 Coal | Unit 2 Coal | Unit 2 Coal | Total | PM | PM10 | PM2.5 |
|----------------|-----------------|--------------------|-----------------|--------------------|--------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| | Usage (tons) | Ash Content (%) | Usage (tons) | Ash Content (%) | Unit 1 & 2 Flyash (tons) | Filterable Emissions (tons) | Filterable Emissions (tons) | Filterable Emissions (tons) |
| 3/2019 | 21,074 | 8.96% | 73,058 | 9.03% | 6,788 | 0.02371 | 0.00831 | 0.00831 |
| 4/2019 | 0 | 0.00% | 58,035 | 8.97% | 4,165 | 0.01455 | 0.00510 | 0.00510 |
| 5/2019 | 44,409 | 9.11% | 68,309 | 9.08% | 8,198 | 0.02864 | 0.01003 | 0.01003 |
| 6/2019 | 56,145 | 9.29% | 63,042 | 9.28% | 8,853 | 0.03092 | 0.01083 | 0.01083 |
| 7/2019 | 71,216 | 9.33% | 70,568 | 9.33% | 10,583 | 0.03697 | 0.01295 | 0.01295 |
| 8/2019 | 68,476 | 9.42% | 67,333 | 9.43% | 10,240 | 0.03577 | 0.01253 | 0.01253 |
| 9/2019 | 67,272 | 9.15% | 60,312 | 9.13% | 9,329 | 0.03259 | 0.01142 | 0.01142 |
| 10/2019 | 73,422 | 9.40% | 73,925 | 9.40% | 11,080 | 0.03870 | 0.01356 | 0.01356 |
| 11/2019 | 64,380 | 9.70% | 72,685 | 9.71% | 10,642 | 0.03717 | 0.01302 | 0.01302 |
| 12/2019 | 72,906 | 9.75% | 68,406 | 9.76% | 11,028 | 0.03852 | 0.01349 | 0.01349 |
| 1/2020 | 71,262 | 9.78% | 82,174 | 9.78% | 12,005 | 0.04193 | 0.01469 | 0.01469 |
| 2/2020 | 66,244 | 9.86% | 75,163 | 9.86% | 11,154 | 0.03896 | 0.01365 | 0.01365 |
| 3/2020 | 59,470 | 9.97% | 84,985 | 9.97% | 11,522 | 0.04024 | 0.01410 | 0.01410 |
| 4/2020 | 63,995 | 9.94% | 38,436 | 9.95% | 8,148 | 0.02846 | 0.00997 | 0.00997 |
| 5/2020 | 63,359 | 10.02% | 0 | 0.00% | 5,079 | 0.01774 | 0.00621 | 0.00621 |
| 6/2020 | 57,413 | 10.09% | 0 | 0.00% | 4,634 | 0.01619 | 0.00567 | 0.00567 |
| 7/2020 | 65,451 | 10.21% | 0 | 0.00% | 5,346 | 0.01867 | 0.00654 | 0.00654 |
| 8/2020 | 64,748 | 10.28% | 0 | 0.00% | 5,325 | 0.01860 | 0.00652 | 0.00652 |
| 9/2020 | 55,962 | 10.40% | 0 | 0.00% | 4,656 | 0.01626 | 0.00570 | 0.00570 |
| 10/2020 | 67,634 | 10.35% | 0 | 0.00% | 5,600 | 0.01956 | 0.00685 | 0.00685 |
| 11/2020 | 62,140 | 10.41% | 66,397 | 10.41% | 10,705 | 0.03739 | 0.01310 | 0.01310 |
| 12/2020 | 62,047 | 10.43% | 71,579 | 10.44% | 11,155 | 0.03897 | 0.01365 | 0.01365 |
| 1/2021 | 79,509 | 10.37% | 74,209 | 10.37% | 12,752 | 0.04454 | 0.01560 | 0.01560 |
| 2/2021 | 58,020 | 10.29% | 58,536 | 10.29% | 9,595 | 0.03351 | 0.01174 | 0.01174 |
| 24-month Total | 1,436,554 | | | | 208,584 | 0.729 | 0.255 | 0.255 |
| Annual Avg | 718,277 | | | | 104,292 | 0.364 | 0.128 | 0.128 |

Sample Calculations: (for 2/2021 for Unit 1 for PM)

Total Unit 1 & 2 Flyash = 80% x (58,020 tons x 10.29% + 58,536 tons x 10.29%) = 9,595 tons/mo flyash

PM Filterable Emissions = 9,595 tons flyash/mo x 6.99E-03 lb/ton / 2,000 lb/ton = 0.03351 tons/mo PM

Annual Average Baseline PM Emissions for Flyash Transfer = 0.729 tons/24-months / 2 years/24-month = 0.364 tpy PM

18. Mill Creek Unit 1 and 2 Sorbent and PAC Silos - Emission Reductions from Shutdowns

- > In conjunction with the shutdown of the Unit 1 and 2 boilers, two of the six existing Sorbent Silos (U16) used for holding dry sorbent or Trona will be shutdown. Similarly, two of the six existing PAC Storage Silos (U17) associated with the PAC Injection Systems will also shutdown. The remaining four Sorbent Silos and PAC Silos will continue to operate to serve Units 3 and 4 and will be unaffected by the project. The small level of PM emission reductions associated with the shutdown of two of the Sorbent Silos and PAC Silos are quantified in this section.

18.1 Sorbent and PAC Silos Emission Unit Nomenclature

- > All six Sorbent Silos serving the Units 1 to 4 Boilers are designated as Emission Unit U16 and are individually Emission Points E40a to E40f. Sorbent Silos E40a and E40b will be shutdown and the remaining E40c to E40f Silos will remain.
- > All six PAC Silos serving the Units 1 to 4 Boilers are designated as Emission Unit U17 and are individually Emission Points E41a to E41f. PAC Silos E41a and E41b will be shutdown and the remaining E41c to E41f Silos will remain.

| Emission Unit | Emission Point | Control Device | Stack ID |
|---|---|---------------------------|----------|
| Emission Points Shutting Down with NCGG Project | | | |
| U16 - Sorbent Storage Silos | E40a-b - Two of Six Sorbent Silos for Dry Sorbent or Trona | C32a-b - Bin Vent Filters | S35a-b |
| U17 - PAC Storage Silos | E41a-b - Two of Six PAC Silos for PAC Injection System | C33a-b - Bin Vent Filters | S36a-b |
| Emission Points Remaining to Serve Units 3 and 4 Boilers | | | |
| U16 - Sorbent Storage Silos | E40c-f - Four of Six Sorbent Silos for Dry Sorbent or Trona | C32c-f - Bin Vent Filters | S35c-f |
| U17 - PAC Storage Silos | E41c-f - Four of Six PAC Silos for PAC Injection System | C33c-f - Bin Vent Filters | S36c-f |

18.2 PM/PM10/PM2.5 Baseline Actual Emissions

- > LG&E has selected the 24-month period ending February 2021 for defining baseline actual emissions of PM, PM10, and PM2.5.

18.2.1 PM Emission Factors

- > LG&E has historically calculated uncontrolled PM, PM10 and PM2.5 emissions for transfers to the Sorbent and PAC Silos using representative emission factors in AP-42 Section 11.17 (Lime Manufacturing), Table 11.17.4 for product loading operations, of 0.61 lb/ton. This emission factor is also mandated in Table A3, Attachment H of Title V Permit O-0127-20-V.
- > The Sorbent and PAC Silos are each equipped with bin vent filter systems that provide control of PM emissions. As specified in Attachment G of Title V Permit O-0127-20-V, a 99% control efficiency is used for calculating emissions to the atmosphere based on data provided by the filter manufacturer. Given the presence of the PM filter, all PM is assumed to be in the PM_{2.5} size fraction.

| | |
|--------------------------------------|-------------------------------------|
| Emission factor from Table 11.17-4 | 0.61 lb/ton |
| Bin Vent Filter Control Efficiency | 99% |
| Controlled Emission Factor for Silos | 0.0061 lb/ton (for PM, PM10, PM2.5) |

18.2.2 Unit 1 & 2 Sorbent and PAC Silos Baseline Actual PM/PM10/PM2.5 Emissions

Imber

> LG&E tracks annual throughput rates of sorbent and PAC used in total. Throughput rates for the two of six silos being shutdown are calculated as 1/3 of the total. A reasonable estimate of the monthly throughput rates in the silos for each month in 2019 to 2021 during the baseline period were made by apportioning the annual process rate based on monthly operating hours. The baseline actual PM/PM10/PM2.5 emissions are calculated based on emission factors shown and these throughput rates.

| | Sorbent Silos | | | PAC Silos | | |
|----------------|---------------------------------|---------------------------------------|---|-----------------------------|----------------------------|---|
| | Total Sorbent Throughput (tons) | E40a & E40b Sorbent Throughput (tons) | PM/PM10/PM2.5 Filterable Emissions (tons) | Total PAC Throughput (tons) | E41a & E41b PAC Throughput | PM/PM10/PM2.5 Filterable Emissions (tons) |
| Year | | | | | | |
| 2019 | 13,419 | 4,473 | 0.014 | 501 | 167 | 0.0005 |
| 2020 | 10,963 | 3,654 | 0.011 | 311 | 104 | 0.0003 |
| 2021 | 12,729 | 4,243 | 0.013 | 388 | 129 | 0.0004 |
| Month | | | | | | |
| 3/2019 | 729 | 243 | 7.41E-04 | 27.2 | 9.1 | 2.77E-05 |
| 4/2019 | 468 | 156 | 4.75E-04 | 17.5 | 5.8 | 1.78E-05 |
| 5/2019 | 1,137 | 379 | 1.16E-03 | 42.4 | 14.1 | 4.31E-05 |
| 6/2019 | 1,221 | 407 | 1.24E-03 | 45.6 | 15.2 | 4.64E-05 |
| 7/2019 | 1,312 | 437 | 1.33E-03 | 49.0 | 16.3 | 4.98E-05 |
| 8/2019 | 1,312 | 437 | 1.33E-03 | 49.0 | 16.3 | 4.98E-05 |
| 9/2019 | 1,170 | 390 | 1.19E-03 | 43.7 | 14.6 | 4.44E-05 |
| 10/2019 | 1,310 | 437 | 1.33E-03 | 48.9 | 16.3 | 4.97E-05 |
| 11/2019 | 1,159 | 386 | 1.18E-03 | 43.3 | 14.4 | 4.40E-05 |
| 12/2019 | 1,196 | 399 | 1.22E-03 | 44.7 | 14.9 | 4.54E-05 |
| 1/2020 | 1,315 | 438 | 1.34E-03 | 37.3 | 12.4 | 3.79E-05 |
| 2/2020 | 1,236 | 412 | 1.26E-03 | 35.1 | 11.7 | 3.56E-05 |
| 3/2020 | 1,188 | 396 | 1.21E-03 | 33.7 | 11.2 | 3.42E-05 |
| 4/2020 | 995 | 332 | 1.01E-03 | 28.2 | 9.4 | 2.87E-05 |
| 5/2020 | 659 | 220 | 6.70E-04 | 18.7 | 6.2 | 1.90E-05 |
| 6/2020 | 569 | 190 | 5.78E-04 | 16.1 | 5.4 | 1.64E-05 |
| 7/2020 | 625 | 208 | 6.36E-04 | 17.7 | 5.9 | 1.80E-05 |
| 8/2020 | 657 | 219 | 6.68E-04 | 18.7 | 6.2 | 1.90E-05 |
| 9/2020 | 565 | 188 | 5.75E-04 | 16.0 | 5.3 | 1.63E-05 |
| 10/2020 | 660 | 220 | 6.71E-04 | 18.7 | 6.2 | 1.90E-05 |
| 11/2020 | 1,189 | 396 | 1.21E-03 | 33.7 | 11.2 | 3.43E-05 |
| 12/2020 | 1,307 | 436 | 1.33E-03 | 37.1 | 12.4 | 3.77E-05 |
| 1/2021 | 1,643 | 548 | 1.67E-03 | 50.1 | 16.7 | 5.09E-05 |
| 2/2021 | 1,126 | 375 | 1.15E-03 | 34.3 | 11.4 | 3.49E-05 |
| 24-month Total | 24,745 | 8,248 | 0.025 | | 269 | 0.0008 |
| Annual Avg | 12,373 | 4,124 | 0.013 | | 134 | 0.0004 |

Sample Calculations: (for 12/2020 for Sorbent Silos)

E40a & E40b Sorbent Throughput = 1,307 tons/mo x 2 / 6 silos = 0,436 tons/mo

PM Emissions = 436 tons/mo x 0.0061 lb/ton / 2,000 lb/ton = 0.0013 tons/mo PM

Annual Average Baseline PM Emissions = 0.025 tons/24-months / 2 years/24-month = 0.013 tpy PM

19. Mill Creek Unit 2 Cooling Tower - Emission Reductions from Shutdown

Imber

- > In conjunction with the shutdown of the Unit 1 and 2 boilers, the Cooling Tower serving Unit 2 will also shutdown resulting in emission decreases of PM that are quantified in this section.

19.1 Unit 2 Cooling Tower Nomenclature and Specifications

- > The existing cooling tower serving the Unit 2 Boiler is currently designated as an insignificant activity in the Title V permit.

| | |
|----------------|---|
| Emission Unit | IA5 - Other Insignificant Activities |
| Emission Point | IE14a - Cooling Tower for Unit 2 |

19.2 Methodology for Defining Baseline PM Emissions from Cooling Tower

19.2.1 PM Emission Factor

- > As the water flows down through a cooling tower, the draft air picks up water droplets that can be emitted from the top of the tower (i.e., "drift loss"). Drift loss is minimized through the use of mist eliminators. Particulate matter emissions can result due to the presence of dissolved solids in the cooling tower water droplets that are released from the tower. As the cooling tower droplets disperse in the atmosphere, the liquid water evaporates, leaving behind solid particles in the form of particulate matter.
- > Particulate matter emissions from cooling towers are estimated using the procedures of AP-42 Section 13.4 (1/1995 edition), in which PM emissions are estimated as a function of the tower flow capacity, drift loss, and total dissolved solids (TDS) in the cooling tower recirculating water.
- > For 2019, 2020, and 2021, LG&E used a 150,000 gpm recirculation rate in the Unit 2 cooling tower. The nominal average TDS content of the recirculating water is 479 ppm. These values are used to define the baseline actual PM emissions.
- > As specified in Table A.5 of Title V Permit O-0127-20-V, the drift loss% specification for the Unit 2 cooling tower is 0.00002%.

| | | |
|---|--------------|--|
| Circulating Water Flow Rate | 150,000 gpm | |
| | 9.0 MMgal/hr | $150,000 \text{ gpm} \times 60 \text{ min/hr} / 1\text{E}6 = 9.0 \text{ MMgal/hr}$ |
| Total Dissolved Solids (TDS) of Recirculating Water | 479 ppm | |
| Drift Percentage for Cooling Tower Mist Eliminator | 0.00002 % | |
| Density of Circulating Water | 8.34 lb/gal | |

PM emission factor based on AP42 13.4 methodology:

$$\text{PM Factor} = 2.0\text{E-}07 \text{ gal drift/gal flow} \times 8.34 \text{ lb/gal} \times 479 \text{ ppm} =$$

| |
|-------------------|
| 0.000799 lb/MMgal |
|-------------------|

19.2.2 PM10 and PM2.5 Emission Factors

Imber

- > PM₁₀ and PM_{2.5} emission factors are derived from the PM emission factor calculated above using the methodology presented in "Calculating Realistic PM₁₀ Emissions from Cooling Towers" by Joe Reisman and Gordon Frisbie, Environmental Progress, Volume 21, Issue 2 (April 20, 2004).
- > The aerodynamic diameter of a particle resulting from drift was calculated over a target droplet size distribution presented in the table below, taken from the source cited above. By interpolating on the calculated aerodynamic particle diameter, the corresponding mass percentage smaller than PM_{2.5} and PM₁₀ can be derived.

| Droplet Diameter Size ¹ (μm) | EPRI % Mass Smaller ¹ (%) | Droplet Volume (μm ³) | Droplet Mass (μg) | Particle Mass (Solids) (μg) | Solid Particle Volume (μm ³) | Solid Particle Diameter (μm) | Aerodyn. Particle Diameter (μm) |
|--|---|--------------------------------------|----------------------|--------------------------------|---|---------------------------------|------------------------------------|
| 10 | 0 | 524 | 5.24E-04 | 2.51E-07 | 0.11 | 0.60 | 0.9 |
| 20 | 0.196 | 4,189 | 4.19E-03 | 2.01E-06 | 0.91 | 1.20 | 1.8 |
| 28.0 | 0.220 | 11,515 | 1.15E-02 | 5.52E-06 | 2.51 | 1.69 | 2.5 |
| 30 | 0.226 | 14,137 | 0.01 | 6.77E-06 | 3.08 | 1.80 | 2.7 |
| 40 | 0.514 | 33,510 | 0.03 | 1.61E-05 | 7.30 | 2.41 | 3.6 |
| 50 | 1.816 | 65,450 | 0.07 | 3.14E-05 | 14.25 | 3.01 | 4.5 |
| 60 | 5.702 | 113,097 | 0.11 | 5.42E-05 | 24.62 | 3.61 | 5.4 |
| 70 | 21.348 | 179,594 | 0.18 | 8.60E-05 | 39.10 | 4.21 | 6.2 |
| 90 | 49.812 | 381,704 | 0.38 | 1.83E-04 | 83.11 | 5.41 | 8.0 |
| 110 | 70.509 | 696,910 | 0.70 | 3.34E-04 | 152 | 6.62 | 9.8 |
| 112.1 | 71.700 | 736,973 | 0.74 | 3.53E-04 | 160.46 | 6.74 | 10.0 |
| 130 | 82.023 | 1,150,347 | 1.15 | 5.51E-04 | 250 | 7.82 | 11.6 |
| 150 | 88.012 | 1,767,146 | 1.77 | 8.46E-04 | 385 | 9.02 | 13.4 |
| 180 | 91.032 | 3,053,628 | 3.05 | 1.46E-03 | 665 | 10.83 | 16.1 |
| 210 | 92.468 | 4,849,048 | 4.85 | 2.32E-03 | 1,056 | 12.63 | 18.7 |
| 240 | 94.091 | 7,238,229 | 7.24 | 3.47E-03 | 1,576 | 14.44 | 21.4 |
| 270 | 94.689 | 10,305,995 | 10.31 | 4.94E-03 | 2,244 | 16.24 | 24.1 |
| 300 | 96.288 | 14,137,167 | 14.14 | 6.77E-03 | 3,078 | 18.05 | 26.8 |
| 350 | 97.011 | 22,449,298 | 22.45 | 1.08E-02 | 4,888 | 21.06 | 31.2 |
| 400 | 98.340 | 33,510,322 | 33.51 | 1.61E-02 | 7,296 | 24.06 | 35.7 |
| 450 | 99.071 | 47,712,938 | 47.71 | 2.29E-02 | 10,388 | 27.07 | 40.2 |
| 500 | 99.071 | 65,449,847 | 65.45 | 3.14E-02 | 14,250 | 30.08 | 44.6 |
| 600 | 100 | 113,097,336 | 113.10 | 5.42E-02 | 24,624 | 36.10 | 53.5 |

Bold highlights indicate interpolated values to determine PM₁₀ and PM_{2.5} size fractions.

¹ Based on drift droplet size distribution testing from EPRI test facility published in the Reisman and Frisbie paper.

Estimated PM₁₀/PM Ratio 0.717 EPRI ratio of mass smaller than PM₁₀ (based on interpolation in table above)

Estimated PM_{2.5}/PM Ratio 2.20E-03 EPRI ratio of mass smaller than PM_{2.5} (based on interpolation in table above)

| Pollutant | Emission Factor (lb/MMgal) | Basis |
|-------------------|-------------------------------|--|
| PM | 0.000799 | |
| PM ₁₀ | 0.000573 | = 0.000799 lb PM/MMgal circulating water x 0.717 Estimated PM10/PM Ratio |
| PM _{2.5} | 1.76E-06 | = 0.000799 lb PM/MMgal circulating water x 2.20E-03 Estimated PM2.5/PM Ratio |

19.3 Unit 2 Cooling Tower Baseline Actual Emissions

| Pollutant | Emission Factor | | Baseline Period | BAE (tpy) |
|-------------------|-----------------|---|-------------------------|-----------|
| | (lb/MMgal) | Basis | Recirc. Rate (MMgal/hr) | |
| PM | 0.000799 | 479 ppm TDS in recirculating water and 0.00002% drift | 9.0 | 0.031 |
| PM ₁₀ | 0.000573 | EPRI PM ₁₀ /PM ratio | 9.0 | 0.023 |
| PM _{2.5} | 1.758E-06 | EPRI PM _{2.5} /PM ratio | 9.0 | 6.9E-05 |

Sample Calculations:


$$\text{PM (tpy)} = 0.00080 \text{ lb/MMgal} \times 9.0 \text{ MMgal/hr} \times 8,760 \text{ hr/yr} / 2,000 \text{ lb/ton} = 0.031 \text{ tpy PM}$$

APPENDIX C. AIR PERMIT APPLICATION FORMS

The following APCD air permit application forms are included with this permit application:

1. Form AP-100A – Administrative Information
2. Form AP-100B – Emission Unit Definition (5)
3. Form AP-100C – Emissions Data
4. Form AP-100D – Stack Data (4)
5. Form AP-100E – Emission Calculations
6. Form AP-100H – Applicable Requirements (3)
7. Form AP-100J – Compliance Monitoring (3)
8. Form AP-100N – Episode Standby Plan
9. Form AP-100P – Insignificant Activities
10. Form AP-200E – Combustion Source (2)
11. Form AP-200J – Generator or Engine (3)
12. Form AP-300A – Generic Control Equipment (for GT/DB Oxidation Catalyst)
13. Form AP-300G – Reducing System (for GT/DB SCR)

The Acid Rain Program revision application covering the NGCC Project is also provided in this appendix following the application forms.

| | |
|--|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100A</p> <p>Administrative Information</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|--|---|

In accordance with District regulation 2.03, section 1, you may not install, modify, or operate an affected facility unless a permit has been issued by the District. Please complete all requested information in this application and associated attachments. Incomplete applications may result in denial of issuing a permit to construct or operate the affected facility.

| Type of Application | | | |
|--|---|--|--|
| <input checked="" type="checkbox"/> Construction | Proposed date to start construction: | <u>03/2024</u> | <input checked="" type="checkbox"/> Operating <input type="checkbox"/> Renewal |
| <input type="checkbox"/> Update : | Date of original application submission: | | |
| Administrative Change : | <input type="checkbox"/> RO Change (pg. 5) | <input type="checkbox"/> Address/Contact information | <input type="checkbox"/> Owner or Operator |
| Modification/Revision : | <input checked="" type="checkbox"/> Major | <input type="checkbox"/> Minor | |
| Source Category: | <input checked="" type="checkbox"/> Major (Title V) | <input type="checkbox"/> FEDOOP | <input type="checkbox"/> FEDOOP, STAR Exempt <input type="checkbox"/> Minor |
| Date of application submission: | <u>12/15/2022</u> | | |
| To apply as an Exempt or Registered source, submit Form AP-500A rather than this form. | | | |

| Source Information | | | |
|---|--|-------------------------------------|--|
| Plant (Facility) name: | <u>Louisville Gas & Electric Company - Mill Creek Generating Station</u> | Plant ID: | <u>127</u> |
| Plant street address: | <u>14460 Dixie Highway</u> | | |
| City: | <u>Louisville</u> | ZIP + 4: | <u>40272</u> |
| Primary Source Industrial Classification (SIC) No.: | <u>4911</u> | OR | Primary NAICS No.: <u>221112</u> |
| KY Secretary of State Organization number: | <u>32196</u> | | |
| Nature of business: | <u>Generation of electricity for local and remote distribution</u> | | |
| Nature of surrounding area: | <input checked="" type="checkbox"/> Residential | <input type="checkbox"/> Industrial | <input type="checkbox"/> Commercial <input type="checkbox"/> Rural <input checked="" type="checkbox"/> Urban |

| Applicant Information | | | |
|---|--------------------------------|-----------------------------------|---|
| Name: | <u>Alex Betz</u> | Title: (if an individual) | <u>General Manager</u> |
| Address: | <u>14460 Dixie Highway</u> | | |
| City: | <u>Louisville</u> | State: | <u>KY</u> ZIP + 4: <u>40272</u> |
| Applicant is: | <input type="checkbox"/> Owner | <input type="checkbox"/> Operator | <input checked="" type="checkbox"/> Owner & Operator <input type="checkbox"/> Corporation/LLC <input type="checkbox"/> LP |
| <ul style="list-style-type: none"> • If the applicant is a Corporation or a Limited Liability Corporation, submit a copy of the current Certificate of Authority from the Kentucky Secretary of State. • If the applicant is a Limited Partnership, submit a copy of the current Certificate of Limited Partnership from the Kentucky Secretary of State. | | | |
| <input checked="" type="checkbox"/> Certificate has not changed since last submission on <u>02</u> / <u>16</u> / <u>2016</u> . (a new certificate is not required.) | | | |
| Applicants agent (if applicable): | | | |
| Applicant or agent e-mail: | <u>alex.betz@lge-ku.com</u> | Applicant or agent phone: | <u>(502) 933-6534</u> |

| Owner Information (same as applicant <input checked="" type="checkbox"/>) | |
|--|-----------------|
| Name: | Title: |
| Address: | |
| City: | State: ZIP + 4: |
| e-mail: | Phone: |

| Operation Information (same as applicant <input checked="" type="checkbox"/>) | |
|--|-----------------|
| Name: | Title: |
| Address: | |
| City: | State: ZIP + 4: |
| e-mail: | Phone: |

| Responsible Official (same as applicant <input type="checkbox"/>) | |
|--|--|
| Name: Steven Turner | Title: VP Power Production |
| Address: 220 W. Main Street | |
| City: Louisville | State: KY ZIP + 4: 40202 |
| e-mail: steven.turner@lge-ku.com | Phone: |

| Environmental Contact (same as <input type="checkbox"/> owner <input type="checkbox"/> operator <input type="checkbox"/> applicant) | |
|---|--|
| Name: Brandan Burfict | Title: Environmental Engineer |
| Address: 220 W. Main Street | |
| City: Louisville | State: KY ZIP + 4: 40202 |
| e-mail: Brandan.Burfict@lge-ku.com | Phone: (502) 627-2791 |

| Billing Contact (same as <input type="checkbox"/> owner <input type="checkbox"/> operator <input type="checkbox"/> applicant <input checked="" type="checkbox"/> environmental) | |
|---|-----------------|
| Name: | Title: |
| Address: | |
| City: | State: ZIP + 4: |
| e-mail: | Phone: |

| Brief description of project, or reason for application |
|--|
| LG&E plans to install a new natural gas-fired combined-cycle turbine and supporting processes. Existing coal-fired EGUs Units 1 and Unit 2 are being retired and the new NGCC Unit is being constructed to replace their capacity. |

Application Documents

Check all other forms which are attached as part of this application, indicating the number of copies, if multiple:

Forms marked with an * are **REQUIRED** from Title V and FEDOOP sources submitting an operating or renewal application.

| | | |
|---|--|--|
| <input checked="" type="checkbox"/> AP-100B: Emission Unit Definition * | <input type="checkbox"/> AP-200A: Generic Process | <input checked="" type="checkbox"/> AP-300A: Generic Control Device |
| <input checked="" type="checkbox"/> AP-100C: Emission Data * | <input type="checkbox"/> AP-200B: Abrasive Blasting | <input type="checkbox"/> AP-300B: Baghouse (Fabric Filter) |
| <input checked="" type="checkbox"/> AP-100D: Stack Data * | <input type="checkbox"/> AP-200C: Grain Terminal | <input type="checkbox"/> AP-300C: Cyclone |
| <input checked="" type="checkbox"/> AP-100E: Emission Calculations * | <input type="checkbox"/> AP-200D: Silo/Storage Bin | <input type="checkbox"/> AP-300D: Settling Chamber |
| <input type="checkbox"/> AP-100F: Emission Summary | <input checked="" type="checkbox"/> AP-200E: Combustion Source | <input type="checkbox"/> AP-300E: Electrostatic Precipitator |
| <input type="checkbox"/> AP-100G: Alternate Operating Scenario | <input type="checkbox"/> AP-200F: Crematory | <input type="checkbox"/> AP-300F: Chemical Scrubber |
| <input checked="" type="checkbox"/> AP-100H: Applicable Requirements * | <input type="checkbox"/> AP-200G: Printing Press Operation | <input checked="" type="checkbox"/> AP-300G: Reducing System (SCR, etc.) |
| <input checked="" type="checkbox"/> AP-100J: Compliance Monitoring * | <input type="checkbox"/> AP-200H: Surface Coating Operation | <input type="checkbox"/> AP-300H: Condenser |
| <input type="checkbox"/> AP-100K: Compliance Certification * | <input checked="" type="checkbox"/> AP-200J: Generator or Engine | <input type="checkbox"/> AP-300J: Liquid/Vapor Separator |
| <input type="checkbox"/> AP-100L: Compliance Schedule # | <input type="checkbox"/> AP-200K: Used Oil Heater | <input type="checkbox"/> AP-300K: Adsorption |
| <input type="checkbox"/> AP-100M: Risk Management Plan | <input type="checkbox"/> AP-200L: Hot Mix Asphalt | <input type="checkbox"/> AP-300L: Oxidizer or Afterburner |
| <input type="checkbox"/> AP-100N: Episode Standby Plan | <input type="checkbox"/> AP-200M: Dry Cleaning | <input type="checkbox"/> AP-300M: Flare |
| <input checked="" type="checkbox"/> AP-100P: Insignificant Activities * | <input type="checkbox"/> AP-200N: VOC Storage Tank | <input type="checkbox"/> AP-300N: Venturi Scrubber |
| <input type="checkbox"/> AP-150B: Production Rate * | <input type="checkbox"/> AP-200P: Solvent Metal Cleaning | |
| <input type="checkbox"/> AP-101X: Request for Temporary Exemption | <input type="checkbox"/> AP-200R: Cooling Tower | <input type="checkbox"/> AP-900B: Certified Progress Report # |

Supporting Documents

Check other attachments which are part of this application:

- Process Flow Diagram (**Required** for all construction applications)
- Material Safety Data Sheets (MSDS)
- Calculations for Actual emissions (**Required for FEDOOP Renewals**)
- Stack Test Reports
- Claim of Confidentiality
- Other: [Site Map](#); [Application Report](#); [Acid Rain Permit Application](#)

Filing Fee

The filing fee listed in the revision of APCD Regulation 2.08 Schedule of Fees in effect on the date of filing is due with the submittal of the application. Your application will not be acted upon until the fee is received.

This fee is not required when updating facility information such as contacts or Responsible Officials.
This fee is not required for renewal of existing Title V and FEDOOP operating permits.


Fees may be paid with any major credit card EXCEPT American Express.

Contact Monica Little (502-574-7246) to pay by credit card.

- The appropriate filing fee is included with this application No fee required (as described above)

| Emission Information | | | |
|---|---------------------------------|---|--|
| Minor sources are not required to complete the Actual Emissions and Requested Limit columns of the following section. Minor sources may also leave the Potential Emissions column blank, but doing so may delay processing of this application. FEDOOP and Title V sources must complete this section of the application. | | | |
| The emissions shown below are: <input type="checkbox"/> plant-wide <input checked="" type="checkbox"/> this project only | | | |
| Pollutant | Potential Emissions (tons/year) | Previous Year Actual Emissions (Required for FEDOOP renewals) (tons/year) | Requested Limit PSD/NSR, FEDOOP*, etc. (tons/year) |
| PM | 104.03 | N/A | |
| PM ₁₀ | 102.94 | N/A | |
| PM _{2.5} | 101.98 | N/A | |
| CO | 161.42 | N/A | |
| NO _x | 199.90 | N/A | |
| SO ₂ | 25.28 | N/A | |
| Lead | 8.85E-03 | N/A | |
| VOC | 51.56 | N/A | |
| Total HAP | 25.98 | N/A | |
| Single HAP | 16.40 | N/A | |

* FEDOOP must have at least one requested limit.

| Responsible Office Certification | |
|--|---|
| <p>The “Responsible Official” is the person in charge of a principal business function, or other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of that person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit. See District regulation 1.02, section 1.71 for a complete, detailed definition of Responsible Official.</p> | |
| <p>Based on information and belief formed after reasonable inquiry, I certify that the statements and information in this document and all associated attachments are true, accurate, and complete.</p> | |
| <p>BY:</p> <p style="text-align: center;"><u>Steven Turner</u> Typed or Printed Name of Signatory</p> <p style="text-align: center;">DocuSigned by:  Authorized Signature</p> | <p style="text-align: right;">12/15/2022 8:20 AM EST</p> <p style="text-align: center;">_____ Date</p> <p style="text-align: center;"><u>VP Power Production</u> Title of Signatory</p> |

Change Responsible Official (RO) Designation

This is notification that our facility is requesting to add the Responsible Official named below.
 This is notification that our facility is requesting to remove the Responsible Official named below.

This request must be signed by a current Responsible Official.

_____ Date

Typed or printed name of added or deleted R.O.

_____ Title of added R.O.

Authorized Signature of added R.O.

Additional RO e-mail: _____ Phone: _____

Change Responsible Official (RO) Designation

This is notification that our facility is requesting to add the Responsible Official named below.
 This is notification that our facility is requesting to remove the Responsible Official named below.

This request must be signed by a current Responsible Official.


_____ Date

Typed or printed name of added or deleted R.O.

_____ Title of added R.O.

Authorized Signature of added R.O.

Additional RO e-mail: _____ Phone: _____

| | | |
|---|---|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100B Emission Unit Definition | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |


| General Information | |
|---|--|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of Submission: 12/15/2022 | |
| Emission Unit Name: EGU Unit 5 Gas Turbine with HRSG | Emission Unit ID: U23 |
| SIC code: | SCC code: 20100201 <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Batch |

| Operating Schedule | | | | | |
|--------------------|-----------|--------------------|-------------------|--------------------|-------------------------------|
| | | Hours / day | Days / week | Weeks / year | Seasonal Variation (%) |
| Normal | (Mon-Fri) | 24 | 5 | 52 | Jan - Mar: 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Apr - Jun: 25 |
| Maximum | (Mon-Fri) | 24 | 5 | 52 | Jul - Sep: 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Oct - Dec: 25 |

| Emission Unit Definition | |
|--------------------------|---|
| Process Description: | Internal combustion of natural gas in a single-cycle combustion turbine followed by a heat recovery steam generator (HRSG) with duct burning to power a combined-cycle GT and ST system |
| Raw Materials: | Natural Gas |
| Products: | Electricity |

| Fuel Usage | | | | |
|-------------------------|---|---------------------|--------------------|----------------|
| | Emission Process # E49a | | Emission Process # | |
| | Primary Fuel | Secondary Fuel | Primary Fuel | Secondary Fuel |
| Fuel Type: | Natural Gas | N/A | | |
| Normal usage per year: | 20,856 MMscf/yr | N/A | | |
| Maximum usage per year: | 34,385 MMscf/yr | N/A | | |

| Emission Process Information | | | | | | | |
|--------------------------------------|---------------------------------------|--|---------|------------------------------|---------------------------------|-----------------------------|--------------|
| Emission Process/ Point Number | Emission Process/Point Description | Manufacturer | Model # | Maximum Rated Capacity | Date Installed (mm/dd/yy) | Control Equipment ID# | Stack ID# |
| E49a | Natural Gas Firing in GT & DB | Specific details regarding turbine manufacturer and model information will not be known until the project is further in development. | | 4,157 MMBtu/hr | 3/1/2024 | C43, C44 | S49 |
| E49b | Cold Startup Events | | | 4,157 MMBtu/hr | 3/1/2024 | -- | S49 |
| E49c | Warm Startup Events | | | 4,157 MMBtu/hr | 3/1/2024 | -- | S49 |
| E49d | Hot Startup Events | | | 4,157 MMBtu/hr | 3/1/2024 | -- | S49 |
| E49e | Shutdown Events | | | 4,157 MMBtu/hr | 3/1/2024 | -- | S49 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

| | | |
|---|--|--|
|  | <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100B</p> <p>Emission Unit Definition</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|--|--|


| General Information | | | |
|---|------------------------------------|--|--------------------------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | | Plant ID: 127 | |
| Date of Submission: 12/15/2022 | | | |
| Emission Unit Name: Auxiliary Steam Boiler | | Emission Unit ID: U24 | |
| SIC code: | SCC code: 10200602 | <input checked="" type="checkbox"/> Continuous | <input type="checkbox"/> Batch |

| Operating Schedule | | | | | | |
|--------------------|-----------|--------------------|-------------------|--------------------|------------------------|--------------------|
| | | Hours / day | Days / week | Weeks / year | Seasonal Variation (%) | |
| Normal | (Mon-Fri) | 24 | 5 | 52 | Jan - Mar: | 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Apr - Jun: | 25 |
| Maximum | (Mon-Fri) | 24 | 5 | 52 | Jul - Sep: | 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Oct - Dec: | 25 |

| Emission Unit Definition | |
|--------------------------|--|
| Process Description: | Natural-gas fired indirect heat exchanger designed to periodically assist with warm and cold startups of the CCT (U23) |
| Raw Materials: | Natural Gas |
| Products: | Steam |

| Fuel Usage | | | | |
|-------------------------|--|---------------------|--------------------|----------------|
| | Emission Process # E50 | | Emission Process # | |
| | Primary Fuel | Secondary Fuel | Primary Fuel | Secondary Fuel |
| Fuel Type: | Natural Gas | N/A | | |
| Normal usage per year: | 206.6 MMscf/yr | N/A | | |
| Maximum usage per year: | 826.4 MMscf/yr | N/A | | |

| Emission Process Information | | | | | | | |
|-------------------------------|-------------------------------------|---|---------|------------------------|---------------------------|-----------------------|-----------|
| Emission Process/Point Number | Emission Process/Point Description | Manufacturer | Model # | Maximum Rated Capacity | Date Installed (mm/dd/yy) | Control Equipment ID# | Stack ID# |
| E50 | Natural Gas Combustion w/ LNB & FGR | Specific details regarding auxiliary boiler manufacturer and model information will not be known until the project is further in development. | | 99.9 MMBtu/hr | 3/1/2024 | -- | S50 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

| | | |
|---|---|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100B Emission Unit Definition | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |


| General Information | | | |
|---------------------|---|--|--------------------------------|
| Plant Name: | Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: | 127 |
| Date of Submission: | 12/15/2022 | | |
| Emission Unit Name: | Fuel Gas (Dewpoint) Heater | Emission Unit ID: | U26 |
| SIC code: | SCC code: 39990003 | <input checked="" type="checkbox"/> Continuous | <input type="checkbox"/> Batch |

| Operating Schedule | | | | | | |
|--------------------|-----------|-------------|-------------|--------------|------------------------|----|
| | | Hours / day | Days / week | Weeks / year | Seasonal Variation (%) | |
| Normal | (Mon-Fri) | 24 | 5 | 52 | Jan - Mar: | 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Apr - Jun: | 25 |
| Maximum | (Mon-Fri) | 24 | 5 | 52 | Jul - Sep: | 25 |
| | (Sat-Sun) | 24 | 2 | 52 | Oct - Dec: | 25 |

| Emission Unit Definition | |
|--------------------------|---|
| Process Description: | Natural gas-fired fuel gas (dewpoint) preheater to provide supplemental heating to NGCC system inlet natural gas feed stream when needed. |
| Raw Materials: | Natural Gas |
| Products: | Heat |

| Fuel Usage | | | | |
|-------------------------|------------------------|----------------|--------------------|----------------|
| | Emission Process # E52 | | Emission Process # | |
| | Primary Fuel | Secondary Fuel | Primary Fuel | Secondary Fuel |
| Fuel Type: | Natural Gas | N/A | | |
| Normal usage per year: | 124.1 MMscf/yr | N/A | | |
| Maximum usage per year: | 124.1 MMscf/yr | N/A | | |

| Emission Process Information | | | | | | | |
|-------------------------------|------------------------------------|--|---------|------------------------|---------------------------|-----------------------|-----------|
| Emission Process/Point Number | Emission Process/Point Description | Manufacturer | Model # | Maximum Rated Capacity | Date Installed (mm/dd/yy) | Control Equipment ID# | Stack ID# |
| E52 | NG Fuel Combustion (15 MMBtu/hr) | Specific details regarding dewpoint heater manufacturer and model information will not be known until the project is further in development. | | 15.0 MMBtu/hr | 3/1/2024 | -- | S52 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

| | | |
|---|--|---|
|  | <h2 style="margin: 0;">Louisville Metro Air Pollution Control District</h2> <h3 style="margin: 10px 0 0 0;">Permit Application and Renewal Form AP-100B</h3> <h3 style="margin: 10px 0 0 0;">Emission Unit Definition</h3> | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
|---|--|---|


| General Information | | | |
|---|------------------------------------|--|--------------------------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | | Plant ID: 127 | |
| Date of Submission: 12/15/2022 | | | |
| Emission Unit Name: 2 MW Diesel Emergency Generator | | Emission Unit ID: U25 | |
| SIC code: | SCC code: 20200102 | <input checked="" type="checkbox"/> Continuous | <input type="checkbox"/> Batch |

| Operating Schedule | | | | | |
|--------------------|-----------|--|-------------|--------------|-------------------------------|
| | | Hours / day | Days / week | Weeks / year | Seasonal Variation (%) |
| Normal | (Mon-Fri) | Emergency use only, maximum of 500 hr/yr operation | | | Jan - Mar: 25 |
| | (Sat-Sun) | | | | Apr - Jun: 25 |
| Maximum | (Mon-Fri) | | | | Jul - Sep: 25 |
| | (Sat-Sun) | | | | Oct - Dec: 25 |

| Emission Unit Definition | |
|--------------------------|---|
| Process Description: | A new diesel-fired emergency generator will be installed as part of the NGCC project to supply electrical power in the event of a power outage. |
| Raw Materials: | Diesel |
| Products: | Electricity |

| Fuel Usage | | | | |
|-------------------------|--|---------------------|--------------------|----------------|
| | Emission Process # E51 | | Emission Process # | |
| | Primary Fuel | Secondary Fuel | Primary Fuel | Secondary Fuel |
| Fuel Type: | Diesel | N/A | | |
| Normal usage per year: | 68.5 Mgal/yr | N/A | | |
| Maximum usage per year: | 68.5 Mgal/yr | N/A | | |

| Emission Process Information | | | | | | | |
|--------------------------------------|---------------------------------------|---|---------|------------------------------|---------------------------------|-----------------------------|--------------|
| Emission Process/ Point Number | Emission Process/Point Description | Manufacturer | Model # | Maximum Rated Capacity | Date Installed (mm/dd/yy) | Control Equipment ID# | Stack ID# |
| E51 | Diesel Fuel Combustion | Specific details regarding emergency generator engine manufacturer and model information will not be known until the project is further in development. | | 2,682 bhp | 3/1/2024 | -- | S51 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |


| | | |
|---|--|--|
|  | <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100B</p> <p>Emission Unit Definition</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|--|--|

| General Information | | | |
|---|------------------------------------|--|--------------------------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | | Plant ID: 127 | |
| Date of Submission: 12/15/2022 | | | |
| Emission Unit Name: 400 HP Diesel Driven Fire Pump | | Emission Unit ID: IA4/IE28 | |
| SIC code: | SCC code: 20200102 | <input checked="" type="checkbox"/> Continuous | <input type="checkbox"/> Batch |

| Operating Schedule | | | | | |
|--------------------|-----------|--|-------------|--------------|-------------------------------|
| | | Hours / day | Days / week | Weeks / year | Seasonal Variation (%) |
| Normal | (Mon-Fri) | Emergency use only, maximum of 500 hr/yr operation | | | Jan - Mar: 25 |
| | (Sat-Sun) | | | | Apr - Jun: 25 |
| Maximum | (Mon-Fri) | | | | Jul - Sep: 25 |
| | (Sat-Sun) | | | | Oct - Dec: 25 |

| Emission Unit Definition | |
|--------------------------|---|
| Process Description: | Diesel-fired emergency fire pump engine designed to supply water in the event of a fire and/or power outage at the NGCC plant |
| Raw Materials: | Diesel |
| Products: | Shaft Work |

| Fuel Usage | | | | |
|-------------------------|---|---------------------|--------------------|----------------|
| | Emission Process # IE28 | | Emission Process # | |
| | Primary Fuel | Secondary Fuel | Primary Fuel | Secondary Fuel |
| Fuel Type: | Diesel | N/A | | |
| Normal usage per year: | 10.2 Mgal/yr | N/A | | |
| Maximum usage per year: | 10.2 Mgal/yr | N/A | | |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100C Emission Data | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |

| | |
|---|-------------------------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of Submission: 12/15/2022 | |

| Emission Information | | | | | | | |
|--|-----------|---|---|--|---|-------------------------|-------------------|
| Emission Process/Point: E49a | | Emission Process Description: Natural Gas Firing in GT & DB | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM | N/A | 98.28 tpy | 5 (see Section 5.3 in Apx B) | | | | N |
| PM ₁₀ | N/A | 98.28 tpy | | | | | N |
| PM _{2.5} | N/A | 98.28 tpy | | | | | N |
| NO _x | N/A | 147.67 tpy | | 15 ppm at 15% O ₂ or 54 ng/J (0.43 lb/MWh) of useful output | 40 CFR 60.4320 6.42, Section 4.3 | | Y |
| Emission Process/Point: E49a | | Emission Process Description: Natural Gas Firing in GT & DB | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO | 630-08-0 | 89.84 tpy | 5 (see Section 5.3 in Apx B) | | | | Y |
| VOC | N/A | 31.36 tpy | | | | | Y |
| SO ₂ | 7446-09-5 | 24.54 tpy | 2 | 0.060 lb/MMBtu SO ₂ | 40 CFR 60.4365 | | N |
| H ₂ SO ₄ | 7664-93-9 | 8.64 tpy | 2 | | | | N |
| Emission Process/Point: E49a | | Emission Process Description: Natural Gas Firing in GT & DB | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO ₂ e | N/A | 2,149,207 tpy | 3 (AP-42 Section 3.1 and 40 CFR 98 Subpart C) | | | | N |
| Lead | 7439-92-1 | 0.01 tpy | 3 (AP-42 Section 1.4) | | | | N |
| Acetaldehyde | 75-07-0 | 3.09 tpy | 3 (AP-42 Section 3.1) | | | | Y |
| Formaldehyde | 50-00-0 | 3.95 tpy | 6 (NESHAP YYYY) | 91 ppbvd at 15% O ₂ | 40 CFR 63.6100 | | Y |

| Emission Process/Point: E49a Emission Process Description: Natural Gas Firing in GT & DB | | | | | | | |
|--|----------|-----------------------|---|-------------------------|-----------------------|-------------------------|-------------------|
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| Hexane | 110-54-3 | 15.47 tpy | 3 (AP-42 Section 1.4) | | | | Y |
| Toluene | 108-88-3 | 1.14 tpy | 3 (AP-42 Section 3.1) | | | | Y |
| 1,3-Butadiene | 106-99-0 | 0.004 tpy | 3 (AP-42 Section 3.1) | | | | Y |
| Acrolein | 107-02-8 | 0.06 tpy | 3 (AP-42 Section 3.1) | | | | Y |
| Emission Process/Point: E49a Emission Process Description: Natural Gas Firing in GT & DB | | | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| Propylene Oxide | 75-56-9 | 0.25 tpy | 3 (AP-42 Section 3.1) | | | | Y |
| Total HAP | N/A | 25.00 tpy | 3 (sum of individual HAP) | | | | Y |
| | | | | | | | |
| | | | | | | | |
| Emission Process/Point: E49b Emission Process Description: Cold Startup Events | | | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| NO _x | N/A | 1.05 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| CO | 630-08-0 | 1.90 tpy | | | | | N |
| VOC | N/A | 0.34 tpy | | | | | N |
| PM | N/A | 0.08 tpy | | | | | N |
| Emission Process/Point: E49b Emission Process Description: Cold Startup Events | | | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM ₁₀ | N/A | 0.08 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| PM _{2.5} | N/A | 0.08 tpy | | | | | N |
| | | | | | | | |
| | | | | | | | |


| Emission Process/Point: | | Emission Process Description: | | | | | |
|-------------------------|----------|-------------------------------|---|-------------------------|-----------------------|-------------------------|-------------------|
| E49c | | Warm Startup Events | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| NO _x | N/A | 5.85 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| CO | 630-08-0 | 10.71 tpy | | | | | N |
| VOC | N/A | 2.72 tpy | | | | | N |
| PM | N/A | 0.61 tpy | | | | | N |
| Emission Process/Point: | | Emission Process Description: | | | | | |
| E49c | | Warm Startup Events | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM ₁₀ | N/A | 0.61 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| PM _{2.5} | N/A | 0.61 tpy | | | | | N |
| | | | | | | | |
| Emission Process/Point: | | Emission Process Description: | | | | | |
| E49d | | Hot Startup Events | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| NO _x | N/A | 6.75 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| CO | 630-08-0 | 15.15 tpy | | | | | N |
| VOC | N/A | 4.55 tpy | | | | | N |
| PM | N/A | 0.75 tpy | | | | | N |
| Emission Process/Point: | | Emission Process Description: | | | | | |
| E49d | | Hot Startup Events | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM ₁₀ | N/A | 0.75 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| PM _{2.5} | N/A | 0.75 tpy | | | | | N |
| Emission Process/Point: | | Emission Process Description: | | | | | |
| E49e | | Shutdown Events | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| NO _x | N/A | 5.85 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| CO | 630-08-0 | 18.30 tpy | | | | | N |
| VOC | N/A | 8.85 tpy | | | | | N |
| PM | N/A | 0.38 tpy | | | | | N |

| Emission Process/Point: E49e | | Emission Process Description: Shutdown Events | | | | | |
|--------------------------------|-----------|---|---|---|-----------------------|-------------------------|-------------------|
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM ₁₀ | N/A | 0.38 tpy | 6 (vendor estimate) (see Section 5.5 in Apx B) | | | | N |
| PM _{2.5} | N/A | 0.38 tpy | | | | | N |
| | | | | | | | |
| | | | | | | | |
| Emission Process/Point: E50 | | Emission Process Description: Natural Gas Combustion w/ LNB & FGR | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM | N/A | 1.43 tpy | 3 (AP-42 Section 1.4) | 0.1 lb/MMBtu | 7.06, Section 4.1.2 | | N |
| PM ₁₀ | N/A | 1.43 tpy | 3 (AP-42 Section 1.4) | | | | N |
| | | | 6 (EPA Speciate Database) | | | | |
| PM _{2.5} | N/A | 1.43 tpy | 3 (AP-42 Section 1.4) | | | | N |
| | | | 6 (EPA Speciate Database) | | | | |
| NO _x | N/A | 15.93 tpy | 6 (vendor guarantee) | 0.04 lb/MMBtu with LNB or LNB/FGR, per suggested RACT | 6.42, Section 4.3 | | N |
| | | | | | | | |
| Emission Process/Point: E50 | | Emission Process Description: Natural Gas Combustion w/ LNB & FGR | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO | 630-08-0 | 16.16 tpy | 6 (vendor guarantee) | | | | N |
| VOC | N/A | 2.27 tpy | 3 (AP-42, Section 1.4) | | | | N |
| SO ₂ | 7446-09-5 | 0.59 tpy | 2 | 0.8 lb/MMBtu | 7.06, Section 5.1.2 | | N |
| H ₂ SO ₄ | 7664-93-9 | 0.045 tpy | 2 | | | | N |
| | | | | | | | |
| Emission Process/Point: E50 | | Emission Process Description: Natural Gas Combustion w/ LNB & FGR | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO _{2e} | N/A | 51,238 tpy | 3 (40 CFR 98 Subpart C) | | | | N |
| Lead | 7439-92-1 | 0.0002 tpy | 3 (AP-42, Section 1.4) | | | | N |
| Formaldehyde | 50-00-0 | 0.03 tpy | 3 (AP-42, Section 1.4) | | | | N |
| Total HAP | N/A | 0.78 tpy | 3 (sum of individual HAP) | | | | N |

| Emission Process/Point: E51 | | Emission Process Description: Diesel Fuel Combustion | | | | | |
|-----------------------------|-----------|--|---------------------------|------------------------------------|-----------------------|-------------------------|-------------------|
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM | N/A | 0.06 tpy | 6 (NSPS IIII requirement) | 0.20 g/kWh | 40 CFR 60.4205(b) | | N |
| PM ₁₀ | N/A | 0.06 tpy | 6 (NSPS IIII requirement) | | | | N |
| PM _{2.5} | N/A | 0.06 tpy | 6 (NSPS IIII requirement) | | | | N |
| NO _x | N/A | 9.70 tpy | 6 (vendor guarantee) | 6.4 g/kWh (NO _x + NMHC) | 40 CFR 60.4205(b) | | N |
| Emission Process/Point: E51 | | Emission Process Description: Diesel Fuel Combustion | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO | 630-08-0 | 0.80 tpy | 6 (NSPS IIII requirement) | 3.5 g/kWh | 40 CFR 60.4205(b) | | N |
| VOC | N/A | 0.21 tpy | 6 (vendor guarantee) | 6.4 g/kWh (NO _x + NMHC) | 40 CFR 60.4205(b) | | N |
| SO ₂ | 7446-09-5 | 0.01 tpy | 3 (AP-42 Section 3.4) | | | | N |
| CO ₂ e | N/A | 767.93 tpy | 3 (40 CFR 98 Subpart C) | | | | N |
| Emission Process/Point: E51 | | Emission Process Description: Diesel Fuel Combustion | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| Formaldehyde | N/A | 0.0004 tpy | 3 (AP-42 Section 3.4) | | | | N |
| Total HAP | N/A | 0.01 tpy | 3 (sum of individual HAP) | | | | N |
| | | | | | | | |
| | | | | | | | |
| Emission Process/Point: E52 | | Emission Process Description: NG Fuel Combustion (15 MMBtu/hr) | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| PM | N/A | 0.12 tpy | 3 (AP-42 Section 1.4) | 0.1 lb/MMBtu | 7.06, Section 4.1.2 | | N |
| PM ₁₀ | N/A | 0.12 tpy | 3 (AP-42 Section 1.4) | | | | N |
| | | | 6 (EPA Speciate Database) | | | | |
| PM _{2.5} | N/A | 0.12 tpy | 3 (AP-42 Section 1.4) | | | | N |
| | | | 6 (EPA Speciate Database) | | | | |
| NO _x | N/A | 2.39 tpy | 6 (vendor guarantee) | 0.04 lb/MMBtu, per suggested RACT | 6.42, Section 4.3 | | N |

| Emission Process/Point: E52 | | Emission Process Description: NG Fuel Combustion (15 MMBtu/hr) | | | | | |
|--------------------------------|-----------|--|-------------------------|-------------------------|-----------------------|-------------------------|-------------------|
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO | 630-08-0 | 4.90 tpy | 6 (vendor guarantee) | | | | N |
| VOC | N/A | 0.34 tpy | 3 (AP-42, Section 1.4) | | | | N |
| SO ₂ | 7446-09-5 | 0.09 tpy | 2 | 0.8 lb/MMBtu | 7.06, Section 5.1.2 | | N |
| H ₂ SO ₄ | 7664-93-9 | 0.0068 tpy | 2 | | | | N |
| Emission Process/Point: E52 | | Emission Process Description: NG Fuel Combustion (15 MMBtu/hr) | | | | | |
| Regulated Pollutant | CAS# | Maximum Emission Rate | Method (see note) | Allowable Emission Rate | Applicable Regulation | Requested Emission Rate | Controlled? (Y/N) |
| CO ₂ e | N/A | 7,693 tpy | 3 (40 CFR 98 Subpart C) | | | | N |
| Lead | 7439-92-1 | 0.00003 tpy | 3 (AP-42, Section 1.4) | | | | N |
| Formaldehyde | 50-00-0 | 0.005 tpy | 3 (AP-42, Section 1.4) | | | | N |
| Total HAP | N/A | 0.12 tpy | 3 (sum of individual) | | | | N |


Note: Determination Method: (1) – Stack Test; (2) – Material Balance; (3) – Standard emission factor (AP-42, or specify); (4) – Engineering estimate; (5) - Special emission factor (specify); (6) – Other (specify)

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100D Exhaust Stack Information | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Associated process equipment: EGU Unit 5 Gas Turbine with HRSG | Emission Process/Point: U23 |
| Date of submission: 12/15/2022 | |

| Exhaust Process/Point Information | |
|--|---|
| Stack ID: S49 | |
| Description of exhaust point (stack, vent, roof monitor, indoors, etc.): Stack | |
| Distance to nearest plant boundary from exhaust point discharge: 1,574 ft | |
| Discharge height above grade: 185 ft | Good Engineering Practice (GEP) height: 323 ft |
| Diameter (or equivalent diameter) of exhaust point: 24 ft | |
| Exit gas flow rate: Maximum (ACFM) - 1,600,000 | Minimum (ACFM) - |
| Exit gas temperature: @ maximum airflow - 171 °F | @ maximum airflow - |
| Orientation of exhaust: Vertical Unobstructed | Is there a stack cap? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Stack location: Latitude - 38.0508 | Longitude - -85.907408 |


| Stack Site Information | | | |
|---|--------------------------------|---------------------------|----------|
| Dimensions of building on which exhaust point is located: | Length - | Width - | Height - |
| Location of stack relative to building: | Distance from North edge - | Distance from East edge - | |
| Distance to nearest building : | Direction to Nearest building: | | |
| Dimensions of the nearest building: | Length - | Width - | Height - |

| | |
|---|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100D</p> <p>Exhaust Stack Information</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|---|

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Associated process equipment: Auxiliary Steam Boiler | Emission Process/Point: U24 |
| Date of submission: 12/15/2022 | |

| Exhaust Process/Point Information | |
|--|---|
| Stack ID: S50 | |
| Description of exhaust point (stack, vent, roof monitor, indoors, etc.): Stack | |
| Distance to nearest plant boundary from exhaust point discharge: 1,389 ft | |
| Discharge height above grade: 60 ft | Good Engineering Practice (GEP) height: 309 ft |
| Diameter (or equivalent diameter) of exhaust point: 3 ft | |
| Exit gas flow rate: Maximum (ACFM) - 30,000 | Minimum (ACFM) - |
| Exit gas temperature: @ maximum airflow - 295 °F | @ maximum airflow - |
| Orientation of exhaust: Vertical unobstructed | Is there a stack cap? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Stack location: Latitude - 38.050286 | Longitude - -85.906463 |


| Stack Site Information | | | |
|---|--------------------------------|---------------------------|----------|
| Dimensions of building on which exhaust point is located: | Length - | Width - | Height - |
| Location of stack relative to building: | Distance from North edge - | Distance from East edge - | |
| Distance to nearest building : | Direction to Nearest building: | | |
| Dimensions of the nearest building: | Length - | Width - | Height - |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | Permit Application and Renewal Form AP-100D | <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| Exhaust Stack Information | | |

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Associated process equipment: Fuel Gas (Dewpoint) Heater | Emission Process/Point: U26 |
| Date of submission: 12/15/2022 | |

| Exhaust Process/Point Information | | | |
|--|---|------------------------------|--|
| Stack ID: | S52 | | |
| Description of exhaust point (stack, vent, roof monitor, indoors, etc.): | Stack | | |
| Distance to nearest plant boundary from exhaust point discharge: | 1,383 ft | | |
| Discharge height above grade: 18 ft | Good Engineering Practice (GEP) height: | 320 ft | |
| Diameter (or equivalent diameter) of exhaust point: | | | |
| Exit gas flow rate: | Maximum (ACFM) - | 1,250 | Minimum (ACFM) - |
| Exit gas temperature: | @ maximum airflow - | 750 °F | @ maximum airflow - |
| Orientation of exhaust: Vertical unobstructed | Is there a stack cap? | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No |
| Stack location: Latitude - | 38.049703 | Longitude - | -85.906274 |


| Stack Site Information | | | |
|---|--------------------------------|---------------------------|----------|
| Dimensions of building on which exhaust point is located: | Length - | Width - | Height - |
| Location of stack relative to building: | Distance from North edge - | Distance from East edge - | |
| Distance to nearest building : | Direction to Nearest building: | | |
| Dimensions of the nearest building: | Length - | Width - | Height - |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | Permit Application and Renewal Form AP-100D | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| Exhaust Stack Information | | |

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Associated process equipment: 2 MW Diesel Emergency Generator | Emission Process/Point: U25 |
| Date of submission: 12/15/2022 | |

| Exhaust Process/Point Information | |
|--|--|
| Stack ID: S51 | |
| Description of exhaust point (stack, vent, roof monitor, indoors, etc.): Stack | |
| Distance to nearest plant boundary from exhaust point discharge: 1,532 ft | |
| Discharge height above grade: 16 ft | Good Engineering Practice (GEP) height: 323 ft |
| Diameter (or equivalent diameter) of exhaust point: 18 in. | |
| Exit gas flow rate: Maximum (ACFM) - 16,200 | Minimum (ACFM) - |
| Exit gas temperature: @ maximum airflow - 900 °F | @ maximum airflow - |
| Orientation of exhaust: Vertical | Is there a stack cap? <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Stack location: Latitude - 38.050414 | Longitude - -85.906984 |


| Stack Site Information | | | |
|---|--------------------------------|---------------------------|----------|
| Dimensions of building on which exhaust point is located: | Length - | Width - | Height - |
| Location of stack relative to building: | Distance from North edge - | Distance from East edge - | |
| Distance to nearest building : | Direction to Nearest building: | | |
| Dimensions of the nearest building: | Length - | Width - | Height - |

| | |
|---|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100D</p> <p>Exhaust Stack Information</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|---|

| | |
|---|--|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Associated process equipment: 400 HP Diesel Driven Fire Pump | Emission Process/Point: IA4/IE28 |
| Date of submission: 12/15/2022 | |


| Exhaust Process/Point Information | |
|--|--|
| Stack ID: S53 | |
| Description of exhaust point (stack, vent, roof monitor, indoors, etc.): Stack | |
| Distance to nearest plant boundary from exhaust point discharge: 1,176 ft | |
| Discharge height above grade: 13 ft | Good Engineering Practice (GEP) height: 213 ft |
| Diameter (or equivalent diameter) of exhaust point: 8 in. | |
| Exit gas flow rate: Maximum (ACFM) - 1,875 | Minimum (ACFM) - |
| Exit gas temperature: @ maximum airflow - 960 °F | @ maximum airflow - |
| Orientation of exhaust: Horizontal | Is there a stack cap? <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Stack location: Latitude - 38.050368 | Longitude - -85.905731 |

| Stack Site Information | | | |
|---|--------------------------------|---------------------------|----------|
| Dimensions of building on which exhaust point is located: | Length - | Width - | Height - |
| Location of stack relative to building: | Distance from North edge - | Distance from East edge - | |
| Distance to nearest building : | Direction to Nearest building: | | |
| Dimensions of the nearest building: | Length - | Width - | Height - |

| | |
|---|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100E</p> <p>Emission Calculations</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|---|

| | |
|---|---------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of submission: 12/15/2022 | |

| |
|--|
| Emission Calculations |
| <p>See Appendix B of the Application Package</p> |

| | |
|---|--|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100H</p> <p>Applicable Requirements</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|--|

| | |
|---|---------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of submission: 12/15/2022 | |

Applicable Regulations

| | |
|---|------------------------------|
| Emission Process/Point Name: EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | Emission Process/Point: E49a |
|---|------------------------------|

Pollutant: [All Regulated Pollutants](#)

| | | | | |
|--|---------------------------|---|----------------------------|---|
| | Special conditions: | 40 CFR 60.4333(a); 40 CFR 63.6105(c) : Operate and maintain the emissions unit, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. | | |
| | Emission regulation: | | Emission standard: | |
| | Recordkeeping regulation: | 40 CFR 60.5525 | Recordkeeping requirement: | Maintain fuel purchase records for the permitted fuel(s). |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |

| | |
|---|------------------------------|
| Emission Process/Point Name: EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | Emission Process/Point: E49a |
|---|------------------------------|

Pollutant: [NO_x](#)

| | | | | |
|--|----------------------|---|--------------------|--|
| | Special conditions: | | | |
| | Emission regulation: | 40 CFR 60.4320(a); Regulation 6.42, Section 4.3 | Emission standard: | For turbines operating at peak load: 15 ppm at 15% O₂ 0.43 lb/MWh gross energy output For turbines operating at less than 75% of peak load: 96 ppm at 15% O₂ 4.7 lb/MWh gross energy output |
| | | Regulation 6.42, Section 4.3 | Emission standard: | The NO_x emission rate for the NGCC (U23) shall be determined using the methods and procedures specified in the NO_x RACT Plan, except that any reference to an annual average shall be read as a rolling 30-day average. |

| | | | |
|---------------------------|------------------------------|----------------------------|---|
| Recordkeeping regulation: | 40 CFR 60.4350(b) | Recordkeeping requirement: | For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.4345(b), is obtained for both NO _x and diluent monitors, the data acquisition and handling system must calculate and record the hourly NO _x emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of 40 CFR 60. For any hour in which the hourly average O ₂ concentration exceeds 19.0 percent O ₂ (or the hourly average CO ₂ concentration is less than 1.0 percent CO ₂), a diluent cap value of 19.0 percent O ₂ or 1.0 percent CO ₂ (as applicable) may be used in the emission calculations. |
| Reporting regulation: | 40 CFR 60.4375(a) | Reporting requirement: | Submit reports of excess emissions and monitor downtime, as defined in 40 CFR 60.4380(b), in accordance with 40 CFR 60.7. Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction. |
| | 40 CFR 60.4395 | Reporting requirement: | Submit reports of excess emissions to the Administrator semiannually, except when more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance of the source. All reports shall be postmarked by the 60th day following the end of each six month period. |
| | 40 CFR 75 Subpart G | Reporting requirement: | Comply with the reporting requirements for Continuous Emissions Monitoring as specified in 40 CFR 75 Subpart G. |
| | Regulation 6.42, Section 4.3 | Reporting requirement: | Comply with the quarterly reporting requirements as specified in Appendix A to the NO _x RACT Plan. |
| Monitoring regulation: | 40 CFR 60.4340(b)(1) | Monitoring requirement: | Install, calibrate, maintain and operate a continuous emissions monitoring system as described in 40 CFR 60.4335(b) and 40 CFR 60.4345. |
| | 40 CFR 60.4350 | Monitoring requirement: | Identify excess emissions using the guidelines for CEMS equipment specified in 40 CFR 60.4350(a)-(f) and (h). |

| | | | | |
|------------------------------|---------------------------|--|----------------------------|--|
| | Testing regulation: | 40 CFR 60.4405 | Testing requirement: | Perform the initial performance test required under 40 CFR 60.8 in the alternative manner specified by 40 CFR 60.4405(a) through (d). |
| | | 40 CFR 60.4400(b) | Testing requirement: | Perform the initial performance test required under 40 CFR 60.8 as specified by 40 CFR 60.4400(b)(2) and (4) through (6). |
| Emission Process/Point Name: | | EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | | Emission Process/Point: E49a |
| Pollutant: SO ₂ | | | | |
| | Special conditions: | | | |
| | Emission regulation: | 40 CFR 60.4330(a)(2) | Emission standard: | The owner or operator shall not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input. |
| | Recordkeeping regulation: | | Recordkeeping requirement: | |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | 40 CFR 60.4365(a) | Monitoring requirement: | The owner or operator must demonstrate that the fuel used will not exceed potential sulfur emissions of 26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input and will have a total sulfur content of 20 grains of sulfur or less per 100 standard cubic feet by using fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel. |
| | Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: | | EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | | Emission Process/Point: E49a |
| Pollutant: CO ₂ | | | | |
| | Special conditions: | | | |
| | Emission regulation: | 40 CFR 60.5520(a) | Emission standard: | 1,000 lb/MWh of gross energy output or 1,030 lb/MWh of net energy output on a 12-month rolling average basis |

| | | | | |
|------------------------------|---------------------------|--|----------------------------|---|
| | Recordkeeping regulation: | 40 CFR 60.5520(d)(1) | Recordkeeping requirement: | Stationary combustion turbines that are only permitted to burn fuels with a consistent chemical composition (i.e., uniform fuels) that result in a consistent emission rate of 160 lb CO ₂ /MMBtu or less are not subject to any monitoring or reporting requirements under this subpart. These fuels include, but are not limited to, natural gas, methane, butane, butylene, ethane, ethylene, propane, naphtha, propylene, jet fuel kerosene, No. 1 fuel oil, No. 2 fuel oil, and biodiesel. Stationary combustion turbines qualifying under this paragraph are only required to maintain purchase records for permitted fuels. |
| | Reporting regulation: | 40 CFR 60.5550 | Reporting requirement: | Prepare and submit the notifications specified in 40 CFR 60.7(a)(1) and (3) and 60.19, as applicable. |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: | | EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | | Emission Process/Point: E49a |
| Pollutant: VOC | | | | |
| | Special conditions: | Regulation 6.42, Section 4.1/4.2: Implement good combustion and operating practices and comply with the applicable operating limitations of 40 CFR 63, Subpart YYYYY. | | |
| | Emission regulation: | | Emission standard: | |
| | Recordkeeping regulation: | Regulation 6.42, Section 4.1/4.2 | Recordkeeping requirement: | Comply with applicable recordkeeping requirements of 40 CFR 63, Subpart YYYYY. |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | Regulation 6.42, Section 4.1/4.2 | Monitoring requirement: | Comply with applicable monitoring requirements of 40 CFR 63, Subpart YYYYY. |
| | Testing regulation: | | Testing requirement: | |

| | | | |
|---|---|------------------------------|---|
| Emission Process/Point Name: EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | | Emission Process/Point: E49a | |
| Pollutant: TAC | | | |
| Special conditions: | <p>Regulation 5.20: When a new TAC is introduced or for any existing TAC which does not have an established BAC or <i>de minimis</i> value, the owner or operator shall calculate and report these values as part of any aforementioned EA Demonstration. The form may be used for determining BAC and <i>de minimis</i> values.</p> <p>Regulation 5.21: The owner or operator shall perform a new Environmental Acceptability (EA) Demonstration or <i>de minimis</i> determination when the following events occur and submit the EA Demonstration on the schedule noted in the reporting section:</p> <p>(1) An application to construct or modify a process or process equipment is submitted to the District pursuant to Regulation 2.03, 2.04 or 2.05;</p> <p>(2) A modification of any physical modeling parameters such as fence lines or building heights that are not otherwise subject to the requirements in this permit that affects the demonstration of compliance; or</p> <p>(3) A change occurs in the process or process equipment, including raw material or fuel type substitution.</p> | | |
| Emission regulation: | Regulations 5.00 and 5.21 | Emission standard: | The owner or operator shall not allow emissions of any TAC to exceed environmentally acceptable (EA) levels, whether specifically established by modeling or determined by the District to be <i>de minimis</i> . |
| Recordkeeping regulation: | STAR Regulations | Recordkeeping requirement: | The owner or operator shall maintain records sufficient to demonstrate environmental acceptability, including, but not limited to, (M)SDS, analysis of emissions, and/or modeling results. |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |


| | | | |
|---|-------------------|------------------------------|--|
| Emission Process/Point Name: EGU Unit 5 Gas Turbine with HRSG - Natural Gas Firing in GT & DB | | Emission Process/Point: E49a | |
| Pollutant: HAP | | | |
| Special conditions: | | | |
| Emission regulation: | 40 CFR 63.6100 | Emission standard: | Limit the concentration of formaldehyde to 91 ppbvd or less at 15% O ₂ , except during turbine startup. The period of time for turbine startup is subject to the limits specified in the definition of startup in 40 CFR 63.6175. |
| Recordkeeping regulation: | 40 CFR 63.6125(e) | Recordkeeping requirement: | Since the temperature monitoring system is a continuous monitoring system (CMS), the permittee must develop and implement a CMS quality control program that included written procedures for CMS according to 40 CFR 63.8(d)(1) through (2). The permittee must keep these written procedures on record for the life of the affected source or until the affected source is no longer subject to the provisions of this part, to be made available for inspection, upon request, by the Administrator. If the performance evaluation plan is revised, the owner or operator shall keep previous (i.e., superseded) versions of the performance evaluation plan on record to be made available for inspection, upon request, by the Administrator, for a period of 5 years after each revision to the plan. The program of corrective action should be included in the plan required under 40 CFR 63.8(d)(2). |
| | 40 CFR 63.6155(a) | Recordkeeping requirement: | Keep the records as described in 40 CFR 63.6155(a)(1) through (7). |

| | | | | |
|--|---------------------------|-------------------|----------------------------|---|
| | Recordkeeping regulation: | 40 CFR 63.6155(c) | Recordkeeping requirement: | Keep the records required in Table 5 of 40 CFR 63 Subpart YYYYY to show continuous compliance with each operating limitation that applies. |
| | | 40 CFR 63.6155(d) | Recordkeeping requirement: | Any records required to be maintained by this part that are submitted electronically via the EPA's CEDRI may be maintained in electronic format. This ability to maintain electronic copies does not affect the requirement for facilities to make records, data, and reports available upon request to a delegated air agency or the EPA as part of an on-site compliance evaluation. |
| | Reporting regulation: | 40 CFR 63.6140(b) | Reporting requirement: | Report each instance in which each emission limitation or operating limitation was not met. Report each instance in which the requirements in Table 7 40 CFR 63 Subpart YYYYY that apply were not met. These instances are deviations from the emission and operating limitations 40 CFR 63 Subpart YYYYY. These deviations must be reported according to the requirements in 40 CFR 63.6150. |
| | | 40 CFR 63.6145(a) | Reporting requirement: | Submit all of the notifications in 40 CFR 63.7(b) and (c), 63.8(f)(4), and 63.9(b) and (h) that apply by the dates specified. |
| | | 40 CFR 63.6145(e) | Reporting requirement: | Submit a notification of intent to conduct an initial performance test at least 60 calendar days before the initial performance test is scheduled to begin as required in 40 CFR 63.7(b)(1). |
| | | 40 CFR 63.6145(f) | Reporting requirement: | Submit a Notification of Compliance Status according to 40 CFR 63.9(h)(2)(ii). For each performance test required to demonstrate compliance with the emission limitation for formaldehyde, submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test. |

| | | | |
|-----------------------|----------------------|------------------------|--|
| Reporting regulation: | 40 CFR 63.6150(a) | Reporting requirement: | <p>Anyone who owns or operates a stationary combustion turbine which must meet the emission limitation for formaldehyde must submit a semiannual compliance report according to Table 6 of 40 CFR 63 Subpart YYYY. The semiannual compliance report must contain the information described in 40 CFR 63.6150 (a)(1) through (5). The semiannual compliance report, including the excess emissions and monitoring system performance reports of 40 CFR 63.10(e)(3), must be submitted by the dates specified in paragraphs (b)(1) through (5) of this section, unless the Administrator has approved a different schedule. After September 8, 2020, or once the reporting template has been available on the Compliance and Emissions Data Reporting Interface (CEDRI) website for 180 days, whichever date is later, you must submit all subsequent reports to the EPA following the procedure specified in 40 CFR 63.6150(g).</p> |
| | 40 CFR 63.6150(b) | Reporting requirement: | <p>The first semiannual report and each subsequent semiannual report shall cover the periods specified in 40 CFR 63.6150(b)(1) and (3), respectively. The first semiannual report and each subsequent semiannual report shall be postmarked or delivered no later than the dates specified in 40 CFR 63.6150(b)(2) and (4), respectively.</p> |
| | 40 CFR 63.6150(b)(5) | Reporting requirement: | <p>For each stationary combustion turbine that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established the date for submitting annual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), the permittee may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in 40 CFR 63.6150(b)(1) through (4).</p> |
| | 40 CFR 63.6150(f) | Reporting requirement: | <p>Within 60 days after the date of completing each performance test required by 40 CFR 63 Subpart YYYY, submit the results of the performance test (as specified in 40 CFR 63.6145(f)) following the procedures specified in 40 CFR 63.6150(f)(1) through (3).</p> |

| | | | | |
|--|------------------------|-------------------|-------------------------|--|
| | Monitoring regulation: | 40 CFR 63.6125(a) | Monitoring requirement: | For each stationary combustion turbine that is required to comply with the emission limitation for formaldehyde and is using an oxidation catalyst, maintain the 4-hour rolling average of the catalyst inlet temperature within the range suggested by the catalyst manufacturer. The permittee is not required to use the catalyst inlet temperature data that is recorded during engine startup in the calculations of the 4-hour rolling average catalyst inlet temperature. |
| | | 40 CFR 63.6135(a) | Monitoring requirement: | Except for monitor malfunctions, associated repairs, and required quality assurance or quality control activities (including, as applicable, calibration checks and required zero and span adjustments of the monitoring system), the permittee must conduct all parametric monitoring at all times the stationary combustion turbine is operating. |
| | Monitoring regulation: | 40 CFR 63.6135(b) | Monitoring requirement: | Do not use data recorded during monitor malfunctions, associated repairs, and required quality assurance or quality control activities for meeting the requirements of this subpart, including data averages and calculations. The permittee must use all the data collected during all other periods in assessing the performance of the control device or in assessing emissions from the new or reconstructed stationary combustion turbine. |
| | | 40 CFR 63.6110(a) | Testing requirement: | The permittee must conduct the initial performance tests or other initial compliance demonstrations in Table 4 of NESHAP YYYY that apply within 180 calendar days after the compliance date that is specified for the stationary combustion turbine in 40 CFR 63.6095 and according to the provisions in 40 CFR 63.7(a)(2). |
| | Testing regulation: | 40 CFR 63.6110(b) | Testing requirement: | An owner or operator is not required to conduct an initial performance test to determine outlet formaldehyde concentration on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in 40 CFR 63.6110(b)(1) through (b)(5). |

| | | | |
|---------------------|---------------------------|----------------------|--|
| Testing regulation: | 40 CFR 63.6115 | Testing requirement: | Subsequent performance tests must be performed on an annual basis as specified in Table 3 of 40 CFR 63 Subpart YYYYY. |
| | 40 CFR 63.6120(a) and (b) | Testing requirement: | Conduct each performance test in Table 3 of 40 CFR 63 Subpart YYYYY that applies. |
| | 40 CFR 63.6120(c) | Testing requirement: | Performance tests must be conducted at high load, defined as 100 percent plus or minus 10 percent. After September 8, 2020, performance tests shall be conducted under such conditions based on representative performance of the affected source for the period being tested. Representative conditions exclude periods of startup and shutdown. The owner or operator may not conduct performance tests during periods of malfunction. The owner or operator must record the process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation. Upon request, the owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of performance tests. |
| | 40 CFR 63.6120(d) | Testing requirement: | Conduct three separate test runs for each performance test, and each test run must last at least 1 hour. |

| | |
|---|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100H</p> <p>Applicable Requirements</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|---|---|

| | |
|---|-------------------------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of submission: 12/15/2022 | |

| Applicable Regulations | | | |
|--|-------------------------------------|--|---|
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 | |
| Pollutant: All Regulated Pollutants | | | |
| | Special conditions: | | |
| | Emission regulation: | Emission standard: | |
| Recordkeeping regulation: | 40 CFR 48c(g)(2) | Recordkeeping requirement: | The owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in 40 CFR 60.48c(f) to demonstrate compliance with the SO ₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month. |
| | 40 CFR 60.48c(i) | Recordkeeping requirement: | All records required under 40 CFR 60.48c shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record. |
| Reporting regulation: | 40 CFR 60.48c(a) | Reporting requirement: | The owner or operator shall submit notification of the date of construction or reconstruction and actual startup, as provided by 40 CFR 60.7. The notification shall include the design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility. |
| Monitoring regulation: | 40 CFR 60.48c(g)(2) | Monitoring requirement: | Monitor fuel usage (MMscf) on a monthly basis. |

| | | | | |
|------------------------------|---------------------------|--|----------------------------|--|
| | Testing regulation: | Regulation 1.04, Section 2.8 | Testing requirement: | Permit the District or Administrator of the EPA to conduct performance tests at any reasonable time, cause the affected facility to be operated for purposes of those tests under the conditions as the District or the Administrator of the EPA may specify based on representative performance of the affected facility, and make available to the District those records as may be necessary to determine the performance. |
| Emission Process/Point Name: | | NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 |
| Pollutant: HAP | | | | |
| | Special conditions: | <p>40 CFR 63.7500(a)(1): Meet each emission limit and work practice standard in Tables 1 through 3, and 11 through 13 to 40 CFR 63 Subpart DDDDD, as applicable, for each boiler or process heater, except as provided under 40 CFR 63.7522.</p> <p>40 CFR 63.7500(a)(3): Operate and maintain any affected source (as defined in 40 CFR 63.7490), including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.</p> <p>40 CFR 63.7505(a): The owner or operator shall be in compliance with the work practice standards in 40 CFR 63, Subpart DDDDD</p> | | |
| | Emission regulation: | | Emission standard: | |
| | Recordkeeping regulation: | 40 CFR 63.7555(a) | Recordkeeping requirement: | <p>You must keep records according to 40 CFR 63.7555(a)(1) and (2):</p> <p>(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that you submitted, according to the requirements in 40 CFR 63.10(b)(2)(xiv).</p> <p>(2) Records of performance tests, fuel analyses, or other compliance demonstrations and performance evaluations as required in 40 CFR 63.10(b)(2)(viii).</p> |

| | | | |
|---------------------------|-------------------|----------------------------|---|
| Recordkeeping regulation: | 40 CFR 63.7555(h) | Recordkeeping requirement: | If the permittee operates a unit in the unit designed to burn gas 1 subcategory that is subject to this subpart, and uses an alternative fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart under this part, other gas 1 fuel, or gaseous fuel subject to another subpart of this part or part 60, 61, or 65, the permittee must keep records of the total hours per calendar year that alternative fuel is burned and the total hours per calendar year that the unit operated during periods of gas curtailment or gas supply emergencies. |
| | 40 CFR 63.7560 | Recordkeeping requirement: | Records shall be in a form suitable and readily available for expeditious review, according to 40 CFR 63.10(b)(1). Each record shall be kept for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. Each record shall be kept on site, or they shall be accessible from on site (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). Records can be kept off site for the remaining 3 years. |
| Reporting Regulation: | 40 CFR 63.7495(d) | Reporting requirement: | Meet the notification requirements in 40 CFR 63.7545 according to the schedule in 40 CFR 63.7545 and in 40 CFR 63, Subpart A. Some of the notifications must be submitted before the permittee is required to comply with the emission limits and work practice standards in 40 CFR 63, Subpart DDDDD. |
| | 40 CFR 63.7530(f) | Reporting requirement: | Submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 40 CFR 7545(e). |
| | 40 CFR 63.7540(b) | Reporting requirement: | Report each instance in which an emission limit and operating limit in 40 CFR 63, Subpart DDDDD, Table 3, as applicable, was not met. These instances are deviations from the emission limits or operating limits, respectively, in 40 CFR 63, Subpart DDDDD. These deviations shall be reported according to the requirements in 40 CFR 63.7550. |

| | | | |
|-----------------------|----------------------|------------------------|--|
| Reporting Regulation: | 40 CFR 63.7545(a) | Reporting requirement: | Submit to the Administrator all of the notifications in 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (6), and 63.9(b) through (h) that apply by the dates specified. |
| | 40 CFR 63.7545(c) | Reporting requirement: | As specified in 40 CFR 63.9(b)(4) and (5), for startup of a new or reconstructed affected source on or after January 31, 2013, the permittee shall submit an Initial Notification not later than 15 days after the actual date of startup of the affected source. |
| | 40 CFR 63.7545(e) | Reporting requirement: | The permittee shall submit the Notification of Compliance Status and shall contain the information specified in 40 CFR 63.7545(e)(1) and (8) and shall be submitted within 60 days of the compliance date specified at 40 CFR 63.7495(b). |
| | 40 CFR 63.7545(f) | Reporting requirement: | If the permittee operates a unit designed to burn natural gas, refinery gas, or other gas 1 fuels that is subject to this subpart, and intends to use a fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart of this part, part 60, 61, or 65, or other gas 1 fuel to fire the affected unit during a period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575, the permittee must submit a notification of alternative fuel use within 48 hours of the declaration of each period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575. The notification must include the information specified in 40 CFR 63.7545(f)(1) through (5). |
| | 40 CFR 63.7550(a) | Reporting requirement: | Submit each report in 40 CFR 63, Subpart DDDDD, Table 9 that applies. |
| | 40 CFR 63.7550(b) | Reporting requirement: | Submit only an annual, biennial, or 5-year compliance report, as applicable, as specified in 40 CFR 63.7550(b)(1) through (4). |
| | 40 CFR 63.7550(b)(5) | Reporting requirement: | For each affected source that is subject to permitting regulations pursuant to 40 CFR 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A), the permittee may submit the first and subsequent compliance reports according to the dates the permitting authority has established in the permit instead of according to the dates in 40 CFR 63.7550(b)(1) through (4). |


| | | | | |
|---------------------|-------------------------------|----------------------|---|---|
| | Reporting Regulation: | 40 CFR 63.7550(c)(1) | Reporting requirement: | Submit a compliance report with the information in 40 CFR 63.7550 (c)(5)(i) through (iii), (xiv), and (xvii). |
| | | 40 CFR 63.7550(h)(1) | Reporting requirement: | The permittee must submit all reports required by Table 9 of this subpart electronically to the EPA via the CEDRI. (CEDRI can be accessed through the EPA's CDX.) The permittee must use the appropriate electronic report in CEDRI for this subpart. Instead of using the electronic report in CEDRI for this subpart, the permittee may submit an alternate electronic file consistent with the XML schema listed on the CEDRI Web site (http://www.epa.gov/ttn/chief/cedri/index.html), once the XML schema is available. If the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the permittee must submit the report to the Administrator at the appropriate address listed in 40 CFR 63.13. The permittee must begin submitting reports via CEDRI no later than 90 days after the form becomes available in CEDRI. |
| | Monitoring regulation: | 40 CFR 63.7515(d) | Monitoring requirement: | Conduct an annual performance tune-up according to 40 CFR 63.7540(a)(10). Each annual tune-up specified in 40 CFR 63.7540(a)(10) shall be no more than 13 months after the previous tune-up, respectively. The first annual tune-up shall be no later than 13 months after the initial startup of the new affected source, respectively. |
| | | 40 CFR 63.7510(g) | Testing requirement: | Demonstrate initial compliance with applicable work practice standards in Table 3 annually as specified in 63.7515(d). |
| | 40 CFR 63.7540(a) | Testing requirement: | Demonstrate continuous compliance with the work practice standards in Table 3 to 40 CFR 63, Subpart DDDDD that apply. | |
| | 40 CFR 63.7540(a)(10) or (12) | Testing requirement: | Conduct an annual (or every 5 years if using continuous oxygen trim system) tune-up of the process heater to demonstrate continuous compliance as specified in 63.7540(a)(10)(i) through (vi). Conduct the tune-up while burning the type of fuel that provided the majority of the heat input to the process heater over the 12 months prior to the tune-up. | |
| Testing regulation: | 40 CFR 63.7540(a)(13) | Testing requirement: | If the unit is not operating on the required date for a tune-up, the tune-up shall be conducted within 30 calendar days of startup. | |

| | | | |
|--|----------------------------------|----------------------------------|--|
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 | |
| Pollutant: NO _x | | | |
| Special conditions: | | | |
| Emission regulation: | Regulation 6.42, Section 4.3 | Emission standard: | See permit attached NO _x RACT Plan |
| Recordkeeping regulation: | Regulation 6.42, Section 4.3 | Recordkeeping requirement: | <p>The owner or operator shall record and maintain records of the amount of fuel combusted in each unit during each calendar month.</p> <p>The owner or operator shall calculate and maintain records of the lb/hr NO_x emissions from each unit, determined by multiplying the actual total heat input (in MMBtu) and the manufacturer certified emissions factor, based upon a rolling 30-day average, in order to demonstrate compliance.</p> |
| Reporting regulation: | Regulation 2.16, Section 4.1.9.3 | Reporting requirement: | <p>The owner or operator shall identify all periods of exceeding a NO_x emission standard during a semi-annual reporting period. The semi-annual compliance report shall include the following:</p> <ol style="list-style-type: none"> (1) Emission Unit ID number and emission point ID number; (2) Identification of all periods during which a deviation occurred; (3) A description, including the magnitude, of the deviation; (4) If known, the cause of the deviation; (5) A description of all corrective actions taken to abate the deviation; and (6) If no deviations occur during a semi-annual reporting period, the report shall contain a negative declaration. |
| Monitoring regulation: | | Monitoring requirement: | |

| | | | | |
|------------------------------|---------------------------|---|----------------------------|---|
| | Testing regulation: | Regulation 6.42, Section 5.1 | Testing requirement: | Owners or operators subject to Section 4 shall conduct performance tests or conduct continuous emission monitoring to verify compliance. For sources that opt for performance testing, a performance test shall be required annually for the first 2 years. If the facility is found to be in compliance during both of these tests, then the performance tests shall be conducted every two years after the second test, unless the facility fails to demonstrate compliance with its VOC or NO emission standard. In this case, the facility shall return to the annual performance test schedule for that pollutant until the District determines that compliance has been shown for a duration adequate to demonstrate that emissions are not likely to exceed the standards in the future. |
| Emission Process/Point Name: | | NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 |
| Pollutant: PM | | | | |
| | Special conditions: | | | |
| | Emission regulation: | Regulation 7.06, Section 4.1.2 | Emission standard: | The owner or operator shall not cause to be discharged into the atmosphere from each affected facility PM in excess of 0.10 lb/MMBtu actual total heat input based upon a rolling 30-day average. |
| | Recordkeeping regulation: | | Recordkeeping requirement: | |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: | | NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 |
| Pollutant: SO ₂ | | | | |
| | Special conditions: | | | |
| | Emission regulation: | Regulation 7.06, Section 5.1.2 | Emission standard: | The owner or operator shall not cause to be discharged into the atmosphere from each affected facility any gases which contain SO ₂ in excess of 0.8 lb/MMBtu actual total heat input based upon a rolling 30- day average. |
| | Recordkeeping regulation: | | Recordkeeping requirement: | |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |

| | | | |
|--|---|----------------------------------|---|
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 | |
| Pollutant: VOC | | | |
| Special conditions: | Regulation 6.42, Section 4.1/4.3: Implement good combustion and operating practices. | | |
| Emission regulation: | | Emission standard: | |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 | |
| Pollutant: TAC | | | |
| Special conditions: | <p>Regulation 5.20: When a new TAC is introduced or for any existing TAC which does not have an established BAC or <i>de minimis</i> value, the owner or operator shall calculate and report these values as part of any aforementioned EA Demonstration. The form may be used for determining BAC and <i>de minimis</i> values.</p> <p>Regulation 5.21: The owner or operator shall perform a new Environmental Acceptability (EA) Demonstration or <i>de minimis</i> determination when the following events occur and submit the EA Demonstration on the schedule noted in the reporting section:</p> <p>(1) An application to construct or modify a process or process equipment is submitted to the District pursuant to Regulation 2.03, 2.04 or 2.05;</p> <p>(2) A modification of any physical modeling parameters such as fence lines or building heights that are not otherwise subject to the requirements in this permit that affects the demonstration of compliance; or</p> <p>(3) A change occurs in the process or process equipment, including raw material or fuel type substitution.</p> | | |
| Emission regulation: | Regulations 5.00 and 5.21 | Emission standard: | The owner or operator shall not allow emissions of any TAC to exceed environmentally acceptable (EA) levels, whether specifically established by modeling or determined by the District to be <i>de minimis</i> . |
| Recordkeeping regulation: | STAR Regulations | Recordkeeping requirement: | The owner or operator shall maintain records sufficient to demonstrate environmental acceptability, including, but not limited to, (M)SDS, analysis of emissions, and/or modeling results. |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |

| | | | |
|--|------------------------------|----------------------------------|--|
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater (15 MMBtu/hr) | | Emission Process/Point: E50, E52 | |
| Pollutant: Opacity | | | |
| Special conditions: | | | |
| Emission regulation: | Regulation 7.06, Section 4.2 | Emission standard: | The owner or operator combusting natural gas shall not cause to be discharged into the atmosphere from any affected facility PM emissions which exhibit greater than 20% opacity. A maximum of 40% opacity shall be permissible for not more than two consecutive minutes in any 60 consecutive minutes. A maximum of 40% opacity shall be permissible for not more than six consecutive minutes in any 60 consecutive minutes during cleaning the fire box or blowing soot. |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100H Applicable Requirements | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 <hr/> (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |

| | |
|--|----------------------|
| Plant Name: <u>Louisville Gas & Electric Company - Mill Creek Generating Station</u> | Plant ID: <u>127</u> |
| Date of submission: <u>12/15/2022</u> | |

| Applicable Regulations | | | |
|--|--|------------------------------------|---|
| Emission Process/Point Name: <u>2 MW Diesel Emergency Generator - Diesel Fuel Combustion</u> | | Emission Process/Point: <u>E51</u> | |
| Pollutant: <u>All Regulated Pollutants</u> | | | |
| Special conditions: | <p>40 CFR 60.4207(b): Use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel.</p> <p>40 CFR 60.4211(a): Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions. Change only those emission-related settings that are permitted by the manufacturer. Meet the requirements of 40 CFR parts 89, 94, and/or 1068, as they apply.</p> <p>40 CFR 60.4211(c): Comply by purchasing an engine certified to the emission standards in 40 CFR 60.4205(b) for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in 40 CFR 60.4205(g).</p> <p>40 CFR 60.4211(f): Operate according to the requirements in 40 CFR 60.4211(f)(1) through (3) to be considered an emergency stationary ICE.</p> | | |
| Emission regulation: | | Emission standard: | |
| Recordkeeping regulation: | <u>40 CFR 60.4214(b)</u> | Recordkeeping requirement: | <u>Maintain records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.</u> |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | <u>40 CFR 60.4209(a)</u> | Monitoring requirement: | <u>Install a non-resettable hour meter prior to startup of the engine.</u> |
| Testing regulation: | | Testing requirement: | |


| | | | | | |
|---|---------------------------|--|----------------------------|---|--|
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | | | Emission Process/Point: E51 | |
| Pollutant: NO _x | | | | | |
| | Special conditions: | | | | |
| | Emission regulation: | 40 CFR 60.4202(a)(2), via 40 CFR 60.4205(b) | Emission standard: | NMHC + NOX shall not exceed 6.4 g/kWh according to Tier 2 standards for > 560 kW engines. | |
| | Recordkeeping regulation: | | Recordkeeping requirement: | | |
| | Reporting regulation: | | Reporting requirement: | | |
| | Monitoring regulation: | | Monitoring requirement: | | |
| | Testing regulation: | | Testing requirement: | | |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | | | Emission Process/Point: E51 | |
| Pollutant: VOC | | | | | |
| | Special conditions: | | | | |
| | Emission regulation: | 40 CFR 60.4202(a)(2), via 40 CFR 60.4205(b) | Emission standard: | NMHC + NOX shall not exceed 6.4 g/kWh according to Tier 2 standards for > 560 kW engines. | |
| | Recordkeeping regulation: | | Recordkeeping requirement: | | |
| | Reporting regulation: | | Reporting requirement: | | |
| | Monitoring regulation: | | Monitoring requirement: | | |
| | Testing regulation: | | Testing requirement: | | |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | | | Emission Process/Point: E51 | |
| Pollutant: CO | | | | | |
| | Special conditions: | | | | |
| | Emission regulation: | 40 CFR 60.4202(a)(2), via 40 CFR 60.4205(b) | Emission standard: | CO shall not exceed 3.5 g/kWh according to Tier 2 standards for > 560 kW engines. | |
| | Recordkeeping regulation: | | Recordkeeping requirement: | | |
| | Reporting regulation: | | Reporting requirement: | | |
| | Monitoring regulation: | | Monitoring requirement: | | |
| | Testing regulation: | | Testing requirement: | | |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | | | Emission Process/Point: E51 | |
| Pollutant: PM | | | | | |
| | Special conditions: | | | | |
| | Emission regulation: | 40 CFR 60.4202(a)(2), via 40 CFR 60.4205(b) | Emission standard: | PM shall not exceed 0.20 g/kWh according to Tier 2 standards for > 560 kW engines. | |
| | Recordkeeping regulation: | | Recordkeeping requirement: | | |
| | Reporting regulation: | | Reporting requirement: | | |
| | Monitoring regulation: | | Monitoring requirement: | | |
| | Testing regulation: | | Testing requirement: | | |

| | | | |
|---|---|-----------------------------|--|
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | Emission Process/Point: E51 | |
| Pollutant: HAP | | | |
| Special conditions: | 40 CFR 63.6590(c): Meet the requirements of 40 CFR 63 Subpart ZZZZ by complying with 40 CFR 60 Subpart IIII. | | |
| Emission regulation: | | Emission standard: | |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | 40 CFR 63.6645(f) | Reporting requirement: | Submit an Initial Notification with the information in 40 CFR 63.9(b)(2)(i) through (v), and a statement that the stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions). By 63.6645(c), the initial notification should be submitted no later than 120 days after startup (since 63.6595(a)(3) states startup is when compliance begins). |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion | | Emission Process/Point: E51 | |
| Pollutant: TAC | | | |
| Special conditions: | <p>Regulation 5.20: When a new TAC is introduced or for any existing TAC which does not have an established BAC or <i>de minimis</i> value, the owner or operator shall calculate and report these values as part of any aforementioned EA Demonstration. The form may be used for determining BAC and <i>de minimis</i> values.</p> <p>Regulation 5.21: The owner or operator shall perform a new Environmental Acceptability (EA) Demonstration or <i>de minimis</i> determination when the following events occur and submit the EA Demonstration on the schedule noted in the reporting section:</p> <p>(1) An application to construct or modify a process or process equipment is submitted to the District pursuant to Regulation 2.03, 2.04 or 2.05;</p> <p>(2) A modification of any physical modeling parameters such as fence lines or building heights that are not otherwise subject to the requirements in this permit that affects the demonstration of compliance; or</p> <p>(3) A change occurs in the process or process equipment, including raw material or fuel type substitution.</p> | | |
| Emission regulation: | Regulations 5.00 and 5.21 | Emission standard: | The owner or operator shall not allow emissions of any TAC to exceed environmentally acceptable (EA) levels, whether specifically established by modeling or determined by the District to be <i>de minimis</i> . |
| Recordkeeping regulation: | STAR Regulations | Recordkeeping requirement: | The owner or operator shall maintain records sufficient to demonstrate environmental acceptability, including, but not limited to, (M)SDS, analysis of emissions, and/or modeling results. |

| | | | | |
|---|---------------------------|--|----------------------------|--|
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator - Diesel Fuel Combustion Emission Process/Point: E51 | | | | |
| Pollutant: Smoke | | | | |
| | Special conditions: | | | |
| | Emission regulation: | 40 CFR 4202(a)(2), via 40 CFR 60.4205(b) | Emission standard: | Measure smoke as specified in 40 CFR 1039.501(c). Smoke from your engines may not exceed the following standards: (1) 20 percent during the acceleration mode. (2) 15 percent during the lugging mode. (3) 50 percent during the peaks in either the acceleration or lugging modes. |
| | Recordkeeping regulation: | | Recordkeeping requirement: | |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | | Monitoring requirement: | |
| | Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump Emission Process/Point: IA4 | | | | |
| Pollutant: All Regulated Pollutants | | | | |
| | Special conditions: | <p>40 CFR 60.4207(b): Use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel.</p> <p>40 CFR 60.4211(a): Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions. Change only those emission-related settings that are permitted by the manufacturer. Meet the requirements of 40 CFR parts 89, 94, and/or 1068, as they apply.</p> <p>40 CFR 60.4211(c): Comply by purchasing an engine certified to the emission standards in 40 CFR 60.4205(c) for the same model year and NFPA nameplate engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in 40 CFR 60.4205(g).</p> | | |
| | Emission regulation: | | Emission standard: | |
| | Recordkeeping regulation: | 40 CFR 60.4214(b) | Recordkeeping requirement: | Maintain records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. |
| | Reporting regulation: | | Reporting requirement: | |
| | Monitoring regulation: | 40 CFR 60.4209(a) | Monitoring requirement: | Install a non-resettable hour meter prior to startup of the engine. |
| | Testing regulation: | | Testing requirement: | |

| | | | |
|---|-------------------|-----------------------------|--|
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: NO _x | | | |
| Special conditions: | | | |
| Emission regulation: | 40 CFR 60.4205(c) | Emission standard: | NMHC + NOX shall not exceed 4.0 g/kWh according to Table 4 to 40 CFR Subpart IIII for engine ratings between 300 and 600 hp. |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: VOC | | | |
| Special conditions: | | | |
| Emission regulation: | 40 CFR 60.4205(c) | Emission standard: | NMHC + NOX shall not exceed 4.0 g/kWh according to Table 4 to 40 CFR Subpart IIII for engine ratings between 300 and 600 hp. |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: CO | | | |
| Special conditions: | | | |
| Emission regulation: | 40 CFR 60.4205(c) | Emission standard: | CO shall not exceed 3.5 g/kWh according to Table 4 to 40 CFR Subpart IIII for engine ratings between 300 and 600 hp. |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: PM | | | |
| Special conditions: | | | |
| Emission regulation: | 40 CFR 60.4205(c) | Emission standard: | PM shall not exceed 0.20 g/kWh according to Table 4 to 40 CFR Subpart IIII for engine ratings between 300 and 600 hp. |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |

| | | | |
|---|---|-----------------------------|---|
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: HAP | | | |
| Special conditions: | 40 CFR 63.6590(c): Meet the requirements of 40 CFR 63 Subpart ZZZZ by complying with 40 CFR 60 Subpart IIII. | | |
| Emission regulation: | | Emission standard: | |
| Recordkeeping regulation: | | Recordkeeping requirement: | |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |
| Emission Process/Point Name: 400 HP Diesel Driven Fire Pump | | Emission Process/Point: IA4 | |
| Pollutant: TAC | | | |
| Special conditions: | <p>Regulation 5.20: When a new TAC is introduced or for any existing TAC which does not have an established BAC or <i>de minimis</i> value, the owner or operator shall calculate and report these values as part of any aforementioned EA Demonstration. The form may be used for determining BAC and <i>de minimis</i> values.</p> <p>Regulation 5.21: The owner or operator shall perform a new Environmental Acceptability (EA) Demonstration or <i>de minimis</i> determination when the following events occur and submit the EA Demonstration on the schedule noted in the reporting section:</p> <p>(1) An application to construct or modify a process or process equipment is submitted to the District pursuant to Regulation 2.03, 2.04 or 2.05;</p> <p>(2) A modification of any physical modeling parameters such as fence lines or building heights that are not otherwise subject to the requirements in this permit that affects the demonstration of compliance; or</p> <p>(3) A change occurs in the process or process equipment, including raw material or fuel type substitution.</p> | | |
| Emission regulation: | Regulations 5.00 and 5.21 | Emission standard: | The owner or operator shall not allow emissions of any TAC to exceed environmentally acceptable (EA) levels, whether specifically established by modeling or determined by the District to be <i>de minimis</i> . |
| Recordkeeping regulation: | STAR Regulations | Recordkeeping requirement: | The owner or operator shall maintain records sufficient to demonstrate environmental acceptability, including, but not limited to, (M)SDS, analysis of emissions, and/or modeling results. |
| Reporting regulation: | | Reporting requirement: | |
| Monitoring regulation: | | Monitoring requirement: | |
| Testing regulation: | | Testing requirement: | |

| | |
|---|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Permit Application and Renewal Form AP-100J</p> <p>Compliance Monitoring</p> | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Emission Process/Point Name: EGU Unit 5 Gas Turbine with HRSG | Emission Process/Point: U23 |
| Date of submission: 12/15/2022 | |

| Monitoring Definition | | | | | |
|--|----------------------------|---|-----------------------|--|------------|
| List the operational parameters that are monitored and the frequency of monitoring | | | | | |
| Parameter | Frequency | Method of measurement | | Method of recording | |
| Fuel Purchase Records | Continuous | Purchase records | | Paper or digital files | |
| NO_x Emissions | Continuous | CEMS | | DAHS | |
| Fuel Sulfur Content | Continuous | Current, valid purchase contract, tariff sheet, or transportation contract for natural gas fuel | | Paper or digital files | |
| VOC Emissions | Monthly | Manual calculations | | Digital files | |
| Catalyst Inlet Temperature | Continuous | CMS | | DAHS | |
| Describe any monitors in use, including manufacturer, model #, frequency of calibration, and location | | | | | |
| Monitor Identification | Manufacturer | Model | Calibration Frequency | Location | Other Info |
| Specific details regarding CEMS information will not be known until the project is further in development. | | | | | |
| Are any of these Continuous Emission monitors? | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | |
| Pollutants monitored (check all that apply): | | <input type="checkbox"/> Particulates (PM) <input type="checkbox"/> Metals (specify): <input type="checkbox"/> Volatiles (VOC) <input type="checkbox"/> HAP/TAC (specify): <input checked="" type="checkbox"/> Nitrogen oxides (NO _x) <input type="checkbox"/> Sulfur dioxide (SO ₂) <input type="checkbox"/> Other: | | | |
| Attach manufacturer's specification sheets, or complete the following: | | | | | |
| Will multiple emission processes be monitored at the same location? | | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| Which emission processes are monitored? | | | | | |
| Will more than one emission process be emitting from the combined stack at any time? | | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| Which emission processes emit simultaneously? | | | | | |

Monitoring and Alarm Information

Describe the System Alarm(s): [Specific details regarding CEMS alarm information will not be known until the project is further in development.](#)


If there are more than three alarms, attach additional copies of this page as needed.

| Operating Parameter Monitored | Describe Alarm Trigger | Monitoring Device or Alarm Type | Does the Alarm Initiate an Automated Response? |
|-------------------------------|------------------------|--|---|
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |

Emission Tests

List any emission measurement tests (stack tests) that have been performed in the past and attach a copy of the test reports:

| | |
|---------------|------------|
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100J Compliance Monitoring | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |

| | |
|--|--|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Emission Process/Point Name: NG Fired Auxiliary Boiler (99.9 MMBtu/hr); Fuel Gas (Dewpoint) Heater | Emission Process/Point: U24, U26 |
| Date of submission: 12/15/2022 | |

| Monitoring Definition | | | | | |
|--|-------------------------|---|--|--|------------|
| List the operational parameters that are monitored and the frequency of monitoring | | | | | |
| Parameter | Frequency | Method of measurement | | Method of recording | |
| Fuel Usage | Monthly | Utility bills | | Paper or digital files | |
| NO_x Emissions | Monthly | Manual calculations | | Digital files | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| Describe any monitors in use, including manufacturer, model #, frequency of calibration, and location | | | | | |
| Monitor Identification | Manufacturer | Model | Calibration Frequency | Location | Other Info |
| No monitors will be installed to record the above operational parameters for this unit. | | | | | |
| Are any of these Continuous Emission monitors? <input type="checkbox"/> Yes <input type="checkbox"/> No | | | | | |
| Pollutants monitored (check all that apply): | | | | | |
| | | <input type="checkbox"/> Particulates (PM) | <input type="checkbox"/> Metals (specify:) | | |
| | | <input type="checkbox"/> Volatiles (VOC) | <input type="checkbox"/> HAP/TAC (specify:) | | |
| | | <input type="checkbox"/> Nitrogen oxides (NO _x) | <input type="checkbox"/> Sulfur dioxide (SO ₂) | | |
| | | <input type="checkbox"/> Other: | | | |
| Attach manufacturer's specification sheets, or complete the following: | | | | | |
| Will multiple emission processes be monitored at the same location? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | | | |
| Which emission processes are monitored? | | | | | |
| Will more than one emission process be emitting from the combined stack at any time? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | | | |
| Which emission processes emit simultaneously? | | | | | |

Monitoring and Alarm Information

Describe the System Alarm(s): *No monitors will be installed to record the above operational parameters.*


If there are more than three alarms, attach additional copies of this page as needed.

| Operating Parameter Monitored | Describe Alarm Trigger | Monitoring Device or Alarm Type | Does the Alarm Initiate an Automated Response? |
|-------------------------------|------------------------|--|---|
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |

Emission Tests

List any emission measurement tests (stack tests) that have been performed in the past and attach a copy of the test reports:

| | |
|---------------|------------|
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-100J Compliance Monitoring | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |

| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Emission Process/Point Name: 2 MW Diesel Emergency Generator; 400 HP Diesel Driven Fire Pump | Emission Process/Point: U25, IA4/IE28 |
| Date of submission: 12/15/2022 | |

| Monitoring Definition | | | | | |
|---|---------------------------------|--|-----------------------|--|------------|
| List the operational parameters that are monitored and the frequency of monitoring | | | | | |
| Parameter | Frequency | Method of measurement | | Method of recording | |
| Hours of Operation | While operating | Non-resettable hours meter | | Non-resettable hours meter | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| Describe any monitors in use, including manufacturer, model #, frequency of calibration, and location | | | | | |
| Monitor Identification | Manufacturer | Model | Calibration Frequency | Location | Other Info |
| <p>Specific details regarding the non-resettable hours meter information will not be known until the project is further in development.</p> | | | | | |
| Are any of these Continuous Emission monitors? | | <input type="checkbox"/> Yes <input type="checkbox"/> No | | | |
| Pollutants monitored (check all that apply): | | <input type="checkbox"/> Particulates (PM) <input type="checkbox"/> Metals (specify:) <input type="checkbox"/> Volatiles (VOC) <input type="checkbox"/> HAP/TAC (specify:) <input type="checkbox"/> Nitrogen oxides (NO _x) <input type="checkbox"/> Sulfur dioxide (SO ₂) <input type="checkbox"/> Other: | | | |
| Attach manufacturer's specification sheets, or complete the following: | | | | | |
| Will multiple emission processes be monitored at the same location? | | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| Which emission processes are monitored? | | | | | |
| Will more than one emission process be emitting from the combined stack at any time? | | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| Which emission processes emit simultaneously? | | | | | |

Monitoring and Alarm Information

Describe the System Alarm(s): [Specific details regarding non-resettable hours meter alarm information will not be known until the project is further in development.](#)


If there are more than three alarms, attach additional copies of this page as needed.

| Operating Parameter Monitored | Describe Alarm Trigger | Monitoring Device or Alarm Type | Does the Alarm Initiate an Automated Response? |
|-------------------------------|------------------------|--|---|
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic <input type="checkbox"/> (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic <input type="checkbox"/> (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |
| | | <input type="checkbox"/> Visual <input type="checkbox"/> Auditory <input type="checkbox"/> Automatic <input type="checkbox"/> (Remote Monitoring) <input type="checkbox"/> Other | <input type="checkbox"/> YES <input type="checkbox"/> NO Describe: |

Emission Tests

List any emission measurement tests (stack tests) that have been performed in the past and attach a copy of the test reports:

| | |
|---------------|------------|
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |
| Test Purpose: | Test date: |


| | |
|--|---|
|  <p style="margin: 0;">Louisville Metro Air Pollution Control District</p> <p style="margin: 0;">Permit Application and Renewal Form AP-100P</p> <p style="margin: 0;">Insignificant Activities</p> | <p>Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203</p> <hr style="border: 0; border-top: 1px solid black; margin: 5px 0;"/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|--|---|

| General Information | |
|---|---------------|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of Submission: 12/15/2022 | |

Emissions from Insignificant Activities must be reported on Emissions Inventory reports and must be included when calculating all plant-wide emission limits.

| Reg 1.02 § # | Facility Type | Number of Units | PTE (each) |
|---|--|-----------------|------------|
| A.1.1 | Indirect heat exchangers less than 10 MMBtu/hr, except those that burn waste oil. Size of unit(s): _____ Fuel(s) burned: _____ | | |
| A.1.2 | Indirect heat exchangers for residential building heat. | | |
| A.2 | Fixed internal combustion unless regulated elsewhere. (Emergency generator emissions are calculated based on operation for 500 hrs/yr) | | |
| Any of the following facilities to which no standard is applicable or which emit an air pollutant to which no standard applies: | | | |
| A.3.1 | Presses for extruding metals, minerals, or wood. | | |
| A.3.2 | Dry cleaners for which there is no emission, performance, or other standard. | | |
| A.3.3 | Lint traps used in conjunction with commercial laundry and dry cleaners. | | |
| A.3.4 | Brazing, soldering or welding equipment. | | |
| A.3.5 | Equipment commonly used in wood-working operations, except for conveying, hogging or burning of sawdust or wood waste. | | |
| A.3.6 | Foundry core-making equipment to which no heat is applied and for which there is no emission standard. | | |
| A.3.7 | Ovens used exclusively for curing potting materials or castings made with epoxy resins. | | |
| A.3.8 | Equipment used for compression or injection molding of plastics. | | |
| A.3.9.1 | Containers, reservoirs, or tanks used exclusively for dipping operations for coating objects with oils, waxes, or greases and where no organic solvents, diluents, or thinners are used. | | |
| A.3.9.2 | Containers, reservoirs, or tanks used exclusively for storage of lubricating oils or fuel oils with a vapor pressure of less than 10 mmHg at conditions of 20°C and 760 mmHg. | | |
| A.3.10 | Emergency relief vents, stacks and ventilating systems. | | |
| A.3.11 | Laboratory ventilating and exhausting systems which are not used for radioactive air contaminants. | | |

| Reg 1.02 § # | Facility Type | Number of Units | PTE (each) |
|--|--|--------------------|------------|
| A.3.12 | Process, exhaust or ventilating systems in bakeries or eating establishments preparing food for human consumption. | | |
| A.3.13 | Blast cleaning equipment using a suspension of abrasives in water. | | |
| A.3.14 | Equipment used exclusively for heat treating, soaking, case hardening or surface conditioning of metal objects ... when natural gas or LP gas is used as fuel. | | |
| A.3.15 | Equipment used for washing or drying products fabricated from metal or glass provided no volatile organic materials are used in the process and no oil or solid fuel is burned. | | |
| A.3.16 | Equipment, machines, devices, or contrivances built or installed to be used at a domestic residence for domestic use. | | |
| A.3.17 | Porcelain enameling furnaces, porcelain enameling drying ovens, vitreous enameling furnaces or vitreous enameling drying ovens. | | |
| A.3.18 | Crucible or pot furnaces with a brim full capacity of less than 450 cubic inches of any molten metal. | | |
| A.3.19 | Facilities using only peanut oil, sunflower oil, cottonseed oil or canola oil. | | |
| A.3.20 | Soil or ground water contamination remediation projects that are entirely passive or entail the total removal of the contaminated substrate for disposal in a certified landfill. | | |
| A.3.21 | Dust or particulate collectors that are located in-doors, vent directly indoors into the work space, collect no more than one ton of material per year. | | |
| A.3.23 | Portable diesel or gasoline storage tanks with a maximum capacity of less than 500 gallons. | | |
| A.3.24 | Storage vessels for VOCs with a maximum capacity of 250 gallons or less. List materials stored: | | |
| A.3.25 | Diesel or fuel oil storage tanks that are not used for distribution, sale or resale, and that have less than two times the capacity of the vessel in annual turnover of the fluid contained. | | |
| A.2.3.26 | All pressurized VOC storage vessels. List materials stored: | | |
| A.3.27 | Research and Development (R&D) facilities. Describe R&D activities carried out: | | |
| Describe any other processes or activities that you believe should be included as insignificant, and your justification for this belief. | | | |
| The following units have a PTE less than 5 tpy for all regulated pollutants and less than 1,000 lb/yr for all HAP (See Appendix B of the Application Package): | | | |
| 1) Diesel Storage Tanks (4,000-gallon and 440-gallon) | | | |
| 2) Mechanical Draft Cooling Tower (8 Cells) for NGCCT | | | |
| 3) Lube Oil System with Demister Vents | | | |
| 4) HVAC Heaters (less than 10 MMBtu/hr total) | | | |


| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-200E Combustion Source | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |

| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Control equipment associated with this process equipment: -- |

| Equipment Description | | Emission Process/Point # | E50 |
|---|--------------------------------------|--|--------------------------------------|
| Manufacturer: | TBD | Model: | TBD |
| Date of Manufacturer: | TBD | Date of Installation: | 3/2024 |
| Firing method: <input type="checkbox"/> Direct <input checked="" type="checkbox"/> Indirect | | Rated Maximum Heat Input: | 99.9 MMBTU/hr |
| Fuel Information | | | |
| Primary Fuel | | Secondary Fuel | |
| <input checked="" type="checkbox"/> Natural Gas | <input type="checkbox"/> Coal | <input type="checkbox"/> Natural Gas | <input type="checkbox"/> Coal |
| <input type="checkbox"/> #2 Fuel Oil | <input type="checkbox"/> #6 Fuel Oil | <input type="checkbox"/> #2 Fuel Oil | <input type="checkbox"/> #6 Fuel Oil |
| <input type="checkbox"/> Other: | | <input type="checkbox"/> Other: | |
| Maximum annual consumption: | 826.4 MMscf/yr | Maximum annual consumption: | |
| Maximum firing rate: | 99.9 MMBtu/hr | Maximum firing rate: | |
| Is a low NOx burner used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Is a low NOx burner used? <input type="checkbox"/> Yes <input type="checkbox"/> No | |
| If yes, enter rated NOx emission rate: TBD | | If yes, enter rated NOx emission rate: | |
| Is flue gas recirculation used? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Is flue gas recirculation used? <input type="checkbox"/> Yes <input type="checkbox"/> No | |
| What percentage of recirculation is used? TBD % | | What percentage of recirculation is used? | % |

| Ash Handling Information | | | |
|---|---|---|--|
| Is ash handling equipment used? <input type="checkbox"/> Yes (Attach mfg spec sheet) <input checked="" type="checkbox"/> No | | | |
| Type of ash handling system | <input type="checkbox"/> Pneumatic | <input type="checkbox"/> Hydraulic | |
| | <input type="checkbox"/> Mechanical | <input type="checkbox"/> Other: | |
| Ash storage containment system | <input type="checkbox"/> Storage silo | <input type="checkbox"/> Settling Basin | |
| | <input type="checkbox"/> Trucked off site | <input type="checkbox"/> Other: | |
| Ash generation rate: | | On-site ash storage capacity: | |

| Soot Blowing Information | | | |
|--|---|------------|--------------|
| Is soot blowing conducted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>If 'Yes,' complete the following</i> | | | |
| Frequency of soot blowing: | / | Duration : | Time of day: |


| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Permit Application and Renewal Form AP-200E Combustion Source | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |

| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Control equipment associated with this process equipment: -- |

| Equipment Description | | Emission Process/Point # |
|---|--|-------------------------------------|
| Manufacturer: | TBD | Model: TBD |
| Date of Manufacturer: | TBD | Date of Installation: 3/2024 |
| Firing method: <input type="checkbox"/> Direct <input checked="" type="checkbox"/> Indirect | Rated Maximum Heat Input: 15 MMBTU/hr | |
| Fuel Information | | |
| Primary Fuel | | Secondary Fuel |
| <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Coal | <input type="checkbox"/> Natural Gas <input type="checkbox"/> Coal | |
| <input type="checkbox"/> #2 Fuel Oil <input type="checkbox"/> #6 Fuel Oil | <input type="checkbox"/> #2 Fuel Oil <input type="checkbox"/> #6 Fuel Oil | |
| <input type="checkbox"/> Other: | <input type="checkbox"/> Other: | |
| Maximum annual consumption: 124.1 MMscf/yr | Maximum annual consumption: | |
| Maximum firing rate: 15 MMBtu/hr | Maximum firing rate: | |
| Is a low NOx burner used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | Is a low NOx burner used? <input type="checkbox"/> Yes <input type="checkbox"/> No | |
| If yes, enter rated NOx emission rate: | If yes, enter rated NOx emission rate: | |
| Is flue gas recirculation used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | Is flue gas recirculation used? <input type="checkbox"/> Yes <input type="checkbox"/> No | |
| What percentage of recirculation is used? % | What percentage of recirculation is used? % | |

| Ash Handling Information | | | |
|---|---|---|--|
| Is ash handling equipment used? <input type="checkbox"/> Yes (Attach mfg spec sheet) <input checked="" type="checkbox"/> No | | | |
| Type of ash handling system | <input type="checkbox"/> Pneumatic | <input type="checkbox"/> Hydraulic | |
| | <input type="checkbox"/> Mechanical | <input type="checkbox"/> Other: | |
| Ash storage containment system | <input type="checkbox"/> Storage silo | <input type="checkbox"/> Settling Basin | |
| | <input type="checkbox"/> Trucked off site | <input type="checkbox"/> Other: | |
| Ash generation rate: | | On-site ash storage capacity: | |

| Soot Blowing Information | | | |
|--|---|------------|--------------|
| Is soot blowing conducted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>If 'Yes,' complete the following</i> | | | |
| Frequency of soot blowing: | / | Duration : | Time of day: |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Process Permit Application Form AP-200J Engine or Generator | Deliver application to: Imber 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |


| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Control equipment associated with this process equipment: C43, C44 |

| Equipment Description | | Emission Process/Point # | E49a |
|--|--|---|---|
| Manufacturer: GE 7HA.03, Mitsubishi 501JAC, Siemens 9000HL, or Similar | | Model: | TBD |
| Date of: | Manufacturer - TBD | Installation - 3/2024 | Modification - N/A |
| Type of Engine: | <input type="checkbox"/> Reciprocating Internal Combustion <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Other: | | |
| Fuel: | <input type="checkbox"/> Gasoline <input checked="" type="checkbox"/> Natural Gas | | Rated Output: ¹ 664,000 <input type="checkbox"/> HP <input checked="" type="checkbox"/> kW |
| | <input type="checkbox"/> Diesel <input type="checkbox"/> Propane <input type="checkbox"/> Other: | | Maximum Fuel Consumption: 3.981 MMscf/hr |
| For Reciprocating Internal Combustion Engines | | | |
| | | Displacement: | |
| | | Number of cylinders: | <input type="checkbox"/> in-line <input checked="" type="checkbox"/> V <input type="checkbox"/> radical |
| | | Ignition source: | <input type="checkbox"/> spark <input type="checkbox"/> compression <input type="checkbox"/> Other: |
| | | Engine Type: | <input type="checkbox"/> 2 stroke <input type="checkbox"/> 4 stroke |
| Non-resettable hour meter: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | Emergency use ? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | |
| Output Use | Non –Emergency Equipment | | Emergency Equipment |
| | Describe: Electricity Distribution | | <input type="checkbox"/> Flood Pump <input type="checkbox"/> Electrical Generator <input type="checkbox"/> Fire Pump <input type="checkbox"/> Other: |
| Output device rating: 664 MW | | | |

| Fuel Storage Tank Information | | | |
|--|--|---|---|
| <input checked="" type="checkbox"/> No fuel storage tank is required. Reason: The natural gas fuel will be conveyed to the NGCC unit via pipeline. | | | |
| <input type="checkbox"/> Aboveground <input type="checkbox"/> Underground | | <input type="checkbox"/> Vertical <input type="checkbox"/> Horizontal | |
| Diameter: | | Height or Length: | |
| Working Volume: | | | |
| Tank construction | <input type="checkbox"/> Fiberglass <input type="checkbox"/> Plastic <input type="checkbox"/> Aluminum <input type="checkbox"/> Steel | Roof Type | <input type="checkbox"/> Flat, Fixed <input type="checkbox"/> Dome <input type="checkbox"/> Floating <input type="checkbox"/> Other: |
| Does this tank have a submerged fill pipe, as defined in District regulation 7.12 <input type="checkbox"/> Yes <input type="checkbox"/> No | | | |

¹ If this is an engine used to drive an electrical generator, be sure to list the mechanical rating of the engine, NOT the electrical output of the generator. If the output on the engine cannot be determined, multiply the electrical output by 1.1

| Federal Regulation Applicability | |
|---|--|
| <i>Check any Federal regulations which may be applicable to this installation</i> | |
| <input type="checkbox"/> | 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. |
| <input type="checkbox"/> | 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines. |
| <input checked="" type="checkbox"/> | 40 CFR 60, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines. |
| <input checked="" type="checkbox"/> | 40 CFR 63, Subpart YYYY – National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines. |
| <input type="checkbox"/> | 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District Process Permit Application Form AP-200J Engine or Generator | Deliver application to: Imber 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |


| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Control equipment associated with this process equipment: -- |

| Equipment Description | | Emission Process/Point # | E51 |
|----------------------------|---|--|--|
| Manufacturer: | Caterpillar 3516C or Similar | Model: | TBD |
| Date of: | Manufacturer - TBD Installation - 3/2024 | Modification - | N/A |
| Type of Engine: | <input checked="" type="checkbox"/> Reciprocating Internal Combustion <input type="checkbox"/> Turbine <input type="checkbox"/> Other: | | |
| Fuel: | <input type="checkbox"/> Gasoline <input type="checkbox"/> Natural Gas <input checked="" type="checkbox"/> Diesel <input type="checkbox"/> Propane <input type="checkbox"/> Other: | Rated Output: ¹ 2,682 | <input checked="" type="checkbox"/> HP <input type="checkbox"/> kW Maximum Fuel Consumption: 0.137 Mgal/hr |
| | For Reciprocating Internal Combustion Engines | | |
| | Displacement: | 78.1 L | |
| | Number of cylinders: | 16 | <input type="checkbox"/> in-line <input checked="" type="checkbox"/> V <input type="checkbox"/> radical |
| | Ignition source: | <input type="checkbox"/> spark <input checked="" type="checkbox"/> compression <input type="checkbox"/> Other: | |
| | Engine Type: | <input type="checkbox"/> 2 stroke <input checked="" type="checkbox"/> 4 stroke | |
| Non-resettable hour meter: | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | Emergency use ? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Output Use | Non –Emergency Equipment | Emergency Equipment | |
| | Describe: N/A | <input type="checkbox"/> Flood Pump <input checked="" type="checkbox"/> Electrical Generator <input type="checkbox"/> Fire Pump <input type="checkbox"/> Other: | |
| Output device rating: | 2,000 kW | | |

| Fuel Storage Tank Information | |
|---|--|
| <input type="checkbox"/> No fuel storage tank is required. Reason: | |
| <input type="checkbox"/> Aboveground <input type="checkbox"/> Underground | <input type="checkbox"/> Vertical <input type="checkbox"/> Horizontal |
| Diameter: 6.98 ft | Height or Length: 13.97 ft Working Volume: 4,000 gal |
| Tank construction | <input type="checkbox"/> Fiberglass <input type="checkbox"/> Plastic <input type="checkbox"/> Aluminum <input type="checkbox"/> Steel |
| Roof Type | <input type="checkbox"/> Flat, Fixed <input type="checkbox"/> Dome <input type="checkbox"/> Floating <input type="checkbox"/> Other: |
| Does this tank have a submerged fill pipe, as defined in District regulation 7.12 | |
| <input type="checkbox"/> Yes <input type="checkbox"/> No | |

¹ If this is an engine used to drive an electrical generator, be sure to list the mechanical rating of the engine, NOT the electrical output of the generator. If the output on the engine cannot be determined, multiply the electrical output by 1.1

| Federal Regulation Applicability | |
|---|--|
| <i>Check any Federal regulations which may be applicable to this installation</i> | |
| <input checked="" type="checkbox"/> | 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. |
| <input type="checkbox"/> | 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines. |
| <input type="checkbox"/> | 40 CFR 60, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines. |
| <input type="checkbox"/> | 40 CFR 63, Subpart YYYY – National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines. |
| <input checked="" type="checkbox"/> | 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. |

| | | |
|---|--|---|
|  | Louisville Metro Air Pollution Control District | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 |
| | Process Permit Application Form AP-200J | (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| Engine or Generator | | |


| | |
|--|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Control equipment associated with this process equipment: -- |

| Equipment Description | | Emission Process/Point # | IE28 |
|--|--|---|--|
| Manufacturer: Clarke JW6H-UFAD80 or Similar | | Model: | TBD |
| Date of: | Manufacturer - TBD | Installation - 3/2024 | Modification - N/A |
| Type of Engine: | <input checked="" type="checkbox"/> Reciprocating Internal Combustion <input type="checkbox"/> Turbine <input type="checkbox"/> Other: | | |
| Fuel: | <input type="checkbox"/> Gasoline <input type="checkbox"/> Natural Gas | | Rated Output: ¹ 400 <input checked="" type="checkbox"/> HP <input type="checkbox"/> kW |
| | <input checked="" type="checkbox"/> Diesel <input type="checkbox"/> Propane <input type="checkbox"/> Other: | | Maximum Fuel Consumption: 0.020 Mgal/hr |
| For Reciprocating Internal Combustion Engines | | | |
| | | Displacement: | 9 L |
| | | Number of cylinders: | 6 <input checked="" type="checkbox"/> in-line <input type="checkbox"/> V <input type="checkbox"/> radical |
| | | Ignition source: | <input type="checkbox"/> spark <input checked="" type="checkbox"/> compression <input type="checkbox"/> Other: |
| | | Engine Type: | <input type="checkbox"/> 2 stroke <input checked="" type="checkbox"/> 4 stroke |
| Non-resettable hour meter: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | Emergency use ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Output Use | Non –Emergency Equipment | | Emergency Equipment |
| | Describe: N/A | | <input type="checkbox"/> Flood Pump <input type="checkbox"/> Electrical Generator <input checked="" type="checkbox"/> Fire Pump <input type="checkbox"/> Other: |
| Output device rating: 400 bhp | | | |

| Fuel Storage Tank Information | | | |
|--|--|---|--|
| <input type="checkbox"/> No fuel storage tank is required. Reason: | | | |
| <input type="checkbox"/> Aboveground <input type="checkbox"/> Underground | | <input type="checkbox"/> Vertical <input type="checkbox"/> Horizontal | |
| Diameter: | 3.35 ft | Height or Length: | 6.69 ft Working Volume: 440 gal |
| Tank construction | <input type="checkbox"/> Fiberglass <input type="checkbox"/> Plastic <input type="checkbox"/> Aluminum <input type="checkbox"/> Steel | Roof Type | <input checked="" type="checkbox"/> Flat, Fixed <input type="checkbox"/> Dome <input type="checkbox"/> Floating <input type="checkbox"/> Other: |
| Does this tank have a submerged fill pipe, as defined in District regulation 7.12 <input type="checkbox"/> Yes <input type="checkbox"/> No | | | |


¹ If this is an engine used to drive an electrical generator, be sure to list the mechanical rating of the engine, NOT the electrical output of the generator. If the output on the engine cannot be determined, multiply the electrical output by 1.1

| Federal Regulation Applicability | |
|---|--|
| <i>Check any Federal regulations which may be applicable to this installation</i> | |
| <input checked="" type="checkbox"/> | 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. |
| <input type="checkbox"/> | 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines. |
| <input type="checkbox"/> | 40 CFR 60, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines. |
| <input type="checkbox"/> | 40 CFR 63, Subpart YYYY – National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines. |
| <input checked="" type="checkbox"/> | 40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. |

| | | |
|---|---|---|
|  | Louisville Metro Air Pollution Control District Control Device Permit Application Form AP-300A Generic Control Equipment | Deliver application to: 701 W. Ormsby Ave. Suite 303 Louisville, KY 40203 (502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov |
| | | |

| | |
|--|---|
| Plant Name: <u>Louisville Gas & Electric Company - Mill Creek Generating Station</u> | Plant ID: <u>127</u> |
| Date of construction, modification, installation, or operation: <u>3/2024</u> | Control equipment associated with this process equipment: <u>Oxidation Catalyst</u> |

| Equipment Description | | Control ID# |
|--|--|--|
| Manufacturer: | <u>TBD</u> | Model: <u>TBD</u> |
| Describe Control Equipment operation: | <u>Oxidation catalyst formulated with precious metals and placed in a catalyst bed downstream of the gas turbine exhaust and upstream of the gas turbine SCR catalyst bed.</u> | |
| Airflow: <u>TBD</u> acfm | Draft: <u>N/A</u> | Forced <input type="checkbox"/> Induced <input type="checkbox"/> |
| Inlet temperature: <u>600-1,200</u> °F | Outlet temperature: <u>600-750</u> °F | |
| <i>List the contaminants in the waste stream that are removed by the reduction system:</i> | | |
| Contaminant | CAS # (if applicable) | Gas stream concentration |
| CO | 630-08-0 | 90% |
| VOC | N/A | 50% |
| SO ₂ | 7446-09-5 | 0% |
| 1,3-Butadiene | 106-99-0 | 50% |
| Acetaldehyde | 75-07-0 | 50% |
| Acrolein | 107-02-8 | 43% |
| Benzene | 71-43-2 | 73% |
| Ethylbenzene | 100-41-4 | 50% |
| Formaldehyde | 50-00-0 | 68% |
| Naphthalene | 91-20-3 | 50% |
| PAH | N/A | 50% |
| Propylene Oxide | 75-56-9 | 50% |
| Toluene | 108-88-3 | 50% |
| Xylenes | 1330-20-7 | 50% |
| Dichlorobenzene | 25321-22-6 | 50% |
| Hexane | 110-54-3 | 0.5 |
| Describe how the control efficiency was determined: | <u>CO/VOC: Nominal values expected from oxidation catalyst</u> <u>SO₂: Pages 6-4 & 6-5 of Estimating Total Sulfuric Acid Emissions from Stationary Power Plants: 2018 Update. EPRI, Palo Alto, CA: 2018. 3002012398</u> <u>HAP: AP-42 Sections 1.4 and 3.1</u> <u>Refer to Section 5.3 in Appendix B of the application package.</u> <i>(If other than Manufacturer's specification, include documentation supporting the claimed efficiency)</i> | |
| Describe any monitoring devices, gauges, test ports, etc: | | |

| | |
|--|---|
|  <p>Louisville Metro Air Pollution Control District</p> <p>Control Device Permit Application Form AP-300G</p> <p>Reducing System</p> | <p>Deliver application to: 850 Barret Avenue Louisville, KY 40203</p> <hr/> <p>(502) 574-6000 FAX: (502) 574-5137 www.louisvilleky.gov/apcd airpermits@louisvilleky.gov</p> |
|--|---|

| | |
|---|---|
| Plant Name: Louisville Gas & Electric Company - Mill Creek Generating Station | Plant ID: 127 |
| Date of construction, modification, installation, or operation: 3/2024 | Process equipment associated with this process equipment: Selective Catalytic Reduction (SCR) |

| Equipment Description | | Control ID# | |
|---|--|--|--------------------|
| Manufacturer: TBD | | Model: TBD | |
| Type of System | <input checked="" type="checkbox"/> Selective catalytic <input type="checkbox"/> Selective non-catalytic <input checked="" type="checkbox"/> Ammonia injection <input type="checkbox"/> Non-selective catalytic <input type="checkbox"/> Other: | | |
| Exhaust gas flow rate: Minimum - 5,604,358 lb/h | Maximum - 6,847,000 lb/h | Pressure drop - 0.6-1.0 in. w.g. | |
| <i>Attach a copy of the manufacturer's spec sheets for the reduction system with this application</i> | | | |
| <i>List the components of the waste stream that are removed by the reduction system:</i> | | | |
| Contaminant | CAS # (if applicable) | Gas steam concentration | % Destruction |
| NO_x | N/A | < 2 ppmvd | 90 |
| SO₂ | 7446-09-5 | Varies | 3 |
| Describe how the removal efficiency was determined: <i>(If other than Manufacturer's specification, include documentation supporting the claimed efficiency)</i> | | | |
| Operational Information | | | |
| Ammonia/Urea Injection: | Operating Temperature - 550-700 ° F | Allowable ammonia slip - 5 ppm | |
| | Describe how slip is determined: Vendor Guarantees | | |
| | Describe how ammonia injection rate is monitored and controlled: TBD | | |
| Catalytic Reduction | Operating temperature range - 550 -- 700 ° F | | |
| | Catalyst used: TiO₂ ceramic substrate with transition metals such as Vanadium, Tungsten, and Molybdenum as activation sites | | |
| | Reducing agent used: 19% Aqueous Ammonia | | |
| | Reducing agent usage rate: 400-700 lb/hr | | |
| | Describe how waste from this operation is handled: TBD | | |

Permit Requirements

STEP 3

Read the standard requirements.

- (1) The designated representative of each affected source and each affected unit at the source shall:
 - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
 - (ii) Have an Acid Rain Permit.

Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).

Sulfur Dioxide Requirements, Cont'd.

STEP 3, Cont'd.

- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

- (1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission

of a new certificate of representation changing the designated representative;

STEP 3, Cont'd.

Recordkeeping and Reporting Requirements, Cont'd.

- (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
 - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
- (6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with

any other provision of the Act, including the provisions of title I of the Act relating

STEP 3, Cont'd.

Effect on Other Authorities, Cont'd.

to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a source can hold; *provided*, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,


(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Read the certification statement, sign, and date.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

| | |
|--------------|--|
| Steve Turner | |
| Name | |
| Signature | <div style="display: flex; align-items: center;"> <div style="border: 1px solid black; border-radius: 50%; padding: 2px; margin-right: 5px;">DocuSigned by:</div>  </div> <p style="font-size: small; margin-top: 2px;">8AD647306F3F4A0...</p> |
| Date | 12/15/2022 8:20 AM EST |



Instructions for the Acid Rain Program ^{Imber} Permit Application

The Acid Rain Program requires the designated representative to submit an Acid Rain permit application for each source with an affected unit. A complete Certificate of Representation must be received by EPA before the permit application is submitted to the title V permitting authority. A complete Acid Rain permit application, once submitted, is binding on the owners and operators of the affected source and is enforceable in the absence of a permit until the title V permitting authority either issues a permit to the source or disapproves the application.

Please type or print. If assistance is needed, contact the title V permitting authority.

STEP 1 A Plant Code is a 4 or 5 digit number assigned by the Department of Energy=s (DOE) Energy Information Administration (EIA) to facilities that generate electricity. For older facilities, "Plant Code" is synonymous with "ORISPL" and "Facility" codes. If the facility generates electricity but no Plant Code has been assigned, or if there is uncertainty regarding what the Plant Code is, send an email to the EIA. The email address is EIA-860@eia.gov.

STEP 2 In column "a," identify each unit at the facility by providing the appropriate unit identification number, consistent with the identifiers used in the Certificate of Representation and with submissions made to DOE and/or EIA. Do not list duct burners. For new units without identification numbers, owners and operators must assign identifiers consistent with EIA and DOE requirements. Each Acid Rain Program submission that includes the unit identification number(s) (e.g., Acid Rain permit applications, monitoring plans, quarterly reports, etc.) should reference those unit identification numbers in exactly the same way that they are referenced on the Certificate of Representation.

Submission Deadlines

For new units, an initial Acid Rain permit application must be submitted to the title V permitting authority 24 months before the date the unit commences operation. Acid Rain permit renewal applications must be submitted at least 6 months in advance of the expiration of the acid rain portion of a title V permit, or such longer time as provided for under the title V permitting authority's operating permits regulation.

Submission Instructions

Submit this form to the appropriate title V permitting authority. If you have questions regarding this form, contact your local, State, or EPA Regional Acid Rain contact, or call EPA's Acid Rain Hotline at (202) 343-9620.

Paperwork Burden Estimate

The public reporting and record keeping burden for this collection of information is estimated to average 8 hours per response. Burden means the total time, effort, or financial resources expended by persons to generate, maintain, retain, or disclose or provide information to or for a Federal agency. This includes the time needed to review instructions; develop, acquire, install, and utilize technology and systems for the purposes of collecting, validating, and verifying information, processing and maintaining information, and disclosing and providing information; adjust the existing ways to comply with any previously applicable instructions and requirements; train personnel to be able to respond to a collection of information; search data sources; complete and review the collection of information; and transmit or otherwise disclose the information. An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

Send comments on the Agency's need for this information, the accuracy of the provided burden estimates, and any suggested methods for minimizing respondent burden, including through the use of automated collection techniques to the Director, Collection Strategies Division, U.S. Environmental Protection Agency (2822T), 1200 Pennsylvania Ave., NW., Washington, D.C. 20460. Include the OMB control number in any correspondence.

Do not send the completed form to this address.

APPENDIX D. SUGGESTED REVISIONS TO PERMIT

To assist APCD in reviewing the application and to promote efficiency in APCD's efforts at preparing a construction permit and revised Title V operating permit, sample suggested edits to the Mill Creek Generating Station's existing Title V permit (O-0127-20-V) (shown in blue font) that reflect the new and modified regulatory and permitting requirements impacted by the NGCC Project are provided in this appendix.

The suggested provisions for new emission units encompass the operating limits, emission standards, and associated compliance assurance monitoring provisions that are derived from applicable regulations and/or are believed to be appropriate to address the permitting requirements triggered by the NGCC Project. LG&E understands that APCD retains the authority and responsibility for developing a construction permit that the agency believes is appropriate for the project. These suggested provisions are only being provided to promote efficiency and timeliness in the agency's review.



Louisville Metro Air Pollution Control District
701 West Ormsby Avenue, Suite 303
Louisville, Kentucky 40203-3137



Title V Operating Permit

Permit No.: O-0127-20-V

Plant ID: 127

Effective Date: 07/27/2020

Expiration Date: 07/31/2025

Permission is hereby given by the Louisville Metro Air Pollution Control District to operate the process(es) and equipment described herein which are located at:

Source: Louisville Gas & Electric
Company
Mill Creek Generating Station
14460 Dixie Highway
Louisville, KY 40272

Owner: Louisville Gas & Electric
Company
220 W. Main Street
Louisville, KY 40202

The applicable procedures of District Regulation 2.16 regarding review by the U.S. EPA and public participation have been followed in the issuance of this permit. Based on review of the application on file with the District, permission is given to operate under the conditions stipulated herein. If a renewal permit is not issued prior to the expiration date, the owner or operator may continue to operate in accordance with the terms and conditions of this permit beyond the expiration date, provided that a complete renewal application is submitted to the District no earlier than eighteen months and no later than six months prior to the expiration date.

Application No.: See **Application and Related Documents** table.

Administratively Complete Date: 03/26/2019

Public Notice Date: 06/11/2020

Proposed Permit Date: 06/11/2020

Permit writer: Yiqiu Lin

Air Pollution Control Officer
7/27/2020

Deleted pages with no edits

Plantwide Requirements

Facility Description

Louisville Gas & Electric- Mill Creek Generating Station generates electric energy for local and remote distribution. Coal is the primary fuel used to fire commercial boilers for generation of electricity via steam turbines and generators.

Plantwide Applicable Regulations

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|-----------------------------------|--|-------------------------|
| Regulation | Title | Applicable Sections |
| 2.16 | Title V Operating Permits | 1 through 6 |
| 40 CFR 52 Subpart A | Approval and Promulgation of Implementation Plans – General Provisions | 52.01 through 52.39 |
| 40 CFR 68 Subpart G | Risk Management Plan | 68.150 through 68.195 |
| 40 CFR 97 Subpart AAAAA | CSAPR NO _x Annual Trading Program | 97.401 through 97.435 |
| 40 CFR 97 Subpart GGGGG | CSAPR NO _x Ozone Season Group 3 Trading Program | 97.1001 through 97.1035 |
| 40 CFR 97 Subpart CCCCC | CSAPR SO ₂ Group 1 Trading Program | 97.601 through 97.635 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|---------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.15 | Chemical Accident Prevention Provisions | 1, 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Plantwide Specific Conditions

S1. Standards

[Regulation 2.16, Section 4.1.1]

a. SO₂

- i. The owner or operator shall not allow SO₂ emissions from any of the boilers U1, U2, U3, or U4, to exceed 0.20 lb/MMBtu of heat input based on a rolling 30-day average.¹ [40 CFR 52]

b. TAC

- i. The owner or operator shall not allow emissions of any TAC to exceed environmentally acceptable (EA) levels, whether specifically established by modeling or determined by the District to be *de minimis*. (See Comment 1) [Regulations 5.00 and 5.21]
- ii. The owner or operator shall perform a new Environmental Acceptability (EA) Demonstration or *de minimis* determination when the following events occur and submit the EA Demonstration on the schedule noted in the reporting section:²
 - (1) An application to construct or modify a process or process equipment is submitted to the District pursuant to Regulation 2.03, 2.04 or 2.05. [Regulation 5.21, section 4.22.1]
 - (2) A modification of any physical modeling parameters such as fence lines or building heights that are not otherwise subject to the requirements in this permit that affects the demonstration of compliance. [Regulation 5.21, section 4.22.2]; or
 - (3) A change occurs in the process or process equipment, including raw material or fuel type substitution. [Regulation 5.21, section 4.22.3]
- iii. When a new TAC is introduced or for any existing TAC which does not have an established BAC or *de minimis* value, the owner or operator shall calculate and report these values as part of any aforementioned EA Demonstration. The form, located in Attachment I, may be used for

¹ KDAQ and APCD performed AERMOD modeling for attainment of 1-hour SO₂ NAAQS at LG&E Mill Creek Station. Based on the modeled critical SO₂ emission rate and an established 30-day vs. 1-hour SO₂ emission ratio, the suggested 30-day average critical SO₂ emission rates for each emission unit are determined. APCD believes an average single compliance ratio for all emission units would reasonably reflect the variability of emissions for the whole plant. Also, the same single emission limit for each unit is more conservative since the calculated annual potential total SO₂ emissions based on the single limit 0.20 lb/MMBtu for all units are less than the total SO₂ emissions based on the separate different limit for each unit. On October 20, 2016, LG&E submitted an application form AP-100A and requested the emission standards to be incorporated into its Title V permit.

² Changes to the air dispersion modeling program or meteorological data used in the most recent Environmental Acceptability Demonstration do not trigger the requirement to perform a new Environmental Acceptability Demonstration.

determining BAC and *de minimis* values.
[Regulation 5.20, sections 3 and 4]

c. **Cross-State Air Pollution Rule (CSAPR)³**

i. The owner or operator shall comply with CSAPR applicable requirements in 40 CFR 97 Subpart AAAAA, Subpart GGGGG, and Subpart CCCCC (See Attachment F).

d. **District Regulation 5.15 Regulated Substance** [40 CFR Part 68 Subpart G]

i. If any toxic substances listed in Tables 1 through 4 to 40 CFR 68.130 are present at the stationary source in an amount greater than the threshold quantity specified in Regulation 5.15, the owner or operator shall comply with the requirements specified in Regulation 5.15, including the requirement to submit a Risk Management Plan in a method and format as specified by the District and EPA.

S2. Monitoring and Record Keeping

[Regulation 2.16, Section 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the following records for a minimum of five years and make the records readily available to the District upon request.

a. **SO₂**

- i. See each emission unit (U1, U2, U3, and U4) for the specific monitoring and record keeping requirements.
- ii. The owner or operator shall, on a daily basis, monitor and keep records of fuel type, feed rate (or firing rate) of each boiler (U1, U2, U3, and U4).

b. **TAC**

i. The owner or operator shall maintain records sufficient to demonstrate environmental acceptability, including, but not limited to, (M)SDS, analysis of emissions, and/or modeling results.

c. **Cross-State Air Pollution Rule (CSAPR)**

i. The owner or operator shall comply with CSAPR applicable requirements in 40 CFR 97 Subpart AAAAA, Subpart GGGGG, and Subpart CCCCC (See Attachment F).

³ EPA approved on May 8, 2019 (84 FR 13800) the Kentucky State SIP Revision to replace The Clean Air Interstate Rule (CAIR) with Cross State Air Pollution Rule (CSAPR). CAIR requirements have been removed from the permit.

d. **District Regulation 5.15 Regulated Substance** [40 CFR Part 68, Subpart G]

- i. If any toxic substances listed in Tables 1 through 4 to 40 CFR 68.130 are present at the stationary source in an amount greater than the threshold quantity specified in Regulation 5.15, the owner or operator shall monitor the processes and keep records required by Regulation 5.15.

S3. Reporting

[Regulation 2.16, Section 4.1.1]

The owner or operator shall report the following information, as required by General Condition G14: (See Comment 2)

a. **SO₂**

- i. See each emission unit (U1, U2, U3, and U4) for the specific reporting requirements.
- ii. Excess emissions for affected facilities (U1, U2, U3, and U4) are defined as: [40 CFR 52]
 - (1) For affected facilities complying with the 0.20 lb/MMBtu emission standard, any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO₂ as measured by a CEMS exceed the standard.

b. **TAC**

- i. The owner or operator shall submit new EA Demonstrations involving applications to construct or modify with the construction permit application. [Regulation 5.21, section 4.22.1]
- ii. The owner or operator shall submit new EA Demonstrations involving modification of any physical modeling parameter, such as fence lines or building heights, that are not otherwise subject to the permit requirements for that facility that affects the demonstration of compliance with the operating permit renewal application. [Regulation 5.21, section 4.22.2]
- iii. The owner or operator shall submit new EA Demonstrations involving a change in a process or process equipment, including raw material or fuel type substitution before making the change. [Regulation 5.21, section 4.22.3]
 - (1) Prior approval by the District is not required if the change does not result in emissions that exceed an EA goal, does not cause emissions of a TAC to no longer be de minimis, and a permit modification is

not required. In this case, the new EA Demonstration shall be submitted within 6 months of the change.

c. Cross-State Air Pollution Rule (CSAPR)

- i. The owner or operator shall comply with CSAPR applicable requirements in 40 CFR 97 Subpart AAAAA, Subpart GGGGG, and Subpart CCCCC (See Attachment F).

d. District Regulation 5.15 Regulated Substance [40 CFR Part 68, Subpart G]

- i. If any toxic substances listed in Tables 1 through 4 to 40 CFR 68.130 are present at the stationary source in an amount greater than the threshold quantity specified in Regulation 5.15, the owner or operator shall comply with the reporting requirements specified in Regulation 5.15, including the requirement to submit a Risk Management Plan in a method and format as specified by the District and EPA.

Comments for Plantwide Requirements

1. LG&E Mill Creek submitted their TAC Environmental Acceptability Demonstration to the District on December 28, 2006, March 25, 2008, April 9, 2010, April 2, 2012, May 13, 2014, and January 21, 2016. Compliance with the STAR EA Goals was demonstrated in the source's EA Demonstrations. SCREEN3 air dispersion modeling was performed for each emission unit that has non-de minimis TAC emissions. The following table demonstrates that the carcinogen risk and non-carcinogen risk values, calculated using the District approved PTE for each unit and the SCREEN model results from the source's EA Demonstration, comply with the STAR EA goals required in Regulation 5.21 controlled.

| Plantwide Sum | All existing & new | | All new P/PE | |
|---------------------------------|--------------------|-------|--------------|-------|
| | | | | |
| Industrial Total R _C | 4.16 | < 75 | 0.61 | < 38 |
| Non-Ind. Total R _C | 4.16 | < 7.5 | 0.61 | < 3.8 |
| Industrial Max. R _{NC} | 0.16 | < 3.0 | | |
| Non-Ind. Max. R _{NC} | 0.16 | < 1.0 | | |

Plant ID: 0127

| TAC | R _{NC} Total | | U1 | | U2 | | U3 | | U4 | | U8 | | U9 | | U22 | |
|---|-----------------------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|
| | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | | Ind./Non-Ind. | |
| | R _{NC} | R _{NC} | R _C | R _{NC} | R _C | R _{NC} | R _C | R _{NC} | R _C | R _{NC} | R _C | R _{NC} | R _C | R _{NC} | R _C | R _{NC} |
| Total R_C/ Max. R_{NC} | 0.16 | 0.16 | 0.65 | | 0.65 | | 1.09 | | 1.07 | | 0.58 | | 0.10 | | 0.03 | |
| Ar & compounds | 0.03 | 0.03 | 0.29 | 0.00 | 0.29 | 0.00 | 0.48 | 0.01 | 0.48 | 0.01 | 0.56 | 0.01 | 0.10 | 0.002 | 0.02 | 0.00 |
| Cd & compounds | 0.00 | 0.00 | 0.02 | 0.00 | 0.02 | 0.00 | 0.03 | 0.00 | 0.03 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Cr IV & compounds | 0.02 | 0.02 | 0.28 | 0.00 | 0.28 | 0.00 | 0.48 | 0.00 | 0.47 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Cr III & compounds | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Formaldehyde | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Ni & compounds | 0.03 | 0.03 | 0.02 | 0.01 | 0.02 | 0.01 | 0.03 | 0.01 | 0.03 | 0.01 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Co & compounds | 0.01 | 0.01 | 0.03 | 0.00 | 0.03 | 0.00 | 0.06 | 0.00 | 0.06 | 0.00 | 0.03 | 0.001 | 0.00 | 0.00 | 0.00 | 0.00 |
| Hydrofluoric acid | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Pb & compounds | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Mn & compounds | 0.01 | 0.01 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Naphthalene | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Sulfuric acid | 0.16 | 0.16 | 0.00 | 0.03 | 0.00 | 0.03 | 0.00 | 0.05 | 0.00 | 0.05 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

2. The compliance reports are due on or before the following dates of each calendar year:

Reporting Period

January 1st through March 31th

April 1st through June 30th

July 1st through September 30th

October 1st through December 31st

Report Due Date

May 30th

August 29th

November 29th

March 1st

Emission Unit U1: Electric Utility Steam Generating Unit (EGU) – Unit 1**Applicable Regulations**

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|---|--|
| Regulation | Title | Applicable Sections |
| 6.02 | Emission Monitoring for Existing Sources | 1, 2, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18 |
| 6.07 | Standards of Performance for Existing Indirect Heat Exchangers | 1, 2, 3, 4 |
| 6.09 | Standards of Performance for Existing Process Operations | 1, 2, 3, 5 |
| 6.42 | Reasonably Available Control Technology Requirements for Major Volatile Organic Compound- and Nitrogen Oxides-Emitting Facilities | 1, 2, 3, 4, 5 |
| 6.47 | Federal Acid Rain Program for Existing Sources Incorporated by Reference | 1, 2, 3, 4, 5 |
| 40 CFR 64 | Compliance Assurance Monitoring for Major Stationary Sources | 64.1 through 64.10 |
| 40 CFR 72 | Permits Regulation | Subparts A, B, C, D, E, F, G, H, I |
| 40 CFR 73 | Sulfur Dioxide Allowance System | Subparts A, B, C, D, E, F, G |
| 40 CFR 75 | Continuous Emission Monitoring | Subparts A, B, C, D, E, F, G |
| 40 CFR 76 | Acid Rain Nitrogen Oxides Emission Reduction Program | 76.1, 76.2, 76.3, 76.4, 76.5, 76.7, 76.8, 76.9, 76.11, 76.13, 76.14, 76.15, Appendix A, Appendix B |
| 40 CFR 77 | Excess Emissions | 77.1, 77.2, 77.3, 77.4, 77.5, 77.6 |
| 40 CFR 78 | Appeals Procedures for Acid Rain Program | 78.1, 78.2, 78.3, 78.4, 78.5, 78.6, 78.8, 78.9, 78.10, 78.11, 78.13, 78.14, 78.15, 78.16, 78.17, 78.18, 78.19, 78.20 |
| 40 CFR 63 Subpart UUUUU | National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units (EGU MACT) | 63.9980 through 63.10042 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|--|--------------------|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.02 | Adoption of National Emission Standards for Hazardous Air Pollutants | 1, 3.95 and 4 |
| 5.14 | Hazardous Air Pollutants and Source Categories | 1, 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|--|---------------------|---|-------------------|-------------------|
| E1 | One (1) tangentially fired boiler, rated capacity 3,085 MMBtu/hr, make Combustion Engineering, using pulverized coal as a primary fuel and natural gas as secondary fuel. | 1970 | STAR, 5.02, 5.14, 6.02, 6.07, 6.42, 6.47, 40CFR64, 40CFR72-73, 40CFR75-78, 40CFR63UUUUU | C1, C26, C27 | S33 |
| E2 | Four (4) coal silos, make Fisher-Klosterman, controlled by a centrifugal dust collector and equipped with four (4) coal mills, make Combustion Engineering Raymond Bowl Mills. | 1970 | STAR, 6.09 | C3 | S5 |

Control Devices

| Control ID | Description | Control Efficiency | Performance Indicator |
|-------------------|--|---------------------------|------------------------------|
| C1 | One (1) custom-built electrostatic precipitator (ESP) for PM control, make Western Precipitator Division | N/A | N/A ⁴ |

⁴ This unit is equipped with CEMS for NO_x, SO₂, and PM. According to the District's letter dated November 1, 2005, parametric monitoring of the ESP, FGD, and PJFF for this unit is removed as such monitoring would no longer be required for demonstration of compliance. On July 22, 2016, LG&E reported the normal pressure drop range for U1 PJFF, 2 – 6 inches of water, established during 90 consecutive operating days.

| Control ID | Description | Control Efficiency | Performance Indicator |
|------------|--|--|--|
| C3 | One (1) centrifugal dust collector, make Fisher-Klosterman | 90% | N/A ⁵ |
| C26 | One (1) HAP particulate matter control system, consists of: one (1) powdered activated carbon (PAC) injection system; one (1) dry sorbent injection system; liquid additive system(s); and one (1) pulse-jet fabric filter (PJFF) baghouse used for collecting PM from the boiler and PAC and dry sorbent injection system. PJFF baghouse make Clyde Bergemann Power Group, model Structural Pulse Jet | H ₂ SO ₄ : ⁶ 98.7% Hg: 89.3% PM: 99.2% | PM Control: PM emission data from PM CEMS (if PM CEMS is not used to demonstrate compliance) Hg control: (1) Minimum PAC injection rate; ⁷ (2) pH of reactant in FGD, 4.8-6.4; (3) Hg emission data from Sorbent Traps |
| C27 | One (1) combined Flue Gas desulfurization (FGD) unit for SO ₂ control using limestone scrubbing liquor, make Babcock Power Environmental | N/A | N/A ⁴ |

⁵ For the coal silos (E2), the owner or operator has shown, by worst-case calculations without allowance for a control device, that the hourly uncontrolled PM emission standard cannot be exceeded; therefore, no additional monitoring, recordkeeping, or reporting is required to demonstrate compliance with the applicable PM standards specified in Regulation 6.09 is required for this emission point.

⁶ Control efficiencies of C26 are based on stack test conducted on June 4-8, 2015.

⁷ In a letter dated October 4, 2016, LG&E demonstrated that in certain circumstance EGUs at this plant can meet the MACT mercury standard at zero PAC injection rate. Therefore, the source is allowed to use flexible mercury control measures, including PAC injection or liquid additive system, to achieve compliance with MACT mercury standard.

U1 Specific Conditions

S1. Standards⁸

[Regulation 2.16, Section 4.1.1]

a. **BART** [40 CFR 52, Subpart S]

- i. The owner or operator shall continue to utilize PJFF baghouse and/or existing ESP to control PM emissions for this unit.⁹
[40 CFR 52.920(e) refer to Kentucky Regional Haze SIP]

b. **HAP** [40 CFR 63 Subpart UUUUU]

- i. The owner or operator shall comply with emission standards required in 40 CFR 63 Subpart UUUUU (See Attachment A).

c. **NO_x**

- i. The owner or operator shall not allow the average NO_x emissions to exceed the alternate contemporaneous emission limitation of 0.40 lb/MMBtu of heat input on an annual average basis, as specified in Acid Rain Permit No.176-97-AR (R5) which is attached and considered part of the Title V Operating Permit. (See Acid Rain Permit Attachment)
[Regulation 6.47, section 3.5 referencing 40 CFR Part 76]
- ii. The owner or operator shall not exceed the NO_x RACT emissions standard of 0.47 lb/MMBtu of heat input based on a rolling 30-day average. (See NO_x RACT, Attachment D) [Regulation 6.42, section 4.3]
- iii. The owner or operator shall install, maintain, calibrate and operate a continuous emission monitoring system (CEMS) for the measurement or calculation of nitrogen oxides in the flue gas.
[Regulation 6.02, section 6.1.3] [NO_x RACT Plan] [Regulation 6.47, section 3.4 referencing 40 CFR 75.10(a)(2)]

d. **Opacity**

- i. The owner or operator shall not cause the emission into the open air of particulate matter from any indirect heat exchanger which is greater than 20% opacity, except emissions into the open air of particulate matter from any indirect heat exchanger during building a new fire, cleaning the fire box, or blowing soot for a period or periods aggregating not more than ten

⁸ The emission standards, monitoring, record keeping, and reporting requirements only apply to boiler E1 (not coal silos E2) unless otherwise noted.

⁹ On March 30, 2012, EPA finalized a limited approval and a limited disapproval of the Kentucky state implementation plan submitted on June 25, 2008 and May 28, 2010. According to 40 CFR 52.920(e), the owner or operator shall meet BART requirements summarized in Table 7.5.3-2 of the Commonwealth's May 28, 2010 submittal.

minutes in any 60 minutes which are less than 40% opacity.
[Regulation 6.07, section 3.2 and 3.3]

- ii. The company shall follow one of the two options in the table under Specific Condition for PM to demonstrate compliance with opacity standards.
- iii. For coal silos (E2), the owner or operator shall not allow visible emissions to equal or exceed 20% opacity. [Regulation 6.09, section 3.1]

e. **PM**

- i. The owner or operator shall not exceed an allowable particulate emission rate of 0.11 lbs/MMBtu heat input based on a 3-hour rolling average. [Regulation 6.07, section 3.1]
- ii. At all time, including periods of startup, shutdown, and malfunction, the owner or operator shall, to the extent practicable, maintain and operate boiler E1 including associated PM control equipment (PJFF) in a manner consistent with good air pollution control practice for minimizing emissions. Following commissioning of the PJFF baghouses, the owner or operator may elect to operate, turn down, or turn off the ESP to ensure the efficient operation of the PJFF baghouse.¹⁰
[Regulation 1.05, section 5]
- iii. The company shall follow one of the two options below to demonstrate compliance with PM standards:

| Compliance Options | PM | Opacity | Control Device Performance indication |
|--------------------|-------------------|--------------------------------|---------------------------------------|
| Option 1 | Certified PM CEMS | VE/Method 9, or Certified COMS | N/A |
| Option 2 | Annual testing | Certified COMS | PM CEMS |

- iv. For coal silos (E2), the owner or operator shall not exceed an allowable particulate emission rate of 82.95 lbs/hr from four coal silos combined based on actual operating hours in a calendar day.¹¹
[Regulation 6.09, section 3.2]

¹⁰ The PM emissions cannot meet the standards uncontrolled. The owner or operator is required to operate the control devices to meet the applicable limits for PM.

¹¹ For the coal silos (E2), the owner or operator has shown, by worst-case calculations without allowance for a control device, that the hourly uncontrolled PM emission standard cannot be exceeded; therefore, no additional monitoring, recordkeeping, or reporting is required to demonstrate compliance with the applicable PM standards specified in Regulation 6.09 is required for this emission point.

f. **SO₂**

- i. The owner or operator shall not exceed 1.2 lb/MMBtu per hour heat input based on a 3-hour rolling average. [Regulation 6.07, section 4.1]
- ii. The owner or operator shall comply with the SO₂ emission allowances specified in Acid Rain Permit No.176-97-AR (R5). (See Acid Rain Permit Attachment) [Regulation 6.47, section 3.2 referencing 40 CFR Part 73]
- iii. At all time, including periods of startup, shutdown, and malfunction, the owner or operator shall, to the extent practicable, maintain and operate boiler E1 including associated SO₂ control equipment (FGD) in a manner consistent with good air pollution control practice for minimizing emissions.¹² [Regulation 1.05, section 5]
- iv. The owner or operator shall install, maintain, calibrate and operate a continuous emission monitoring system (CEMS) for the measurement of sulfur dioxide in the flue gas.
[Regulation 6.02, section 6.1.2] [Regulation 6.47, section 3.4 referencing 40 CFR 75.10(a)(1)]

g. **TAC**

- i. The owner or operator shall not allow TAC emissions from boiler E1 to exceed the TAC emission standards determined based upon the EA Demonstration provided to the District.¹³ (See Comment 1)
[Regulation 5.21, section 4.2 and section 4.3]

| TAC Name | CAS # | TAC Limits Determination | |
|-------------------|------------|--------------------------|-----------------|
| | | (lbs/yr) | Basis of Limits |
| Naphthalene | 91-20-3 | 16.6 | Controlled PTE |
| Formaldehyde | 50-00-0 | 70.3 | Controlled PTE |
| Hydrogen fluoride | 7664-39-3 | 13,385 | Controlled PTE |
| Arsenic compounds | 7440-38-2 | 266 | Controlled PTE |
| Cadmium compounds | 7440-43-9 | 42.1 | Controlled PTE |
| Chromium VI | 7440-47-3 | 94.5 | Controlled PTE |
| Chromium III | 16065-83-1 | 216 | Controlled PTE |
| Cobalt compounds | 7440-48-4 | 56.2 | Controlled PTE |
| Lead compounds | 7439-92-1 | 332 | Controlled PTE |

¹² The SO₂ emissions cannot meet the standards uncontrolled. The owner or operator is required to operate the control devices to meet the applicable limits for SO₂.

¹³ This table for TAC emission standards has been revised to exclude Category 3 and 4 TACs for existing sources and use “de minimis values”, instead of actual numbers for current de minimis levels, as emission standards.

| TAC Name | CAS # | TAC Limits Determination | |
|----------------------------|-----------|--------------------------------------|-----------------|
| | | (lbs/yr) | Basis of Limits |
| Manganese compounds | 7439-96-5 | 424 | Controlled PTE |
| Nickel compounds | 7440-02-0 | 307 | Controlled PTE |
| Sulfuric acid | 7664-93-9 | 118,679 | Controlled PTE |
| Benzene | 71-43-2 | De minimis values (See Comment 1) | De Minimis |
| Bromoform | 75-25-2 | | De Minimis |
| Chloroform | 67-66-3 | | De Minimis |
| Methylene chloride | 75-09-2 | | De Minimis |
| Tetrachloroethylene (Perc) | 127-18-4 | | De Minimis |
| Toluene | 108-88-3 | | De Minimis |
| Xylene | 1330-20-7 | | De Minimis |
| Hydrochloric acid | 7647-01-0 | | De Minimis |

- ii. See Plantwide Requirements.

h. Unit Operation

- i. The owner or operator shall shut down the existing emission unit U1 prior to the date when the new emission unit U23 becomes operational and begins to emit a particular pollutant. Any replacement unit that requires shakedown becomes operational only after a reasonable shakedown period, not to exceed 180 days. (Regulation 2.05)

S2. Monitoring and Record Keeping

[Regulation 2.16, Section 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the following records for a minimum of five years and make the records readily available to the District upon request.

- a. **BART** [40 CFR 52, Subpart S]
- i. The owner or operator shall maintain daily records of any periods of time where the process was operating and both PJFF baghouse and ESP were not operating or a declaration that the PJFF baghouse and/or ESP operated at all times that day when the process was operating.
- b. **HAP** [40 CFR 63 Subpart UUUUU]
- i. The owner or operator shall comply with monitoring and record keeping requirements in 40 CFR 63 Subpart UUUUU. (See Attachment A)

- ii. The owner or operator shall establish a site-specific minimum activated carbon injection rate for PAC injection system according to Attachment B.¹⁴ The owner or operator shall monitor and record the activated carbon injection rate during each operating day.
 - iii. The owner or operator shall monitor and record all Hg emission data from the Hg sorbent traps, which is used as the indicator of normal operation of the Hg control measures.
 - iv. The owner or operator shall monitor and record the pH of the reactant material in the FGD and any other parameters verified as having a direct effect on Hg emissions during each operating day, which is (are) used as the indicator(s) of normal operation of Hg control measures.¹⁵
 - v. The owner or operator shall maintain records of which Hg control devices/measure was being used during each operating day.
- c. **NO_x**
- i. The owner or operator shall demonstrate compliance with NO_x RACT Plan limits by continuous emissions monitors (CEMs) as specified in the NO_x RACT Plan. (See NO_x RACT Attachment) [Regulation 6.42, section 4.3]
 - ii. The owner or operator shall keep a record identifying all deviations from the requirements of the NO_x RACT Plan.
 - iii. The owner or operator shall comply with the NO_x compliance plan requirements specified in the attached Acid Rain Permit, No.176-97-AR (R5). These record keeping requirements shall be determined in accordance with the Title IV Phase II Acid Rain Permit and are specified in 40 CFR Part 75 Subpart F. (See Appendix A to NO_x RACT Plan) [Regulation 6.47, section 3.4 and 3.5 referencing 40 CFR Parts 75 and 76]
 - iv. The owner or operator shall record on an hourly basis all NO_x emission data specified in 40 CFR Part 75, section 75.57(d). For each NO_x emission rate (in lb/mmBtu) measured by a NO_x-diluent monitoring system, or, if applicable, for each NO_x concentration (in ppm) measured by a NO_x concentration monitoring system used to calculate NO_x mass emissions under 40 CFR 75.71(a)(2), record the following data as measured and reported from the certified primary monitor, certified back-up monitor, or other approved method of emissions determination:

¹⁴ In a letter dated October 4, 2016, LG&E demonstrated that in certain circumstance EGUs at this plant can meet the MACT mercury standard at zero PAC injection rate. Therefore the source is allowed to use flexible mercury control measures, including PAC injection or liquid additive system, to achieve compliance with MACT mercury standard.

¹⁵ LG&E has established normal pH range per monitoring records during consecutive 180 days. On 10/20/2016, LG&E reported that the normal pH range for this unit is 4.8 – 6.4.

- (1) Component-system identification code, as provided in 40 CFR 75.53 (including identification code for the moisture monitoring system, if applicable); [40 CFR 75.57(d)(1)]
- (2) Date and hour; [40 CFR 75.57(d)(2)]
- (3) Hourly average NO_x concentration (ppm, rounded to the nearest tenth) and hourly average NO_x concentration (ppm, rounded to the nearest tenth) adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d); [40 CFR 75.57(d)(3)]
- (4) Hourly average diluent gas concentration (for NO_x -diluent monitoring systems, only, in units of percent O₂ or percent CO₂, rounded to the nearest tenth); [40 CFR 75.57(d)(4)]
- (5) If applicable, the hourly average moisture content of the stack gas (percent H₂O, rounded to the nearest tenth). If the continuous moisture monitoring system consists of wet- and dry-basis oxygen analyzers, also record both the hourly wet- and dry-basis oxygen readings (in percent O₂, rounded to the nearest tenth); [40 CFR 75.57(d)(5)]
- (6) Hourly average NO_x emission rate (for NO_x -diluent monitoring systems only, in units of lb/mmBtu, rounded to the nearest thousandth); [40 CFR 75.57(d)(6)]
- (7) Hourly average NO_x emission rate (for NO_x -diluent monitoring systems only, in units of lb/mmBtu, rounded to the nearest thousandth), adjusted for bias if bias adjustment factor is required, as provided in 40 CFR 75.24(d). The requirement to report hourly NO_x emission rates to the nearest thousandth shall not affect NO_x compliance determinations under part 76 of this chapter; compliance with each applicable emission limit under part 76 shall be determined to the nearest hundredth pound per million Btu; [40 CFR 75.57(d)(7)]
- (8) Percent monitoring system data availability (recorded to the nearest tenth of a percent), for the NO_x -diluent or NO_x concentration monitoring system, and, if applicable, for the moisture monitoring system, calculated pursuant to 40 CFR 75.32; [40 CFR 75.57(d)(8)]
- (9) Method of determination for hourly average NO_x emission rate or NO_x concentration and (if applicable) for the hourly average moisture percentage, using Codes 1–55 in Table 4a of 40 CFR 75.57; and [40 CFR 75.57(d)(9)]
- (10) Identification codes for emissions formulas used to derive hourly average NO_x emission rate and total NO_x mass emissions, as provided in 40 CFR 75.53, and (if applicable) the F-factor used to convert NO_x concentrations into emission rates. [40 CFR 75.57(d)(10)]

- v. A CEMS for measuring either oxygen (O₂) or carbon dioxide (CO₂) in the flue gases shall be installed, calibrated, maintained, and operated by the owner or operator. [Regulation 6.02, section 6.1.3] (NO_x RACT Plan)
- vi. The owner or operator shall monitor the NO_x emissions, the NO_x allowances, as specified in the applicable NO_x cap and trade program(s) in effect.
- vii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:
- (1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO₂ and NO_x continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in 40 CFR 60.46(d).
 - (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.
 - (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO_x the span value shall be determined using one of the following procedures:
 - (a) Except as provided under paragraph 40 CFR 60.45(c)(3)(ii), SO₂ and NO_x span values shall be determined as follows:

| Fossil fuel | In parts per million | |
|-------------|--------------------------------|--------------------------------|
| | Span value for SO ₂ | Span value for NO _x |
| Gas | Not Applicable | 500. |
| Liquid | 1,000 | 500. |
| Solid | 1,500 | 1,000. |
 - (b) As an alternative to meeting the requirements of paragraph 40 CFR 60.45(c)(3)(i), the owner or operator of an affected facility may elect to use the SO₂ and NO_x span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.
- viii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: The conversion procedures in 40 CFR 60.45(e) and (f) shall be used to convert the continuous monitoring data into units of the applicable standards.

- (1) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

- (a) When a CEMS for measuring O₂ is selected, the measurement of the pollutant concentration and O₂ concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF \left(\frac{20.9}{(20.9 - \%O_2)} \right)$$

Where E, C, F, and %O₂ are determined under paragraph (f) of this section.

- (b) When a CEMS for measuring CO₂ is selected, the measurement of the pollutant concentration and CO₂ concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where E, C, F_c and %CO₂ are determined under paragraph (f) of this section.

- (2) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

- (a) E = pollutant emissions, ng/J (lb/MMBtu).
- (b) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^{-4} M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO₂ and 46.01 for NO_x.
- (c) %O₂, %CO₂ = O₂ or CO₂ volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.
- (d) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO₂ generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

- (i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2,723 \times 10^{-7}$ dscm/J (10,140 dscf/MMBtu) and $F_c = 0.532 \times 10^{-7}$ scm CO₂/J (1,980 scf CO₂/MMBtu).
 - (ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2.637 \times 10^{-7}$ dscm/J (9,820 dscf/MMBtu) and $F_c = 0.486 \times 10^{-7}$ scm CO₂/J (1,810 scf CO₂/MMBtu).
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/MMBtu) and $F_c = 0.384 \times 10^{-7}$ scm CO₂/J (1,430 scf CO₂/MMBtu).
 - (iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO₂/J (1,040 scf CO₂/MMBtu) for natural gas, 0.322×10^{-7} scm CO₂/J (1,200 scf CO₂/MMBtu) for propane, and 0.338×10^{-7} scm CO₂/J (1,260 scf CO₂/MMBtu) for butane.
 - (v) For bark $F = 2.589 \times 10^{-7}$ dscm/J (9,640 dscf/MMBtu) and $F_c = 0.500 \times 10^{-7}$ scm CO₂/J (1,840 scf CO₂/MMBtu). For wood residue other than bark $F = 2.492 \times 10^{-7}$ dscm/J (9,280 dscf/MMBtu) and $F_c = 0.494 \times 10^{-7}$ scm CO₂/J (1,860 scf CO₂/MMBtu).
 - (vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2.659 \times 10^{-7}$ dscm/J (9,900 dscf/MMBtu) and $F_c = 0.516 \times 10^{-7}$ scm CO₂/J (1,920 scf CO₂/MMBtu).
- (e) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂/J, or scf CO₂/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^6 \frac{|227.2 (\%H) + 95.5 (\%C) + 35.6 (\%S) + 8.7 (\%N) - 28.7 (\%O)|}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-5} (\%C)}{GCV \text{ (SI units)}}$$

$$F = 10^6 \frac{|3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)|}{GCV \text{ (English units)}}$$

$$F_c = \frac{20.0 (\%C)}{GCV \text{ (SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV \text{ (English units)}}$$

- (i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O₂ (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see 40 CFR 60.17.)
- (ii) GVC is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see 40 CFR 60.17.)
- (iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.
- (f) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

Where:

X_i = Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F_i or (F_c)_i = Applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

d. **Opacity**

- i. If certified COMS is used to demonstrate compliance with opacity standards, the owner or operator shall record on an hourly basis all opacity from COMS.¹⁶
- ii. If VE/Method 9 is used to demonstrate compliance with opacity standards, in order for the owner or operator to use its VE observations to satisfy the opacity monitoring requirement, the following conditions must be met:¹⁶ (EPA Letter, 2007)
 - (1) On a weekly basis, the owner or operator shall attempt to perform VE observations in accordance with procedures in EPA Method 9.
 - (2) On the weeks when it is possible to collect unit-specific VE data, at least one hour of Method 9 data shall be collected for each unit.
 - (3) Records of the Method 9 readings shall be submitted with the quarterly excess emission reports for PM emissions.
- iii. The owner or operator shall keep a record of every Method 9 test performed or the reason why it could not be performed that day.
- iv. For coal silos (E2):
 - (1) The owner or operator shall, weekly, conduct a one-minute visible emissions survey, during normal operation, of the PM Emission Points (stacks). For Emission Points without observed visible emissions during twelve consecutive operating weeks, the owner or operator may elect to conduct a monthly one-minute visible emission survey, during normal operation.
 - (2) At Emission Points where visible emissions are observed, the owner or operator shall initiate corrective action within eight hours of the initial observation. If the visible emissions persist, the owner or operator shall perform or cause to be performed a Method 9 for stack emissions within 24 hours of the initial observation. If the opacity standard is exceeded, the owner or operator shall report the exceedance to the District, according to Regulation 1.07, and take all practicable steps to eliminate the exceedance.
 - (3) The owner or operator shall, monthly, maintain records of the results of all visible emissions surveys and tests. Records of the results of any visible emissions survey shall include the date of the survey, the name of the person conducting the survey, whether or not visible

¹⁶ According to LG&E's request, PM CEMS have been installed, calibrated, maintained, and operated for Unit 1. LG&E requested permission to remove COMS for Unit 3 and 4 under provisions in 40 CFR 60.13(i)(1), "Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases." LG&E's proposal for Unit 3 and 4 was accepted in a letter from EPA dated Feb. 28, 2007. The District accordingly approved LG&E's request for removing COMS for Unit 1 and 2 providing PM CEMS are appropriately installed for these units.

emissions were observed, and what if any corrective action was performed. If an emission point is not being operated during a given month, then no visible emission survey needs to be performed and a negative declaration shall be entered in the record.

e. **PM**

i. The company shall follow one of the two options below to demonstrate compliance with PM standards:

- (1) Option 1: the owner or operator shall install, maintain, calibrate, and operate a PM CEMS for each steam generating unit.^{17, 18} [Regulation 2.16, section 4.1.1] [40 CFR 64]
 - (a) The use of PM CEMS as the measurement technique must be appropriate for the stack conditions.
 - (b) The PM CEMS must be installed, operated and maintained in accordance with the manufacturer's recommendations.
 - (c) The PM CEMS must be certified in accordance with Performance Specification 11, Specifications and Test Procedures for Particulate Matter Continuous Emission Monitoring Systems at Stationary Sources, found in 40 CFR 60 Appendix B.
 - (d) A quality assurance/quality control program must be implemented in accordance with procedures in 40 CFR 60 Appendix F, Procedure 2 (Quality Assurance Requirements for Particulate Matter Continuous Emission Monitoring Systems at Stationary Sources).
 - (e) Compliance with the particulate matter emission limit will be based upon 3-hour rolling average periods during source operation.
 - (f) Quarterly excess emission reports must be submitted, and PM excess emissions shall be reported based upon 3-hour rolling averages during source operation.

¹⁷ According to LG&E's request, PM CEMS have been installed, calibrated, maintained, and operated for Unit 1. LG&E requested permission to remove COMS for Unit 3 and 4 under provisions in 40 CFR 60.13(i)(1), "Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases." LG&E's proposal for Unit 3 and 4 was accepted in a letter from EPA dated Feb. 28, 2007. The District accordingly approved LG&E's request for removing COMS for Unit 1 and 2 providing PM CEMS are appropriately installed for these units.

¹⁸ The coal-fired boilers are subject to 40 CFR Part 64 - Compliance Assurance Monitoring (CAM) for Major Stationary Source since SO₂, PM, and NO_x emissions from each of the boilers may be greater than the major source threshold and control devices are required to achieve compliance with standards. On 3/20/2020, LG&E submitted a revised CAM Plan in which SO₂ and NO_x CEMS are used for compliance demonstration. PM CEMS is used to demonstrate compliance or provide an indication of continuous PM control.

- (2) Option 2: the owner or operator shall conduct an annual EPA Reference Method 5 performance test following the testing requirements in Attachment B.
- ii. If certified PM CEMS (Option 1) is used to demonstrate compliance with PM standards, the owner or operator shall record on an hourly basis all PM emission data, in lb/MMBtu, from PM CEMS.¹⁹ [40 CFR 64]
- iii. If annual PM testing (Option 2) is used to demonstrate compliance with PM standards, the owner or operator shall use PM CEMS as a performance indicator of continuous normal operation of the PM control devices and do the following:¹⁹ [40 CFR 64]
- (1) The owner or operator shall monitor and record all PM emission data from PM CEMS, which is used as the indicator of normal operation of the PM control devices.
 - (2) The owner or operator shall maintain daily records of any periods of time where the process was operating and the PM control devices were not operating or a declaration that the PM control devices operated at all times that day when the process was operating.
 - (3) If there is any time that the PM control devices are bypassed or not in operation when the process is operating, then the owner or operator shall keep a record of the following for each bypass event:
 - (a) Date;
 - (b) Start time and stop time;
 - (c) Identification of the control devices and process equipment;
 - (d) PM emissions during the bypass in lb/hr;
 - (e) Summary of the cause or reason for each bypass event;
 - (f) Corrective action taken to minimize the extent or duration of the bypass event; and
 - (g) Measures implemented to prevent reoccurrence of the situation that resulted in the bypass event.
- f. **SO₂**
- i. The owner or operator shall maintain hourly records of SO₂ emissions as specified in Regulation 6.02, section 6.1.2.

¹⁹ The coal-fired boilers are subject to 40 CFR Part 64 - Compliance Assurance Monitoring (CAM) for Major Stationary Source since SO₂, PM, and NO_x emissions from each of the boilers may be greater than the major source threshold and control devices are required to achieve compliance with standards. On 3/20/2020, LG&E submitted a revised CAM Plan in which SO₂ and NO_x CEMS are used for compliance demonstration. PM CEMS is used to demonstrate compliance or provide an indication of continuous PM control.

- ii. The owner or operator shall record on an hourly basis all SO₂ emission data specified in 40 CFR 75.57(c): [40 CFR 64]
- (1) For SO₂ concentration during unit operation, as measured and reported from each certified primary monitor, certified back-up monitor, or other approved method of emissions determination:
[40 CFR 75.57(c)(1)]
- (a) Component-system identification code, as provided in 40 CFR 75.53; [40 CFR 75.57(c)(1)(i)]
 - (b) Date and hour; [40 CFR 75.57(c)(1)(ii)]
 - (c) Hourly average SO₂ concentration (ppm, rounded to the nearest tenth); [40 CFR 75.57(c)(1)(iii)]
 - (d) Hourly average SO₂ concentration (ppm, rounded to the nearest tenth), adjusted for bias if bias adjustment factor is required, as provided in 40 CFR 75.24(d);
[40 CFR 75.57(c)(1)(iv)]
 - (e) Percent monitor data availability (recorded to the nearest tenth of a percent), calculated pursuant to 40 CFR 75.32; and
[40 CFR 75.57(c)(1)(v)]
 - (f) Method of determination for hourly average SO₂ concentration using Codes 1–55 in Table 4a of 40 CFR 75.57. [40 CFR 75.57(c)(1)(vi)]
- (2) For flow rate during unit operation, as measured and reported from each certified primary monitor, certified back-up monitor, or other approved method of emissions determination:
[40 CFR 75.57(c)(2)]
- (a) Component-system identification code, as provided in 40 CFR 75.53; [40 CFR 75.57(c)(2)(i)]
 - (b) Date and hour; [40 CFR 75.57(c)(2)(ii)]
 - (c) Hourly average volumetric flow rate (in scfh, rounded to the nearest thousand); [40 CFR 75.57(c)(2)(iii)]
 - (d) Hourly average volumetric flow rate (in scfh, rounded to the nearest thousand), adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d);
[40 CFR 75.57(c)(2)(iv)]
 - (e) Percent monitor data availability (recorded to the nearest tenth of a percent) for the flow monitor, calculated pursuant to 40 CFR 75.32; and [40 CFR 75.57(c)(2)(v)]
 - (f) Method of determination for hourly average flow rate using Codes 1–55 in Table 4a of 40 CFR 75.57.
[40 CFR 75.57(c)(2)(vi)]

- (3) For SO₂ mass emission rate during unit operation, as measured and reported from the certified primary monitoring system(s), certified redundant or non-redundant back-up monitoring system(s), or other approved method(s) of emissions determination:
[40 CFR 75.57(c)(4)]
- (a) Date and hour; [40 CFR 75.57(c)(4)(i)]
 - (b) Hourly SO₂ mass emission rate (lb/hr, rounded to the nearest tenth); [40 CFR 75.57(c)(4)(ii)]
 - (c) Hourly SO₂ mass emission rate (lb/hr, rounded to the nearest tenth), adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d); and [40 CFR 75.57(c)(4)(iii)]
 - (d) Identification code for emissions formula used to derive hourly SO₂ mass emission rate from SO₂ concentration and flow and (if applicable) moisture data in paragraphs (c)(1), (c)(2), and (c)(3) of 40 CFR 75.57, as provided in 40 CFR 75.53. [40 CFR 75.57(c)(4)(iv)]
- iii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:
- (1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO₂ and NO_x continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in 40 CFR 60.46(d).
 - (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.
 - (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO_x the span value shall be determined using one of the following procedures:
 - (a) Except as provided under paragraph 40 CFR 60.45(c)(3)(ii), SO₂ and NO_x span values shall be determined as follows:

| Fossil fuel | In parts per million | |
|-------------|--------------------------------|--------------------------------|
| | Span value for SO ₂ | Span value for NO _x |
| Gas | Not Applicable | 500. |
| Liquid | 1,000 | 500. |
| Solid | 1,500 | 1,000. |

- (b) As an alternative to meeting the requirements of paragraph 40 CFR 60.45(c)(3)(i), the owner or operator of an affected facility may elect to use the SO₂ and NO_x span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.
- iv. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: The conversion procedures in 40 CFR 60.45(e) and (f) shall be used to convert the continuous monitoring data into units of the applicable standards.

- (1) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

- (a) When a CEMS for measuring O₂ is selected, the measurement of the pollutant concentration and O₂ concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF \left(\frac{20.9}{(20.9 - \%O_2)} \right)$$

Where E, C, F, and %O₂ are determined under paragraph (f) of this section.

- (b) When a CEMS for measuring CO₂ is selected, the measurement of the pollutant concentration and CO₂ concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where E, C, F_c and %CO₂ are determined under paragraph (f) of this section.

- (2) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

- (a) E = pollutant emissions, ng/J (lb/MMBtu).
- (b) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^{-4} M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO₂ and 46.01 for NO_x.
- (c) %O₂, %CO₂= O₂ or CO₂ volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.
- (d) F, F_c= a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO₂ generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:
- (i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), F = $2,723 \times 10^{-17}$ dscm/J (10,140 dscf/MMBtu) and F_c= 0.532×10^{-17} scm CO₂/J (1,980 scf CO₂/MMBtu).
 - (ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), F = 2.637×10^{-7} dscm/J (9,820 dscf/MMBtu) and F_c= 0.486×10^{-7} scm CO₂/J (1,810 scf CO₂/MMBtu).
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, F = 2.476×10^{-7} dscm/J (9,220 dscf/MMBtu) and F_c= 0.384×10^{-7} scm CO₂/J (1,430 scf CO₂/MMBtu).
 - (iv) For gaseous fossil fuels, F = 2.347×10^{-7} dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, F_c= 0.279×10^{-7} scm CO₂/J (1,040 scf CO₂/MMBtu) for natural gas, 0.322×10^{-7} scm CO₂/J (1,200 scf CO₂/MMBtu) for propane, and 0.338×10^{-7} scm CO₂/J (1,260 scf CO₂/MMBtu) for butane.
 - (v) For bark F = 2.589×10^{-7} dscm/J (9,640 dscf/MMBtu) and F_c= 0.500×10^{-7} scm CO₂/J (1,840 scf CO₂/MMBtu). For wood residue other than bark F = 2.492×10^{-7} dscm/J (9,280 dscf/MMBtu) and F_c= 0.494×10^{-7} scm CO₂/J (1,860 scf CO₂/MMBtu).
 - (vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17),

$F = 2.659 \times 10^{-7}$ dscm/J (9,900 dscf/MMBtu) and
 $F_c = 0.516 \times 10^{-7}$ scm CO₂/J (1,920 scf CO₂/MMBtu).

- (e) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂/J, or scf CO₂/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^6 \frac{[227.2 (\%H) + 95.5 (\%C) + 35.6 (\%S) + 8.7 (\%N) - 28.7 (\%O)]}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-3} (\%C)}{GCV \text{ (SI units)}}$$

$$F = 10^6 \frac{[3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)]}{GCV \text{ (English units)}}$$

$$F_c = \frac{20.0 (\%C)}{GCV \text{ (SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV \text{ (English units)}}$$

- (i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O₂ (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see 40 CFR 60.17.)
- (ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see 40 CFR 60.17.)
- (iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.

- (f) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

Where:

X_i= Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F_i or (F_c)_i= Applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

g. **TAC**

- i. The owner or operator shall, monthly, calculate and record TAC emissions for this unit in order to demonstrate compliance with the TAC emission standards.
- ii. See Plantwide Requirements.

S3. Reporting

[Regulation 2.16, Section 4.1.1]

The owner or operator shall report the following information, as required by General Condition G14:

a. **BART** [40 CFR 52, Subpart S]

- i. The owner or operator shall report any periods of time where the process was operating and both PJFF baghouse and ESP were not operating.

b. **HAP** [40 CFR 63 Subpart UUUUU]

- i. The owner or operator shall comply with reporting requirements in 40 CFR 63 Subpart UUUUU. (See Attachment A)
- ii. Report normal pH range of reactant material in the FGD and normal range of any other parameters verified as having a direct effect on Hg emission within 30 days of establishing the normal range.
- iii. The owner or operator shall identify all periods of the activated carbon injection rate are less than the minimum injection rate, or the pH of the reactant material in the FGD are out of normal range, or anytime other verified parameters are outside of their normal range, and any corrective action taken for each exceedance.

c. **NO_x**

- i. The owner or operator shall identify all periods of exceeding a NO_x emission standard during a quarterly reporting period. The quarterly compliance report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;
 - (4) If known, the cause of the deviation;
 - (5) A description of all corrective actions taken to abate the deviation; and
 - (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.

- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known. The averaging period used for data reporting should correspond to the averaging period specified in the emission test method used to determine compliance with an emission standard for the pollutant/source category in question. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. The required report shall include:
[Regulation 6.02, section 16.1]
 - (1) For gaseous measurements, the summary shall consist of hourly averages in the units of the applicable standard. The hourly averages shall not appear in the written summary, but shall be made available electronically.²⁰ [Regulation 6.02, section 16.3]
 - (2) The data and time identifying each period during which the continuous monitoring system was inoperative, except for zero and span checks, and the nature of system repairs or adjustment shall be reported. Proof of continuous monitoring system performance whenever system repairs or adjustments have been made is required. [Regulation 6.02, section 16.4]
 - (3) When no excess emissions have occurred and the continuous monitoring systems have been inoperative, repaired, or adjusted, such information shall be included in the report. [Regulation 6.02, section 16.5]
 - (4) Owners or operators of affected facilities shall maintain a file of all information reported in the quarterly summaries, and all other data collected either by the continuous monitoring system or as necessary to convert monitoring data to the units of the applicable standard for a minimum of two years from the date of collection of such data or

²⁰ The hourly averages are only required to be made available in electronic summary, not in written summary.

submission of such summaries.
[Regulation 6.02, section 16.6]

- iii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, Monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator²¹, and Retired Unit Petitions shall be submitted as specified in Subpart G - reporting requirements. (See Attachment E)
- iv. The owner or operator shall comply with the reporting requirements for the Title IV NO_x Budget Emission Limitation, 0.40 lb/MMBtu, as specified in 40 CFR Part 76.
- v. Excess emissions for affected facilities using a CEMS for measuring NO_x are defined as: [Regulation 2.16, section 4.1.9.3]
 - (1) Any annual average period during which the average emissions (arithmetic average of all one-hour period during the 12 month period) of NO_x as measured by a CEMS exceed the applicable standard.
 - (2) Any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of NO_x as measured by a CEMS exceed the applicable standard.

d. Opacity

- i. The owner or operator shall identify all periods of exceeding an opacity standard during a quarterly reporting period. The report shall include the following:
 - (1) Any deviation from the requirement to perform daily (or monthly, if required) visible emission surveys or Method 9 tests and documented reason;
 - (2) Any deviation from the requirement to record the results of each VE survey and Method 9 test performed and documented reason;
 - (3) The number, date, and time of each VE Survey where visible emissions were observed and the results of the Method 9 test performed;
 - (4) Identification of all periods of exceeding an opacity standard;
 - (5) Description of any corrective action taken for each exceedance of the opacity standard; or

²¹ In this permit, Administrator means the District.

- (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator, and Retired Unit Petitions shall be submitted as specified in Subpart G - reporting requirements. (See Attachment E)
[Regulation 6.47, section 3.4 and 3.5 referencing 40 CFR Parts 75 and 76]
- iii. For coal silos (E2):
The owner or operator shall identify all periods of exceeding an opacity standard during a quarterly reporting period. The report shall include the following:
- (1) Emission Unit ID number, Stack ID number, and/or Emission point ID number;
 - (2) The beginning and ending date of the reporting period;
 - (3) The date, time and results of each exceedance of the opacity standard;
 - (4) Description of any corrective action taken for each exceedance.
- e. **PM**
- i. The owner or operator shall identify all periods of exceeding a PM emission standard during a quarterly reporting period. The report shall include the following:
- (1) Emission Unit ID number and emission point ID number;
 - (2) The date and duration (including the start and stop time) during which a deviation occurred;
 - (3) The magnitude of excess emissions;
 - (4) Description of the deviation and summary information on the cause or reason for excess emissions;
 - (5) Corrective action taken to minimize the extent and duration of each excess emissions event;
 - (6) Measures implemented to prevent reoccurrence of the situation that resulted in excess PM emissions; or
 - (7) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known.

f. SO₂

- i. The owner or operator shall identify all periods of exceeding a SO₂ emission standard during a quarterly reporting period. The report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;
 - (4) If known, the cause of the deviation;
 - (5) A description of all corrective actions taken to abate the deviation; and
 - (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known.
- iii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator, and Retired Unit Petitions shall be submitted as specified in Subpart G - Reporting Requirements. (See Attachment E)
- iv. Excess emissions for affected facilities using a CEMS for measuring SO₂ are defined as: [Regulation 2.16, section 4.1.9.3]
 - (1) Any 3-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO₂ as measured by a CEMS exceed the applicable standard; or
 - (2) Any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO₂ as measured by a CEMS exceed the applicable standard.

g. TAC

- i. The owner or operator shall identify all periods of exceeding a TAC emission standard during a quarterly reporting period. The report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;

- (4) If known, the cause of the deviation;
- (5) A description of all corrective actions taken to abate the deviation; and
- (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.

ii. See Plantwide Requirements.

S4. Testing

[Regulation 2.16, section 4.3.1]

a. Control efficiency determination

- i. The owner or operator shall conduct performance test for the new EGU control device C26 and C27, according to the testing requirements in Attachment B, C and H.^{22, 23} [Regulation 2.16, section 4.1.9.1]
- ii. The owner or operator shall conduct a subsequent performance test to determine the control efficiency for sulfuric acid (H₂SO₄) by June 3, 2025, according to the testing requirements in Attachment B and C.²⁴ [Regulation 2.16, section 4.1.9.1]

U1 Comments

1. Boiler (E1) has TAC emission standards since its EA Demonstration was based on controlled PTE. If the controlled PTE for the TAC is less than de minimis level, use De Minimis as limit. If the controlled PTE for the TAC is greater than de minimis level, modeling results were used to calculate risk value to compare to the EA Goals. In this case, controlled PTE is used as limit. TAC emissions for the coal silos (E2) are de minimis according to Regulation 5.21, section 2.1. The TAC emission limits determined by de minimis values shall be updated each time when the District revises the BAC/de minimis values for these TACs. The current de minimis values per TAC list revised on 11/9/2017 are as the following:

| TAC Name | CAS # | De minimis values | | |
|----------|---------|-------------------|-----------------|---------|
| | | (lb/hr) | (lb/Ave Period) | (lb/yr) |
| Benzene | 71-43-2 | 0.24 | | 216 |

²² Per an EPA rule change (“Restructuring of the Stationary Source Audit Program.” Federal Register 75:176 (September 13, 2010) pp 55636-55657), if an audit sample is required by the test method, sources became responsible for obtaining the audit samples directly from accredited audit sample suppliers, not the regulatory agencies.

²³ This unit was modified under construction permit 34595-12-C. According to permit 34595-12-C, the source is required to conduct stack tests to obtain actual emission factors and control efficiencies. Control efficiencies stack test for C26 and C27 were conducted on June 4-8, 2015.

²⁴ Compliance with STAR Program for sulfuric acid was based on controlled sulfuric acid emissions. The source shall use the updated control efficiency to calculate actual sulfuric acid emissions.

Plant ID: 0127

| TAC Name | CAS # | De minimis values | | |
|----------------------------|-----------|-------------------|-----------------|---------|
| | | (lb/hr) | (lb/Ave Period) | (lb/yr) |
| Bromoform | 75-25-2 | 0.49 | | 437 |
| Chloroform | 67-66-3 | 0.023 | | 20.64 |
| Methylene chloride | 75-09-2 | 54 | | 48,000 |
| Tetrachloroethylene (Perc) | 127-18-4 | 2.08 | | 1,848 |
| Toluene | 108-88-3 | 2700 | 2,400,000 lb/yr | |
| Xylene | 1330-20-7 | 54 | 48,000 lb/yr | |
| Hydrochloric acid | 7647-01-0 | 10.8 | 9,600 lb/yr | |

Emission Unit U2: Electric Utility Steam Generating Unit (EGU) – Unit 2**Applicable Regulations**

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|---|--|
| Regulation | Title | Applicable Sections |
| 6.02 | Emission Monitoring for Existing Sources | 1, 2, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18 |
| 6.07 | Standards of Performance for Existing Indirect Heat Exchangers | 1, 2, 3, 4 |
| 6.09 | Standards of Performance for Existing Process Operations | 1, 2, 3, 5 |
| 6.42 | Reasonably Available Control Technology Requirements for Major Volatile Organic Compound- and Nitrogen Oxides-Emitting Facilities | 1, 2, 3, 4, 5 |
| 6.47 | Federal Acid Rain Program for Existing Sources Incorporated by Reference | 1, 2, 3, 4, 5 |
| 40 CFR 64 | Compliance Assurance Monitoring for Major Stationary Sources | 64.1 through 64.10 |
| 40 CFR 72 | Permits Regulation | Subparts A, B, C, D, E, F, G, H, I |
| 40 CFR 73 | Sulfur Dioxide Allowance System | Subparts A, B, C, D, E, F, G |
| 40 CFR 75 | Continuous Emission Monitoring | Subparts A, B, C, D, E, F, G |
| 40 CFR 76 | Acid Rain Nitrogen Oxides Emission Reduction Program | 76.1, 76.2, 76.3, 76.4, 76.5, 76.7, 76.8, 76.9, 76.11, 76.13, 76.14, 76.15, Appendix A, Appendix B |
| 40 CFR 77 | Excess Emissions | 77.1, 77.2, 77.3, 77.4, 77.5, 77.6 |
| 40 CFR 78 | Appeals Procedures for Acid Rain Program | 78.1, 78.2, 78.3, 78.4, 78.5, 78.6, 78.8, 78.9, 78.10, 78.11, 78.13, 78.14, 78.15, 78.16, 78.17, 78.18, 78.19, 78.20 |
| 40 CFR 63 Subpart UUUUU | National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units (EGU MACT) | 63.9980 through 63.10042 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|--|--------------------|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.02 | Adoption of National Emission Standards for Hazardous Air Pollutants | 1, 3.95 and 4 |
| 5.14 | Hazardous Air Pollutants and Source Categories | 1, 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|--|---------------------|--|-------------------|-------------------|
| E3 | One (1) tangentially fired boiler, rated capacity 3,085 MMBtu/hr, make Combustion Engineering, using pulverized coal as a primary fuel and natural gas as secondary fuel. | 1970 | STAR, 5.02, 5.14, 6.02, 6.07, 6.42, 6.47, 40CFR64, 40CFR72-73, 40CFR75-78, 40CFR63 UUUUU | C4, C27, C28 | S33 |
| E4 | Four (4) coal silos, make American Air Filter, controlled by a centrifugal dust collector and equipped with four (4) coal mills, make Combustion Engineering Raymond Bowl Mills. | 1970 | STAR, 6.09 | C6 | S6 |

Control Devices

| Control ID | Description | Control Efficiency | Performance Indicator |
|-------------------|--|---------------------------|------------------------------|
| C4 | One (1) custom-built electrostatic precipitator (ESP) for PM control, make Western Precipitator Division | N/A | N/A ²⁵ |

²⁵ This unit is equipped with CEMS for NOx, SO2, and PM. According to the District's letter dated November 1, 2005, parametric monitoring of the ESP, FGD, and PJFF for this unit is removed as such monitoring would no longer be required for demonstration of compliance. On July 22, 2016, LG&E reported the normal pressure drop range for U2 PJFF, 2 – 6 inches of water, established during 90 consecutive operating days.

| Control ID | Description | Control Efficiency | Performance Indicator |
|------------|---|---|---|
| C6 | One (1) centrifugal dust collector, make American Air Filter | 90% | N/A ²⁶ |
| C27 | One (1) combined Flue Gas desulfurization (FGD) unit for SO ₂ control using limestone scrubbing liquor, make Babcock Power Environmental | N/A | N/A ²⁵ |
| C28 | One (1) HAP particulate matter control system, consists of: one (1) powdered activated carbon (PAC) injection system; one (1) dry sorbent injection system; liquid additive system(s); and one (1) pulse-jet fabric filter (PJFF) baghouse used for collecting PM from the boiler and PAC and dry sorbent injection system. PJFF make Clyde Bergemann Power Group, model Structural Pulse Jet | H ₂ SO ₄ : ²⁷ 99.8% Hg: 85.5% PM: 99.5% | PM Control: PM emission data from PM CEMS (if PM CEMS is not used to demonstrate compliance) Hg control: (1) Minimum PAC injection rate; ²⁸ (2) pH of reactant in FGD, 4.8-6.4; (3) Hg emission data from Sorbent Traps |

²⁶ For the coal silos (E4), the owner or operator has shown, by worst-case calculations without allowance for a control device, that the hourly uncontrolled PM emission standard cannot be exceeded; therefore, no additional monitoring, recordkeeping, or reporting is required to demonstrate compliance with the applicable PM standards specified in Regulation 6.09 is required for this emission point.

²⁷ Control efficiencies of C28 are based on stack test conducted on June 4-8, 2015.

²⁸ In a letter dated October 4, 2016, LG&E demonstrated that in certain circumstance EGUs at this plant can meet the MACT mercury standard at zero PAC injection rate. Therefore, the source is allowed to use flexible mercury control measures, including PAC injection or liquid additive system, to achieve compliance with MACT mercury standard.

U2 Specific Conditions

S1. Standards²⁹

[Regulation 2.16, Section 4.1.1]

a. BART [40 CFR 52, Subpart S]

- i. The owner or operator shall continue to utilize PJFF baghouse and/or existing ESP to control PM emissions for this unit.³⁰
[40 CFR 52.920(e) refer to Kentucky Regional Haze SIP]

b. HAP [40 CFR 63 Subpart UUUUU]

- i. The owner or operator shall comply with emission standards required in 40 CFR 63 Subpart UUUUU (See Attachment A).

c. NO_x

- i. The owner or operator shall not allow the average NO_x emissions to exceed the alternate contemporaneous emission limitation of 0.40 lb/MMBtu of heat input on an annual average basis, as specified in Acid Rain Permit No.176-97-AR (R5) which is attached and considered part of the Title V Operating Permit. (See Acid Rain Permit Attachment)
[Regulation 6.47, section 3.5 referencing 40 CFR Part 76]
- ii. The owner or operator shall not exceed the NO_x RACT emissions standard of 0.47 lb/MMBtu of heat input based on a rolling 30-day average. (See NO_x RACT, Attachment D) [Regulation 6.42, section 4.3]
- iii. The owner or operator shall install, maintain, calibrate and operate a continuous emission monitoring system (CEMS) for the measurement or calculation of nitrogen oxides in the flue gas.
[Regulation 6.02, section 6.1.3] [NO_x RACT Plan] [Regulation 6.47, section 3.4 referencing 40 CFR 75.10(a)(2)]

d. Opacity

- i. The owner or operator shall not cause the emission into the open air of particulate matter from any indirect heat exchanger which is greater than 20% opacity, except emissions into the open air of particulate matter from any indirect heat exchanger during building a new fire, cleaning the fire box, or blowing soot for a period or periods aggregating not more than ten

²⁹ The emission standards, monitoring, record keeping, and reporting requirements only apply to the boiler E3 (not the coal silos E4) if not indicated.

³⁰ On March 30, 2012, EPA finalized a limited approval and a limited disapproval of the Kentucky state implementation plan submitted on June 25, 2008 and May 28, 2010. According to 40 CFR 52.920(e), the owner or operator shall meet BART requirements summarized in Table 7.5.3-2 of the Commonwealth's May 28, 2010 submittal.

minutes in any 60 minutes which are less than 40% opacity.
[Regulation 6.07, section 3.2 and 3.3]

- ii. The company shall follow one of the two options in the table under Specific Condition for PM to demonstrate compliance with opacity standards.
- iii. For coal silos (E4), the owner or operator shall not allow visible emissions to equal or exceed 20% opacity. [Regulation 6.09, section 3.1]

e. **PM**

- i. The owner or operator shall not exceed an allowable particulate emission rate of 0.11 lbs/MMBtu heat input based on a 3-hour rolling average. [Regulation 6.07, section 3.1]
- ii. At all time, including periods of startup, shutdown, and malfunction, the owner or operator shall, to the extent practicable, maintain and operate boiler E3 including associated PM control equipment (PJFF) in a manner consistent with good air pollution control practice for minimizing emissions. Following commissioning of the PJFF baghouses, the owner or operator may elect to operate, turn down, or turn off the ESP to ensure the efficient operation of the PJFF baghouse.³¹
[Regulation 1.05, section 5]
- iii. The company shall follow one of the two options below to demonstrate compliance with PM standards:

| Compliance Options | PM | Opacity | Control Device Performance indication |
|--------------------|-------------------|--------------------------------|---------------------------------------|
| Option 1 | Certified PM CEMS | VE/Method 9, or Certified COMS | N/A |
| Option 2 | Annual testing | Certified COMS | PM CEMS |

- iv. For coal silos (E4), the owner or operator shall not exceed an allowable particulate emission rate of 82.95 lbs/hr from four coal silos combined based on actual operating hours in a calendar day.³²
[Regulation 6.09, section 3.2]

³¹ The PM emissions cannot meet the standards uncontrolled. The owner or operator is required to operate the control devices to meet the applicable limits for PM.

³² For the coal silos (E2), the owner or operator has shown, by worst-case calculations without allowance for a control device, that the hourly uncontrolled PM emission standard cannot be exceeded; therefore, no additional monitoring, recordkeeping, or reporting is required to demonstrate compliance with the applicable PM standards specified in Regulation 6.09 is required for this emission point.

f. **SO₂**

- i. The owner or operator shall not exceed 1.2 lb/MMBtu per hour heat input based on a 3-hour rolling average. [Regulation 6.07, section 4.1]
- ii. The owner or operator shall comply with the SO₂ emission allowances specified in Acid Rain Permit No.176-97-AR (R5). (See Acid Rain Permit Attachment) [Regulation 6.47, section 3.2 referencing 40 CFR Part 73]
- iii. At all time, including periods of startup, shutdown, and malfunction, the owner or operator shall, to the extent practicable, maintain and operate boiler E3 including associated SO₂ control equipment (FGD) in a manner consistent with good air pollution control practice for minimizing emissions.³³ [Regulation 1.05, section 5]
- iv. The owner or operator shall install, maintain, calibrate and operate a continuous emission monitoring system (CEMS) for the measurement of sulfur dioxide in the flue gas.
[Regulation 6.02, section 6.1.2] [Regulation 6.47, section 3.4 referencing 40 CFR 75.10(a)(1)]

g. **TAC**

- i. The owner or operator shall not allow TAC emissions from boiler E3 to exceed the TAC emission standards determined based upon the EA Demonstration provided to the District.³⁴ (See Comment 1)
[Regulation 5.21, section 4.2 and section 4.3]

| TAC Name | CAS # | TAC Limits Determination | |
|-------------------|------------|--------------------------|-----------------|
| | | (lbs/yr) | Basis of Limits |
| Naphthalene | 91-20-3 | 16.6 | Controlled PTE |
| Formaldehyde | 50-00-0 | 70.3 | Controlled PTE |
| Hydrogen fluoride | 7664-39-3 | 13,385 | Controlled PTE |
| Arsenic compounds | 7440-38-2 | 266 | Controlled PTE |
| Cadmium compounds | 7440-43-9 | 42.1 | Controlled PTE |
| Chromium VI | 7440-47-3 | 94.5 | Controlled PTE |
| Chromium III | 16065-83-1 | 216 | Controlled PTE |
| Cobalt compounds | 7440-48-4 | 56.2 | Controlled PTE |
| Lead compounds | 7439-92-1 | 332 | Controlled PTE |

³³ The SO₂ emissions cannot meet the standards uncontrolled. The owner or operator is required to operate the control devices to meet the applicable limits for SO₂.

³⁴ This table for TAC emission standards has been revised to exclude Category 3 and 4 TACs for existing sources and use “de minimis values”, instead of actual numbers for current de minimis levels, as emission standards.

| TAC Name | CAS # | TAC Limits Determination | |
|----------------------------|-----------|--------------------------------------|-----------------|
| | | (lbs/yr) | Basis of Limits |
| Manganese compounds | 7439-96-5 | 424 | Controlled PTE |
| Nickel compounds | 7440-02-0 | 307 | Controlled PTE |
| Sulfuric acid | 7664-93-9 | 118,679 | Controlled PTE |
| Benzene | 71-43-2 | De minimis values (See Comment 1) | De Minimis |
| Bromoform | 75-25-2 | | De Minimis |
| Chloroform | 67-66-3 | | De Minimis |
| Methylene chloride | 75-09-2 | | De Minimis |
| Tetrachloroethylene (Perc) | 127-18-4 | | De Minimis |
| Toluene | 108-88-3 | | De Minimis |
| Xylene | 1330-20-7 | | De Minimis |
| Hydrochloric acid | 7647-01-0 | | De Minimis |

- ii. See Plantwide Requirements.

h. Unit Operation

- i. The owner or operator shall shut down the existing emission unit U2 prior to the date when the new emission unit U23 becomes operational and begins to emit a particular pollutant. Any replacement unit that requires shakedown becomes operational only after a reasonable shakedown period, not to exceed 180 days. (Regulation 2.05)

S2. Monitoring and Record Keeping

[Regulation 2.16, Section 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the following records for a minimum of five years and make the records readily available to the District upon request.

- a. **BART** [40 CFR 52, Subpart S]
- i. The owner or operator shall maintain daily records of any periods of time where the process was operating and both PJFF baghouse and ESP were not operating or a declaration that the PJFF baghouse and/or ESP were operated at all times that day when the process was operating.
- b. **HAP** [40 CFR 63 Subpart UUUUU]
- i. The owner or operator shall comply with monitoring and record keeping requirements in 40 CFR 63 Subpart UUUUU. (See Attachment A)

- ii. The owner or operator shall establish a site-specific minimum activated carbon injection rate for PAC injection system according to Attachment B.³⁵ The owner or operator shall monitor and record the activated carbon injection rate during each operating day.
 - iii. The owner or operator shall monitor and record all Hg emission data from the Hg sorbent traps, which is used as the indicator of normal operation of the Hg control measures.
 - iv. The owner or operator shall monitor and record the pH of the reactant material in the FGD and any other parameters verified as having a direct effect on Hg emissions during each operating day, which is (are) used as the indicator(s) of normal operation of Hg control measures.³⁶
 - v. The owner or operator shall maintain records of which Hg control devices/measure was being used during each operating day.
- c. **NO_x**
- i. The owner or operator shall demonstrate compliance with NO_x RACT Plan limits by continuous emissions monitors (CEMs) as specified in the NO_x RACT Plan. (See NO_x RACT Attachment) [Regulation 6.42, section 4.3]
 - ii. The owner or operator shall keep a record identifying all deviations from the requirements of the NO_x RACT Plan.
 - iii. The owner or operator shall comply with the NO_x compliance plan requirements specified in the attached Acid Rain Permit, No.176-97-AR (R5). These record keeping requirements shall be determined in accordance with the Title IV Phase II Acid Rain Permit and are specified in 40 CFR Part 75 Subpart F. (See Appendix A to NO_x RACT Plan) [Regulation 6.47, section 3.4 and 3.5 referencing 40 CFR Parts 75 and 76]
 - iv. The owner or operator shall record on an hourly basis all NO_x emission data specified in 40 CFR Part 75, section 75.57(d). For each NO_x emission rate (in lb/mmBtu) measured by a NO_x-diluent monitoring system, or, if applicable, for each NO_x concentration (in ppm) measured by a NO_x concentration monitoring system used to calculate NO_x mass emissions under 40 CFR 75.71(a)(2), record the following data as measured and reported from the certified primary monitor, certified back-up monitor, or other approved method of emissions determination:

³⁵ In a letter dated October 4, 2016, LG&E demonstrated that in certain circumstance EGUs at this plant can meet the MACT mercury standard at zero PAC injection rate. Therefore, the source is allowed to use flexible mercury control measures, including PAC injection or liquid additive system, to achieve compliance with MACT mercury standard.

³⁶ LG&E has established normal pH range per monitoring records during consecutive 180 days. On 10/20/2016, LG&E reported that the normal pH range for this unit is 4.8 – 6.4.

- (1) Component-system identification code, as provided in 40 CFR 75.53 (including identification code for the moisture monitoring system, if applicable); [40 CFR 75.57(d)(1)]
- (2) Date and hour; [40 CFR 75.57(d)(2)]
- (3) Hourly average NO_x concentration (ppm, rounded to the nearest tenth) and hourly average NO_x concentration (ppm, rounded to the nearest tenth) adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d); [40 CFR 75.57(d)(3)]
- (4) Hourly average diluent gas concentration (for NO_x -diluent monitoring systems, only, in units of percent O₂ or percent CO₂, rounded to the nearest tenth); [40 CFR 75.57(d)(4)]
- (5) If applicable, the hourly average moisture content of the stack gas (percent H₂O, rounded to the nearest tenth). If the continuous moisture monitoring system consists of wet- and dry-basis oxygen analyzers, also record both the hourly wet- and dry-basis oxygen readings (in percent O₂, rounded to the nearest tenth); [40 CFR 75.57(d)(5)]
- (6) Hourly average NO_x emission rate (for NO_x -diluent monitoring systems only, in units of lb/mmBtu, rounded to the nearest thousandth); [40 CFR 75.57(d)(6)]
- (7) Hourly average NO_x emission rate (for NO_x -diluent monitoring systems only, in units of lb/mmBtu, rounded to the nearest thousandth), adjusted for bias if bias adjustment factor is required, as provided in 40 CFR 75.24(d). The requirement to report hourly NO_x emission rates to the nearest thousandth shall not affect NO_x compliance determinations under part 76 of this chapter; compliance with each applicable emission limit under part 76 shall be determined to the nearest hundredth pound per million Btu; [40 CFR 75.57(d)(7)]
- (8) Percent monitoring system data availability (recorded to the nearest tenth of a percent), for the NO_x -diluent or NO_x concentration monitoring system, and, if applicable, for the moisture monitoring system, calculated pursuant to 40 CFR 75.32; [40 CFR 75.57(d)(8)]
- (9) Method of determination for hourly average NO_x emission rate or NO_x concentration and (if applicable) for the hourly average moisture percentage, using Codes 1–55 in Table 4a of 40 CFR 75.57; and [40 CFR 75.57(d)(9)]
- (10) Identification codes for emissions formulas used to derive hourly average NO_x emission rate and total NO_x mass emissions, as provided in 40 CFR 75.53, and (if applicable) the F-factor used to convert NO_x concentrations into emission rates. [40 CFR 75.57(d)(10)]

- v. A CEMS for measuring either oxygen (O₂) or carbon dioxide (CO₂) in the flue gases shall be installed, calibrated, maintained, and operated by the owner or operator. [Regulation 6.02, section 6.1.3] (NO_x RACT Plan)
- vi. The owner or operator shall monitor the NO_x emissions, the NO_x allowances, as specified in the applicable NO_x cap and trade program(s) in effect.
- vii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

- (1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO₂ and NO_x continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in 40 CFR 60.46(d).
- (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.
- (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO_x the span value shall be determined using one of the following procedures:
 - (a) Except as provided under paragraph 40 CFR 60.45(c)(3)(ii), SO₂ and NO_x span values shall be determined as follows:

| Fossil fuel | In parts per million | |
|-------------|--------------------------------|--------------------------------|
| | Span value for SO ₂ | Span value for NO _x |
| Gas | Not Applicable | 500. |
| Liquid | 1,000 | 500. |
| Solid | 1,500 | 1,000. |

- (b) As an alternative to meeting the requirements of paragraph 40 CFR 60.45(c)(3)(i), the owner or operator of an affected facility may elect to use the SO₂ and NO_x span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.
- viii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: The conversion procedures in 40 CFR 60.45(e) and (f) shall be used to convert the continuous monitoring data into units of the applicable standards.

- (1) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

- (a) When a CEMS for measuring O₂ is selected, the measurement of the pollutant concentration and O₂ concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF \left(\frac{20.9}{(20.9 - \%O_2)} \right)$$

Where E, C, F, and %O₂ are determined under paragraph (f) of this section.

- (b) When a CEMS for measuring CO₂ is selected, the measurement of the pollutant concentration and CO₂ concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where E, C, F_c and %CO₂ are determined under paragraph (f) of this section.

- (2) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

- (a) E = pollutant emissions, ng/J (lb/MMBtu).
- (b) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO₂ and 46.01 for NO_x.
- (c) %O₂, %CO₂ = O₂ or CO₂ volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.
- (d) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO₂ generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

- (i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2,723 \times 10^{-7}$ dscm/J (10,140 dscf/MMBtu) and $F_c = 0.532 \times 10^{-7}$ scm CO₂/J (1,980 scf CO₂/MMBtu).
 - (ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2.637 \times 10^{-7}$ dscm/J (9,820 dscf/MMBtu) and $F_c = 0.486 \times 10^{-7}$ scm CO₂/J (1,810 scf CO₂/MMBtu).
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/MMBtu) and $F_c = 0.384 \times 10^{-7}$ scm CO₂/J (1,430 scf CO₂/MMBtu).
 - (iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO₂/J (1,040 scf CO₂/MMBtu) for natural gas, 0.322×10^{-7} scm CO₂/J (1,200 scf CO₂/MMBtu) for propane, and 0.338×10^{-7} scm CO₂/J (1,260 scf CO₂/MMBtu) for butane.
 - (v) For bark $F = 2.589 \times 10^{-7}$ dscm/J (9,640 dscf/MMBtu) and $F_c = 0.500 \times 10^{-7}$ scm CO₂/J (1,840 scf CO₂/MMBtu). For wood residue other than bark $F = 2.492 \times 10^{-7}$ dscm/J (9,280 dscf/MMBtu) and $F_c = 0.494 \times 10^{-7}$ scm CO₂/J (1,860 scf CO₂/MMBtu).
 - (vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), $F = 2.659 \times 10^{-7}$ dscm/J (9,900 dscf/MMBtu) and $F_c = 0.516 \times 10^{-7}$ scm CO₂/J (1,920 scf CO₂/MMBtu).
- (e) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂/J, or scf CO₂/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^6 \frac{|227.2 (\%H) + 95.5 (\%C) + 35.6 (\%S) + 8.7 (\%N) - 28.7 (\%O)|}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-5} (\%C)}{GCV \text{ (SI units)}}$$

$$F = 10^6 \frac{|3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)|}{GCV \text{ (English units)}}$$

$$F_c = \frac{20.0 (\%C)}{GCV \text{ (SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV \text{ (English units)}}$$

- (i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O₂ (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see 40 CFR 60.17.)
- (ii) GVC is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see 40 CFR 60.17.)
- (iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.
- (f) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

Where:

X_i = Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F_i or (F_c)_i = Applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

d. **Opacity**

- i. If certified COMS is used to demonstrate compliance with opacity standards, the owner or operator shall record on an hourly basis all opacity from COMS.³⁷
- ii. If VE/Method 9 is used to demonstrate compliance with opacity standards, in order for the owner or operator to use its VE observations to satisfy the opacity monitoring requirement, the following conditions must be met:¹⁶ (EPA Letter, 2007)
 - (1) On a weekly basis, the owner or operator shall attempt to perform VE observations in accordance with procedures in EPA Method 9.
 - (2) On the weeks when it is possible to collect unit-specific VE data, at least one hour of Method 9 data shall be collected for each unit.
 - (3) Records of the Method 9 readings shall be submitted with the quarterly excess emission reports for PM emissions.
- iii. The owner or operator shall keep a record of every Method 9 test performed or the reason why it could not be performed that day.
- iv. For coal silos (E4):
 - (1) The owner or operator shall, weekly, conduct a one-minute visible emissions survey, during normal operation, of the PM Emission Points (stacks). For Emission Points without observed visible emissions during twelve consecutive operating weeks, the owner or operator may elect to conduct a monthly one-minute visible emission survey, during normal operation.
 - (2) At Emission Points where visible emissions are observed, the owner or operator shall initiate corrective action within eight hours of the initial observation. If the visible emissions persist, the owner or operator shall perform or cause to be performed a Method 9 for stack emissions within 24 hours of the initial observation. If the opacity standard is exceeded, the owner or operator shall report the exceedance to the District, according to Regulation 1.07, and take all practicable steps to eliminate the exceedance.
 - (3) The owner or operator shall, monthly, maintain records of the results of all visible emissions surveys and tests. Records of the results of any visible emissions survey shall include the date of the survey, the name of the person conducting the survey, whether or not visible

³⁷ According to LG&E's request, PM CEMS have been installed, calibrated, maintained, and operated for Unit 2. LG&E requested permission to remove COMS for Unit 3 and 4 under provisions in 40 CFR 60.13(i)(1), "Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases." LG&E's proposal for Unit 3 and 4 was accepted in a letter from EPA dated Feb. 28, 2007. The District accordingly approved LG&E's request for removing COMS for Unit 1 and 2 providing PM CEMS are appropriately installed for these units.

emissions were observed, and what if any corrective action was performed. If an emission point is not being operated during a given month, then no visible emission survey needs to be performed and a negative declaration shall be entered in the record.

e. **PM**

i. The company shall follow one of the two options below to demonstrate compliance with PM standards:

- (1) Option 1: the owner or operator shall install, maintain, calibrate, and operate a PM CEMS for each steam generating unit.^{38, 39} [Regulation 2.16, section 4.1.1] [40 CFR 64]
 - (a) The use of PM CEMS as the measurement technique must be appropriate for the stack conditions.
 - (b) The PM CEMS must be installed, operated and maintained in accordance with the manufacturer's recommendations.
 - (c) The PM CEMS must be certified in accordance with Performance Specification 11, Specifications and Test Procedures for Particulate Matter Continuous Emission Monitoring Systems at Stationary Sources, found in 40 CFR 60 Appendix B.
 - (d) A quality assurance/quality control program must be implemented in accordance with procedures in 40 CFR 60 Appendix F, Procedure 2 (Quality Assurance Requirements for Particulate Matter Continuous Emission Monitoring Systems at Stationary Sources).
 - (e) Compliance with the particulate matter emission limit will be based upon 3-hour rolling average periods during source operation.
 - (f) Quarterly excess emission reports must be submitted, and PM excess emissions shall be reported based upon 3-hour rolling averages during source operation.

³⁸ According to LG&E's request, PM CEMS have been installed, calibrated, maintained, and operated for Unit 2. LG&E requested permission to remove COMS for Unit 3 and 4 under provisions in 40 CFR 60.13(i)(1), "Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases." LG&E's proposal for Unit 3 and 4 was accepted in a letter from EPA dated Feb. 28, 2007. The District accordingly approved LG&E's request for removing COMS for Unit 1 and 2 providing PM CEMS are appropriately installed for these units.

³⁹ The coal-fired boilers are subject to 40 CFR Part 64 - Compliance Assurance Monitoring (CAM) for Major Stationary Source since SO₂, PM, and NO_x emissions from each of the boilers may be greater than the major source threshold and control devices are required to achieve compliance with standards. On 3/20/2020, LG&E submitted a revised CAM Plan in which SO₂ and NO_x CEMS are used for compliance demonstration. PM CEMS is used to demonstrate compliance or provide an indication of continuous PM control.

- (2) Option 2: the owner or operator shall conduct an annual EPA Reference Method 5 performance test following the testing requirements in Attachment B.
- ii. If certified PM CEMS (Option 1) is used to demonstrate compliance with PM standards, the owner or operator shall record on an hourly basis all PM emission data, in lb/MMBtu, from PM CEMS.⁴⁰ [40 CFR 64]
- iii. If annual PM testing (Option 2) is used to demonstrate compliance with PM standards, the owner or operator shall use PM CEMS as a performance indicator of continuous normal operation of the PM control devices and do the following:⁴⁰ [40 CFR 64]
- (1) The owner or operator shall monitor and record all PM emission data from PM CEMS, which is used as the indicator of normal operation of the PM control devices.
- (2) The owner or operator shall maintain daily records of any periods of time where the process was operating and the PM control devices were not operating or a declaration that the PM control devices operated at all times that day when the process was operating.
- (3) If there is any time that the PM control devices are bypassed or not in operation when the process is operating, then the owner or operator shall keep a record of the following for each bypass event:
- (a) Date;
- (b) Start time and stop time;
- (c) Identification of the control devices and process equipment;
- (d) PM emissions during the bypass in lb/hr;
- (e) Summary of the cause or reason for each bypass event;
- (f) Corrective action taken to minimize the extent or duration of the bypass event; and
- (g) Measures implemented to prevent reoccurrence of the situation that resulted in the bypass event.
- f. **SO₂**
- i. The owner or operator shall maintain hourly records of SO₂ emissions as specified in Regulation 6.02, section 6.1.2.

⁴⁰ The coal-fired boilers are subject to 40 CFR Part 64 - Compliance Assurance Monitoring (CAM) for Major Stationary Source since SO₂, PM, and NO_x emissions from each of the boilers may be greater than the major source threshold and control devices are required to achieve compliance with standards. On 3/20/2020, LG&E submitted a revised CAM Plan in which SO₂ and NO_x CEMS are used for compliance demonstration. PM CEMS is used to demonstrate compliance or provide an indication of continuous PM control.

- ii. The owner or operator shall record on an hourly basis all SO₂ emission data specified in 40 CFR 75.57(c): [40 CFR 64]
- (1) For SO₂ concentration during unit operation, as measured and reported from each certified primary monitor, certified back-up monitor, or other approved method of emissions determination:
[40 CFR 75.57(c)(1)]
- (a) Component-system identification code, as provided in 40 CFR 75.53; [40 CFR 75.57(c)(1)(i)]
 - (b) Date and hour; [40 CFR 75.57(c)(1)(ii)]
 - (c) Hourly average SO₂ concentration (ppm, rounded to the nearest tenth); [40 CFR 75.57(c)(1)(iii)]
 - (d) Hourly average SO₂ concentration (ppm, rounded to the nearest tenth), adjusted for bias if bias adjustment factor is required, as provided in 40 CFR 75.24(d);
[40 CFR 75.57(c)(1)(iv)]
 - (e) Percent monitor data availability (recorded to the nearest tenth of a percent), calculated pursuant to 40 CFR 75.32; and
[40 CFR 75.57(c)(1)(v)]
 - (f) Method of determination for hourly average SO₂ concentration using Codes 1–55 in Table 4a of 40 CFR 75.57. [40 CFR 75.57(c)(1)(vi)]
- (2) For flow rate during unit operation, as measured and reported from each certified primary monitor, certified back-up monitor, or other approved method of emissions determination:
[40 CFR 75.57(c)(2)]
- (a) Component-system identification code, as provided in 40 CFR 75.53; [40 CFR 75.57(c)(2)(i)]
 - (b) Date and hour; [40 CFR 75.57(c)(2)(ii)]
 - (c) Hourly average volumetric flow rate (in scfh, rounded to the nearest thousand); [40 CFR 75.57(c)(2)(iii)]
 - (d) Hourly average volumetric flow rate (in scfh, rounded to the nearest thousand), adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d);
[40 CFR 75.57(c)(2)(iv)]
 - (e) Percent monitor data availability (recorded to the nearest tenth of a percent) for the flow monitor, calculated pursuant to 40 CFR 75.32; and [40 CFR 75.57(c)(2)(v)]
 - (f) Method of determination for hourly average flow rate using Codes 1–55 in Table 4a of 40 CFR 75.57.
[40 CFR 75.57(c)(2)(vi)]

- (3) For SO₂ mass emission rate during unit operation, as measured and reported from the certified primary monitoring system(s), certified redundant or non-redundant back-up monitoring system(s), or other approved method(s) of emissions determination: [40 CFR 75.57(c)(4)]
- (a) Date and hour; [40 CFR 75.57(c)(4)(i)]
 - (b) Hourly SO₂ mass emission rate (lb/hr, rounded to the nearest tenth); [40 CFR 75.57(c)(4)(ii)]
 - (c) Hourly SO₂ mass emission rate (lb/hr, rounded to the nearest tenth), adjusted for bias if bias adjustment factor required, as provided in 40 CFR 75.24(d); and [40 CFR 75.57(c)(4)(iii)]
 - (d) Identification code for emissions formula used to derive hourly SO₂ mass emission rate from SO₂ concentration and flow and (if applicable) moisture data in paragraphs (c)(1), (c)(2), and (c)(3) of 40 CFR 75.57, as provided in 40 CFR 75.53. [40 CFR 75.57(c)(4)(iv)]
- iii. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:
- (1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of SO₂ and NO_x continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in 40 CFR 60.46(d).
 - (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.
 - (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or NO_x the span value shall be determined using one of the following procedures:
 - (a) Except as provided under paragraph 40 CFR 60.45(c)(3)(ii), SO₂ and NO_x span values shall be determined as follows:

| Fossil fuel | In parts per million | |
|-------------|--------------------------------|--------------------------------|
| | Span value for SO ₂ | Span value for NO _x |
| Gas | Not Applicable | 500. |
| Liquid | 1,000 | 500. |
| Solid | 1,500 | 1,000. |

- (b) As an alternative to meeting the requirements of paragraph 40 CFR 60.45(c)(3)(i), the owner or operator of an affected facility may elect to use the SO₂ and NO_x span values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.
- iv. The owner or operator shall comply with the following in order to demonstrate compliance with the emission standard as required by 40 CFR 52: The conversion procedures in 40 CFR 60.45(e) and (f) shall be used to convert the continuous monitoring data into units of the applicable standards.

- (1) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

- (a) When a CEMS for measuring O₂ is selected, the measurement of the pollutant concentration and O₂ concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF \left(\frac{20.9}{(20.9 - \%O_2)} \right)$$

Where E, C, F, and %O₂ are determined under paragraph (f) of this section.

- (b) When a CEMS for measuring CO₂ is selected, the measurement of the pollutant concentration and CO₂ concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where E, C, F_c and %CO₂ are determined under paragraph (f) of this section.

- (2) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

- (a) E = pollutant emissions, ng/J (lb/MMBtu).
- (b) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^{-4} M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO₂ and 46.01 for NO_x.
- (c) %O₂, %CO₂ = O₂ or CO₂ volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.
- (d) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO₂ generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:
- (i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), F = $2,723 \times 10^{-17}$ dscm/J (10,140 dscf/MMBtu) and F_c = 0.532×10^{-17} scm CO₂/J (1,980 scf CO₂/MMBtu).
 - (ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17), F = 2.637×10^{-7} dscm/J (9,820 dscf/MMBtu) and F_c = 0.486×10^{-7} scm CO₂/J (1,810 scf CO₂/MMBtu).
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, F = 2.476×10^{-7} dscm/J (9,220 dscf/MMBtu) and F_c = 0.384×10^{-7} scm CO₂/J (1,430 scf CO₂/MMBtu).
 - (iv) For gaseous fossil fuels, F = 2.347×10^{-7} dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, F_c = 0.279×10^{-7} scm CO₂/J (1,040 scf CO₂/MMBtu) for natural gas, 0.322×10^{-7} scm CO₂/J (1,200 scf CO₂/MMBtu) for propane, and 0.338×10^{-7} scm CO₂/J (1,260 scf CO₂/MMBtu) for butane.
 - (v) For bark F = 2.589×10^{-7} dscm/J (9,640 dscf/MMBtu) and F_c = 0.500×10^{-7} scm CO₂/J (1,840 scf CO₂/MMBtu). For wood residue other than bark F = 2.492×10^{-7} dscm/J (9,280 dscf/MMBtu) and F_c = 0.494×10^{-7} scm CO₂/J (1,860 scf CO₂/MMBtu).
 - (vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see 40 CFR 60.17),

$F = 2.659 \times 10^{-7}$ dscm/J (9,900 dscf/MMBtu) and
 $F_c = 0.516 \times 10^{-7}$ scm CO₂/J (1,920 scf CO₂/MMBtu).

- (e) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂/J, or scf CO₂/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^6 \frac{[227.2 (\%H) + 95.5 (\%C) + 35.6 (\%S) + 8.7 (\%N) - 28.7 (\%O)]}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-3} (\%C)}{GCV \text{ (SI units)}}$$

$$F = 10^6 \frac{[3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)]}{GCV \text{ (English units)}}$$

$$F_c = \frac{20.0 (\%C)}{GCV \text{ (SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV \text{ (English units)}}$$

- (i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O₂ (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see 40 CFR 60.17.)
- (ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see 40 CFR 60.17.)
- (iii) For affected facilities which fire both fossil fuels and non-fossil fuels, the F or F_c value shall be subject to the Administrator's approval.

- (f) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

Where:

X_i= Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

F_i or (F_c)_i= Applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

g. TAC

- i. The owner or operator shall, monthly, calculate and record TAC emissions for this unit in order to demonstrate compliance with the TAC emission standards.
- ii. See Plantwide Requirements.

S3. Reporting

[Regulation 2.16, Section 4.1.1]

The owner or operator shall report the following information, as required by General Condition G14:

a. BART [40 CFR 52, Subpart S]

- i. The owner or operator shall report any periods of time where the process was operating and both PJFF baghouse and ESP were not operating.

b. HAP [40 CFR 63 Subpart UUUUU]

- i. The owner or operator shall comply with reporting requirements in 40 CFR 63 Subpart UUUUU. (See Attachment A)
- ii. Report normal pH range of reactant material in the FGD and normal range of any other parameters verified as having a direct effect on Hg emission within 30 days of establishing the normal range.
- iii. The owner or operator shall identify all periods of the activated carbon injection rate are less than the minimum injection rate, or the pH of the reactant material in the FGD are out of normal range, or anytime other verified parameters are outside of their normal range, and any corrective action taken for each exceedance.

c. **NO_x**

- i. The owner or operator shall identify all periods of exceeding a NO_x emission standard during a quarterly reporting period. The quarterly compliance report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;
 - (4) If known, the cause of the deviation;
 - (5) A description of all corrective actions taken to abate the deviation; and
 - (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.

- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known. The averaging period used for data reporting should correspond to the averaging period specified in the emission test method used to determine compliance with an emission standard for the pollutant/source category in question. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. The required report shall include:
[Regulation 6.02, section 16.1]
 - (1) For gaseous measurements, the summary shall consist of hourly averages in the units of the applicable standard. The hourly averages shall not appear in the written summary, but shall be made available electronically.⁴¹ [Regulation 6.02, section 16.3]
 - (2) The data and time identifying each period during which the continuous monitoring system was inoperative, except for zero and span checks, and the nature of system repairs or adjustment shall be reported. Proof of continuous monitoring system performance whenever system repairs or adjustments have been made is required. [Regulation 6.02, section 16.4]
 - (3) When no excess emissions have occurred and the continuous monitoring systems have been inoperative, repaired, or adjusted, such information shall be included in the report. [Regulation 6.02, section 16.5]
 - (4) Owners or operators of affected facilities shall maintain a file of all information reported in the quarterly summaries, and all other data collected either by the continuous monitoring system or as necessary to convert monitoring data to the units of the applicable standard for a minimum of two years from the date of collection of such data or

⁴¹ The hourly averages are only required to be made available in electronic summary, not in written summary.

submission of such summaries.
[Regulation 6.02, section 16.6]

- iii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, Monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator⁴², and Retired Unit Petitions shall be submitted as specified in Subpart G - reporting requirements. (See Attachment E)
- iv. The owner or operator shall comply with the reporting requirements for the Title IV NO_x Budget Emission Limitation, 0.40 lb/MMBtu, as specified in 40 CFR Part 76.
- v. Excess emissions for affected facilities using a CEMS for measuring NO_x are defined as: [Regulation 2.16, section 4.1.9.3]
 - (1) Any annual average period during which the average emissions (arithmetic average of all one-hour period during the 12 month period) of NO_x as measured by a CEMS exceed the applicable standard.
 - (2) Any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of NO_x as measured by a CEMS exceed the applicable standard.

d. Opacity

- i. The owner or operator shall identify all periods of exceeding an opacity standard during a quarterly reporting period. The report shall include the following:
 - (1) Any deviation from the requirement to perform daily (or monthly, if required) visible emission surveys or Method 9 tests and documented reason;
 - (2) Any deviation from the requirement to record the results of each VE survey and Method 9 test performed and documented reason;
 - (3) The number, date, and time of each VE Survey where visible emissions were observed and the results of the Method 9 test performed;
 - (4) Identification of all periods of exceeding an opacity standard;
 - (5) Description of any corrective action taken for each exceedance of the opacity standard; or

⁴² In this permit, Administrator means the District.

- (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator, and Retired Unit Petitions shall be submitted as specified in Subpart G - reporting requirements. (See Attachment E)
[Regulation 6.47, section 3.4 and 3.5 referencing 40 CFR Parts 75 and 76]
- iii. For coal silos (E4):
The owner or operator shall identify all periods of exceeding an opacity standard during a quarterly reporting period. The report shall include the following:
- (1) Emission Unit ID number, Stack ID number, and/or Emission point ID number;
 - (2) The beginning and ending date of the reporting period;
 - (3) The date, time and results of each exceedance of the opacity standard;
 - (4) Description of any corrective action taken for each exceedance.
- e. **PM**
- i. The owner or operator shall identify all periods of exceeding a PM emission standard during a quarterly reporting period. The report shall include the following:
- (1) Emission Unit ID number and emission point ID number;
 - (2) The date and duration (including the start and stop time) during which a deviation occurred;
 - (3) The magnitude of excess emissions;
 - (4) Description of the deviation and summary information on the cause or reason for excess emissions;
 - (5) Corrective action taken to minimize the extent and duration of each excess emissions event;
 - (6) Measures implemented to prevent reoccurrence of the situation that resulted in excess PM emissions; or
 - (7) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known.

f. SO₂

- i. The owner or operator shall identify all periods of exceeding a SO₂ emission standard during a quarterly reporting period. The report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;
 - (4) If known, the cause of the deviation;
 - (5) A description of all corrective actions taken to abate the deviation; and
 - (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.
- ii. The owner or operator shall submit a written report of excess emissions and the nature and cause of the excess emissions if known.
- iii. The owner or operator shall comply with the reporting requirements for the Acid Rain Permit No.176-97-AR (R5), specified in 40 CFR 75 Subpart G. Notifications, monitoring Plans, Initial Certification and Recertification Applications, Quarterly Reports, Opacity Reports, Petitions to the Administrator, and Retired Unit Petitions shall be submitted as specified in Subpart G - Reporting Requirements. (See Attachment E)
- iv. Excess emissions for affected facilities using a CEMS for measuring SO₂ are defined as: [Regulation 2.16, section 4.1.9.3]
 - (1) Any 3-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO₂ as measured by a CEMS exceed the applicable standard; or
 - (2) Any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO₂ as measured by a CEMS exceed the applicable standard.

g. TAC

- i. The owner or operator shall identify all periods of exceeding a TAC emission standard during a quarterly reporting period. The report shall include the following:
 - (1) Emission Unit ID number and emission point ID number;
 - (2) Identification of all periods during which a deviation occurred;
 - (3) A description, including the magnitude, of the deviation;

- (4) If known, the cause of the deviation;
- (5) A description of all corrective actions taken to abate the deviation; and
- (6) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.

ii. See Plantwide Requirements.

S4. Testing

[Regulation 2.16, section 4.3.1]

a. Control efficiency determination

- i. The owner or operator shall conduct performance test for the new EGU control device C27 and C28, according to the testing requirements in Attachment B, C and H.^{43,44} [Regulation 2.16, section 4.1.9.1]
- ii. The owner or operator shall conduct a subsequent performance test to determine the control efficiency for sulfuric acid (H₂SO₄) by June 3, 2025, according to the testing requirements in Attachment B and C.⁴⁵ [Regulation 2.16, section 4.1.9.1]

U2 Comments

1. Boiler (E3) has TAC emission standards since its EA Demonstration was based on controlled PTE. If the controlled PTE for the TAC is less than de minimis level, use De Minimis as limit. If the controlled PTE for the TAC is greater than de minimis level, modeling results were used to calculate risk value to compare to the EA Goals. In this case, controlled PTE is used as limit. TAC emissions for the coal silos (E4) are de minimis according to Regulation 5.21, section 2.1. The TAC emission limits determined by de minimis values shall be updated each time when the District revises the BAC/de minimis values for these TACs. The current de minimis values per TAC list revised on 11/9/2017 are as the following:

| TAC Name | CAS # | De minimis values | | |
|----------|---------|-------------------|-----------------|---------|
| | | (lb/hr) | (lb/Ave Period) | (lb/yr) |
| Benzene | 71-43-2 | 0.24 | | 216 |

⁴³ Per an EPA rule change (“Restructuring of the Stationary Source Audit Program.” Federal Register 75:176 (September 13, 2010) pp 55636-55657), if an audit sample is required by the test method, sources became responsible for obtaining the audit samples directly from accredited audit sample suppliers, not the regulatory agencies.

⁴⁴ This unit was modified under construction permit 34595-12-C. According to permit 34595-12-C, the source is required to conduct stack tests to obtain actual emission factors and control efficiencies. Control efficiencies stack test for C26 and C27 were conducted on June 4-8, 2015

⁴⁵ Compliance with STAR Program for sulfuric acid was based on controlled sulfuric acid emissions. The source shall use the updated control efficiency to calculate actual sulfuric acid emissions.

Plant ID: 0127

| TAC Name | CAS # | De minimis values | | |
|----------------------------|-----------|-------------------|-----------------|---------|
| | | (lb/hr) | (lb/Ave Period) | (lb/yr) |
| Bromoform | 75-25-2 | 0.49 | | 437 |
| Chloroform | 67-66-3 | 0.023 | | 20.64 |
| Methylene chloride | 75-09-2 | 54 | | 48,000 |
| Tetrachloroethylene (Perc) | 127-18-4 | 2.08 | | 1,848 |
| Toluene | 108-88-3 | 2700 | 2,400,000 lb/yr | |
| Xylene | 1330-20-7 | 54 | 48,000 lb/yr | |
| Hydrochloric acid | 7647-01-0 | 10.8 | 9,600 lb/yr | |

Deleted pages with no edits

Emission Unit U23: EGU Unit 5 Gas Turbine with HRSG (664 MW Net)

Applicable Regulations⁷

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|---|---|
| Regulation | Title | Applicable Sections |
| 2.05 | Prevention of Significant Deterioration of Air Quality | 1, 2 |
| 2.16 | Title V Operating Permits | 1 through 6 |
| 6.42 | Reasonably Available Control Technology Requirements for Major Volatile Organic Compound- and Nitrogen Oxides-Emitting Facilities | 1, 2, 3, 4, 5 |
| 6.47 | Federal Acid Rain Program for Existing Sources Incorporated by Reference | 1, 2, 3, 4, 5 |
| 40 CFR 60 Subpart KKKK | Standards of Performance for Stationary Combustion Turbines | 40 CFR 60.4300 through 60.4420, Table 1 (Subpart KKKK) |
| 40 CFR 60 Subpart TTTT | Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units | 40 CFR 60.5508 through 60.5580, Tables 1 through 3 (Subpart TTTT) |
| 40 CFR 63 Subpart YYYY | National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines | 40 CFR 63.6080 through 63.6175, Tables 1 through 7 (Subpart YYYY) |
| 40 CFR 72 | Permits Regulation | Subparts A, B, C, D, E, F, G, H, I |
| 40 CFR 73 | Sulfur Dioxide Allowance System | Subparts A, B, C, D, E, F, G |
| 40 CFR 75 | Continuous Emission Monitoring | Subparts A, B, C, D, E, F, G |
| 40 CFR 76 | Acid Rain Nitrogen Oxides Emission Reduction Program | 76.1-9, 11, 13, 14, 15, Appendix A and B |
| 40 CFR 77 | Excess Emissions | 77.1- 6 |
| 40 CFR 78 | Appeals Procedures for Acid Rain Program | 78.1-20 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| 7.02 | Federal New Source Performance Standards Incorporated by Reference | 1 through 5 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|---|---------------------|--|-------------------|-------------------|
| E49a | Natural gas-fired combustion turbine (H Class or similar), Manufacturer: TBD, Model: TBD, equipped with a heat recovery steam generator (HRSG) with natural gas-fired duct burners (DB): Emissions from Cold; Warm, and Hot Startups, and Shutdown events will be released from same emissions point. | 2027 | STAR, 5.02, 5.14, 6.42, 6.47, 7.02, 40 CFR 72-73, 75-78, 40 CFR 60 Subpart KKKK & TTTT 40 CFR 63 Subpart YYYYY | C43 & C44 | S49 |

Control Devices

| Control ID | Description | Control Efficiency | Performance Indicator |
|-------------------|---|---------------------------|---|
| C43 | Oxidation Catalyst, make TBD, model TBD, used to control CO, VOC, and OHAP emissions for GT and DB | 50-90% | Pressure drop range 0.5" to 1.0" water column and Catalytic bed inlet gas temperature |
| C44 | SCR controls with aqueous ammonia injection, make TBD, model TBD, used to control NO _x emissions for GT and DB | 75-91% | Ammonia solutions injection rate and NO _x emissions from CEM |

U23 Specific Conditions

S1. Standards

[Regulation 2.16, Section 4.1.1]

a. NO_x

- i. The new combustion turbine firing natural gas, which has a combustion turbine heat input at peak load (HHV) greater than 850 MMBtu/hr, shall meet 15 parts per million (ppm) at 15% oxygen (O₂); or 54 nanograms per Joule (ng/J) of useful output (0.43 pounds per megawatt-hour (lb/MWh)), based upon a 30-unit operating day rolling average (per 40 CFR 60.4350(h)). (See NO_x RACT Plan) [40 CFR 60.4320 & 40 CFR 60, Subpart KKKK, Table 1] [Regulation 6.42, section 4.3]
- ii. For turbines operating at less than 75 percent peak load that have a combustion turbine heat input at peak load (HHV) greater than 30 MW output, shall meet 96 ppm at 15% O₂; or 590 ng/J of useful output (4.7 lb/MWh), based upon a 30-unit operating day rolling average (per 40 CFR 60.4350(h)). (See NO_x RACT Plan) [40 CFR 60.4320 & 40 CFR 60, Subpart KKKK, Table 1] [Regulation 6.42, section 4.3]

b. SO₂

The owner or operator shall comply with the emissions standards in 40 CFR 60.4330(a)(1) or (2). [40 CFR 60.4330(a)]

- i. The owner or operator shall not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO₂/J (0.060 lb SO₂/MMBtu) heat input. [40 CFR 60.4330(a)(2)]

c. General Requirement of NSPS KKKK

- i. The owner or operator must operate and maintain the stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. [40 CFR 60.4333(a)]

d. **CO₂**

- i. The CO₂ emissions of each affected turbine on a 12-month rolling average basis shall not exceed one of the following limits, consistent with 40 CFR 60.5520(b), (c), and (d), as applicable: [40 CFR 60.5520(a) and 60.5525(a) and Table 2 of NSPS TTTT]
- (1) 1,000 lb/MWh of gross energy output; or
 - (2) 1,030 lb/MWh of net energy output.
- ii. Stationary combustion turbines subject to a heat input-based standard in Table 2 of NSPS TTTT that are only permitted to burn one or more uniform fuels, as described in 40 CFR 60.5520(d)(1), are only subject to the monitoring requirements in 40 CFR 60.5520(d)(1). All other stationary combustion turbines subject to a heat input based standard in Table 2 are subject to the requirements in 40 CFR 60.5520(d)(2). [40 CFR 60.5520(d)]
- (1) Stationary combustion turbines that are only permitted to burn fuels with a consistent chemical composition (i.e., uniform fuels) that result in a consistent emission rate of 160 lb CO₂/MMBtu or less are not subject to any monitoring or reporting requirements under this subpart. These fuels include, but are not limited to, natural gas, methane, butane, butylene, ethane, ethylene, propane, naphtha, propylene, jet fuel kerosene, No. 1 fuel oil, No. 2 fuel oil, and biodiesel. Stationary combustion turbines qualifying under this paragraph are only required to maintain purchase records for permitted fuels.

e. **General Requirement of NSPS TTTT**

- i. Combustion turbines qualifying under 40 CFR §60.5520(d)(1) are not subject to any requirements in 40 CFR 60.5525(a) through (c) other than the requirement to maintain fuel purchase records for permitted fuel(s). [40 CFR §60.5525]

f. **HAP**

- i. U23/E49a, which is a lean premix gas-fired stationary combustion turbine as defined in 40 CFR §63.6175, must limit the concentration of formaldehyde to 91 ppbv or less at 15-percent O₂, except during turbine startup. [40 CFR §63.6100 and Table 1, Item 1, of NESHAP YYYY]
- ii. The period of time for turbine startup is subject to the limits specified in

the definition of startup in §63.6175, where startup begins at the first firing of fuel in the stationary combustion turbine. For simple cycle turbines, startup ends when the stationary combustion turbine has reached stable operation or after 1 hour, whichever is less. For combined cycle turbines, startup ends when the stationary combustion turbine has reached stable operation or after 3 hours, whichever is less. Turbines in combined cycle configurations that are operating as simple cycle turbines must meet the startup requirements for simple cycle turbines while operating as simple cycle turbines. [40 CFR §63.6100 and Table 1, Item 1, of 40 CFR 63 Subpart YYYYY]

- iii. For U23/49a that is required to comply with the emission limitation for formaldehyde and uses an oxidation catalyst, the permittee must maintain the 4-hour rolling average of the catalyst inlet temperature within the range suggested by the catalyst manufacturer. The permittee is not required to use the catalyst inlet temperature data that is recorded during engine startup in the calculations of the 4-hour rolling average catalyst inlet temperature. [40 CFR §§63.6100 and 63.6140 and Table 2, Item 1, of NESHAP YYYYY]

g. **General Requirement of NESHAP YYYYY**

- i. Duct burners and waste heat recovery units are considered steam generating units and are not covered under NESHAP YYYYY. In some cases, it may be difficult to separately monitor emissions from the turbine and duct burner, so sources are allowed to meet the required emission limitations with their duct burners in operation. [40 CFR §63.6092]
- ii. The permittee must comply with the emissions limitations and operating limitations of NESHAP YYYYY upon startup of the affected source. [40 CFR §63.6095(a)(4)]
- iii. At all times, the owner or operator must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the owner or operator to make any further efforts to reduce emissions if levels required by the applicable standard have been achieved. Determination of whether a source is operating in compliance with operation and maintenance requirements will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR §63.6105(c)]

h. **VOC**

Plant ID: 0127

- i. The owner or operator shall implement good combustion and operating practices and comply with the applicable operating limitations of 40 CFR 63, Subpart YYYY (See VOC RACT Attachment) [Regulation 6.42, Sections 4.1 and 4.2]

- i. **TAC**

- i. See Plantwide Requirements.¹²³

S2. Monitoring and Record Keeping
[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the required records for a minimum of 5 years and make the records readily available to the District upon request.

- a. **NO_x**

- i. As an alternative to performing annual performance tests, the owner or operator may install, maintain, calibrate and operate one of the following continuous monitoring systems: (See Attachment B - NO_x RACT Plan) [40 CFR 60.4340(b)]
 - (1) Continuous emission monitoring as described in §§60.4335(b) and 60.4345. [40 CFR 60.4340(b)(1)]
 - (2) Pursuant to §60.4335(b),
 - (a) the owner or operator may install, certify, maintain, and operate a CEMS consisting of a NO_x monitor and a diluent gas (oxygen (O₂) or carbon dioxide (CO₂)) monitor, to determine the hourly NO_x emission rate in ppm or lb/MMBtu; and [40 CFR 60.4335(b)(1)]
 - (b) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and [40 CFR 60.4335(b)(2)]
 - (c) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and [40 CFR 60.4335(b)(3)]
 - (d) For combined heat and power units complying with the

¹²³ According to Regulation 5.21, section 2.7, TAC emissions from the natural gas-fired turbine are de minimis.

output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h). [40 CFR 60.4335(b)(4)]

- ii. See NO_x RACT Plan [Regulation 6.42, Section 4.3]
- iii. Pursuant to 40 CFR 60.4340(b)(1), the NO_x CEMS shall meet the following requirements: [40 CFR 60.4345]
 - (1) Each NO_x diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO_x diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis. [40 CFR 60.4345(a)]
 - (2) As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, both the NO_x monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO_x emission rate for the hour. [40 CFR 60.4345(b)]
 - (3) Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart. [40 CFR 60.4345(c)]
 - (4) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions. [40 CFR 60.4345(d)]
 - (5) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring

equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter. [40 CFR 60.4345(e)]

- iv. The owner or operator will identify excess emissions using the following guidelines: [40 CFR 60.4350]
- (1) All CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h). [40 CFR 60.4350(a)]
 - (2) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.4345(b), is obtained for both NO_x and diluent monitors, the data acquisition and handling system must calculate and record the hourly NO_x emission rate in units of ppm or lb/MMBtu, using the appropriate equation from Method 19 in appendix A of this part. For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂ (or the hourly average CO₂ concentration is less than 1.0 percent CO₂), a diluent cap value of 19.0 percent O₂ or 1.0 percent CO₂ (as applicable) may be used in the emission calculations. [40 CFR 60.4350(b)]
 - (3) Correction of measured NO_x concentrations to 15 percent O₂ is not allowed. [40 CFR 60.4350(c)]
 - (4) If the owner or operator have installed and certified a NO_x diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under 40 CFR 60.7(c). [40 CFR 60.4350(d)]
 - (5) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages. [40 CFR 60.4350(e)]
 - (6) Calculate the hourly average NO_x emission rates, in units of the emission standards under 40 CFR 60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output-based standard: [40 CFR 60.4350(f)]
 - (a) For combined-cycle and combined heat and power complying with the output-based standard, use Equation 1 of this subpart, except that the gross energy output is

calculated as the sum of the total electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations: [40 CFR 60.4350(f)(2)]

$$E = \frac{(NO_x)_h * (HI)_h}{P} \quad (\text{Eq. 1})$$

Where:

E = hourly NO_x emission rate, in lb/MWh

(NO_x)_h = hourly NO_x emission rate, in lb/MMBtu

(HI)_h = hourly heat input rate to the unit, in MMBtu/hr, measured using the fuel flowmeters, e.g., calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW

$$P = (PE)_t + (PE)_c + P_s + P_o \quad (\text{Eq. 2})$$

Where:

P = gross energy output of the stationary combustion turbine system (MW)

(PE)_t = electrical or mechanical energy output of the CT (MW)

(PE)_c = electrical or mechanical output of the steam turbine (MW)

$$P_s = \frac{Q * H}{3.413 \times 10^6 \text{ Btu/MWh}} \quad (\text{Eq. 3})$$

Where:

P_s = useful thermal energy of the system, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/hr,

H = enthalpy of steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and

3.413×10^6 = conversion from Btu/hr to MW.

P_o = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

- (7) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from 40 CFR 60.4350(f) of this section to assess excess emissions on a 30-unit operating day rolling average basis, as described in 40 CFR 60.4380(b)(1). [40 CFR 60.4350(h)]

b. **SO₂**

- i. The owner or operator may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO₂/J (0.060 lb SO₂/MMBtu) heat input for units located in continental areas. The owner or operator must use one of the following sources of information to make the required demonstration: [40 CFR 60.4365]

- (1) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and has potential sulfur emissions of less than less than 26 ng SO₂/J (0.060 lb SO₂/MMBtu) heat input for continental areas; or meet 40 CFR 60.4365(b) [40 CFR 60.4365(a)]

c. **CO₂**

- i. Pursuant to 40 CFR §60.5535, combustion turbines qualifying under §60.5520(d)(1) are not subject to any requirements for monitoring and recordkeeping other than the requirement to maintain fuel purchase records for permitted fuel(s). [40 CFR 60.5535]

d. **HAP**

- i. See Plantwide Requirements.
- ii. Since U23/49a is required to comply with the formaldehyde emission limitation and an oxidation catalyst emission control device is used, the permittee must monitor on a continuous basis the catalyst inlet temperature in order to comply with the operating limitations in Table 2 and as specified in Table 5 of NESHAP YYYY. [40 CFR 63.6125(a)]
 - (1) For a stationary combustion turbine that is required to comply with the emissions limitation for formaldehyde and is using an oxidation system, the permitting must maintain the 4-hour rolling average of the catalyst inlet temperature within the range suggested by the catalyst manufacturer. The permittee is not required to use the catalyst inlet temperature data that is recorded during engine startup in the calculations of the 4-hour rolling average catalyst inlet temperature. [40 CFR 63.6125(a) and Table 2, Item 1, of NESHAP YYYY]
 - (2) Initial compliance is demonstrated if the average formaldehyde concentration meets the emission limitations specified in Table 1 of NESHAP YYYY. [40 CFR 63.6110, 63.6125, 63.6130, and Table 4 NESHAP YYYY]
 - (3) Continuous compliance with the operating limit is demonstrated by continuously monitoring the inlet temperature to the catalyst and maintaining the 4-hour rolling average of the inlet temperature within the range suggested by the catalyst manufacturer. [40 CFR 63.6135, 63.6140(a), and Table 5 of NESHAP YYYY]
 - (4) The permittee must report each instance in which they did not meet each emission limitation or operating limitation. The permittee must also report each instance in which they did not meet the requirements in Table 7 of NESHAP YYYY that apply to U23/49a. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6150. [40 CFR 63.6140(b)]
- iii. Since the temperature monitoring system is a continuous monitoring system (CMS), the permittee must develop and implement a CMS quality control program that includes written procedures for CMS according to §63.8(d)(1) through (2). The permittee must keep these written procedures on record for the life of the affected source or until the affected source is no longer subject to the provisions of this part, to

be made available for inspection, upon request, by the Administrator. If the performance evaluation plan is revised, the owner or operator shall keep previous (i.e., superseded) versions of the performance evaluation plan on record to be made available for inspection, upon request, by the Administrator, for a period of 5 years after each revision to the plan. The program of corrective action should be included in the plan required under §63.8(d)(2). [40 CFR 63.6125(e)]

- iv. Except for monitor malfunctions, associated repairs, and required quality assurance or quality control activities (including, as applicable, calibration checks and required zero and span adjustments of the monitoring system), the permittee must conduct all parametric monitoring at all times the stationary combustion turbine is operating. [40 CFR 63.6135(a)]
- v. Do not use data recorded during monitor malfunctions, associated repairs, and required quality assurance or quality control activities for meeting the requirements of this subpart, including data averages and calculations. The permittee must use all the data collected during all other periods in assessing the performance of the control device or in assessing emissions from the new or reconstructed stationary combustion turbine. [40 CFR 63.6135(b)]
- vi. The owner or operator must keep the records as described in 40 CFR 63.6155(a)(1) through (7). [40 CFR 63.6155(a)]
- vii. The owner or operator must keep the records required in Table 5 of 40 CFR 63 Subpart YYYY to show continuous compliance with each operating limitation that applies. [40 CFR 63.6155(c)]
- viii. Any records required to be maintained by this part that are submitted electronically via the EPA's CEDRI may be maintained in electronic format. This ability to maintain electronic copies does not affect the requirement for facilities to make records, data, and reports available upon request to a delegated air agency or the EPA as part of an on-site compliance evaluation. [40 CFR 63.6155(d)]

e. **VOC**

- i. The owner or operator shall comply with the applicable monitoring and recordkeeping requirements of 40 CFR 63, Subpart YYYY (See VOC RACT Attachment) [Regulation 6.42, Sections 4.1 and 4.2].

f. **TAC**

- i. See Plantwide Requirements.

S3. Reporting

[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **General requirements for NSPS KKKK**

- i. For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, the owner or operator must submit reports of excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction. [40 CFR 60.4375(a)]
- ii. Each owner or operator required to install a continuous monitoring device shall submit excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and-or summary report form to the District semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 60th day following the end of each six-month reporting period. Written reports of excess emissions shall include the following information:
[40 CFR 60.4395 and 40 CFR 60.7(c)]
- (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period. [40 CFR 60.7(c)(1)]
- (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted. [40 CFR 60.7(c)(2)]

- (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments. [40 CFR 60.7(c)(3)]
 - (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report. [40 CFR 60.7(c)(4)]
- iii. All reports required under 40 CFR 60.7(c) shall be postmarked by the 60th day following the end of each reporting period. [40 CFR 60.4395]

b. NO_x

- i. For turbines using continuous emission monitoring, periods of excess emissions and monitor downtime that must be reported are defined as follows: [40 CFR 60.4380(b)]
 - (1) An excess emissions is any unit operating period in which the 30-day rolling average NO_x emission rate exceeds the applicable emission limit in 40 CFR 60.4320. For the purposes of this subpart, a “30-day rolling average NO_x emission rate” is the arithmetic average of all hourly NO_x emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NO_x emissions rates for the preceding 30-unit operating days if a valid NO_x emission rate is obtained for at least 75 percent of all operating hours. [40 CFR 60.4380(b)(1)]
 - (2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NO_x concentration, CO₂ or O₂ concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if the owner or operator will use this information for compliance purposes. [40 CFR 60.4380(b)(2)]
- ii. The owner or operator shall comply with the quarterly reporting requirements as specified in the NO_x RACT Plan. (See Attachment D)

c. **CO₂**

- i. For the affected turbines, the Permittee shall comply with the notification notifications in §60.7(a)(1) and (3) and the reporting requirements of §60.19, as applicable. [40 CFR 60, Subpart A, 40 CFR 60.5550(a) and Table 3 of NSPS TTTT]

d. **HAP**

- i. The permittee must submit all of the notifications in §§ 63.7(b) Notification of Performance Testing and (c) Quality Assurance/Test Plan, 63.8(e) CMS Performance Evaluation (Except for §63.8(e)(5)(ii), which applies to COMS), 63.8(f)(4) Alternative Monitoring, and 63.9(b) Initial Notifications and (h) Notice of Compliance Status that apply to the GT by the dates specified. [40 CFR 60, Subpart A, 40 CFR 63.6145(a) and Table 7 of NESHAP YYYY]
- ii. If the permittee is required to submit an Initial Notification but are otherwise not affected by the emission limitation requirements of this subpart, in accordance with §63.6090(b), the notification must include the information in §63.9(b)(2)(i) through (v) and a statement that the new or reconstructed stationary combustion turbine has no additional emission limitation requirements and must explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary combustion turbine). [40 CFR 63.6145(d)]
- iii. If the permittee is required to conduct an initial performance test, the permittee must submit a notification of intent to conduct an initial performance test at least 60 calendar days before the initial performance test is scheduled to begin as required in §63.7(b)(1). [40 CFR 63.6145(e)]
- iv. If the permittee is required to comply with the emission limitation for formaldehyde, the permittee must submit a Notification of Compliance Status according to §63.9(h)(2)(ii). For each performance test required to demonstrate compliance with the emission limitation for formaldehyde, the permittee must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th calendar day following the completion of the performance test. [40 CFR 63.6145(f)]
- v. **Compliance report.** The owner or operator of a stationary combustion turbine which must meet the emission limitation for formaldehyde must submit a semiannual compliance report according to Table 6 of NESHAP YYYY. The semiannual compliance report must contain the information described in §63.6150(a)(1) through (5). The semiannual compliance

report, including the excess emissions and monitoring system performance reports of §63.10(e)(3), must be submitted by the dates specified in §63.6150(b)(1) through (5), unless the Administrator has approved a different schedule. After September 8, 2020, or once the reporting template has been available on the Compliance and Emissions Data Reporting Interface (CEDRI) website for 180 days, whichever date is later, the permittee must submit all subsequent reports to the EPA following the procedure specified in 40 CFR 63.6150(g). [40 CFR 63.6150(a)]

- (1) Company name and address.
 - (2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.
 - (3) Date of report and beginning and ending dates of the reporting period.
 - (4) After September 8, 2020, report each deviation in the semiannual compliance report. Report the information specified in 40 CFR 63.6150(a)(5)(i) through (iv). [40 CFR 60.4380(b)(5)]
 - (a) Report the number of deviations. For each instance, report the start date, start time, duration, and cause of each deviation, and the corrective action taken.
 - (b) For each deviation, the report must include a list of the affected sources or equipment, an estimate of the quantity of each regulated pollutant emitted over any emission limit, a description of the method used to estimate the emissions.
 - (c) Information on the number, duration, and cause for monitor downtime incidents (including unknown cause, if applicable, other than downtime associated with zero and span and other daily calibration checks), as applicable, and the corrective action taken.
 - (d) Report the total operating time of the affected source during the reporting period.
- vi. The first semiannual compliance report must cover the period beginning on the compliance date specified in §63.6095 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date specified in §63.6095. [40 CFR 63.6150(b)(1)]
- vii. The first semiannual compliance report must be postmarked or delivered no later than August 29 or March 1, whichever date follows the end of the first calendar half after the compliance date that is specified in § 63.6095

- [40 CFR 63.6150(b)(2) and (5)]
- viii. Each subsequent semiannual compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31. [40 CFR 63.6150(b)(3)]
- ix. Each subsequent semiannual compliance report must be postmarked or delivered no later than August 29 or March 1, whichever date is the first date following the end of the semiannual reporting period. [40 CFR 63.6150(b)(4) and (5)]
- x. For each stationary combustion turbine that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established the date for submitting annual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), the permittee may submit the first and subsequent compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (4) of this section. [40 CFR 63.6150(b)(5)]
- xi. ***Performance test report.*** After September 8, 2020, within 60 days after the date of completing each performance test required by this subpart, the owner or operator must submit the results of the performance test (as specified in 40 CFR 63.6145(f)) following the procedures specified in 40 CFR 63.6150(f)(1) through (3). [40 CFR 63.6150(f)]
- (1) ***Data collected using test methods supported by the EPA's Electronic Reporting Tool (ERT) as listed on the EPA's ERT website (<https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>) at the time of the test.*** Submit the results of the performance test to the EPA via the CEDRI, which can be accessed through the EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). The data must be submitted in a file format generated through the use of the EPA's ERT. Alternatively, you may submit an electronic file consistent with the extensible markup language (XML) schema listed on the EPA's ERT website. [40 CFR 63.6150(f)(1)]
- (2) ***Data collected using test methods that are not supported by the EPA's ERT as listed on the EPA's ERT website at the time of the test.*** The results of the performance test must be included as an attachment in the ERT or an alternate electronic file consistent with the XML schema listed on the EPA's ERT website. Submit the ERT generated package or alternative file to the EPA via CEDRI. [40 CFR 63.6150(f)(2)]
- (3) ***Confidential business information (CBI).*** If the permittee claims some of the information submitted under 40 CFR

63.6150(f)(1) is CBI, the permittee must submit a complete file, including information claimed to be CBI, to the EPA. The file must be generated through the use of the EPA's ERT or an alternate electronic file consistent with the XML schema listed on the EPA's ERT website. Submit the file on a compact disc, flash drive, or other commonly used electronic storage medium and clearly mark the medium as CBI. Mail the electronic medium to U.S. EPA/OAQPS/CORE CBI Office, Attention: Group Leader, Measurement Policy Group, MD C404-02, 4930 Old Page Rd., Durham, NC 27703. The same file with the CBI omitted must be submitted to the EPA via the EPA's CDX as described in 40 CFR 63.6150(f)(1). [40 CFR 63.6150(f)(3)]

e. **TAC**

- i. See Plantwide Requirements.¹²⁴

S4. Testing

[Regulation 2.16, section 4.1.9.1]

a. **General testing requirements**

- i. See Plantwide Requirements.

b. **NO_x**

- i. If the owner or operator elects to install and certify a NO_x-diluent CEMS under 40 CFR 60.4345, then the initial performance test required under 40 CFR 60.8 may be performed in the following alternative manner: [40 CFR 60.4405]
- (1) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs. [40 CFR 60.4405(a)]
 - (2) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit. [40 CFR 60.4405(b)]

¹²⁴ According to Regulation 5.21, section 2.7, TAC emissions from the natural gas-fired turbine are de minimis.

- (3) Use the test data both to demonstrate compliance with the applicable NO_x emission limit under 40 CFR 60.4320 and to provide the required reference method data for the RATA of the CEMS described under 40 CFR 60.4335. [40 CFR 60.4405(c)]
 - (4) Compliance with the applicable emission limit in 40 CFR 60.4320 is achieved if the arithmetic average of all of the NO_x emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit. [40 CFR 60.4405(d)]
 - ii. The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. The owner or operator may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. The owner or operator must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes. [40 CFR 60.4400(b)]
 - (1) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), the permittee must measure the total NO_x emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test. [40 CFR 60.4400(b)(2)]
 - (2) Compliance with the applicable emission limit in 40 CFR 60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NO_x emission rate at each tested level meets the applicable emission limit in 40 CFR 60.4320. [40 CFR 60.4400(b)(4)]
 - (3) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in 40 CFR 60.4405) as part of the initial performance test of the affected unit. [40 CFR 60.4400(b)(5)]
 - (4) The ambient temperature must be greater than 0°F during the performance test. [40 CFR 60.4400(b)(6)]
- c. **HAP**
 - i. The permittee must conduct the initial performance tests or other initial compliance demonstrations in Table 4 of NESHAP YYYY that apply within 180 calendar days after the compliance date that is specified for the stationary combustion turbine in §63.6095 and according to the provisions in §63.7(a)(2). [40 CFR 63.6110(a)]
 - ii. An owner or operator is not required to conduct an initial performance test to determine outlet formaldehyde concentration on units for which

a performance test has been previously conducted, but the test must meet all of the conditions described in 40 CFR 63.6110(b)(1) through (b)(5). [40 CFR 63.6110(b)]

- (1) The test must have been conducted using the same methods specified in NESHAP YYYY, and these methods must have been followed correctly. [40 CFR 63.6110(b)(1)]
 - (2) The test must not be older than 2 years. [40 CFR 63.6110(b)(2)]
 - (3) The test must be reviewed and accepted by the Administrator. [40 CFR 63.6110(b)(3)]
 - (4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes. [40 CFR 63.6110(b)(4)]
 - (5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load. [40 CFR 63.6110(b)(5)]
- iii. Subsequent performance tests must be performed on an annual basis as specified in Table 3 of NESHAP YYYY. [40 CFR 63.6115]
- iv. The owner or operator must conduct each performance test in Table 3 of NESHAP YYYY that applies. [40 CFR 63.6120(a)]
- (1) Each performance test must be conducted according to the requirements in Table 3 of NESHAP YYYY. Before September 8, 2020, each performance test must be conducted according to the requirements of the General Provisions at § 63.7(e)(1). [40 CFR 63.6120(b)]
 - (2) Performance tests must be conducted at high load, defined as 100 percent plus or minus 10 percent. After September 8, 2020, performance tests shall be conducted under such conditions based on representative performance of the affected source for the period being tested. Representative conditions exclude periods of startup and shutdown. The owner or operator may not conduct performance tests during periods of malfunction. The owner or operator must record the process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation. Upon request, the owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of performance tests. [40 CFR 63.6120(c)]
 - (3) You must conduct three separate test runs for each performance test, and each test run must last at least 1 hour. [40 CFR 63.6120(d)]

Emission Unit U24: 99.9 MMBtu/hr Natural Gas-Fired Auxiliary Steam Boiler**Applicable Regulations**

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|---|--------------------------------|
| Regulation | Title | Applicable Sections |
| 2.05 | Prevention of Significant Deterioration of Air Quality | 1 through 2 |
| 6.42 | Reasonably Available Control Technology Requirements for Major Volatile Organic Compound- and Nitrogen Oxides-Emitting Facilities | 1 through 5 |
| 7.06 | Standards of Performance for New Indirect Heat Exchangers | 1, 2, 3, 4.1.2, 4.2, 5.1.2, 6 |
| 40 CFR 60 Subpart Dc | Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units | 40 CFR 60.40c through 60.48c |
| 40 CFR 63 Subpart DDDDD | National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters | 40 CFR 63.7480 through 63.7575 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1 through 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.02 | Adoption and Incorporation by Reference of National Emission Standards for Hazardous Air Pollutants | 1, 2, 4, 5 |
| 5.14 | Hazardous Air Pollutants and Source Categories | 1, 2, 3.1.1 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 7 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| 7.02 | Adoption of Federal New Source Performance Standards | 1 through 5 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Plant ID: 0127

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|--|---------------------|---|-------------------|-------------------|
| E50 | NG Fired Auxiliary Boiler (99.9 MMBtu/hr) with LNB & FGR | Planned 2027 | STAR, 5.02, 5.14, 6.42, 7.06, 40CFR60-Dc, 40CFR63-DDDDD | N/A | S50 |

Control Devices

There is no control device associated with this unit.

U24 Specific Conditions

S1. Standards

[Regulation 2.16, Section 4.1.1]

- a. **HAP** [40 CFR 63 Subpart DDDDD]
 - i. Because the Auxiliary Boiler (U24) is a unit designed to burn gas 1 fuels, it is not subject to the emission limits in 40 CFR 63, Subpart DDDDD Tables 1 and 2 or 11 through 13, or the operating limits in 40 CFR 63, Subpart DDDDD Table 4. [40 CFR 63.7500(e)]
 - ii. The owner or operator shall complete an annual or 5-year tune-up as applicable as specified in 40 CFR 63.7540. [40 CFR 63.7500(a)(1) referencing Items 1 and 3 of 40 CFR 63, Subpart DDDDD, Table 3]
 - iii. At all times, the permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.7500(a)(3)]
 - iv. The permittee shall demonstrate initial compliance with the applicable work practice standards in 40 CFR 63, Subpart DDDDD, Table 3 within the applicable annual, biennial, or 5-year schedule as specified in 40 CFR 63.7515(d) following the initial compliance date specified in 40 CFR 63.7495(a). Thereafter, the permittee is required to complete the annual, biennial or 5-year tune-up as specified in 40 CFR 63.7515(d). [40 CFR 63.7510(g)]
 - v. If the permittee is required to meet an applicable tune-up work practice standard, the permittee shall conduct an annual, biennial, or 5-year performance tune-up according to 40 CFR 63.7540(a)(10), (11), or (12), respectively. Each annual tune-up specified in 40 CFR 63.7540(a)(10) shall be no more than 13 months after the previous tune-up. Each biennial tune-up specified in 40 CFR 63.7540(a)(11) shall be conducted no more than 25 months after the previous tune-up. Each 5-year tune-up specified in 40 CFR 63.7540(a)(12) shall be conducted no more than 61 months after the previous tune-up. If the unit is not operating on the required date for a tune-up, the tune-up shall be conducted within 30 calendar days of startup. [40 CFR 63.7515(d) and 63.7540(a)(13)]

- vi. The permittee shall conduct an annual tune-up of the boiler or process heater as specified in 40 CFR 63.7540(a)(10)(i) through (vi) to demonstrate continuous compliance. This frequency does not apply to units with continuous oxygen trim systems that maintain an optimum air to fuel ratio. [40 CFR 63.7540(a)(10)]
- (1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (the permittee may perform the burner inspection any time prior to the tune-up or delay the burner inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection. At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment; [40 CFR 63.7540(a)(10)(i)]
 - (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available; [40 CFR 63.7540(a)(10)(ii)]
 - (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection. [40 CFR 63.7540(a)(10)(iii)]
 - (4) Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any NO_x requirement to which the unit is subject. [40 CFR 63.7540(a)(10)(iv)]
 - (5) Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer; and [40 CFR 63.7540(a)(10)(v)]
 - (6) Maintain on-site and submit, if requested by the Administrator, a report containing the information in 40 CFR 63.7540(a)(10)(vi)(A) through (C), [40 CFR 63.7540(a)(10)(vi)]
 - (a) The concentrations of CO in the effluent stream in parts per million by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and

after the tune-up of the boiler or process heater; [40 CFR 63.7540(a)(10)(vi)(A)]

- (b) A description of any corrective actions taken as part of the tune-up; and [40 CFR 63.7540(a)(10)(vi)(B)]
- (c) The type and amount of fuel used over the 12 months prior to the tune-up, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may establish the fuel used by each unit. [40 CFR 63.7540(a)(10)(vi)(C)]

vii. If the boiler or process heater has a continuous oxygen trim system that maintains an optimum air to fuel ratio, the owner or operator must conduct a tune-up of the boiler or process heater every 5 years as specified in 40 CFR 63.7540(a)(10)(i) through (vi) to demonstrate continuous compliance. The owner or operator may delay the burner inspection specified in 40 CFR 63.7540(a)(10)(i) until the next scheduled or unscheduled unit shutdown, but the owner or operator must inspect each burner at least once every 72 months. If an oxygen trim system is utilized on a unit without emission standards to reduce the tune-up frequency to once every 5 years, the owner or operator shall set the oxygen level no lower than the oxygen concentration measured during the most recent tune-up. [40 CFR 63.7450(a)(12)]

viii. During a startup period or shutdown period, the permittee shall comply with the work practice standards established in 401 KAR 59:015, Section 7. An affected facility subject to 40 CFR 63.7500 shall meet the work practice standards established in 40 CFR Part 63, Table 3 to Subpart DDDDD, as established in 401 KAR 63:002, Section 2(4)(iii). [401 KAR 59:015, Section 7 and 401 KAR 59:015, Section 7(2)(a)]

b. NO_x

i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]

c. Opacity

i. The owner or operator shall not allow visible emissions to equal or exceed 20% opacity from emission point E50, except: [Regulation 7.08, section 3.1.2]¹²⁵

- (1) A maximum of 40% opacity shall be permissible for not more than two consecutive minutes in any 60 consecutive minutes; [Regulation 7.06, Section 4.2.1]
- (2) A maximum of 40% opacity shall be permissible for not more than six consecutive minutes in any 60 consecutive minutes during

¹²⁵ The District has determined that using a natural gas fired boiler will inherently meet the 20% opacity standard.

cleaning the fire box or blowing soot; [Regulation 7.06, Section 4.2.2]

- (3) For emissions from an indirect heat exchanger during building a new fire for the period required to bring the boiler up to operating conditions provided the method used is that recommended by the manufacturer and the time does not exceed the manufacturer's recommendations. [Regulation 7.06, Section 4.2.3]

d. **PM**

- i. The owner or operator shall not allow PM emissions to exceed 0.10 lb/MMBtu from emission point E50. [Regulation 7.06, Section 4.1.2]

e. **SO₂**

- i. The owner or operator shall not allow SO₂ emissions to exceed 0.8 lb/MMBtu from emission point E50. [Regulation 7.06, Section 5.1.2]

f. **VOC**

- i. The owner or operator shall implement good combustion and operating practices (See VOC RACT Attachment). [Regulation 6.42, Sections 4.1 and 4.2]

g. **TAC**

- i. See Plantwide Requirements.

S2. Monitoring and Record Keeping

[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

a. **40 CFR 60 Subpart Dc General Requirements**

- i. The owner or operator shall monitor and maintain records of natural gas usage (MMscf) for U24 on a monthly basis. [40 CFR 60.48c(g)(2)]
- ii. All records required under 40 CFR 60.48c shall be maintained by the owner or operator for a period of two years following the date of such record. [40 CFR 60.48c(i)]

b. **HAP** [40 CFR 63 Subpart DDDDD]

- i. The owner or operator shall keep a copy of each notification and report submitted to comply with 40 CFR 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report submitted, according

to the requirements of 40 CFR 63.10(b)(2)(xiv). [40 CFR 63.7555(a) and 63.7555(a)(1)]

- ii. If the owner or operator operates a unit in the unit designed to burn gas 1 subcategory that is subject to this subpart, and uses an alternative fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart under this part, other gas 1 fuel, or gaseous fuel subject to another subpart of this part or part 60, 61, or 65, the permittee must keep records of the total hours per calendar year that alternative fuel is burned and the total hours per calendar year that the unit operated during periods of gas curtailment or gas supply emergencies. [40 CFR 63.7555(h)]
 - iii. Records of notifications and reports submitted to comply with 40 CFR 63 Subpart DDDDD and records of other compliance demonstrations and performance evaluations required in 40 CFR 63.10(b)(2)(viii) shall be in a form suitable and readily available for expeditious review, according to 40 CFR 63.10(b)(1). [40 CFR 63.7560(a)]
 - iv. As specified in 40 CFR 63.10(b)(1), the owner or operator shall keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. [40 CFR 63.7560(b)]
 - v. The owner or operator shall keep each record on site, or they shall be accessible from on site (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). The permittee can keep the records off site for the remaining 3 years. [40 CFR 63.7560(c)]
- c. **NO_x**
 - i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]
 - d. **TAC**
 - i. See Plantwide Requirements

S3. Reporting
[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **40 CFR 60 Subpart Dc General Requirements**

- i. The permittee shall submit notification of the date of construction or reconstruction and actual startup, as provided by 40 CFR 60.7. This notification shall include: [40 CFR 60.48c(a)]
- (1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility. [40 CFR 60.48c(a)(1)]
 - (2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c, or 60.43c. [40 CFR 60.48c(a)(2)]
 - (3) The annual capacity factor at which the permittee anticipates operating the affected facility based on all fuel fired and based on each individual fuel fired. [40 CFR 60.48c(a)(3)]
 - (4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of 40 CFR 60.42c(a) or (b)(1), unless and until this determination is made by the Administrator. [40 CFR 60.48c(a)(4)]

b. **HAP [40 CFR 63 Subpart DDDDD]**

- i. The permittee must meet the notification requirements in 40 CFR 63.7545 according to the schedule in 40 CFR 63.7545 and in 40 CFR 63, Subpart A. Some of the notifications must be submitted before the permittee is required to comply with the emission limits and work practice standards in 40 CFR 63, Subpart DDDDD. [40 CFR 63.7495(d)]
- ii. The permittee must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 40 CFR 7545(e). [40 CFR 63.7530(f)]
- iii. The permittee shall report each instance in which an emission limit and operating limit in 40 CFR 63, Subpart DDDDD, Table 3, as applicable, was not met. These instances are deviations from the emission limits or operating limits, respectively, in 40 CFR 63, Subpart DDDDD. These deviations shall be reported according to the requirements in 40 CFR 63.7550. [40 CFR 63.7540(b)]

Plant ID: 0127

- iv. The permittee shall submit to the Administrator all of the notifications in 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (6), and 63.9(b) through (h) that apply by the dates specified. [40 CFR 63.7545(a)]
- v. As specified in 40 CFR 63.9(b)(4) and (5), for startup of a new or reconstructed affected source on or after January 31, 2013, the permittee shall submit an Initial Notification not later than 15 days after the actual date of startup of the affected source. [40 CFR 63.7545(c)]
- vi. The permittee shall submit the Notification of Compliance Status and shall contain the information specified in 40 CFR 63.7545(e)(1) and (8) and shall be submitted within 60 days of the compliance date specified at 40 CFR 63.7495(b). [40 CFR 63.7545 (e)]
 - (1) A description of the affected units including identification of which subcategories the unit is in, the design heat input capacity of the unit, a description of the add-on controls used on the unit to comply with 40 CFR 63, Subpart DDDDD, description of the fuel burned, including whether the fuel was a secondary material determined by the permittee or the EPA through a petition process to be a non-waste under 40 CFR 241.3, whether the fuel was a secondary material processed from discarded non-hazardous secondary material within the meaning of 40 CFR 241.3, and justification for the selection of fuel burned during the compliance demonstration. [40 CFR 63.7545(e)(1)]
 - (2) In addition to information required in 40 CFR 63.9(h)(2), the notification of compliance status must include the following certifications of compliance, as applicable, and signed by a responsible official: [40 CFR 63.7545(e)(8)]
 - (a) “This facility completed the required initial tune-up for all of the boilers and process heaters covered by 40 CFR part 63 subpart DDDDD at this site according to the procedures in 40 CFR 63.7540(a)(10)(i) through (vi).” [40 CFR 63.7545(e)(8)(i)]
- vii. If the permittee operates a unit designed to burn natural gas, refinery gas, or other gas 1 fuels that is subject to this subpart, and intends to use a fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart of this part, part 60, 61, or 65, or other gas 1 fuel to fire the affected unit during a period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575, the permittee must submit a notification of alternative fuel use within 48 hours of the declaration of each period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575. The notification must include the information specified in 40 CFR 63.7545(f)(1) through (5). [40 CFR 63.7545(f)]
 - (1) Company name and address. [40 CFR 63.7545(f)(1)]

- (2) Identification of the affected unit. [40 CFR 63.7545(f)(2)]
 - (3) Reason the permittee is unable to use natural gas or equivalent fuel, including the date when the natural gas curtailment was declared or the natural gas supply interruption began. [40 CFR 63.7545(f)(3)]
 - (4) Type of alternative fuel that the permittee intends to use. [40 CFR 63.7545(f)(4)]
 - (5) Dates when the alternative fuel use is expected to begin and end. [40 CFR 63.7545(f)(5)]
- viii. The permittee shall submit each report in 40 CFR 63, Subpart DDDDD, Table 9 that applies. [40 CFR 63.7550(a)]
- ix. The permittee may submit only an annual, biennial, or 5-year compliance report, as applicable, as specified in 40 CFR 63.7550(b)(1) through (4): [40 CFR 63.7550(b)]
- (1) If submitting an annual, biennial, or 5-year compliance report, the first compliance report must cover the period beginning on the compliance date that is specified for each boiler or process heater in 40 CFR 63.7495 and ending on December 31 within 1, 2, or 5 years, as applicable, after the compliance date that is specified for the source in 40 CFR 63.7495. [40 CFR 63.7550(b)(1)]
 - (2) The first annual, biennial, or 5-year compliance report must be postmarked or submitted no later than March 1. [40 CFR 63.7550(b)(2) and (5)]
 - (3) Annual, biennial, and 5-year compliance reports must cover the applicable 1-, 2-, or 5- year periods from January 1 to December 31. [40 CFR 63.7550(b)(3)]
 - (4) Annual, biennial, and 5-year compliance reports must be postmarked or submitted no later than March 1. [40 CFR 63.7550(b)(4) and (5)]
 - (5) For each affected source that is subject to permitting regulations pursuant to 40 CFR 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A), the permittee may submit the first and subsequent compliance reports according to the dates the permitting authority has established in the permit instead of according to the dates in 40 CFR 63.7550(b)(1) through (4). [40 CFR 63.7550(b)(5)]
- x. The permittee shall submit a compliance report with the information in 40 CFR 63.7550 (c)(5)(i) through (iii), (xiv), and (xvii): [40 CFR 63.7550(c)(1)]

- (1) Company and Facility name and address. [40 CFR 63.7550(c)(5)(i)]
 - (2) Process unit information, emission limitations, and operating parameter limitations. [40 CFR 63.7550(c)(5)(ii)]
 - (3) Date of report and beginning and ending dates of the reporting period. [40 CFR 63.7550(c)(5)(iii)]
 - (4) Include the date of the most recent tune-up for each unit subject to only the requirement to conduct an annual, biennial, or 5-year tune-up according to 40 CFR 63.7540(a)(10), (11), or (12) respectively. Include the date of the most recent burner inspection if it was not done annual, biennially, or on a 5-year period and was delayed until the next scheduled or unscheduled unit shutdown [40 CFR 63.7550(c)(5)(xiv)]
 - (5) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report. [40 CFR 63.7550(c)(5)(xvii)]
- xi. The permittee shall submit the reports according to the procedures specified in 40 CFR 63.7550(h)(1) through (3). [40 CFR 63.7550(h)]
- (1) The permittee must submit all reports required by Table 9 of this subpart electronically to the EPA via the CEDRI. (CEDRI can be accessed through the EPA's CDX.) The permittee must use the appropriate electronic report in CEDRI for this subpart. Instead of using the electronic report in CEDRI for this subpart, the permittee may submit an alternate electronic file consistent with the XML schema listed on the CEDRI Web site (<http://www.epa.gov/ttn/chief/cedri/index.html>), once the XML schema is available. If the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the permittee must submit the report to the Administrator at the appropriate address listed in 40 CFR 63.13. The permittee must begin submitting reports via CEDRI no later than 90 days after the form becomes available in CEDRI. [40 CFR 63.7550(h)(3)]

c. **NO_x**

- i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]

S4. Testing
[Regulation 2.16, section 4.1.9.3]

a. **General Testing Requirements**

- i. The owner or operator shall permit the District or Administrator of the EPA to conduct performance tests at any reasonable time shall cause the

Plant ID: 0127

affected facility to be operated for purposes of those tests under the conditions as the District or the Administrator of the EPA may specify based on representative performance of the affected facility, and shall make available to the District those records as may be necessary to determine the performance. [Regulation 1.04, Section 2.8]

Emission Unit U26: 15 MMBtu/hr Natural Gas-Fired Fuel Gas Dewpoint Heater

Applicable Regulations

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|---|--------------------------------|
| Regulation | Title | Applicable Sections |
| 2.05 | Prevention of Significant Deterioration of Air Quality | 1 through 2 |
| 6.42 | Reasonably Available Control Technology Requirements for Major Volatile Organic Compound- and Nitrogen Oxides-Emitting Facilities | 1 through 5 |
| 7.06 | Standards of Performance for New Indirect Heat Exchangers | 1, 2, 3, 4.1.2, 4.2, 5.1.2, 6 |
| 40 CFR 60 Subpart Dc | Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units | 40 CFR 60.40c through 60.48c |
| 40 CFR 63 Subpart DDDDD | National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters | 40 CFR 63.7480 through 63.7575 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1 through 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.02 | Adoption and Incorporation by Reference of National Emission Standards for Hazardous Air Pollutants | 1, 2, 4, 5 |
| 5.14 | Hazardous Air Pollutants and Source Categories | 1, 2, 3.1.1 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 7 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| 7.02 | Adoption of Federal New Source Performance Standards | 1 through 5 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Plant ID: 0127

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|----------------|---|--------------|---|------------|------------|
| E52 | NG Fired Fuel Gas Dewpoint Heater (15 MMBtu/hr) | Planned 2027 | STAR, 5.02, 5.14, 6.42, 7.06, 40CFR60-Dc, 40CFR63-DDDDD | N/A | S52 |

Control Devices

There is no control device associated with this unit.

U26 Specific Conditions

S5. Standards

[Regulation 2.16, Section 4.1.1]

- a. **HAP** [40 CFR 63 Subpart DDDDD]
 - i. Because the Fuel Gas (Dewpoint) Heater (U26) is a unit designed to burn gas 1 fuels, they are not subject to the emission limits in 40 CFR 63, Subpart DDDDD Tables 1 and 2 or 11 through 13, or the operating limits in 40 CFR 63, Subpart DDDDD Table 4. [40 CFR 63.7500(e)]
 - ii. The owner or operator shall complete an annual or 5-year tune-up as applicable as specified in 40 CFR 63.7540. [40 CFR 63.7500(a)(1) referencing Items 1 and 3 of 40 CFR 63, Subpart DDDDD, Table 3]
 - iii. At all times, the permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.7500(a)(3)]
 - iv. The permittee shall demonstrate initial compliance with the applicable work practice standards in 40 CFR 63, Subpart DDDDD, Table 3 within the applicable annual, biennial, or 5-year schedule as specified in 40 CFR 63.7515(d) following the initial compliance date specified in 40 CFR 63.7495(a). Thereafter, the permittee is required to complete the annual, biennial or 5-year tune-up as specified in 40 CFR 63.7515(d). [40 CFR 63.7510(g)]
 - v. If the permittee is required to meet an applicable tune-up work practice standard, the permittee shall conduct an annual, biennial, or 5-year performance tune-up according to 40 CFR 63.7540(a)(10), (11), or (12), respectively. Each annual tune-up specified in 40 CFR 63.7540(a)(10) shall be no more than 13 months after the previous tune-up. Each biennial tune-up specified in 40 CFR 63.7540(a)(11) shall be conducted no more than 25 months after the previous tune-up. Each 5-year tune-up specified in 40 CFR 63.7540(a)(12) shall be conducted no more than 61 months after the previous tune-up. If the unit is not operating on the required date for a tune-up, the tune-up shall be conducted within 30 calendar days of startup. [40 CFR 63.7515(d) and 63.7540(a)(13)]

- vi. The permittee shall conduct an annual tune-up of the boiler or process heater as specified in 40 CFR 63.7540(a)(10)(i) through (vi) to demonstrate continuous compliance. This frequency does not apply to units with continuous oxygen trim systems that maintain an optimum air to fuel ratio. [40 CFR 63.7540(a)(10)]
- (1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (the permittee may perform the burner inspection any time prior to the tune-up or delay the burner inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection. At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment; [40 CFR 63.7540(a)(10)(i)]
 - (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available; [40 CFR 63.7540(a)(10)(ii)]
 - (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection. [40 CFR 63.7540(a)(10)(iii)]
 - (4) Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any NO_x requirement to which the unit is subject. [40 CFR 63.7540(a)(10)(iv)]
 - (5) Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer; and [40 CFR 63.7540(a)(10)(v)]
 - (6) Maintain on-site and submit, if requested by the Administrator, a report containing the information in 40 CFR 63.7540(a)(10)(vi)(A) through (C), [40 CFR 63.7540(a)(10)(vi)]
 - (a) The concentrations of CO in the effluent stream in parts per million by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and

after the tune-up of the boiler or process heater; [40 CFR 63.7540(a)(10)(vi)(A)]

- (b) A description of any corrective actions taken as part of the tune-up; and [40 CFR 63.7540(a)(10)(vi)(B)]
- (c) The type and amount of fuel used over the 12 months prior to the tune-up, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may establish the fuel used by each unit. [40 CFR 63.7540(a)(10)(vi)(C)]

vii. If the boiler or process heater has a continuous oxygen trim system that maintains an optimum air to fuel ratio, the owner or operator must conduct a tune-up of the boiler or process heater every 5 years as specified in 40 CFR 63.7540(a)(10)(i) through (vi) to demonstrate continuous compliance. The owner or operator may delay the burner inspection specified in 40 CFR 63.7540(a)(10)(i) until the next scheduled or unscheduled unit shutdown, but the owner or operator must inspect each burner at least once every 72 months. If an oxygen trim system is utilized on a unit without emission standards to reduce the tune-up frequency to once every 5 years, the owner or operator shall set the oxygen level no lower than the oxygen concentration measured during the most recent tune-up. [40 CFR 63.7450(a)(12)]

viii. During a startup period or shutdown period, the permittee shall comply with the work practice standards established in 401 KAR 59:015, Section 7. An affected facility subject to 40 CFR 63.7500 shall meet the work practice standards established in 40 CFR Part 63, Table 3 to Subpart DDDDD, as established in 401 KAR 63:002, Section 2(4)(iii). [401 KAR 59:015, Section 7 and 401 KAR 59:015, Section 7(2)(a)]

b. NO_x

i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]

c. Opacity

i. The owner or operator shall not allow visible emissions to equal or exceed 20% opacity from emission point E52, except:¹²⁶ [Regulation 7.08, section 3.1.2]

- (1) A maximum of 40% opacity shall be permissible for not more than two consecutive minutes in any 60 consecutive minutes; [Regulation 7.06, Section 4.2.1]
- (2) A maximum of 40% opacity shall be permissible for not more than six consecutive minutes in any 60 consecutive minutes during

¹²⁶ The District has determined that using a natural gas fired heater will inherently meet the 20% opacity standard.

cleaning the fire box or blowing soot; [Regulation 7.06, Section 4.2.2]

- (3) For emissions from an indirect heat exchanger during building a new fire for the period required to bring the boiler up to operating conditions provided the method used is that recommended by the manufacturer and the time does not exceed the manufacturer's recommendations. [Regulation 7.06, Section 4.2.3]

d. **PM**

- i. The owner or operator shall not allow PM emissions to exceed 0.10 lb/MMBtu from emission point E52. [Regulation 7.06, Section 4.1.2]

e. **SO₂**

- i. The owner or operator shall not allow SO₂ emissions to exceed 0.8 lb/MMBtu from emission point E52. [Regulation 7.06, Section 5.1.2]

f. **VOC**

- i. The owner or operator shall implement good combustion and operating practices (See VOC RACT Attachment). [Regulation 6.42, Sections 4.1 and 4.2]

g. **TAC**

- i. See Plantwide Requirements.

S6. Monitoring and Record Keeping

[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

a. **40 CFR 60 Subpart Dc General Requirements**

- i. The owner or operator shall monitor and maintain records of natural gas usage (MMscf) for U26 on a monthly basis. [40 CFR 60.48c(g)(2)]
- ii. All records required under 40 CFR 60.48c shall be maintained by the owner or operator for a period of two years following the date of such record. [40 CFR 60.48c(i)]

b. **HAP** [40 CFR 63 Subpart DDDDD]

- i. The owner or operator shall keep a copy of each notification and report submitted to comply with 40 CFR 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report submitted, according

Plant ID: 0127

to the requirements of 40 CFR 63.10(b)(2)(xiv). [40 CFR 63.7555(a) and 63.7555(a)(1)]

- ii. If the owner or operator operates a unit in the unit designed to burn gas 1 subcategory that is subject to this subpart, and uses an alternative fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart under this part, other gas 1 fuel, or gaseous fuel subject to another subpart of this part or part 60, 61, or 65, the permittee must keep records of the total hours per calendar year that alternative fuel is burned and the total hours per calendar year that the unit operated during periods of gas curtailment or gas supply emergencies. [40 CFR 63.7555(h)]
 - iii. Records of notifications and reports submitted to comply with 40 CFR 63 Subpart DDDDD and records of other compliance demonstrations and performance evaluations required in 40 CFR 63.10(b)(2)(viii) shall be in a form suitable and readily available for expeditious review, according to 40 CFR 63.10(b)(1). [40 CFR 63.7560(a)]
 - iv. As specified in 40 CFR 63.10(b)(1), the owner or operator shall keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. [40 CFR 63.7560(b)]
 - v. The owner or operator shall keep each record on site, or they shall be accessible from on site (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). The permittee can keep the records off site for the remaining 3 years. [40 CFR 63.7560(c)]
- c. **NO_x**
 - i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]
 - d. **TAC**
 - i. See Plantwide Requirements

S7. Reporting

[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **40 CFR 60 Subpart Dc General Requirements**

- i. The permittee shall submit notification of the date of construction or reconstruction and actual startup, as provided by 40 CFR 60.7. This notification shall include: [40 CFR 60.48c(a)]
- (1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility. [40 CFR 60.48c(a)(1)]
 - (2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c, or 60.43c. [40 CFR 60.48c(a)(2)]
 - (3) The annual capacity factor at which the permittee anticipates operating the affected facility based on all fuel fired and based on each individual fuel fired. [40 CFR 60.48c(a)(3)]
 - (4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of 40 CFR 60.42c(a) or (b)(1), unless and until this determination is made by the Administrator. [40 CFR 60.48c(a)(4)]

b. **HAP [40 CFR 63 Subpart DDDDD]**

- i. The permittee must meet the notification requirements in 40 CFR 63.7545 according to the schedule in 40 CFR 63.7545 and in 40 CFR 63, Subpart A. Some of the notifications must be submitted before the permittee is required to comply with the emission limits and work practice standards in 40 CFR 63, Subpart DDDDD. [40 CFR 63.7495(d)]
- ii. The permittee must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 40 CFR 7545(e). [40 CFR 63.7530(f)]
- iii. The permittee shall report each instance in which an emission limit and operating limit in 40 CFR 63, Subpart DDDDD, Table 3, as applicable, was not met. These instances are deviations from the emission limits or operating limits, respectively, in 40 CFR 63, Subpart DDDDD. These deviations shall be reported according to the requirements in 40 CFR 63.7550. [40 CFR 63.7540(b)]

Plant ID: 0127

- iv. The permittee shall submit to the Administrator all of the notifications in 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (6), and 63.9(b) through (h) that apply by the dates specified. [40 CFR 63.7545(a)]
- v. As specified in 40 CFR 63.9(b)(4) and (5), for startup of a new or reconstructed affected source on or after January 31, 2013, the permittee shall submit an Initial Notification not later than 15 days after the actual date of startup of the affected source. [40 CFR 63.7545(c)]
- vi. The permittee shall submit the Notification of Compliance Status and shall contain the information specified in 40 CFR 63.7545(e)(1) and (8) and shall be submitted within 60 days of the compliance date specified at 40 CFR 63.7495(b). [40 CFR 63.7545 (e)]
 - (1) A description of the affected units including identification of which subcategories the unit is in, the design heat input capacity of the unit, a description of the add-on controls used on the unit to comply with 40 CFR 63, Subpart DDDDD, description of the fuel burned, including whether the fuel was a secondary material determined by the permittee or the EPA through a petition process to be a non-waste under 40 CFR 241.3, whether the fuel was a secondary material processed from discarded non-hazardous secondary material within the meaning of 40 CFR 241.3, and justification for the selection of fuel burned during the compliance demonstration. [40 CFR 63.7545(e)(1)]
 - (2) In addition to information required in 40 CFR 63.9(h)(2), the notification of compliance status must include the following certifications of compliance, as applicable, and signed by a responsible official: [40 CFR 63.7545(e)(8)]
 - (a) “This facility completed the required initial tune-up for all of the boilers and process heaters covered by 40 CFR part 63 subpart DDDDD at this site according to the procedures in 40 CFR 63.7540(a)(10)(i) through (vi).” [40 CFR 63.7545(e)(8)(i)]
- vii. If the permittee operates a unit designed to burn natural gas, refinery gas, or other gas 1 fuels that is subject to this subpart, and intends to use a fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart of this part, part 60, 61, or 65, or other gas 1 fuel to fire the affected unit during a period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575, the permittee must submit a notification of alternative fuel use within 48 hours of the declaration of each period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575. The notification must include the information specified in 40 CFR 63.7545(f)(1) through (5). [40 CFR 63.7545(f)]
 - (1) Company name and address. [40 CFR 63.7545(f)(1)]

- (2) Identification of the affected unit. [40 CFR 63.7545(f)(2)]
 - (3) Reason the permittee is unable to use natural gas or equivalent fuel, including the date when the natural gas curtailment was declared or the natural gas supply interruption began. [40 CFR 63.7545(f)(3)]
 - (4) Type of alternative fuel that the permittee intends to use. [40 CFR 63.7545(f)(4)]
 - (5) Dates when the alternative fuel use is expected to begin and end. [40 CFR 63.7545(f)(5)]
- viii. The permittee shall submit each report in 40 CFR 63, Subpart DDDDD, Table 9 that applies. [40 CFR 63.7550(a)]
- ix. The permittee may submit only an annual, biennial, or 5-year compliance report, as applicable, as specified in 40 CFR 63.7550(b)(1) through (4): [40 CFR 63.7550(b)]
- (1) If submitting an annual, biennial, or 5-year compliance report, the first compliance report must cover the period beginning on the compliance date that is specified for each boiler or process heater in 40 CFR 63.7495 and ending on December 31 within 1, 2, or 5 years, as applicable, after the compliance date that is specified for the source in 40 CFR 63.7495. [40 CFR 63.7550(b)(1)]
 - (2) The first annual, biennial, or 5-year compliance report must be postmarked or submitted no later than January 31. [40 CFR 63.7550(b)(2)]
 - (3) Annual, biennial, and 5-year compliance reports must cover the applicable 1-, 2-, or 5- year periods from January 1 to December 31. [40 CFR 63.7550(b)(3)]
 - (4) Annual, biennial, and 5-year compliance reports must be postmarked or submitted no later than January 31. [40 CFR 63.7550(b)(4)]
 - (5) For each affected source that is subject to permitting regulations pursuant to 40 CFR 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 71.6(a)(3)(iii)(A), the permittee may submit the first and subsequent compliance reports according to the dates the permitting authority has established in the permit instead of according to the dates in 40 CFR 63.7550(b)(1) through (4). [40 CFR 63.7550(b)(5)]
- x. The permittee shall submit a compliance report with the information in 40 CFR 63.7550 (c)(5)(i) through (iii), (xiv), and (xvii): [40 CFR 63.7550(c)(1)]

- (1) Company and Facility name and address. [40 CFR 63.7550(c)(5)(i)]
 - (2) Process unit information, emission limitations, and operating parameter limitations. [40 CFR 63.7550(c)(5)(ii)]
 - (3) Date of report and beginning and ending dates of the reporting period. [40 CFR 63.7550(c)(5)(iii)]
 - (4) Include the date of the most recent tune-up for each unit subject to only the requirement to conduct an annual, biennial, or 5-year tune-up according to 40 CFR 63.7540(a)(10), (11), or (12) respectively. Include the date of the most recent burner inspection if it was not done annual, biennially, or on a 5-year period and was delayed until the next scheduled or unscheduled unit shutdown [40 CFR 63.7550(c)(5)(xiv)]
 - (5) Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report. [40 CFR 63.7550(c)(5)(xvii)]
- xi. The permittee shall submit the reports according to the procedures specified in 40 CFR 63.7550(h)(1) through (3). [40 CFR 63.7550(h)]
- (1) The permittee must submit all reports required by Table 9 of this subpart electronically to the EPA via the CEDRI. (CEDRI can be accessed through the EPA's CDX.) The permittee must use the appropriate electronic report in CEDRI for this subpart. Instead of using the electronic report in CEDRI for this subpart, the permittee may submit an alternate electronic file consistent with the XML schema listed on the CEDRI Web site (<http://www.epa.gov/ttn/chief/cedri/index.html>), once the XML schema is available. If the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the permittee must submit the report to the Administrator at the appropriate address listed in 40 CFR 63.13. The permittee must begin submitting reports via CEDRI no later than 90 days after the form becomes available in CEDRI. [40 CFR 63.7550(h)(3)]

c. **NO_x**

- i. See NO_x RACT Plan [Regulation 6.42, Section 4.3]

S8. Testing
[Regulation 2.16, section 4.1.9.3]

a. **General Testing Requirements**

- i. The owner or operator shall permit the District or Administrator of the EPA to conduct performance tests at any reasonable time shall cause the

Plant ID: 0127

affected facility to be operated for purposes of those tests under the conditions as the District or the Administrator of the EPA may specify based on representative performance of the affected facility, and shall make available to the District those records as may be necessary to determine the performance. [Regulation 1.04, Section 2.8]

Emission Unit U25: 2 MW Diesel-Fired Emergency Generator**Applicable Regulations**

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|--|---|
| Regulation | Title | Applicable Sections |
| 40 CFR 63 Subpart ZZZZ | National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines | 63.6603, 6604, 6605, 6625, 6640, 6645, 6655 |
| 40 CFR 60 Subpart IIII | Standards of Performance for Stationary Compression Ignition Internal Combustion Engines | 60.4200 - 4219 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|--|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |

STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|--|---------------------|---|-------------------|-------------------|
| E51 | One 2 MW diesel generator, make Caterpillar, model C18, or equivalent, rated at 2,925 BHP, model year post-2006 (Tier 2) | Planned 2027 | 40 CFR 63 Subpart ZZZZ, 40 CFR 60 Subpart IIII, STAR ¹²⁷ | N/A | S51 |

Control Devices

There is no control device associated with this unit.

¹²⁷ This equipment is subject to STAR since it has TAC emissions.

U25 Specific Conditions

S1. Standards

[Regulation 2.16, section 4.1.1]

a. General Requirements for NSPS IIII

- i. The owner or operator of 2007 model year or later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in 40 CFR 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE. [40 CFR 60.4205(b)]

Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in 40 CFR 60.4202(a)(1) through (2).

[40 CFR 60.4202(a) refers to 40 CFR 1039, Appendix I, and 40 CFR 1039.105]

| unit: g/KW-hr | NO _x + NMHC | CO | PM |
|---|--|-----|------|
| Emission Standards (Table 2 to 40 CFR 1039 Appendix I) | 6.4 | 3.5 | 0.20 |
| Smoke emission standard (40 CFR 1039.105(b)) | 1) 20% during acceleration mode 2) 15% during lugging mode 3) 50% during peaks in acceleration or lugging mode | | |

- ii. The owner or operator must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4205 over the entire life of the engine. [40 CFR 60.4206]
- iii. Beginning October 1, 2010, the owner or operator of a stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that uses diesel fuel shall use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted: [40 CFR 60.4207(b)]
 - (1) Sulfur content: 15 parts per million (ppm) maximum for NR diesel fuel. [40 CFR 1090.305(b)]
 - (2) A minimum cetane index of 40; or [40 CFR 1090.305(c)(1)]

- (3) A maximum aromatic content of 35 volume percent.
[40 CFR 1090.305(c)(2)]
- iv. The owner or operator that must comply with the emission standards specified in 40 CFR 60 Subpart IIII shall do all of the following:
[40 CFR 60.4211(a)]
 - (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; [40 CFR 60.4211(a)(1)]
 - (2) Change only those emission-related settings that are permitted by the manufacturer; [40 CFR 60.4211(a)(2)]
- v. The owner or operator shall purchase an engine certified to the emission standards in 40 CFR 60.4205(b), as applicable for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications. [40 CFR 60.4211(c)]
- vi. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 60 CFR 60.4211(f)(1) through (3), is prohibited. If the owner or operator does not operate the engine according to the requirements in 60 CFR 60.4211(f)(1) through (3), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.
[40 CFR 60.4211(f)]
 - (1) There is no time limit on the use of emergency stationary ICE in emergency situations. [40 CFR 60.4211(f)(1)]
 - (2) The owner or operator may operate the emergency stationary ICE for the purpose specified in 40 CFR 60.4211(f)(2)(i) for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by 40 CFR 60.4211(f)(3) counts as part of the 100 hours per calendar year allowed by 40 CFR 60.4211(f)(2).
[40 CFR 60.4211(f)(2)]
 - (a) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner

or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

[40 CFR 60.4211(f)(2)(i)]

- (3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in 40 CFR 60.4211(f)(2). Except as provided in 40 CFR 60.4211(f)(3)(i), the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[40 CFR 60.4211(f)(3)]

- (a) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met: [40 CFR 60.4211(f)(3)(i)]

(i) The engine is dispatched by the local balancing authority or local transmission and distribution system operator; [40 CFR 60.4211(f)(3)(i)(A)]

(ii) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

[40 CFR 60.4211(f)(3)(i)(B)]

(iii) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

[40 CFR 60.4211(f)(3)(i)(C)]

(iv) The power is provided only to the facility itself or to support the local transmission and distribution system. [40 CFR 60.4211(f)(3)(i)(D)]

(v) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these

records on behalf of the engine owner or operator.
[40 CFR 60.4211(f)(3)(i)(E)]

b. HAP

- i. The equipment listed in this emission unit is subject to 40 CFR 63 Subpart ZZZZ, however, there are no applicable HAP standards in this regulation.¹²⁸

c. TAC

- i. See Plantwide Requirements.¹²⁹

S2. Monitoring and Record Keeping

[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the required records for a minimum of 5 years and make the records readily available to the District upon request.

a. Unit Operation

- i. The owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines shall install a non-resettable hour meter prior to startup of the engine. [40 CFR 60.4209(a)]
- ii. The owner or operator is not required to submit an initial notification. Starting with the model years in Table 5 to 40 CFR 60 Subpart IIII, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator shall keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. [40 CFR 60.4214(b)]

¹²⁸ According to 40 CFR 63.6590(c), E51 must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines. No further requirements apply for E51 under 40 CFR 63 other than the initial notification requirements in 40 CFR 63.6645(f).

¹²⁹ TAC emissions from this equipment are de minimis.

Plant ID: 0127

b. **HAP**

- i. There are no compliance monitoring or record keeping requirements for HAP.

c. **TAC**

- i. See Plantwide Requirements.

S3. Reporting

[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **Unit Operation**

- i. The owner or operator is not required to submit an initial notification under 40 CFR Subpart III. [40 CFR 60.4214(b)]

b. **HAP**

- i. If the owner or operator is required to submit an Initial Notification but is otherwise not affected by the requirements of this subpart, the notification should include the information in 40 CFR 63.9(b)(2)(i) through (v), and a statement that the stationary RICE has no additional requirements and explain the basis of the exclusion. [40 CFR 63.6645(f)]

c. **TAC**

- i. See Plantwide Requirements.

Permit Shield

The owner or operator is hereby granted a permit shield that shall apply as long as the owner or operator demonstrates ongoing compliance with all conditions of this permit. Compliance with the conditions of this permit shall be deemed compliance with all applicable requirements of the regulations cited in this permit as of the date of issuance, pursuant to Regulation 2.16, section 4.6.1.

Off-Permit Documents

The source has the following off-permit documents associated with this Title V permit:

- 1) Fugitive Dust Control Plan.

Alternative Operating Scenario

The company requested no alternative operating scenario in its Title V application.

Insignificant Activities

| Equipment | Qty. | PTE (ton/yr) | Regulation Basis |
|---|------|-----------------------|------------------------------------|
| Fuel or Lubricating oils storage tanks with vapor pressure <10mm Hg @ 20 deg C (See unit IA5) | 17 | 0.005 VOC | Regulation 1.02, Appendix A, 3.9.2 |
| 1,000 gallon storage tank for #1 fuel oil with annual turnover < 2X the capacity (See unit IA5) | 1 | 0.001 VOC | Regulation 1.02, Appendix A, 3.25 |
| Minor natural gas combustion sources <10 MMBtu/hr (direct heat exchangers) | 24 | 0.79 NOx | Regulation 2.16, section 1.23 |
| Emergency relief vents for boiler steam supply | 24 | 0 | Regulation 1.02, Appendix A, 3.10 |
| Lab exhaust systems | 3 | 0.001 VOC | Regulation 1.02, Appendix A, 3.11 |
| Portable kerosene storage tanks with capacity less than 500 gallons (See unit IA5) | 1 | 3.5e-5 VOC | Regulation 1.02, Appendix A, 3.23 |
| Ash pond with wet storage | 1 | 0 | Regulation 2.16, section 1.23 |
| Cooling Towers for Unit 2 and Unit 3 (See unit IA5) | 2 | 3.35 PM ₁₀ | Regulation 2.16, section 1.23 |
| Cooling Tower for Unit 23 (See unit IA5) | 1 | 1.03 tpy PM | Regulation 2.16, section 1.23 |
| Stack piles (coal, limestone, gypsum piles) | 3 | 1.66 PM ₁₀ | Regulation 2.16, section 1.23 |
| Turbine oil reservoir vapor extractor | 4 | 0 | Regulation 2.16, section 1.23 |
| Hydrogen seal oil tank vent | 4 | 0 | Regulation 2.16, section 1.23 |
| Gypsum handling equipment (See unit IA5) | 1 | 4.69 PM ₁₀ | Regulation 2.16, section 1.23 |

Plant ID: 0127

| Equipment | Qty. | PTE (ton/yr) | Regulation Basis |
|--|------|--------------------------|-------------------------------|
| Portable gypsum dewatering systems (See unit IA5) | 2 | 1.27 PM ₁₀ | Regulation 2.16, section 1.23 |
| Gasoline storage tank, 3,000 gallons (previous U10, see unit IA1) | 1 | 1.87 VOC | Regulation 2.16, section 1.23 |
| Non-halogenated cold solvent parts washers with secondary reservoir (previous U11, see unit IA2) | 8 | 0.33 VOC | Regulation 2.16, section 1.23 |
| Emergency generators, 800 HP each (previous U13, see unit IA3) | 2 | 4.93 NO _x | Regulation 2.16, section 1.23 |
| Fire pumps, 157 HP, 183 HP (See unit IA4) | 2 | 1.42 NO _x | Regulation 2.16, section 1.23 |
| Fire pump, 400 HP (See unit IA4) | 1 | 0.575 NO _x | Regulation 2.16, section 1.23 |
| Emergency vent for U1 and U2 boilers | 1 | 0.7 NO _x | Regulation 2.16, section 1.23 |
| Bottom/flyash silos (See unit IA5) | 2 | 2.34 PM ₁₀ | Regulation 2.16, section 1.23 |
| Ash pug mill mixers (See unit IA5) | 4 | 4.7 PM ₁₀ | Regulation 2.16, section 1.23 |
| Process water system (See unit IA5) | 1 | 1.69 PM ₁₀ | Regulation 2.16, section 1.23 |
| Emergency generator, natural gas fired, 105 HP (See unit IA3) | 1 | 0.75 CO | Regulation 2.16, section 1.23 |
| HVAC Heaters (Total Heat Input <10 MMBtu/hr, see unit IA5) | 1 | 4.14 tpy NO _x | Regulation 2.16, section 1.23 |
| Lube Oil System Demister Vents (see unit IA5) | 1 | 0.66 tpy VOC | Regulation 2.16, section 1.23 |
| Diesel Storage Tanks for NGCC Units (see unit IA5) | 1 | 1.1E-3 tpy VOC | Regulation 2.16, section 1.23 |

1. Insignificant activities identified in District Regulation 1.02, Appendix A, may be subject to size or production rate disclosure requirements pursuant to Regulation 2.16 section 3.5.4.1.4.
2. Insignificant activities identified in District Regulation 1.02, Appendix A shall comply with generally applicable requirements as required by Regulation 2.16 section 4.1.9.4.
3. The Insignificant Activities Table is correct as of the date the permit was proposed for review by U.S. EPA, Region 4.
4. Emissions from Insignificant Activities shall be reported in conjunction with the reporting of annual emissions of the facility as required by the District.
5. The owner or operator shall submit an updated list of insignificant activities that occurred during the preceding year pursuant to Regulation 2.16 section 4.3.5.3.6.
6. The owner or operator may elect to monitor actual throughputs for each of the insignificant activities and calculate actual annual emissions, or use Potential to Emit (PTE) to be reported on the annual emission inventory.
7. The District has determined pursuant to Regulation 2.16 section 4.1.9.4 that no monitoring, record keeping, or reporting requirements apply to the insignificant activities listed, except

Plant ID: 0127

for the equipment that has an applicable regulation and permitted under an insignificant activity (IA) unit.

Deleted pages with no edits

Emission Unit IA4: Fire Pump Engines ¹⁴⁰

Applicable Regulations

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|--|---|
| Regulation | Title | Applicable Sections |
| 40 CFR 63 Subpart ZZZZ | National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines | 63.6603, 6604, 6605, 6625, 6640, 6645, 6655 |
| 40 CFR 60 Subpart IIII | Standards of Performance for Stationary Compression Ignition Internal Combustion Engines | 60.4200 - 4219 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|--|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |

STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23

Equipment ¹⁴¹

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|---|---------------------|-------------------------------|-------------------|-------------------|
| IE9 | One (1) diesel fire pump engine, make Clarke, model JU4H-UFADY8, rated at 157 HP with | 2014 | 40 CFR 63 Subpart ZZZZ, | N/A | Fugitive |

¹⁴⁰ Per Regulation 5.21, section 2.3, emissions from insignificant activity are de minimis.

¹⁴¹ Potential emissions for this permitted operation are greatest for nitrogen oxides (NOx). Based on AP-42 Emission Factors and 500 hours per year for an emergency generator, as defined by EPA, the potential NOx emissions for this permitted operation is less than 5 tons per year.

Plant ID: 0127

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|----------------|--|--------------|--|------------|------------|
| | a 187 gallon diesel fuel tank. ^{142,143} Model year 2013 | | 40 CFR 60 Subpart III, STAR ¹⁴⁴ | | |
| IE10 | One (1) diesel fire pump engine, make Clarke, model JU6H-UFADY58, rated at 183 HP with a 300 gallon diesel fuel tank. ^{142,143} Model year 2013 | 2014 | 40 CFR 63 Subpart ZZZZ, 40 CFR 60 Subpart III, STAR ¹⁴⁴ | N/A | Fugitive |
| IE28 | One (1) diesel fire pump engine, make Clarke, or similar, rated at 400 HP with a 440 gallon diesel fuel tank. Model year post-2009 | Planned 2027 | 40 CFR 63 Subpart ZZZZ, 40 CFR 60 Subpart III, STAR | N/A | Fugitive |

Control Devices

There is no control device associated with this unit.

¹⁴² This operation is subject to 40 CFR 63 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, because it involves a stationary reciprocating internal combustion engine (RICE) located at a major source of HAP emissions. The proposed new stationary RICE meets the definition in 40 CFR 63.6675 of an emergency stationary RICE, which, per 40 CFR 63.6590(c), shall meet the requirements of 40 CFR 63 Subpart ZZZZ and 40 CFR 60 Subpart III.

¹⁴³ Fire pump engine is an emergency engine per 40 CFR 60 Subpart III, 60.4219, “Fire pump engine” means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.”

¹⁴⁴ This equipment is subject to STAR since it has TAC emissions. Per Regulation 5.21, section 2.3, emissions from insignificant activity are de minimis.

IA4 Specific Conditions

S1. Standards

[Regulation 2.16, section 4.1.1]

a. Unit Operation

- i. The owner or operator that must comply with the emission standards specified in 40 CFR 60 Subpart IIII shall do all of the following:
[40 CFR 60.4211(a)]
 - (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; [40 CFR 60.4211(a)(1)]
 - (2) Change only those emission-related settings that are permitted by the manufacturer; [40 CFR 60.4211(a)(2)]
- ii. The owner or operator shall purchase an engine certified to the emission standards in 40 CFR 60.4205(c), as applicable for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer’s specifications. [40 CFR 60.4211(c)]
- iii. Engine manufacturers shall certify the fire pump stationary CI engines to the emission standards in table 4 to 40 CFR 60 Subpart IIII, for all pollutants, for the same model year and NFPA nameplate power.
[40 CFR 60.4202(d)]

Fire pump engines for this unit are subject to following emission standards in g/KW-hr (g/HP-hr): [Table 4 to 40 CFR 60 Subpart IIII]

| Equipment Description | Model Year | NMHC+ NO _x | CO | PM |
|------------------------|------------|-----------------------|-----------|-------------|
| IE9: 157 HP fire pump | 2013 | 4.0 (3.0) | N/A | 0.30 (0.22) |
| IE10: 183 HP fire pump | 2013 | 4.0 (3.0) | N/A | 0.20 (0.15) |
| IE28: 400 HP fire pump | Post-2009 | 4.0 (3.0) | 3.5 (2.6) | 0.20 (0.15) |

- iv. The owner or operator must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4205 over the entire life of the engine. [40 CFR 60.4206]
- v. The owner or operator shall not combust in the engine a nonroad diesel fuel that contains more than 15 ppm of sulfur.
[40 CFR 60.4207(b)] [40 CFR 80.510(b)(1)(i)]

- vi. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 40 CFR 60.4211(f)(1) through (3), is prohibited. If the owner or operator does not operate the engine according to the requirements in 40 CFR 60.4211(f)(1) through (3), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.
[40 CFR 60.4211(f), 40 CFR 63.6640(f)]
- (1) There is no time limit on the use of emergency stationary ICE in emergency situations.
[40 CFR 60.4211(f)(1), 40 CFR 63.6640(f)(1)]
- (2) The owner or operator may operate the emergency stationary ICE for any combination of the purposes specified in 40 CFR 60.4211(f)(2)(i) through (iii) for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by 40 CFR 60.4211(f)(3) counts as part of the 100 hours per calendar year allowed by this paragraph.
[40 CFR 60.4211(f)(2), 40 CFR 63.6640(f)(2)]
- (a) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
[40 CFR 60.4211(f)(2)(i), 40 CFR 63.6640(f)(2)(i)]
- (3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing.
[40 CFR 60.4211(f)(3), 40 CFR 63.6640(f)(3)]
- vii. At all times the owner or operator shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the owner or operator to make any further efforts to reduce emissions if levels required by this standard have been achieved.

Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605(b)]

b. **HAP**

- i. The equipment listed in this emission unit is subject to 40 CFR 63 Subpart ZZZZ, however, there are no HAP standards.

c. **TAC**

- i. See Plantwide Requirements.¹⁴⁵

S2. Monitoring and Record Keeping

[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the required records for a minimum of 5 years and make the records readily available to the District upon request.

a. **Unit Operation**

- i. The owner or operator is not required to submit an initial notification. The owner or operator shall keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. [40 CFR 60.4214(b)]
- ii. The owner or operator shall maintain records of the fuel MSDS sheets and receipts showing dates, amounts of fuel purchased, sulfur content of fuel purchased and supplier's name and address, to show compliance.

b. **HAP**

- i. There are no compliance monitoring or record keeping requirements for HAP.

c. **TAC**

- i. See Plantwide Requirements.

¹⁴⁵ TAC emissions from this equipment are de minimis.

S3. Reporting

[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **Unit Operation**

i. There are no routine reporting requirements for this equipment.

b. **HAP**

i. There are no routine reporting requirements for this equipment.

c. **TAC**

i. See Plantwide Requirements.

Emission Unit IA5: Other Insignificant Activities**Applicable Regulations**

| FEDERALLY ENFORCEABLE REGULATIONS | | |
|--|--|----------------------------|
| Regulation | Title | Applicable Sections |
| 7.08 | Standards of Performance for New Affected Facilities | 1, 2, 3, 4, 5, 6 |

| DISTRICT ONLY ENFORCEABLE REGULATIONS | | |
|---|---|----------------------------|
| Regulation | Title | Applicable Sections |
| 5.00 | Definitions | 1, 2 |
| 5.01 | General Provisions | 1 through 2 |
| 5.20 | Methodology for Determining Benchmark Ambient Concentration of a Toxic Air Contaminant | 1 through 6 |
| 5.21 | Environmental Acceptability for Toxic Air Contaminants | 1 through 5 |
| 5.22 | Procedures for Determining the Maximum Ambient Concentration of a Toxic Air Contaminant | 1 through 5 |
| 5.23 | Categories of Toxic Air Contaminants | 1 through 6 |
| STAR regulations are 5.00, 5.01, 5.20, 5.21, 5.22, and 5.23 | | |

Equipment

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|-----------------------|--|---------------------|-------------------------------|-------------------|-------------------|
| IE11 | Seventeen (17) lubricating oil tanks, capacity ranged from 400 to 20,000 gallons, each has a vapor pressure less than 1.0 mmHg (< 0.019 psi) | N/A | STAR ¹⁴⁶ | N/A | Fugitive |
| IE12 | One (1) 1,000 gallon storage tank for #1 fuel oil with annual turnover < 2X the capacity, vapor pressure less than 0.019 psi | N/A | | N/A | Fugitive |
| IE13 | One (1) portable kerosene storage tanks with capacity less than 500 gallons, vapor pressure less than 0.019 psi | N/A | | N/A | Fugitive |
| IE14 | Two (2) cooling towers for Unit 2 and Unit 3 | N/A | 7.08 | N/A | Fugitive |

¹⁴⁶ This equipment is subject to STAR since it has TAC emissions. Per Regulation 5.21, section 2.3, emissions from insignificant activity are de minimis.

| Emission Point | Description | Install Date | Applicable Regulations | Control ID | Release ID |
|----------------|--|--------------|------------------------|------------|------------|
| IE15 | One (1) gypsum handling equipment, including two (2) stackers, one (1) overland conveyor, one (1) barge loading, one (1) truck loading, four (4) belt filters, two (2) conveyors, two (2) hoppers, and three (3) transfer towers | N/A | 7.08 | N/A | Fugitive |
| IE17 | One (1) bottom/fly ash storage silo equipped with bin vent filters, make and model TBD, rated capacity 325 tph. ¹⁴⁷ | N/A | 7.08 | C40 | S30 |
| IE18 | One (1) bottom/fly ash storage silo equipped with bin vent filters, make and model TBD, rated capacity 325 tph. ¹⁴⁷ | N/A | 7.08 | C41 | S31 |
| IE19 | One (1) pub mill mixers, make and model TBD, rated capacity 200 tph ¹⁴⁷ | N/A | 7.08 | N/A | Fugitive |
| IE20 | One (1) pub mill mixers, make and model TBD, rated capacity 200 tph ¹⁴⁷ | N/A | 7.08 | N/A | Fugitive |
| IE21 | One (1) pub mill mixers, make and model TBD, rated capacity 200 tph ¹⁴⁷ | N/A | 7.08 | N/A | Fugitive |
| IE22 | One (1) pub mill mixers, make and model TBD, rated capacity 200 tph ¹⁴⁷ | N/A | 7.08 | N/A | Fugitive |
| IE23 | One (1) process water system (PWS), ¹⁴⁸ including: | | | | |
| | IE23-a: one (1) hydrated lime silos with bin vent filters, make and model TBD, rated capacity 10 tph; | NA | 7.08 | C42-a | S32-a |
| | IE23-b: one (1) hydrated lime silos with bin vent filters, make and model TBD, rated capacity 10 tph; | | | C42-b | S32-b |
| | IE23-c: one (1) PWS solid material storage pile; | | | N/A | Fugitive |
| | IE23-d: one (1) front-end loader used to load material to trucks, capacity 20 tph. | | | N/A | Fugitive |
| IE24 | Cooling Tower for Unit 23 | N/A | 7.08 | N/A | Fugitive |
| IE25 | Lube Oil System with Demister Vents | N/A | STAR | N/A | Fugitive |
| IE26 | Diesel Storage Tanks for NGCC Units | N/A | STAR | N/A | Fugitive |
| IE27 | HVAC Heaters (Total Heat Input < 10 MMBtu/hr | N/A | STAR | N/A | Fugitive |

¹⁴⁷ A construction application for this equipment was submitted on 3/24/2017. The District has determined this is an insignificant activity per PTE, therefore no construction permit is required.

¹⁴⁸ A construction application for this equipment was submitted on 3/2/2018. The District has determined this is an insignificant activity per PTE, therefore no construction permit is required.

Control Devices

| Control ID | Description | Control Efficiency | Performance Indicator |
|-------------------|---|---------------------------|------------------------------|
| C40 | One (1) bin vent filter controlling ash storage silo | 98% | N/A ¹⁴⁹ |
| C41 | One (1) bin vent filter controlling ash storage silo | 98% | N/A ¹⁴⁹ |
| C42-a | One (1) bin vent filter controlling PWS hydrated lime silos | 98% | N/A ¹⁴⁹ |
| C42-b | One (1) bin vent filter controlling PWS hydrated lime silos | 98% | N/A ¹⁴⁹ |

¹⁴⁹ The bin vent filter equipped for each silo is considered as an integrated component of the silo. However, there are monitoring, record keeping and reporting requirements associated with any times that the filters are not in place and the process is operated. The District's pre-approved control efficiency for bin vent filters is 98%.

IA5 Specific Conditions

S1. Standards

[Regulation 2.16, section 4.1.1]

a. Opacity

For ash storage silos and pug mill mixers (IE14-IE22), PWS (IE23), and Unit 23 Cooling Tower (IE24): The owner or operator shall not allow visible emissions to equal or exceed 20% opacity. [Regulation 6.09, section 3.1] [Regulation 7.08, section 3.1.1]

b. PM

- i. For cooling towers (IE14 and IE24): The owner or operator shall not allow PM emissions to exceed 93.4 lb/hr for Unit 2 cooling tower and 98.2 lb/hr for Unit 3 cooling tower, and 86.8 lb/hr for Unit 23 cooling tower based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- ii. For gypsum handling equipment (IE15): The owner or operator shall not allow PM emissions from all the gypsum handling equipment combined to exceed 36.2 lb/hr based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- iii. For ash storage silos (IE17 and IE18): The owner or operator shall not allow PM emissions from each silo to exceed 43.7 lb/hr based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- iv. For pug mill mixers (IE19, IE20, IE21, and IE22): The owner or operator shall not allow PM emissions from each pug mill mixer to exceed 40.41 lb/hr based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- v. For hydrated lime silos (IE23-a and IE23-b): The owner or operator shall not allow PM emissions from each silo to exceed 14.97 lb/hr based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- vi. For PWS solid material storage pile (IE23-c) and front-end loader (IE23-d): The owner or operator shall not allow PM emissions from each silo to exceed 23.00 lb/hr based on actual operating hours in a calendar day.¹⁵⁰ [Regulation 7.08, section 3.1.2]
- vii. For ash silos (IE17 and IE18) and lime silos (IE23-a and IE23-b): The owner or operator shall maintain the bin vent filters in place at all times the process equipment is in operation, including periods of startup, shutdown, and

¹⁵⁰ It has been demonstrated that the PM emissions from this equipment cannot exceed the lb/hr PM standards uncontrolled.

malfunction, in a manner consistent with good air pollution control practice to meet the standards. [Regulation 1.05, section 5]

c. **TAC**

For storage tanks (IE11, IE12, and IE13, and IE26), Lube Oil System Demister Vents (IE25), and HVAC Heaters (IE27):

- i. See Plantwide Requirements.¹⁵¹

S2. Monitoring and Record Keeping

[Regulation 2.16, sections 4.1.9.1 and 4.1.9.2]

The owner or operator shall maintain the required records for a minimum of 5 years and make the records readily available to the District upon request.

a. **Opacity**

- i. There are no monitoring and record keeping requirements for IE14, and IE15, and IE24.
- ii. For ash storage silos and pug mill mixers (IE17-IE22), PWS (IE23):
- (1) The owner or operator shall, monthly, conduct a one-minute visible emissions survey, during normal operation, of the emission points. No more than four emission points shall be observed simultaneously. The opacity surveys can be performed on the building exhaust points if the process is inside an enclosure.
 - (2) At emission points where visible emissions are observed, the owner or operator shall initiate corrective action within eight hours of the initial observation. If correction actions are taken then a follow-up visible emission survey shall be made. If the visible emissions persist, the owner or operator shall perform or cause to be performed a Method 9, in accordance with 40 CFR Part 60, Appendix A, 24 hours of the initial observation.

b. **PM**

- i. There are no monitoring and record keeping requirements for IE14, and IE15, and IE24.
- ii. For ash storage silos and pug mill mixers (IE17-IE22), hydrated lime silos (IE23-a and IE23-b):
- (1) The owner or operator shall, monthly, maintain records of the type and amount of material throughput for each piece of equipment.

¹⁵¹ TAC emissions from this equipment are de minimis.

- iii. For ash storage silos (IE17 and IE18), hydrated lime silos (IE23-a and IE23-b):
- (1) The owner or operator shall, monthly, perform a visual inspection of the structural and mechanical integrity of the bin vent filters for signs of damage, air leakage, corrosion, or other equipment defects, and repair and/or replace defective components as needed. The owner or operator shall maintain monthly records of the results.
 - (2) The owner or operator shall maintain daily records of any periods of time where the process was operating and the bin vent filters were not in place or a declaration that the bin vent filters were in place at all times that day when the process was operating.
 - (3) If there is any time that the bin vent filters are not in place when the process is operating, then the owner or operator shall keep a record of the following for each bypass event:
 - (a) Date;
 - (b) Start time and stop time;
 - (c) Identification of the bin vent filters and process equipment;
 - (d) PM emissions during the bypass in lb/hr;
 - (e) Summary of the cause or reason for each bypass event;
 - (f) Corrective action taken to minimize the extent or duration of the bypass event; and
 - (g) Measures implemented to prevent reoccurrence of the situation that resulted in the bypass event.

c. **TAC**

- i. For storage tanks (IE11, IE12, and IE13, and IE26), Lube Oil System Demister Vents (IE25), and HVAC Heaters (IE27): See Plantwide Requirements.

S3. Reporting

[Regulation 2.16, section 4.1.9.3]

The owner or operator shall report the following information, as required by General Condition G14:

a. **Opacity**

- i. There are no reporting requirements for IE14, and IE15, and IE24.

- ii. For ash storage silos and pug mill mixers (IE17-IE22), PWS (IE23): The owner or operator shall identify all periods of exceeding an opacity standard during a quarterly reporting period. The report shall include the following:
- (1) Any deviation from the requirement to perform daily (or monthly, if required) visible emission surveys or Method 9 tests;
 - (2) Any deviation from the requirement to record the results of each VE survey and Method 9 test performed;
 - (3) The date and time of each VE Survey where visible emissions were observed and the results of any Method 9 test performed;
 - (4) The date, time and results of follow-up VE survey;
 - (5) The date, time, and results of any Method 9 test performed;
 - (6) Identification of all periods of exceeding an opacity standard; and
 - (7) If no deviations occur during a quarterly reporting period, the report shall contain a negative declaration.

b. **PM**

- i. There are no reporting requirements for IE14, IE15, IE19, IE20, IE21, and IE22.
- ii. For ash silos (IE17 and IE18) and lime silos (IE23-a and IE23-b): The owner or operator shall report the following information regarding PM By-Pass Activity in the quarterly compliance reports.
- (1) Number of times the PM vent stream by-passes the bin vent filters and is vented to the atmosphere;
 - (2) Duration of each by-pass to the atmosphere;
 - (3) Calculated pound per hour PM emissions for each by-pass; or
 - (4) A negative declaration if no by-passes occurred.

c. **TAC**

- i. For storage tanks (IE11, IE12, and IE13, and IE26), Lube Oil System Demister Vents (IE25), and HVAC Heaters (IE27): See Plantwide Requirements.

Deleted pages with no edits

Attachment D - NO_x RACT Plan - Amendment 1

1. The oxides of nitrogen (NO_x, expressed as NO₂) emission from each utility boiler shall not exceed the rate as specified below, based upon a rolling 30-day average:
 - Unit 1 0.47 lb/mmBtu of heat input
 - Unit 2 0.47 lb/mmBtu of heat input
 - Unit 3 0.52 lb/mmBtu of heat input
 - Unit 4 0.52 lb/mmBtu of heat input

2. The NO_x emission rate for each utility boiler shall be determined using the methods and procedures specified in NO_x RACT Plan Appendix A - Amendment 1, except that any reference to an annual average shall be read as a rolling 30-day average.

3. The Louisville Gas and Electric Company Mill Creek Generating Station (LG&E/MCGS) shall install, maintain, and operate a NO_x continuous emissions monitoring system (CEMS) for each utility boiler and shall keep records and submit reports and other notifications as specified in NO_x RACT Plan Appendix A - Amendment 1.

4. The LG&E/MCGS shall keep a record identifying all deviations from the requirements of this NO_x RACT Plan and shall submit to the District a written report of all deviations that occurred during the preceding calendar quarter. The report shall contain the following information:
 - A. The boiler number,
 - B. The beginning and ending date of the reporting period,
 - C. Identification of all periods during which a deviation occurred,
 - D. A description, including the magnitude, of the deviation,
 - E. If known, the cause of the deviation, and
 - F. A description of all corrective actions taken to abate the deviation.

If no deviation occurred during the calendar quarter, the report shall contain a negative declaration. Each report shall be submitted within 30 days following the end of the calendar quarter.

5. In lieu of the requirements in this NO_x RACT Plan, the LG&E/MCGS may comply with alternative requirements regarding emission limitations, equipment operation, test methods, monitoring, recordkeeping, or reporting, provided the following conditions are met:
 - A. The alternative requirements are established and incorporated into an operating permit pursuant to a Title V Operating Permit issuance, renewal, or significant permit revision process as established in Regulation 2.16,
 - B. The alternative requirements are consistent with the streamlining procedures and guidelines set forth in section II.A. of *White Paper Number 2 for Improved Implementation of the Part 70 Operating Permits Program*, March 5, 1996, U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards. The overall effect of compliance with alternative requirements shall consider the effect on an intrinsic basis, such as pounds per million Btu of heat input. However, alternative requirements that are developed based upon revisions to the applicable

requirements contained in 40 CFR Part 60 or Part 75 shall be approvable pursuant to this NO_x RACT Plan Element,

- C. The U.S. Environmental Protection Agency (EPA) has not objected to the issuance, renewal, or revision of the Title V Operating Permit, and either
- D. If the public comment period preceded the EPA review period, then the District had transmitted any public comments concerning the alternative requirements to EPA with the proposed permit, or
- E. If the EPA and public comment periods ran concurrently, then the District had transmitted any public comments concerning the alternative requirements to EPA no later than 5 working days after the end of the public comment period.

The District's determination of approval of any alternative requirements is not binding on EPA. Noncompliance with any alternative requirement established pursuant to the Title V Operating Permit process constitutes a violation of this NO_x RACT Plan.

History: Approved 11-8-99; effective 1-1-00; amended a1/10-18-00 effective 1-1-01.

Appendix A to NO_x RACT Plan - Amendment 1 Requirements for NO_x CEMS

I. General Operating Requirements

- A. **Primary measurement requirements.** The LG&E/MCGS shall, for each utility boiler, install, certify, operate, and maintain, in accordance with the requirements of 40 CFR 75 an oxides of nitrogen (NO_x) continuous emission monitoring system (CEMS), consisting of a NO_x pollutant concentration monitor and an oxygen (O₂) or carbon dioxide (CO₂) diluent gas monitor, with an automated data acquisition and handling system for measuring and recording NO_x concentration (in parts per million [ppm]), O₂ or CO₂ concentration (in percent O₂ or CO₂) and NO_x emission rate (in lb/mmBtu of heat input) discharged to the atmosphere. Any reference in this Appendix to an annual average shall be read as a rolling 30-day average. The LG&E/MCGS shall account for total NO_x emissions, both nitrogen oxide (NO) and nitrogen dioxide (NO₂), either by monitoring for both NO and NO₂ or by monitoring for NO only and adjusting the emissions data to account for NO₂.
- B. **Primary equipment performance requirements.** The LG&E/MCGS shall ensure that each CEMS used to demonstrate compliance with the NO_x emission limit meets the equipment, installation, and performance specifications in 40 CFR 75 Appendix A, and is maintained according to the quality assurance and quality control procedures in 40 CFR 75 Appendix B. The NO_x emission rate for each utility boiler shall be recorded as lb/mmBtu of heat input.
- C. **Primary equipment hourly operating requirements.**
 - 1. The LG&E/MCGS shall ensure that all CEMS are in operation and monitoring the emissions from the associated utility boiler at all times that

the utility boiler combusts any fuel except during a period of any of the following:

- a. Calibration, quality assurance, or preventive maintenance, any of which is performed pursuant to 40 CFR 75.21, 40 CFR 75 Appendix B, District regulations, District permit conditions, or this NO_x RACT Plan, or
 - b. Repair, backups of data from the data acquisition and handling system, or recertification, any of which is performed pursuant to 40 CFR 75.20.
2. The LG&E/MCGS shall ensure that the following requirements are met:
- a. Each CEMS and component thereof is capable of completing a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute interval. The LG&E/MCGS shall reduce all volumetric flow, CO₂ concentration, O₂ concentration, NO_x concentration, and NO_x emission rate data collected by the monitors to hourly averages. Hourly averages shall be computed using at least one data point in each 15-minute quadrant of an hour during which the utility boiler combusted fuel during that quadrant of the hour. Notwithstanding this requirement, an hourly average may be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of the hour) if data are unavailable as a result of the performance of any activity specified in paragraph I.C.1. of this Appendix. The LG&E/MCGS shall use all valid measurements or data points collected during an hour to calculate the hourly averages. All data points collected during an hour shall be, to the extent practicable, evenly spaced over the hour.
 - b. Failure of a CO₂ or O₂ diluent concentration monitor, flow monitor, or NO_x pollutant concentration monitor to acquire the minimum number of data points for calculation of an hourly average shall result in the failure to obtain a valid hour of data and the loss of such component data for the entire hour. An hourly average NO_x emission rate in lb/mmBtu of heat input is valid only if the minimum number of data points are acquired by both the pollutant concentration monitor (NO_x) and the diluent monitor (CO₂ or O₂). If a valid hour of data is not obtained, the owner or operator shall estimate and record emissions, moisture, or flow data for the missing hour by means of the automated data acquisition and handling system, in accordance with the applicable procedure for missing data substitution in 40 CFR 75 Subpart D .

D. Optional backup monitor requirements. If the LG&E/MCGS chooses to use two or more CEMS, each of which is capable of monitoring the same stack or duct at a specific utility boiler, then the LG&E/MCGS shall designate one CEMS as the primary monitoring system and shall record this designation in the monitoring plan. The LG&E/MCGS shall designate any other CEMS as a backup CEMS in the

monitoring plan. Any other backup CEMS shall be designated as a redundant backup CEMS, non-redundant backup CEMS, or reference method CEMS, as described in 40 CFR 75.20(d). When the certified primary monitoring system is operating and not out-of-control as defined in 40 CFR 75.24, only data from the certified primary monitoring system shall be reported as valid, quality-assured data. Thus, data from a backup CEMS may be reported as valid, quality-assured data only when a backup CEMS is operating and not out-of-control as defined in 40 CFR 75.24 or in the applicable reference method in 40 CFR 60 Appendix A and when the certified primary monitoring system is not operating or is operating but out-of-control. A particular monitor may be designated both as a certified primary monitor for one unit and as a certified redundant backup monitor for another unit.

- E. Minimum measurement capability requirements.** Each CEMS and component thereof shall be capable of accurately measuring, recording, and reporting data, and shall not incur a full scale exceedance, except as provided in section 2.1.2.5 of 40 CFR 75 Appendix A.
- F.** The LG&E/MCGS shall not operate a utility boiler so as to discharge, or allow to be discharged, emissions of NO_x to the atmosphere without accounting for all such emissions in accordance with the methods and procedures specified in this Appendix.
- G.** The LG&E/MCGS shall not disrupt the CEMS, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO_x emissions discharged into the atmosphere, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the provisions of this Appendix.
- H.** The LG&E/MCGS shall not retire or permanently discontinue use of the CEMS, any component thereof, or any other approved emission monitoring system under this Appendix except under any one of the following circumstances:
1. The LG&E/MCGS is monitoring NO_x emissions from the utility boiler with another certified monitoring system approved in accordance with the provisions of paragraph I.D. of this Appendix, or
 2. The LG&E/MCGS submits notification of the date of certification testing of a replacement monitoring system.
- I.** The quality assurance and quality control requirements in 40 CFR 75.21 that apply to NO_x pollutant concentration monitors and diluent gas monitors shall be met. A NO_x pollutant concentration monitor for determining NO_x emissions shall meet the same certification testing requirements, quality assurance requirements, and bias test requirements as those specified in 40 CFR 75 for an SO₂ pollutant concentration monitor.
- J. Moisture correction.** If a correction for the stack gas moisture content is needed to properly calculate the NO_x emission rate in lb/mmBtu of heat input (i.e., if the

NO_x pollutant concentration monitor measures on a different moisture basis from the diluent monitor), LG&E/MCGS shall either report a fuel-specific default moisture value for each utility boiler operating hour, as provided in 40 CFR 75.11(b)(1), or shall install, operate, maintain, and quality assure a continuous moisture monitoring system, as defined in 40 CFR 75.11(b)(2). Notwithstanding this requirement, if Equation 19-3, 19-4 or 19-8 in Method 19 in Appendix A to 40 CFR Part 60 is used to measure NO_x emission rate, the following fuel-specific default moisture percentages shall be used in lieu of the default values specified in 40 CFR 75.11(b)(1): 5.0%, for anthracite coal; 8.0% for bituminous coal; 12.0% for sub-bituminous coal; 13.0% for lignite coal; and 15.0% for wood.

II. Specific Provisions for Monitoring NO_x Emission Rate (NO_x and diluent gas monitors)

- A. The LG&E/MCGS shall meet the general operating requirements in 40 CFR 75.10 for a NO_x CEMS for each utility boiler. The diluent gas monitor in the NO_x CEMS may measure either O₂ or CO₂ concentration in the flue gases.
- B. The LG&E/MCGS shall calculate hourly and rolling 30-day NO_x emission rates (in lb/mmBtu of heat input) by combining the NO_x concentration (in ppm), diluent concentration (in percent O₂ or CO₂), and percent moisture (if applicable) measurements according to the procedures in 40 CFR 75 Appendix F.

III. Monitoring plan

The LG&E/MCGS shall prepare and maintain a monitoring plan as specified in 40 CFR 75.53. The monitoring plan shall be submitted to the District no later than 45 days prior to the first scheduled certification test.

IV. Recordkeeping Provisions

- A. The LG&E/MCGS shall maintain for each utility boiler a file of all measurements, data, reports, and other information required by this Appendix at the stationary source in a form suitable for inspection for at least 5 years from the date of each record. This file shall contain the following information:
 - 1. The data and information required in paragraph IV.B. of this Appendix,
 - 2. The component data and information used to calculate values required in paragraph IV.B. of this Appendix,
 - 3. The current monitoring plan as specified in 40 CFR 75.53, and
 - 4. The quality control plan as described in 40 CFR 75 Appendix B.
- B. **NO_x emission record provisions.** The LG&E/MCGS shall record hourly the following information as measured and reported from the certified primary monitor, certified back-up or certified portable monitor, or other approved method of emissions determination for each utility boiler:
 - 1. Date and hour,

2. Hourly average NO_x concentration (ppm, rounded to the nearest tenth),
3. Hourly average diluent gas concentration (percent O₂ or percent CO₂, rounded to the nearest tenth),
4. Hourly average NO_x emission rate (lb/mmBtu of heat input, rounded to nearest hundredth),
5. Hourly average NO_x emission rate (lb/mmBtu of heat input, rounded to nearest hundredth) adjusted for bias, if a bias adjustment factor is required by 40 CFR 75.24 (d),
6. Percent monitoring system data availability (recorded to the nearest tenth of a percent), calculated pursuant to 40 CFR 75.32,
7. Method of determination for hourly average NO_x emission rate using Codes 1-55 in 40 CFR 75.57 Table 4A, and
8. Unique code identifying emissions formula used to derive hourly average NO_x emission rate, as provided for in 40 CFR 75.53.

V. Certification, Quality Assurance, and Quality Control Record Provisions

- A.** For each NO_x pollutant concentration monitor and diluent gas monitor, the LG&E/MCGS shall record the following:
1. Results of all trial runs and certification tests and quality assurance activities and measurements (including all reference method field test sheets, charts, records of combined system responses, laboratory analyses, and example calculations) necessary to substantiate compliance with all relevant requirements of this Appendix,
 2. Bias test results as specified in 40 CFR 75 Appendix A, section 7.6.4,
 3. The appropriate bias adjustment factor as follows:
 - a. The value derived from Equations A-11 and A-12 in 40 CFR 75 Appendix A for any monitoring system or component that failed the bias test, or
 - b. A value of 1.0 for any monitoring system or component that passed the bias test, and
 4. The component/system identification code.
- B.** For each NO_x pollutant concentration monitor and diluent gas monitor, the LG&E/MCGS shall record the following for all daily and 7-day calibration error tests, including any follow-up tests after corrective action:
1. Instrument span and span scale,
 2. Date and hour,
 3. Reference value (i.e., calibration gas concentration or reference signal value, in ppm or other appropriate units),
 4. Observed value (monitor response during calibration, in ppm or other appropriate units), (flag if using alternative performance specification for low emitters or differential pressure monitors),
 5. Percent calibration error (rounded to the nearest tenth of a percent),
 6. Calibration gas level,
 7. Test number and reason for test,

8. For 7-day calibrations tests for certification or recertification, a certification from the cylinder gas vendor or CEMS vendor that calibration gases as defined in 40 CFR 72.2 and 40 CFR 75 Appendix A were used to conduct calibration error testing,
 9. Description of any adjustments, corrective actions, or maintenance following a test,
 10. For quality test for off-line calibration, whether the unit is off-line or on-line, and
 11. The component/system identification code.
- C.** For each NO_x pollutant concentration monitor and diluent gas monitor, the LG&E/MCGS shall record the following for the initial and all subsequent linearity checks, including any follow-up tests after corrective action:
1. Instrument span and span scale,
 2. Calibration gas level,
 3. Date, hour, and minute of each gas injection at each calibration gas level,
 4. Reference value (i.e., reference gas concentration for each gas injection at each calibration gas level, in ppm or other appropriate units),
 5. Observed value (monitor response to each reference gas injection at each calibration gas level, in ppm or other appropriate units),
 6. Mean of reference values and mean of measured values at each calibration gas level
 7. Linearity error at each of the reference gases concentrations (rounded to the nearest tenth of a percent), (flag if using alternative performance specification),
 8. Test number and reason for test (flag if aborted test),
 9. Description of any adjustments, corrective action, or maintenance prior to a passed test or following a failed test,
 10. The number of out-of-control hours, if any, following any tests, and
 11. The component/system identification code.
- D.** For each NO_x pollutant concentration monitor and diluent gas monitor, the LG&E/MCGS shall record the following information for the initial and all subsequent relative accuracy tests and test audits:
1. Reference method(s) used,
 2. Individual test run data from the relative accuracy test audit for the NO_x pollutant concentration monitor or diluent gas monitor, including:
 - a. Date, hour, and minute of beginning of test run,
 - b. Date, hour, and minute of end of test run,
 - c. Monitoring system identification code,
 - d. Test number and reason for test,
 - e. Operating load level (low, mid, high, or normal, as appropriate) and number of load levels comprising test,
 - f. Normal load indicator for flow RATAs (except for peaking units),
 - g. Units of measure,
 - h. Run number,

- i. Run data from CEMS being tested, in the appropriate units of measure,
 - j. Run data for reference method, in the appropriate units of measure,
 - k. Flag value (0, 1, or 9, as appropriate) indicating whether run has been used in calculating relative accuracy and bias values or whether the test was aborted prior to completion,
 - l. Average gross unit load (expressed as a total gross unit load rounded to the nearest MWe or as steam load rounded to the nearest thousand lb/hr), and
 - m. Flag to indicate whether an alternative performance specification has been used,
3. Calculations and tabulated results, as follows:
 - a. Arithmetic mean of the monitoring system measurement values, reference method values, and of their differences, as specified in Equation A-7 in 40 CFR 75 Appendix A,
 - b. Standard deviation, as specified in Equation A-8 in 40 CFR 75 Appendix A,
 - c. Confidence coefficient, as specified in Equation A-9 in 40 CFR 75 Appendix A,
 - d. Statistical “t” value used in calculations,
 - e. Relative accuracy test results, as specified in Equation A-10 in 40 CFR 75 Appendix A,
 - f. Bias test results as specified in section 7.6.4 in 40 CFR 75 Appendix A,
 - g. Bias adjustment factor from Equation A-12 in 40 CFR 75 Appendix A for any monitoring system or component that failed the bias test (except as otherwise provided in section 7.6.5 in 40 CFR 75 Appendix A) and 1.000 for any monitoring system or component that passed the bias test,
 - h. F-factor value(s) used to convert NO_x pollutant concentration and diluent gas (O₂ or CO₂) concentration measurements into NO_x emission rates (in lb/mmBtu),
 - i. The raw data and calculated results for any stratification tests performed in accordance with sections 6.5.6.1 through 6.5.6.3 in 40 CFR 75 Appendix A, and
 - j. For moisture monitoring systems, the coefficient “K” factor or other mathematical algorithm used to adjust the monitoring system with respect to the reference method,
 4. Description of any adjustment, corrective action, or maintenance prior to a passed test or following a failed or aborted test,
 5. For each run of each test using Method 7E or 3A in Appendix A of 40 CFR 60 to determine NO_x, CO₂, or O₂ concentration the following:
 - a. Pollutant or diluent gas being measured,
 - b. Span of reference method analyzer,
 - c. Type of reference method system (e.g., extractive or dilution type),
 - d. Reference method dilution factor (dilution type systems, only),

- e. Reference gas concentration (low, mid, and high gas levels) used for the 3-point, pre-test analyzer calibration error test (or, for dilution type reference method systems, for the 3-point, pre-test system calibration error test) and for any subsequent recalibrations,
- f. Analyzer responses to the zero-, mid-, and high-level calibration gases during the 3-point pre-test analyzer (or system) calibration error test and during any subsequent recalibration(s),
- g. Analyzer calibration error at each gas level (zero, mid, and high) for the 3-point, pre-test analyzer (or system) calibration error test and for any subsequent recalibration(s) (percent of span value),
- h. Upscale gas concentration (mid or high gas level) used for each pre-run or post-run system bias check or, for dilution type reference method systems, for each pre-run or post-run system calibration error check,
- i. Analyzer response to the calibration gas for each pre-run or post-run system bias (or system calibration error) check,
- j. The arithmetic average of the analyzer responses to the zero-level gas, for each pair of pre- and post-run system bias (or system calibration error) checks,
- k. The arithmetic average of the analyzer responses to the upscale calibration gas, for each pair of pre- and post-run system bias (or system calibration error) checks,
- l. The results of each pre-run and each post-run system bias (or system calibration error) check using the zero-level gas (percentage of span value),
- m. The results of each pre-run and each post-run system bias (or system calibration error) check using the upscale calibration gas (percentage of span value),
- n. Calibration drift and zero drift of analyzer during each RATA run (percentage of span value),
- o. Moisture basis of the reference method analysis,
- p. Moisture content of stack gas, in percent, during each test run (if needed to convert to moisture basis of CEMS being tested),
- q. Unadjusted (raw) average pollutant or diluent gas concentration for each run,
- r. Average pollutant or diluent gas concentration for each run, corrected for calibration bias (or calibration error) and, if applicable, corrected for moisture,
- s. The F-factor used to convert reference method data to units of lb/mmBtu (if applicable)
- t. Date(s) of the latest analyzer interference test(s),
- u. Results of the latest analyzer interference test(s),
- v. Date of the latest NO₂ to NO conversion test (Method 7E only),
- w. Results of the latest NO₂ to NO conversion test (Method 7E only), and

- x. For each calibration gas cylinder used during each RATA, record the cylinder gas vendor, cylinder number, expiration date, pollutant(s) in the cylinder, and
6. The number of out-of-control hours, if any, following any tests, and
7. The component/system identification code.

VI. Notifications

- A. The LG&E/MCGS or a designated representative shall submit notice to the District for the following purposes, as required by this Appendix:
 1. Initial certification and recertification test notifications. Written notification shall be submitted of initial certification tests, recertification tests, and revised test dates as specified in 40 CFR 75.20 for continuous emission monitoring systems, except for testing only of the data acquisition and handling system, and
 2. Notification of initial certification testing. Initial certification test notifications shall be submitted not later than 45 days prior to the first scheduled day of initial certification testing. Testing may be performed on a date other than that already provided in a notice under this subparagraph as long as notice of the new date is provided either in writing or by telephone or other means at least 7 days prior to the original scheduled test date or the revised test date, whichever is earlier.
- B. For retesting following a loss of certification under 40 CFR 75.20(a)(5) or for recertification under 40 CFR 75.20(b), notice of testing shall be submitted either in writing or by telephone at least 7 days prior to the first scheduled day of testing, except that in emergency situations when testing is required following an uncontrollable failure of equipment that results in lost data, notice shall be sufficient if provided within 2 business days following the date when testing is scheduled. Testing may be performed on a date other than that already provided in a notice under this subparagraph as long as notice of the new date is provided by telephone or other means at least 2 business days prior to the original scheduled test date or the revised test date, whichever is earlier.
- C. Notwithstanding the notice requirements of paragraph B. above, the LG&E/MCGS may elect to repeat a certification test immediately, without advance notification, whenever the LG&E/MCGS has determined during the certification testing that a test was failed or that a second test is necessary in order to attain a reduced relative accuracy test frequency.
- D. Written notice shall be submitted, either by mail or facsimile, of the date of periodic relative accuracy testing performed under 40 CFR Part 75 Appendix B no later than 21 days prior to the first scheduled day of testing. Testing may be performed on a date other than that already provided in a notice under this subparagraph as long as notice of the new date is provided either in writing or by telephone or other means acceptable to the District, and the notice is provided as soon as practicable after the

new testing date is known, but no later than 24 hours in advance of the new date of testing.

- E.** Notwithstanding the notice requirements under paragraph D. above, the LG&E/MCGS may elect to repeat a periodic relative accuracy test immediately, without additional notification whenever the LG&E/MCGS has determined that a test was failed, or that a second test is necessary in order to attain a reduced relative accuracy test frequency. If an observer from the District is present when a test is rescheduled, the observer may waive all notification requirements under paragraph D. above for the rescheduled test.

VII. Quarterly reports

- A.** The LG&E/MCGS shall, within 30 days following the end of each calendar quarter, submit a report to the District that includes the following data and information for each utility boiler:
1. The information and hourly data required in this Appendix, including all emissions and quality assurance data, and
 2. Average NO_x emission rate (lb/mmBtu of heat input, rounded to the nearest hundredth) during the rolling 30-day averaging periods.
- B.** The LG&E/MCGS shall submit a certification in support of each quarterly emissions monitoring report. This certification shall indicate whether the monitoring data submitted were recorded in accordance with the requirements of this Appendix. In the event of any missing data periods, this certification shall include a description of the measures taken to minimize or eliminate the causes for the missing data periods.

Appendix A to NO_x RACT Plan - Amendment 2

TBD

Deleted pages with no edits

Attachment F – Cross-State Air Pollution Rule (CSAPR)

The owner or operator shall comply with the following requirements unless there are more current promulgated regulations:

I. Description of CSAPR Monitoring Provisions

The CSAPR subject units, and the unit-specific monitoring provisions at this source, are identified in the following tables. These units are subject to the requirements for the CSAPR NO_x Annual Trading Program, CSAPR NO_x Ozone Season **Group 2** Trading Program {please replace all Group 2 with Group 3}, and CSAPR SO₂ Group 1 Trading Program.

| Unit ID: Unit 1, non-peaking coal-fired boiler with natural gas backup | | | | | |
|--|---|---|---|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75, subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D | Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E |
| SO ₂ | X | | ----- | | |
| NO _x | X | ----- | | | |
| Heat input | X | | ----- | | |

| Unit ID: Unit 2, non-peaking coal-fired boiler with natural gas backup | | | | | |
|--|---|---|---|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75, subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D | Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E |
| SO ₂ | X | | ----- | | |
| NO _x | X | ----- | | | |
| Heat input | X | | ----- | | |

Plant ID: 0127

| Unit ID: Unit 3, non-peaking coal-fired boiler with natural gas backup | | | | | |
|--|---|---|---|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75, subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D | Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E |
| SO ₂ | X | | ----- | | |
| NO _x | X | ----- | | | |
| Heat input | X | | ----- | | |

| Unit ID: Unit 4, non-peaking coal-fired boiler with natural gas backup | | | | | |
|--|--|---|--|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75 subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D | Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75 appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E |
| SO ₂ | X | | ----- | | |
| NO _x | X | ----- | | | |
| Heat input | X | | ----- | | |

| Unit ID: Unit 5, non-peaking natural gas-fired combustion turbine with natural gas-fired duct burners | | | | | |
|---|--|---|--|---|---|
| Parameter | CEMS requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75 subpart H (for NO _x monitoring) | Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D | Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75 appendix E | Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19 | EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E |
| SO ₂ | | X | ----- | | |
| NO _x | X | ----- | | | |
| Heat input | | X | ----- | | |

Deleted pages with no edits