DFS 210 (Rev. 2-95)

COMMONWEALTH OF KENTUCKY CABINET FOR HEALTH AND FAMILY SERVICES DEPARTMENT FOR PUBLIC HEALTH

4	5	23
	2	DATE

Permit/License/ Registration/ Certification

15816 No. **Request for Service**

No.

Gluga	
Sanitation Code	

E Action Code

NOTICE TO CORRECT VIOLATIONS

212.210 PURSUANT TO ISSUED TO: (P) Kesources \cap 103 STATE An inspection conducted at located at under the date of ddres by (Date) (Inspector) disclosed the following violations: ing overflows aterals are Sehiap in the bottom of PUCIDO # This is an official notice to correct the above listed violations with a period of days from the date of receipt of this notice. Failure to comply with this notice within the specified time period may result in suspension of your: DPERMIT DLICENSE REGISTRATION CERTIFICATION or, further legal action (as applicable) being taken against you, unless a written request for a hearing is filed with the cabinet during that time period. ate Received Signature SURMOO Health Official Signature Title VOL 2 Health Department Mailing Address State, Zin Telephone Kentucki



Crystal Stevenson Health Env III Kentucky Department for Public Health P.O. Box 2597 Paducah, KY 42002

sent via email: crystal.stevenson@ky.gov

May 10th, 2023

Subject: Periodic Wastewater Inspections – Notice to Correct Violations Marshall Ridge – No Discharge

Ms. Stevenson-

This letter is submitted in response to your Inspection Report dated April 5th, 2023 (received April 11, 2023). Bluegrass Water purchases distressed small water and wastewater systems that often require extensive upgrades and repairs. Bluegrass Water transforms these utilities by using technology and innovation to quickly assess and invest in infrastructure that meets or exceeds state and federal standards. We have made considerable progress on corrective actions at eighteen facilities purchased in Kentucky since 2019. Based on your Inspection Report we understand the following deficiencies need to be addressed at this time.

Marshall Ridge Deficiency

- Lagoon fencing damaged; gaps in the bottom of the fence in multiple areas.
- Failing overflow sewage laterals for lagoon. Standing sewage in area where overflow laterals are located.

Response to Deficiency

• Our operating partner has begun repairing the fence and as of 5/2/23 is 90% complete with one small opening left. The operator is also planning to add extra reinforcement for particularly determined varmints. An example of fence extended to ground level can be seen in the photo below.



luegrasswateruoc.com





• We have inspected and verified the failing lateral drain field. A third-party engineering firm has been contracted to make plans for drain field improvements and to ensure the overflow does not recur. Design is underway and improvements will begin as soon as possible.

We appreciate your ongoing compliance assistance. If you have any questions regarding this submittal, please contact me directly at 314-492-8425 or <u>jlundgren@cswrgroup.com</u>.

Sincerely,

frain futur

Justin Lundgren EHS Compliance Coordinator



4 1-866-752-8982



support@bluegrasswateruoc.com

Case No. 2022-00432 Bluegrass Water's Response to OAG 1-28 Exhibit OAG 1-28(c) Page 3 of 4

DFS-312 (6-87)

ACTION CODE _E

COMMONWEALTH OF KENTUCKY CABINET FOR HUMAN RESOURCES DEPARTMENT FOR HEALTH SERVICES
NOTICE TO REMEDY INSANITARY CONDITIONS
To Central States Water Resources
Notice is given that the Biling boom system; Standing Seuvice; damaged fencing
Located at 209 Horting Ridge Rd West Bolucan, KY 42086
Is in violation of the Rules and Regulation of the Cabinet for Human Resources or KRS 212.210
Crystal Stevension (270)444 9631 art 130
JoelBarrett (270) 444 9431 4xt 169
and notice is given to abate such conditions within a period of <u>50</u> days.
signed CitySOLASULEMCO
MCradenCounty Health Department
Date 4523

Case No. 2022-00432 Bluegrass Water's Response to OAG 1-28 Exhibit OAG 1-28(c) Page 4 of 4

÷