





# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5-cfs flow (approx.)	
2" wl=27 gpm	6" wl=225 gpm
3" wl=57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

District	East
Year	2021

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
12/21	Caribou Drive	6	<del>X</del>		1 hr	13500
12/21	laurel road	6	FH		15 m	3375
12/21	Smith Brewer Rd	3			30 min	1800
12/21	Talon Trail	3			15 min	900
12/21	Jordan Ln	3			15 min	900

20475

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
	1230					

Operator: BRAD WILSON

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
12/21	CARIBOU DR	6"			2 HRS	27000

FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

					For 2.5 gpm flow (approx.)	
District <del>West Creek</del> EAST					2" wl = 225 gpm	6" wl = 225 gpm
Operator <del>J.P.</del> Nick Day					3" wl = 390 gpm	8" wl = 390 gpm
Year 2021					4" wl = 590 gpm	10" wl = 600 gpm
DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
12-6	Upper Racoon RD	4			30 min	3000
	Cody Bladse					
12-6	Beaver LN (meter)	3/4			1HR	1200
12-13/14	Jarrod George River Oaks Sub Tie Line Back Together Hwy 1189	3			18HR-40Min	67,200

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District	EAST LAUREL
Year	2021

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

Operator : Robert Down II

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
1-28/21	Hydrant Hwy 229 E.O.L. for THM's	6"			16 HRS	351,000

Operator : Nick Day

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
1-20	Hwy 830 E.O.L.	4			10 M	1000
1-26	Hwy 501 @ Hydrant				2 HRS	27000
1-18	Professional DR	6			1 HR	13500

41500

392500

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED







**FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.**

For 2.5 cfs flow (approx.)	
2" wl =27 gpm	6" wl=225 gpm
3" wl =57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

District ~~Wood~~ **EAST**  
 Operator ~~James~~  
 Year **2021**

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
<del>3-1-21</del>	<del>Becker Taber Rd</del>	<del>8"</del>			<del>8 Hrs</del>	
	<b>ROBERT DOAN II</b>					
3-25/26	Hwy 229 E.O.L. Samples	6			6 HRS	81000
3-25/26	Hwy 830 + Pine Creek	8			6 HRS	140400
	<b>TYLER EVANS</b>					
3-24	Portersburg Road	4			2 HRS	12000

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

District	East
Year	21

Operator: AD

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
3/15	Anderson branch	4			15 min	1500
3/29	East 80 Hydrant				15 min	3375

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District	East
Year	2021

For 2.5 cfs flow (approx.)	
2" wl =27 gpm	6" wl=225 gpm
3" wl =57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

Operator : *Ernesto P. Rivera*

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
3/26	1115 Hatcher RD	6			7:00 to 9:00	27000
	F: 0.85 T: 1.01					

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District	EAST LAUREL
Year	2021

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

Operator : Jarrod George

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
1-10	Hwy 638 Loop	6			17H	229,500

Operator : ARON + JOSH DORRMAN

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
1-9	River Oaks SUB	3		1HR	<del>3000</del>	3000
1-10	Hwy 1189	4		1HR	<del>6000</del>	6000

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED











FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District EAST  
 Operator Jeff  
 Year 2021

For 2.5 s flow (approx.)	
2" wl = 1 gpm	6" wl=225 gpm
3" wl = 1 gpm	8" wl=390 gpm
4" wl=1 gpm	10" wl= 600 gpm

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
5/19/21	CASIBOO lane (ELK Creek Sub)	6	1.7	90	2 hrs	27,000
	JAMOD GEORGE					
5/17/18	BUNDY LANE	2"			23H 30M	42,300
5/17/18	TODD Court	6			18 HRS	243,000
5/17/18	Shiloh Court	6			18 HRS	243,000
5/17/18	RUBY Court	6			18 HRS	243,000
5/18/18	JADE Court	6			22 H	297,000
✓	TANNER WAY	6			22 H	297,000
5-17	Hwy 521 + Kirkwood	6			2 HRS	27,000
5-17	HUBBARD RD + Hwy 521	6			30 M	6750
5-17	Hwy 521 + Hwy 1189	6			4H 20Min	58,500
5-21	Taylor Road	2"			30 Min	900

1,458,450

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District	West
Year	2021

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

Operator: Dawson and Snowden

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
5-18-21	Book-7 Auger Springs	3/4	F-1.71		11:40	
			T2.04		12:40	1200

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

District	West
Year	2021

Operator: Snowden / Dawson

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
5-5-21	Bee rock to 5/5/2021		0.98		11:00	20 HRS
5-6-21	Bee rock to 5/6/2021		0.99		8:34	34 MIN
	Flushing for J.W					123,100
	Booth 5					

1234

Operator:

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator:

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator:

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED



# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

District	East
Year	2021

Operator: *Nick Day*

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
7/19	JR Hinkel Rd	3in			20 min	1200

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
7-20	SEWER					103,446
7-21	SEWER					106,585

*422,462*

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED



# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5 cfs flow (approx.)	
2" wl =27 gpm	6" wl=225 gpm
3" wl =57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

District	East
Year	2021

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
8/24	Arielle dr	3			30 min	1800

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

**FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.**

District	EAST LAUREL
Year	2021

For 2.5 cfs flow (approx.)	
2" wl =27 gpm	6" wl=225 gpm
3" wl =57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

Operator : JOSH - MIKE - SNOWDEN

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
9-2	GRUBB ROAD	2			2 HR	3600
9-2	GRUBB RD - SPUR	3			2 HR	7200

Operator : Nick

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
9-16	UPPER Raccoon Cr. RD	3			15 M	900
9-16	Dripping Springs	4			10 M	1000
9-16	Tom Cr Trail Hyd before <sup>OLD</sup> way	4			10 M	400

13,100

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

For 2.5 cfs flow (approx.)	
2" wl = 27 gpm	6" wl = 225 gpm
3" wl = 57 gpm	8" wl = 390 gpm
4" wl = 96 gpm	10" wl = 600 gpm

District <i>East</i>
Operator <i>Spencer B...</i>
Year <i>2021</i>

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
<i>9/16</i>	<i>74 Winners Circle #16383156 R:1609</i>	<i>3"</i>		<i>1130</i>	<i>8:16 to 9:46</i>	<i>61-5400</i>
	<i>JON Green</i>					
<i>9-19</i>	<i>GOLDEN EAGLE SUB - JOHANN AVG.</i>	<i>3</i>			<i>1HR</i>	<i>3600</i>

*9000*





# FLUSHING REPORT, NEW LINES, COMPLAINTS, ETC.

District	EAST LAUREL
Year	2021

For 2.5 cfs flow (approx.)	
2" wl =27 gpm	6" wl=225 gpm
3" wl =57 gpm	8" wl=390 gpm
4" wl=96 gpm	10" wl= 600 gpm

Operator: ~~Ben~~ Jarrod George

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED
11-3/4	New SALEM RD - Inline	4"			12.5 HRS	75,000

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED

Operator :

DATE	LOCATION	LINE SIZE	FREE CL2	EST. P.S.I.	FLUSHING TIME	EST. WATER USED



District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	Est. P.S.I	Est. Time/Flush	Estimated Total
8-9-21	PARKWAY PLAZA	6	1.90		25 MIN	5625
8-9-21	RAMCO DRILLING RD (End of Rd)	3	1.80		20 MIN	1140
8-9-21	460 NORTH MCWHORTER ROAD	2	1.90		20 MIN	540
8-9-21	VAN HOUSE ROAD	3	1.70		15 MIN.	855
8-9-21	LONDON VILLAGE	3	1.70		15 MIN.	855
8-9-21	DAWN SPRINGS VILLA	3	1.70		15 MIN.	855
8-9-21	DAWN SPRINGS VILLA (Hydrant)	3	1.70		15 MIN.	855
8-9-21	DAWN SPRINGS VILLA	6	1.70		15 MIN.	3375
8-9-21	101 HAZEL LANE	2	1.80		15 MIN	405
8-9-21	280 HAZEL LANE -TOP OF HILL	2	1.80		15 MIN.	405
8-9-21	133 RUSH LANE	2	1.70		20 MIN.	540
8-9-21	122 PARKWAY SUB.	2	1.80		20 MIN.	540
8-9-21	ROBINETTE APARTMENTS CAROLYN DRIVE	3	1.90		15 MIN.	855
8-9-21	ROBINETTE APARTMENTS CAROLYN DRIVE	3	1.90		15 MIN.	855
7-28-21	188 SAM BLACK RD. -LEFT	2	1.2		15 MIN.	405
7-28-21	462 SAM BLACK RD	3	1.3		15 MIN.	855
7-28-21	CHESTNUT CEM RD	2	1.4		15 MIN.	405
7-28-21	276 SIM SMITH ROAD	3	1.4		15 MIN	855

T: 20,220

District: EAST LAUREL WATER DISTRICT  
 Year:

PERIODIC FLUSHING REPORT

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	Est. P.S.I	Est. Time/Flush	Estimated Total
7-28-21	ADDISON LANE	3	1.5		20 MIN	1140
7-28-21	114 HOMESTEAD SUB.	2	1.5		20 MIN	550
	COVERED UP					
	CROSS FROM BURLEY AVENUE	3				
	350 FELTNER ROAD	2				
	BESIDE PARKWAY FENCE					
	POINT RIDGE ROAD (Top of Hill)	4				
10-13-21	975 SLATE LICK ROAD	2	1.4		15 MIN.	405
10-13-21	BLAIR ROAD (Old House)	4	1.5		15 MIN.	1500
7-29-21	DEZARN ROAD (Glen Nantz)	3	1.2		15 MIN.	855
7-28-21	MACEDONIA CHURCH ROAD	2	1.3		15 MIN.	405
	Deer Foot Valley Sub					
7-28-21	IVYWOOD DRIVE	3	1.3		15 MIN.	855
	Deer Foot Valley Sub					
7-28-21	LEATHERWOOD DRIVE	3	1.3		15 MIN.	855
	Deer Foot Valley Sub					
7-28-21	COLDWATER TRACE	3	1.2		20 MIN.	1140
	Deer Foot Valley Sub					
7-28-21	DEER FOOT DRIVE	3	1.3		15 MIN.	855
	McPhetridges					
7-28-21	DOTSON ROAD FLUSH HYDRANT	3				Needs changed sized up & out
	Buried Flush Hydrant					
7-28-21	DOTSON ROAD END	3	1.2		15 MIN.	855
	SOUTHARD ROAD	2				

T: 9,415

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 3

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	Free CL-2	Estimated Time/Flush	Estimated Total
	1957 MCWHORTER ROAD (SIDELINE)	3				
	JOHNNY MOORE ROAD	3				
	SALEM SCHOOL ROAD (South End)	3				
	CREECH ROAD	2				
	505 BROWN ROAD	2				
	675 HANNAH LEIGH TRAIL (for Callie Lane)	4				
	HANNAH LEIGH TRAIL (Top of Hill)	3				
	3068 MCWHORTER RD (Inline at Meter)	2				
	169 MULE TRAIN ROAD	3				
	SALEM SCHOOL ROAD (NORTH END)	3				
	1177 MAPLESVILLE ROAD ON HILL	2				
	COUNTRY VIEW ROAD	3				
	K & L Road	3				
	148 SALEM SUB.	2				
	BERT ALLEN RD	3				
	HWY 472 & BERT ALLEN ROAD	4				
	HWY 472 ACROSS FROM HATCHER RD	2				



District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 4

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	Estimate P.S.I	Estimated Time/Flush	Estimated Total
	NEW SALEM ROAD (INLINE)	4				
	BOWLING BRANCH ROAD	3				
	JONES TINCHER ROAD	4				
	SHORTY HAMMONS ROAD	3				
	SHORTY HAMMONS ROAD	3				
	PINE HILL BROCK ROAD	4				
	HWY 687 - INLINE (Before Portersburg Rd)	6				
	BAKER ROAD (LIGHTING ROAD)	3				
	PORTERSBURG ROAD	3				
	HWY 472 (at OLD PS PIT)	4				
7-25-21	GARLAND ROAD	3	.90		15min.	855
	NEW BETHEL CHURCH ROAD	4				
	990 HOUSE ROAD	4				
	JEWELL LANE	3				
	CCD LANE	3				
	MCKNIGHT LANE	3				

T: 855

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 5

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	Estimate P.S.I	Estimated Time/Flush	Estimated Total
	HWY 472 (INLINE @ HAMMONS ROAD)	6				
	LARKEY LANE	3				
	J.B. BUTTERY ROAD #1	4				
	<b>COVERED OVER</b>					
	J.B. BUTTERY ROAD #2	3				
	420 HOUSE ROAD	3				
	EBB SHEPHERD ROAD	3				
	NANTZ ROAD	4				
	HWY 638 (PAST NANTZ RD ON RIGHT)	4				
	HWY 638 (Old Farm House)	4				
	ROCKCASTLE ROAD	3				
	DRIPPING SPRINGS ROAD	4				
	KING DAVID BENGE ROAD	4				
	HWY 638 (ON TOP OF BIG HILL)	6				
	(0.5 Miles Before Pleasant Grove Rd)					
	HWY 472	4				
	PLEASANT GROVE INLINE	4				
	INLINE					
	PLEASANT GROVE RD & MCWHORTER RD	4				
	Add 776-790					
	MCWHORTER ROAD (INLINE)	4				
	ALDERSON BRANCH ROAD	3				

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year :

PAGE 6

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	BRIDGE BRANCH ROAD	3				
	SHIB BRANCH (INLINE)	3				
	SHIB BRANCH - End	3				
7-27-21	FISH AND GAME ROAD	4	.80		20Min.	2000 <sup>11</sup> 600 down
	GOSLIN BRANCH ROAD	3				
	TANYARD BRANCH	4				
	7944 HWY 638	6				
7-27-21	LIPEROTE WAY	6	1.5		20Min.	4500
7-27-21	1033 EAST FOURTH STREET- SIDELINE	2	1.3		15Min.	405
	BROCK CIRCLE ROAD	3				
6-29	SOUTH LAUREL LITTLE LEAGUE FIELD	2	1.7		25Min.	675
3/27	BOWMAN LANE	2	1.9		30Min.	900
3/27	BOWMAN LANE	4	1.9		45Min.	4500
6-29	FIRE DEPT. (TLC LANE)	6	1.7		20Min.	4500
6-29	ENTERPRISE LANE	4	1.7		25Min.	2500
6-29	NAMI PLAZA #1	6	1.6		20Min.	4500
6-29	NAMI PLAZA #2	6	1.6		15Min.	3375
	TEXACO					
6-29	1670 HWY 192 EAST (BEAR, INC.)	4	1.6		20Min.	2000

T: 29.855

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year :

PAGE 7

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	TEXACO					
6-10-21	1670 HWY 192 EAST (BEAR, INC.)	3	1.0		20 MIN	1140
6-10-21	CREEKSIDE DRIVE	4	0.90		20 MIN	2000
	(RIGHT FORK)					
6-10-21	513 LITTLE LAUREL RIVER ROAD	3	1.0		15 MIN	855
6-10-21	141 LITTLE LAUREL RIVER RD	3	1.0		20 MIN	1140
6-10-21	SHERWOOD DRIVE	2	1.1		15 MIN	405
6-10-21	STONEHEDGE DRIVE	2	1.0		20 MIN	540
6-10-21	BRANDI DRIVE	2	1.0		20 MIN	540
6-10-21	WILSHIRE SUBD. 1st Road Left	3	1.0		15 MIN	855
6-10-21	WILSHIRE SUBD. - DAISY DRIVE	6	1.0		15 MIN	3375
6-21-21	WILSHIRE SUBD - BRADLEY LANE	6	1.1		15 MIN	3375
6-21-21	WILSHIRE SUBD. - WEST CLAY COURT	6	1.1		15 MIN	3375
6-21-21	WILSHIRE SUBD - ANNA LANE	6	1.0		20 MIN	4500
6-21-21	186 SHIELDS SUBD. #2	2	1.1		15 MIN	405
6-21-21	175 SHIELDS SUBD.	2	1.0		15 MIN	405
6-21-21	39 SHIELDS SUB. (WIZARD LN)	3	1.1		15 MIN	855
6-21-21	HERITAGE HEIGHTS LANE	3	1.0		20 MIN	1140
6-21-21	99 WILSON LANE	2	.95		15 MIN	405
6-21-21	50 BLUE BIRD LANE	2	.98		15 MIN	405
6-21-21	130 CARDINAL HILL SUBD.	2	1.0		15 MIN	405

T: 26,120

District: EAST LAUREL WATER DISTRICT  
 Year :

PERIODIC FLUSHING REPORT  
 PAGE 8

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	(FANTASY WORLD)		1.10		15 MIN.	855
6-22-21	752 EAST LAUREL ROAD	3				
6-22-21	253 REBECCA LANE	2	1.10		15 MIN.	405
6-22-21	REBECCA LANE (TOP HILL)	3	1.0		20 MIN.	1140
6-22-21	762 BERT REAMS ROAD	4	.90		15 MIN.	1500
	ADD 577					
6-22-21	SALLYS BRANCH ROAD (ON HILL)	3	1.0		20 MIN.	1140
	ADD 577					
6-22-21	SALLYS BRANCH RD & DRIVE UP HILL	3	1.10		20 MIN.	1140
6-22-21	LAUREL FISH AND GAME RD	3	1.10		20 MIN.	1140
6-22-21	120 SALLYS BRANCH EAST	4	1.20		15 MIN.	1500
10-13-21	520 ADDRESS	3	1.60		20 MIN.	1140
10-13-21	MOORES HILL ROAD	2	1.60		15 MIN.	405
	(Pump Station)					
10-13-21	OAK CREEK SPRINGS	2	1.70		15 MIN.	405
6-22-21	SALLYS BRANCH EAST (END)	6	1.20		15 MIN.	3375
7-27-21	1996 SALLY BRANCH ROAD	4	1.30		20 MIN.	2000
10-13-21	1256 EAST LAUREL ROAD - SIDELINE	2	1.50		20 MIN.	540
10-13-21	LAYTON HARRIS ROAD - SIDELINE	2	1.40		15 MIN.	405
7-27-21	SCOTTYS TRAIL	3	1.40		15 MIN.	855
7-27-21	988 PAYNE TRAIL	3	1.30		20 MIN.	1140

T: 19,085

District: EAST LAUREL WATER DISTRICT  
 Year:

PERIODIC FLUSHING REPORT  
 PAGE 9

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	BRUNER SUBD. - BOBBY STREET	2				covered up with Black Top
7-27-21	BRUNER SUBD. - GINA STREET	2	1.30		15 Min.	405
7-27-21	BRUNER SUBS. - SHERRY ST	2	1.30		15 Min.	405
9-1-21	80 SUNRISE SUBD. (INLINE)	2	1.10		30 Min.	900 <sup>+</sup> <del>405</del> 30x
10-7-21	ROSE JONES RD & TOM CAT TRAIL	4	1.40		20 Min.	2000
10-13-21	HOLLY LANE	2	1.50		20 Min.	540
10-7-21	SULFRIDGE FARM ROAD	3	1.20		15 Min.	855
7-29-21	BREWER ROAD	3	1.10		20 Min.	1140
7-29-21	110 WITT ROAD	4	1.0		15 Min.	1500
7-29-21	SERENTY LANE	3	.90		15 Min.	<del>855</del>
7-29-21	HB SMITH ROAD	3	1.0		15 Min.	855
10-13-21	NU WAY TRAIL	3	1.5		20 Min.	1140
7-29-21	SALLYS BRANCH ROAD (NORTH END) (INLINE)	3	1.20		15 Min.	855
			1.10		15 Min.	405
7-29-21	OLD WAY ROAD & HWY 472	2				
8-20-21	2732 TOM CAT TRAIL SIDELINE	3	1.0		20 Min.	1140
	3101 TOM CAT TRAIL SIDELINE (LOST)	4				
10-12-21	WILLIE MARTIN ROAD	3	1.21		12 hrs.	43,200 <del>15 hr</del>

T: 55,340

District: EAST LAUREL WATER DISTRICT  
 Year:

PERIODIC FLUSHING REPORT  
 PAGE 10

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
10-13-21	PINE HILL -BROCK ROAD	3	1.4		20min.	1140
10-13-21	SOUTHERN OAKS ROAD	4	1.3		15min.	1500
10-21-21	HIGHLANDS HEIGHTS LOOP	2	1.5		20min	540
10-21-21	HIGHLANDS HEIGHTS LOOP	3	1.5		15min.	855
10-21-21	295 HIGHLANDS SUB.	3	1.6		15min.	855
10-21-21	BROOKSIDE PLACE SUBD.	6	1.6		30min.	16750
7-26-21	108 BUNDY ROAD	2	1.2		20min.	540
10-21-21	TANNER WAY SW	6	1.3		15min.	3375
10-21-21	TANNER WAY NE	6	1.3		15min	3375
10-21-21	TODD COURT	6	1.4		15min.	3375
10-21-21	TRENT COURT	6	1.3		15min.	3375
10-21-21	JADE CIRCLE (INLINE)	6	1.3		15min.	3375
10-21-21	RUBY COURT	6	1.3		15min.	3375
7-26-21	KIRKWOOD DRIVE (OLD POND)	6	1.2		20min.	4500
7-26-21	KIRKWOOD DRIVE (SHILOH COURT)	6	1.2		20min.	4500
7-26-21	PASTURE VIEW ROAD	2	1.1		15min.	405
8-20-21	JOHNNY EVANS LINE	2	1.0		15min	405

T: 42,240

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 10 - A

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
6-8-21	CUPP LANE (CARTIS CARPENTER)	3	1.60		20 min.	1140
6-8-21	RIVER OAKS SUB (UPPER)	3	1.50		20 min.	1140
6-8-21	RIVER OAKS SUB (LOWER)	3	1.50		20 min.	1140
	<b>OWNER WILL NOT LET US FLUSH</b>					
	374 SIBERT ROAD (BILLY YADEN)	2				
7-27-21	344 SIBERT ROAD (MIKE YADEN)	2	1.40		15 min.	405
	(MOUSIE GRAY)					
7-27-21	SIBERT LANE	3	1.40		20 min.	1140
	(END)					
6-8-21	SIBERT LANE	3	1.40		15 min.	855
6-8-21	1204 ROUGH CREEK RD (ON HILL)	3	1.40		15 min.	855

T: 6,675

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year :

PAGE 11

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
7-26-21	PADDOCK PLACE SUB - DERBY DRIVE	3	1.3		15 MIN.	855
7-26-21	PADDOCK PLACE SUB - DERBY DRIVE	6	1.4		20 MIN.	4500
7-26-21	PADDOCK PLACE SUB - WINNERS CIRCLE	3	1.3		15 MIN.	855
6-8-21	HWY 830 (LAUREL RIVER BRIDGE INLINE)	4	1.2		20 MIN.	2000
6-8-21	COY SCHELL ROAD (Hwy 830)	3	1.0		15 MIN.	855
6-8-21	CARL WEAVER (Loopline)	4	.95		15 MIN.	1500
	<b>WATER NOT ON</b>					
	OPEN SKY ESTATES					
9-14-21	124 BLACKWOOD LN	2	1.5		15 MIN.	405
9-14-21	214 OAK VIEW LANE (END)	3	1.6		15 MIN.	855
8-20-21	668 REED ROAD	2	.95		15 MIN.	405
10-4-21	SOUTH FORK ESTATES - ASHTON LANE	3	1.4		15 MIN.	855
10-4-21	SOUTH FORK ESTATES - KARA LANE	3	1.4		15 MIN.	855
10-4-21	WATKINS ROAD	2	1.5		20 MIN.	540
10-5-21	GRUBB ROAD SPUR	3	1.4		15 MIN.	855
10-5-21	GRUBB ROAD	2	1.4		15 MIN.	405
9-15-21	PARSLEY HILL ROAD #1	2	1.0		20 MIN.	540
9-15-21	PARSLEY HILL ROAD #2	2	1.0		20 MIN.	540
9-15-21	STALEY ROAD	2	1.1		15 MIN.	405

T: 17,225





District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 14

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	<b>TOP BROKE OFF</b>					
	310 DON MINTON ROAD	2				
	HOOPPOLE ROAD	3				
	CAMP BRANCH ROAD #1	3				
	CAMP BRANCH ROAD #2	3				
	HACKER LANE (BROCK MINTON)	3				
	OFF HWY 80					
	BROCK MINTON ROAD EAST	3				
	GOINS LANE	3				
	HAYRE ROAD (JIM BERNARD ROAD)	3				
	MARLIN JONES ROAD	4				
	YORK CEMETERY SPUR ROAD	4				
	WEBB HOLLOW ROAD	4				
	1035 ELISHA FELTNER ROAD	4				
	OFF HWY 80					
	BROCK MINTON ROAD EAST	3				
	CHARLIE SMITH ROAD	4				
	ELBERT SMITH ROAD	3				
	(LEFT)					
9-15-21	268 EAST 80 CHURCH ROAD	2	1.0		15 MIN.	405
9-15-21	EAST 80 CHURCH ROAD	3	1.0		15 MIN.	855
9-15-21	HARRIS CEMETERY ROAD #1	3	1.1		15 MIN.	855

T: 2,115

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 15

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
	HARRIS CEMETERY ROAD #2	3				
	91 DAN BROWN ROAD	2				
	BROCK LANE	3				
	DAVIDSON RD - SPLIT RAIL LANE	3				
9-15-21	HWY 80 E.O.L.	2	.90		20 MIN.	540
8-3-21	EMERALD POINTE APARTMENTS	6	1.2		20 MIN.	4500
8-3-21	251 HIDEWAY ROAD	2	1.1		20 MIN.	540
8-3-21	PENNY - ABBY LANE	2	1.1		15 MIN.	405
8-3-21	OAKS SUBDIVISION - OAK POINT	4	1.2		15 MIN.	1500
8-3-21	OAKS SUBD. - OAKWOOD DRIVE	4	1.2		15 MIN.	1500
8-3-21	OAKS SUBD. - PINE OAK TRAIL	6	1.1		20 MIN.	4500
8-3-21	CEDAR RIDGE DRIVE	4	1.1		15 MIN.	1500
8-3-21	DARRIN SIZEMORE DRIVE	3	1.0		15 MIN.	855
8-3-21	DARRIN SIZEMORE DRIVE	2	1.0		15 MIN.	405
8-3-21	OAKS SUBD. - BEECHWOOD DRIVE	4	1.1		20 MIN.	2000
8-3-21	OAKS SUBD. - POPLAR RIDGE	4	1.1		15 MIN.	1500
8-3-21	OAKS SUBD. - HICKORY COURT	4	1.2		15 MIN.	1500
8-3-21	OAKS SUBD. - PINWOOD COURT	6	1.2		15 MIN.	3400

T: 24,645

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 15 -A

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST P.S.I	Estimated Time/Flush	Estimated Total
10-26-21	ROBINSON ROAD EAST	2	1.7		20 MIN.	540
10-26-21	260 COON CLUB ROAD	2	1.6		15 MIN.	405
10-26-21	COON CLUB ROAD NO. 2	3	1.6		15 MIN.	855
10-26-21	320 WHISPERING PINES	3	1.5		20 MIN.	1140

T: 2940

District: EAST LAUREL WATER DISTRICT  
 Year:

PERIODIC FLUSHING REPORT  
 PAGE 16

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	SIZE	Free CL-2	EST. P.S.I	Estimated Time/Flush	Estimated Total
	(HYDRANT)					
8-31-21	SILVER EAGLE DRIVE	4	1.2		15 MIN.	1500
8-31-21	97 COURTNEY LANE	4	1.2		15 MIN.	1500
10-26-21	JORDAN AVENUE & TALON TRAIL	3	1.6		15 MIN.	855
8-31-21	TALON TRAIL	3	1.0		20 MIN.	1140
	(HYDRANT)					
	956 HWY 1189 (WEST)	4				
	1383 PARK SUBDIVISION (Body Shop)	2				
	HWY 1189 (INLINE BEFORE BRIDGE)	3				
	WREN ROAD	2				
	DARRELLS WAY	3				
7-1-21	SMITH BREWER ROAD (INLINE)	3	1.30		15 MIN.	855
8-31-21	ANN LANE	3	1.0		15 MIN.	855
7-1-21	HAPPY HOLLOW ROAD	3	1.10		15 MIN.	855
7-1-21	QUAIL RIDGE SUB.	3	1.20		20 MIN.	1140
8-31-21	HOPKINS CEM. & OLD STATE RD. JCT. (INLINE)	2	1.10		20 MIN.	540

T: 9,240

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 16-A

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	SIZE	Free CL-2	EST. P.S.I	Estimated Time/Flush	Estimated Total
7-1-21	SLATE RIDGE ROAD (ROAD TO LEFT)	3	1.0		15min.	855
7-1-21	SLATE RIDGE ROAD	4	1.1		15min.	1500
8-31-21	CHERRY HILL ROAD	3	1.0		20min.	1140
8-19-21	DILLION DRIVE	3	1.2		20min.	1140
8-19-21	WAGERS ROAD (Off Engle Ridge Rd)	3	1.3		15min.	855
8-31-21	ECHOING HILLS SUB. #1	4	1.0		15min.	1500
8-31-21	ECHOING HILLS SUB. #2	4	1.0		15min.	1500
8-19-21	ENGLE RIDGE ROAD	4	1.2		15min.	1500
8-31-21	MCFADDEN LANE	2	.90		20min.	540

T: 10,530

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 17

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	SIZE	Free CL-2	EST. P.S.I	Estimated Time/Flush	Estimated Total
10-7-21	LAUREL RIVER ROAD (INLINE)	2	1.6		15 MIN.	405
	DREW LANE	3				
	BRYER LANE	3				
3/28	1600 LAUREL RIVER ROAD	4	1.3		1 hr.	6000
12-7	SETTLES LANE	3				
12-7	4053 ECHO VALLEY ROAD (Inline)	2	.			
12-7	4053 ECHO VALLEY ROAD (Inline)	2				
12-7	HWY 1223 (SPRING CUT RD)	3				
12-7	HWY 830	4				
12-7	GOOD BRANCH ROAD	4				
12-7	HWY 233	4				
	HWY 830 & Hwy 1810 Jct. (Inline)	3				
	SAM PARKER ROAD (RIGHT)	4				
	SCOTTS CHAPEL ROAD	4				

T: 6,405

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 18

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST. P.S.I	Estimated Time/Flush	Estimated Total
10-14-21	HWY 830 (Robert Sulfridge)	4	1.30		20 Min.	2000
10-14-21	HWY 830 & Hwy 1023 Jct (Inline)	4	1.30		15 Min.	1500
	Past Creek 150 Feet					
10-13-21	MCLURE BRIDGE ROAD (INLINE)	4	1.50		15 Min.	1500
7-29-21	1551 MCLURE BRIDGE ROAD (INLINE)	4	.90		15 Min.	1500
10-14-21	GOOD BRANCH ROAD	3	1.20		20 Min.	1140
10-14-21	HALE ROAD	4	1.20		15 Min.	1500
10-14-21	HWY 1023 (INLINE @ GATE)	4	1.30		15 Min.	1500
10-14-21	BRANNON MILL ROAD	4	1.20		20 Min.	2000
9-22-21	LIPPS LANE	3	.90		15 Min.	855
7-29-21	187 CAMP GROUND SCH. ROAD (Richard Smith Dr)	3	1.0		20 Min.	1140
7-29-21	422 CAMP GROUND SCH. ROAD	2	1.0		20 Min.	540
10-14-21	BLUE SKY LANE	2	1.1		15 Min.	405
3/28	LAUREL RIVER CHURCH RD (INLINE)	4	1.5		45 Min.	4500
10-14-21	MEADOWVIEW SUB.	3	1.2		20 Min.	1140
7-29-21	PAY LAKE ROAD #1	3	1.1		15 Min.	855
7-29-21	PAY LAKE ROAD #2	3	1.0		20 Min.	1140 - rke
8-10-21	C. SMITH ROAD (Off Burnett Rd)	2	1.1		15 Min.	405
8-10-21	FARMER ROAD (Inline)	3	1.2		20 Min.	1140 - pvc

T: 24,760

District: EAST LAUREL WATER DISTRICT

PERIODIC FLUSHING REPORT

Year:

PAGE 19

DATE:	LOCATION OF HYDRANTS OR BLOW-OFFS	Size	Free CL-2	EST. P.S.I	Estimated Time/Flush	Estimated Total
8-26-21	1351 BURNETT ROAD (INLINE)	3	.90		15 MIN.	855
9-22-21	TAYLOR SUB. NO. 2	3	.80		20 MIN.	1140
9-22-21	22 TAYLOR SUB. # 1	2	.80		20 MIN.	540
9-22-21	MULLINS ROAD (SIDELINE RIGHT)	3	.70		15 MIN.	855
9-22-21	TRISH LANE	2	1.60		15 MIN.	405
9-22-21	347 SWAFFORD DRIVE	3	.60		15 MIN.	855
8-26-21	521 MULLINS ROAD	3	.50		20 MIN.	1140
4-1-21	147 GREENLAWN SUBD.	2	.70		20 MIN.	540
8-26-21	POPULAR HOLLOW ROAD	3	.50		20 MIN.	1140
8-26-21	SHIRLEY MARTIN ROAD	3	.40		20 MIN.	1140
8-26-21	GLASS-SASSER CEM. ROAD	3	.50		15 MIN.	855
8-26-21	HOPPER CREEK (INLINE)	3	.50		20 MIN.	1140
3-25-21	11424 KNOX COUNTY LINE	6	1.0 ppm		6 hrs slow	81,000
6-9-21	224 MT OLIVET CHURCH ROAD	4	.70		15 MIN.	1500
6-9-21	540 ROARK ROAD	3	.70		15 MIN.	855
9-22-21	BEN PENNINGTON FARM DRIVE	3	.60		20 MIN.	1140
9-22-21	BARNEY DRIVE	3	.60		15 MIN.	855
9-22-21	GREEN VALLEY ROAD	3	.50		20 MIN.	1140

T. 97,095













































### HYDRANT RECORD

Location: Hwy 80 & Sunrise Subdivision  
 Type: fire  
 No. Outlets: 2 2.5" 1 4.5"  
 Size of Main: 6"  
 Static Pressure: 70psi  
 Connected to Grid? Yes x No  
 Gate Valve?                     

No. 53  
 Make Anniston  
 In Service                       
 Size of Riser 30"  
 Flow Pressure 18psi  
 Discharge(gpm) 710gpm  
 Give Location                     

### ANNUAL INSPECTION REPORT

Date	Flushed	Lub.	Paint ed	Rep- aired	Pentagon	Cap/Chain	Check By	Remarks
5-28-21	✓	NA	NA	NA	NA	✓	JD	oil plug stuck had to turn off

### HYDRANT RECORD

Location: 1134 Tom Cat Trail  
 Type: Flush  
 No. Outlets: 2 2.5" 1 4.5"  
 Size of Main: 4"  
 Static Pressure: 73  
 Connected to Grid? Yes x No  
 Gate Valve? yes

No. 54  
 Make Mueller  
 In Service 1978  
 Size of Riser 30"  
 Flow Pressure 3psi  
 Discharge(gpm) 250  
 Give Location 15 ft.

### ANNUAL INSPECTION REPORT

Date	Flushed	Lub.	Paint ed	Rep- aired	Pentagon	Cap/Chain	Check By	Remarks
5-28-21	NA	NA	NA	NA	NA	NA	JD	Removed

### HYDRANT RECORD

Location: Tom Cat Trail & Old Way Rd.  
 Type: fire  
 No. Outlets: 2 2.5" 1 4.5"  
 Size of Main: 4"  
 Static Pressure: 47psi  
 Connected to Grid? Yes x No  
 Gate Valve? yes

No. 55  
 Make Mueller  
 In Service 1988  
 Size of Riser 30"  
 Flow Pressure 6psi  
 Discharge(gpm) 400  
 Give Location 4ft

### ANNUAL INSPECTION REPORT

Date	Flushed	Lub.	Paint ed	Rep- aired	Pentagon	Cap/Chain	Check By	Remarks
5-28-21	✓	✓	NA	NA	NA	✓	JD	



