

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

Electronic Application Of Kentucky Power Company)
For (1) A General Adjustment Of Its Rates For Electric)
Service; (2) Approval Of Tariffs And Riders; (3))
Approval Of Accounting Practices To Establish)
Regulatory Assets And Liabilities; (4) A)
Securitization Financing Order; And (5) All Other)
Required Approvals And Relief)

Case No. 2023-00159

DIRECT TESTIMONY OF
TIMOTHY C. KERNS
ON BEHALF OF KENTUCKY POWER COMPANY

**DIRECT TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2023-00159

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	BACKGROUND	1
III.	PURPOSE OF TESTIMONY	4
IV.	KENTUCKY POWER’S GENERATING ASSETS.....	5
V.	KENTUCKY POWER GENERATION O&M	9
VI.	GENERATION CAPITAL ADDITIONS	11
VII.	GENERATION PERFORMANCE DURING WINTER STORM ELLIOTT	17
VIII.	CONCLUSION.....	24

EXHIBITS

EXHIBIT	DESCRIPTION
Exhibit TCK-1	Company’s Response to Commission’s Staff Set 1, Question 6 in Case No. 2023-00145

**DIRECT TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2023-00159

I. INTRODUCTION,

1 **Q. PLEASE STATE YOUR NAME, POSITION, AND BUSINESS ADDRESS.**

2 A. My name is Timothy C. Kerns. My business address is 200 Association Drive,
3 Charleston, WV, 25311. In March 2023, I accepted the position of Vice President
4 of Generating Assets for Appalachian Power Company (“Appalachian Power”) and
5 Wheeling Power Company (“Wheeling Power”) effective April 2023. Appalachian
6 Power and Wheeling Power are wholly owned subsidiaries of American Electric
7 Power Company, Inc. (“AEP”). Immediately prior to my current role, I was Vice
8 President of Generating Assets for Kentucky Power Company (“Kentucky Power”
9 or “the Company”) and Indiana Michigan Power Company (“I&M”) from 2020 to
10 2023.

II. BACKGROUND,

11 **Q. PLEASE BRIEFLY DESCRIBE YOUR EDUCATIONAL BACKGROUND**
12 **AND BUSINESS EXPERIENCE.**

13 A. I earned a Bachelor of Science in Mechanical Engineering Degree from West
14 Virginia Institute of Technology and have been employed by AEP system
15 companies for 34 years. I have worked at various power plants across the AEP
16 System since 1989 in various positions including as a Performance Engineer, a

1 Maintenance Engineer, and a Plant Manager where, among other things, I
2 performed, directed, and managed outage and non-outage maintenance and capital
3 work. Specifically, from 1989 to 1996 I was a Performance, Maintenance and
4 Environmental Engineer at the Philip Sporn Plant; from 1996-1998 I was an
5 Equipment Troubleshooting Specialist for the Regional Services Organization
6 (“RSO”); from 1998-1999 I was a Zone Superintendent for the RSO; from 1999-
7 2000 I was a Regional Engineer Manager; from 2001 to 2006 I was the RSO
8 Manager; from 2006-2011 I was the Plant Manager at the Tanners Creek and
9 Lawrenceburg Plants; from 2011 to 2017 I was the Plant Manager at the Rockport
10 Plant; from 2017 to 2020 I was the Managing Director of Generating Assets for
11 I&M; and from 2020 to 2023 I was the Vice President of Generating Assets for
12 Kentucky Power, Wheeling Power and I&M.

13 **Q. PLEASE BRIEFLY DESCRIBE YOUR DUTIES AND RESPONSIBILITIES**
14 **AS VICE PRESIDENT GENERATING ASSETS FOR APPALACHIAN**
15 **POWER AND WHEELING POWER.**

16 A. In my new role I am responsible for the safe, reliable, and economic operation of
17 the fossil-fueled generating assets owned and operated by the Companies. This
18 includes the Amos, Mitchell, and Mountaineer coal-fired power plants, as well as
19 the gas-fired Ceredo (simple-cycle combustion turbines), Clinch River (gas-fired
20 boiler), and Dresden (combined-cycle) power plants, and Appalachian Power’s
21 hydro facilities. Specifically, I plan, organize, coordinate, direct, and control plant
22 activities, including the operations, maintenance, engineering, and construction of
23 the plant facilities. I also oversee plant budgets and interface with other AEP
24 functional groups such as Accounting, Regulatory, and Commercial Operations to

1 ensure the needs of the generating plants are met. Additionally, I am responsible
2 for any decommissioning, demolition, and disposition of generating assets owned
3 or operated by the Companies.

4 **Q. PLEASE EXPLAIN YOUR FAMILIARITY WITH KENTUCKY POWER**
5 **GENERATING ASSETS.**

6 A. In my former role as Kentucky Power's Vice President of Generating Assets, I was
7 responsible for the safe and reliable operation of Big Sandy Unit 1 and Mitchell
8 Units 1 and 2 for over three years. More importantly, I was in the role throughout
9 the test year for this proceeding.

10 Prior to the adoption of the resolutions identified in the Written Consent
11 Action of the Mitchell Operating Committee, Kentucky Power was Mitchell Plant's
12 operator until September 1, 2022. Until that time, I also had overall responsibility
13 for the operation and maintenance of the Plant as the Company's Vice President of
14 Generating Assets. I continue to have these responsibilities in my current role on
15 behalf of Wheeling Power now that Wheeling Power is the operator for the Mitchell
16 Plant. I am familiar with the day to-day operation of the Mitchell Plant as a result
17 of my responsibilities in the oversight of Plant personnel in connection with the
18 safe, reliable, and economic operation of the Plant. In this regard, my
19 responsibilities include interacting on a regular basis with the Mitchell Plant
20 manager, who reports directly to me, as well as with other Plant personnel in
21 connection with both day-to-day and longer-term Plant activities. In addition, I
22 regularly review budgets, review investments, and help plan the safe and reliable
23 operation of that facility. I also continue to participate as a non-voting member of
24 Mitchell Plant Operating Committee.

1 Lastly, as part of Wheeling Power’s management team, I work in close
2 coordination with the American Electric Power Service Corporation (“AEPSC”)
3 and Kentucky Power’s Managing Director of Generating Assets to ensure the
4 Mitchell Plant is safe, reliable and provides benefit to customers through effective
5 management of O&M expenditures and capital investments.

6 **Q. HAVE YOU PREVIOUSLY TESTIFIED IN ANY REGULATORY**
7 **PROCEEDINGS?**

8 A. Yes. I have submitted testimony and testified on behalf of Kentucky Power before
9 this Commission in Case Nos. 2020-00174 (2020 base rate case) and 2021-00421
10 (Mitchell Plant operating agreements). I have also submitted testimony on behalf
11 of Wheeling Power before the West Virginia Public Service Commission
12 (“WVPSC”) in Case No. 21-0810-E-PC. In addition, I have submitted testimony
13 and testified on behalf of I&M before the Indiana Utility Regulatory Commission
14 in Cause Nos. 44967, 44511, and 45235, and the Michigan Public Service
15 Commission in Cause Nos. U-18370, U-20070, and U-20359. Finally, I submitted
16 testimony at the Federal Energy Regulatory Commission in AEP Generating
17 Company’s depreciation rate cases.

III. PURPOSE OF TESTIMONY

18 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**
19 **PROCEEDING?**

20 A. The purpose of my testimony is to:

- 21 • Describe Kentucky Power’s generation assets;

- 1 • Describe and support the reasonableness of Kentucky Power’s generation non-
2 fuel, non-labor operation and maintenance (“O&M”) expenses for the Mitchell
3 and Big Sandy Plants;
- 4 • Describe the retired Big Sandy generating assets;
- 5 • Describe capital investments placed in-service at Kentucky Power’s generating
6 assets since the Company’s last base case; and
- 7 • Describe the performance of the Company’s generation fleet during Winter
8 Storm Elliott.

9 **Q. WHAT IS THE TEST YEAR FOR THIS PROCEEDING?**

10 A. The test year in this proceeding is the twelve-month period from April 1, 2022
11 through March 31, 2023.

12 **Q. ARE YOU SPONSORING ANY EXHIBITS AS PART OF YOUR**
13 **TESTIMONY?**

14 A. Yes. I am sponsoring the following exhibits attached to my testimony:

15 EXHIBIT	DESCRIPTION
16 Exhibit TCK-1	Company’s Response to Commission’s Staff Set 1, 17 Question 6 In Case No. 2023-00145

IV. KENTUCKY POWER’S GENERATING ASSETS

18 **Q. PLEASE DESCRIBE KENTUCKY POWER’S GENERATION ASSETS.**

19 A. Kentucky Power’s generation assets consisted of both owned and contracted
20 generation capacity totaling 1,468 MW until December 7, 2022. Beginning
21 December 7, 2022 through the 2022/2023 PJM planning year ending May 31, 2023,
22 Kentucky Power’s owned and contracted generation capacity totaled approximately
23 1,227 MW under the terms and conditions of the Power Coordination Agreement
24 (“PCA”).

1 **Q. PLEASE BRIEFLY DESCRIBE KENTUCKY POWER'S OWNED**
 2 **GENERATION.**

3 A. Kentucky Power's generation assets consist of a total of 1,075 MW of capacity
 4 from two generating plants, Big Sandy and Mitchell. The Company's assets and
 5 their characteristics are listed in Figure TCK-1.

Figure TCK-1: Kentucky Power Generation Assets

Plant	Kentucky Power-Owned Capacity (MW)	No. of Units	Location	Fuel	Expected Retirement Date
Big Sandy	295	1	Louisa, KY	Natural Gas	2031
Mitchell	780	2	Moundsville, WV	Coal	2040

6 Kentucky Power owns and operates the Big Sandy Plant located near
 7 Louisa, Kentucky. The plant currently has a single operating unit with a generating
 8 capacity of 295 MW. Big Sandy Unit 1 was originally placed in service in 1963
 9 and operated as a 278 MW sub-critical coal-fired generating unit through mid-
 10 November 2015. As approved by the Commission in Case No. 2013-00430, and
 11 described later in my testimony, Big Sandy Unit 1 was converted to a natural gas-
 12 fired unit and returned to service May 31, 2016. The Unit is equipped with low
 13 nitrogen oxide ("NO_x") burners with overfire air for reduction of NO_x emissions.

14 The Mitchell Plant is located approximately 12 miles south of Moundsville,
 15 West Virginia on the Ohio River. Kentucky Power owns an undivided 50% interest
 16 in the Mitchell Plant; the other 50% interest is owned, and operated, by Wheeling
 17 Power. The plant comprises two super-critical pulverized coal-fired baseload
 18 generating units. Mitchell Unit 1 has a capacity of 770 MW and Mitchell Unit 2

1 has a capacity of 790 MW for a total capacity of 1,560 MW. Both Units were
2 placed in service in 1971.

3 **Q. PLEASE DESCRIBE WHAT COMPRISES KENTUCKY POWER'S**
4 **CONTRACTED GENERATION.**

5 A. Kentucky Power was a party to a unit power agreement ("UPA") with AEP
6 Generating Company for power from the Rockport Plant that terminated December
7 7, 2022. The Rockport Plant is located along the Ohio River in southern Indiana
8 and consists of two supercritical pulverized coal-fired generating units. Kentucky
9 Power's contractual share of the Rockport output totaled 393 MW. Upon
10 termination of the Rockport UPA, the Company forecasted that it would require
11 152.4 MW of replacement capacity through the 2022/2023 PJM planning year
12 ending May 31, 2023 that would be obtained through the PCA between Kentucky
13 Power and AEP's Operating Companies.

14 **Q. HAVE THE RETIREMENT DATES FOR BIG SANDY UNIT 1 OR**
15 **MITCHELL GENERATING UNITS CHANGED?**

16 A. There have been no changes to the expected retirement dates of either Big Sandy
17 Unit 1 or the Mitchell Plant. With continued investment and maintenance, Big
18 Sandy Unit 1 is expected to reach its current retirement date of 2031 and the
19 Mitchell plant is expected to reach its retirement date of 2040. However, it is my
20 understanding that, based on its recently filed Integrated Resource Plan, the
21 Company is proposing to operate Big Sandy Unit 1 through 2041. Additionally, as
22 a result of the Commission's Order in Case No. 2021-00004 denying a Certificate
23 for Public Convenience and Necessity ("CPCN") for Effluent Limitation

1 Guidelines (“ELG”) projects at Mitchell Plant, Kentucky Power’s interest in
2 Mitchell will terminate in 2028.

3 **Q. PLEASE DESCRIBE THE KENTUCKY POWER GENERATING ASSETS**
4 **THAT HAVE BEEN RETIRED.**

5 A. Due to EPA’s Mercury and Air Toxics (“MATS”) Rule, Big Sandy Unit 2, an
6 800MW coal-fired generating asset, was retired in May 2015 and Big Sandy Unit
7 1 was converted from coal-fired to natural gas-fired in May 2016. The fuel
8 conversion allowed Big Sandy Unit 1 to continue to operate in compliance with the
9 stringent air emission requirements of MATS. There were coal-related assets for
10 Big Sandy Unit 1 that were retired since they were not required for its natural gas
11 operations.

12 Demolition activities at Big Sandy Unit 2 began in 2016. Since that time,
13 the dismantlement of coal handling equipment and the demolition of its cooling
14 tower, turbine building, boiler house, and environmental equipment have been
15 completed. Currently, fly ash pond post-closure monitoring activities and asbestos
16 abatement continue at the Big Sandy Plant. The going-forward coal-related
17 decommissioning ARO costs associated with the fly ash pond and asbestos
18 abatement for Big Sandy Unit 2 are identified by Company Witness Whitney.

19 Big Sandy Unit 1, although converted to a natural gas generating asset in
20 2016, had some equipment solely related to its operation as a coal-fired facility.
21 Examples of Big Sandy Unit 1’s coal-related assets included the coal yard and its
22 associated equipment, the conveyors and silos which transferred coal from the coal
23 yard to the plant, the coal pulverizers, the Electrostatic Precipitators (“ESP”), and
24 the fly ash and bottom ash handling systems. This equipment was no longer

1 necessary when the unit began operating as a natural gas unit and was retired once
2 the unit no longer operated as a coal-fired facility.

V. KENTUCKY POWER GENERATION O&M

3 **Q. WHAT ARE THE O&M REQUIREMENTS OF KENTUCKY POWER'S**
4 **GENERATION ASSETS?**

5 A. Kentucky Power's plants must provide safe, economical, and reliable generation
6 output to serve load and accommodate fluctuating customer needs. In addition, a
7 unit's maintenance needs vary based on its type, design, age, condition, and
8 operational characteristics. All units are maintained to maximize operations, and
9 to do so in a safe manner in compliance with all local, state, and federal regulations.

10 **Q. HOW ARE O&M COSTS CONTROLLED AT THE PLANTS?**

11 A. To minimize O&M expenses, Kentucky Power relies on a system of maintenance
12 and operations management programs to ensure optimal performance of the
13 generating assets. These maintenance programs are:

- 14 • Predictive Maintenance: monitoring, inspections, and/or data analyses
15 conducted to diagnose potential maintenance issues early and usually
16 while the equipment is running to minimize downtime.
- 17 • Preventive Maintenance: protocols, testing, and physical work
18 conducted on equipment to address anticipated or diagnosed
19 vulnerabilities.

20 In addition, continuous improvements are incorporated into the operations
21 and maintenance of the generating units to eliminate waste and increase process
22 efficiencies. Together, these maintenance and operations management programs
23 help to optimize operation of the assets and limit O&M cost escalations.

1 **Q. WHAT IS KENTUCKY POWER'S TEST YEAR LEVEL OF**
 2 **GENERATION O&M EXPENSE?**

3 A. Kentucky Power's non-fuel, non-consumables, non-labor test year Generation
 4 O&M expense is \$27.634 million. As shown in Figure TCK-2 below, Kentucky
 5 Power's test year Generation O&M expenses include steam maintenance and steam
 6 operations amounts for Big Sandy, the Company's 50% undivided interest in
 7 Mitchell, and shared plant costs not attributable to a specific generating unit (known
 8 as Non-Plant costs).

**TCK-2: Test Year Kentucky Power Non-Fuel, Non-Consumables, Non-
 Labor Test Year Generation O&M***

Category	Big Sandy Plant	Mitchell Plant	Non-Plant	Total
Steam Maintenance	\$5,954,613	\$12,408,247	\$212,067	\$18,522,160
Steam Operations	\$1,570,122	\$4,911,699	\$2,629,917	\$9,111,737
Total:	\$7,524,734	\$17,319,946	\$2,841,984	\$27,633,897

*Total may not sum due to rounding

9 **Q. DOES THE TOTAL AMOUNT OF \$27.634 MILLION REPRESENT AN**
 10 **APPROPRIATE AND REASONABLE ONGOING LEVEL FOR O&M FOR**
 11 **KENTUCKY POWER'S GENERATION ASSETS?**

12 A. Yes. This total level is reasonable and fairly reflects an appropriate level of O&M
 13 for Big Sandy and Kentucky Power's undivided 50% share of the Mitchell Plant.

VI. GENERATION CAPITAL ADDITIONS

1 **Q. PLEASE PROVIDE AN OVERVIEW OF GENERATION CAPITAL**
2 **ADDITIONS PLACED IN-SERVICE SINCE THE COMPANY'S LAST**
3 **BASE CASE.**

4 A. As shown in TCK-3 below, Kentucky Power had steam and other generation plant
5 related capital additions totaling approximately \$44.167 million placed in-service
6 since the Company's last base case. Of that amount, \$11.221 million is associated
7 with major fossil fuel generation capital projects and \$22.529 million that is
8 associated with Production Plant Blanket ("PPB") capital projects.

9 Allocations to Kentucky Power's fossil fuel generation organization for
10 intangible projects (information technology projects that are not associated with
11 physical capital additions at Kentucky Power's plants but provide benefits to
12 Kentucky Power) account for a combined total of approximately \$11.551 million.
13 General capital additions that support plant operations account for approximately
14 \$456 thousand. The remaining fossil fuel generation capital amounts include Asset
15 Retirement Obligation ("ARO") estimates that resulted in a reduction of
16 approximately \$1.590 million to capital additions.

17 Figure TCK-3 is inclusive of all environmental project capital additions
18 placed in-service since the last base case. However, all environmental project costs
19 associated with ESP, Selective Catalytic Converter Reduction ("SCR"), and Dry
20 Sorbent Injection ("DSI") capital additions are collected through Environmental
21 Compliance Plan ("ECP") Company filings as discussed by Company Witness
22 Kahn.

**Figure TCK-3: Generation Capital Additions
April 2020 – March 2023**

Plant	Project Description	Addition to Plant (\$)
Big Sandy Plant	Fossil Fuel Major Projects	
	(Non-Environmental)	
	North American Electric Reliability Corporation (NERC) Critical Infrastructure Protection (CIP) Physical Security Upgrade	\$519,594
		\$519,594
	(Environmental)	
	Repurpose Big Sandy Bottom Ash Pond (BAP)	\$417,077
		\$417,077
	Big Sandy Fossil Fuel Major Projects Sub-Total:	
		\$936,672
	Other Fossil Generation Capital Projects	
	Production Plant Blanket Projects:	\$5,811,279
	Non-Environmental	\$5,808,906
	Environmental	\$2,373
	ARO	\$2,752,924
	Big Sandy Other Fossil Generation Capital Projects Sub-Total:	
	\$8,564,203	
Big Sandy Plant Total		\$9,500,875
Mitchell Plant (Kentucky Power Share)	Fossil Fuel Major Projects	
	(Non-Environmental)	
	Mitchell Unit 2 Cooling Tower Components Replacement	\$2,772,398
	Mitchell Unit 2 Air Heater Basket Replacement	\$2,077,824
	Mitchell Unit 1 - Phase 2 Generator Step-up (GSU) Transformer Replacement	\$13,416
		\$4,863,638
	(Environmental)	
	Mitchell Unit 2 Electrostatic Precipitator (ESP)Upgrades	\$2,115,185
	Mitchell Unit 1 Selective Catalytic Converter (SCR) Catalyst Layer 4 Replacement	\$1,357,439
	Mitchell Unit 0 Dry Sorbent Injection (DSI) Lime Conversion	\$1,326,811
	Mitchell Landfill Expansion -Phase 3	\$587,858
	Mitchell Unit 1 SCR Catalyst Layer 3 Replacement	\$27,976
	Mitchell Unit 2 - SCR Catalyst Layer 3 Replacement	\$5,483
		\$5,420,752
	Mitchell Fossil Generation Capital Projects Sub-Total:	
		\$10,284,390
	Other Fossil Generation Capital Projects	
	Production Plant Blanket Projects	\$16,718,190
	Non-Environmental	\$13,365,463
	Environmental	\$3,352,727
ARO	(\$4,343,418)	
Mitchell Other Fossil Generation Capital Projects Sub-Total:		
	\$12,374,772	
Mitchell Plant Total		\$22,659,162
Various Facilities	Intangible Capital Projects	\$11,551,194
	General Capital Projects	\$456,050
Various Facilities Total		\$12,007,244
Total Kentucky Power Capital Additions		\$44,167,280

1 **Q. PLEASE SUMMARIZE INDIVIDUAL MAJOR FOSSIL FUEL**
2 **GENERATION CAPITAL PROJECT ADDITIONS OVER \$1 MILLION**
3 **INCLUDED IN FIGURE TCK-3 AND EXPLAIN WHY THEY WERE**
4 **NECESSARY.**

5 **A.** A summary of individual major fossil fuel generation capital project additions over
6 \$1 million reflected in TCK-3 and associated necessities are summarized below.

1 Mitchell Major Capital Projects

2 Non-Environmental

- 3 • Mitchell Unit 2 Cooling Tower Components – Some of the Cooling Tower
4 components had reached the end of their useful life after 30 years of service
5 and some components had deteriorated to a point where they would not last
6 another 5-years without failing. This project replaced the Hot Water
7 Distribution deck, louvers and louver columns, outer periphery longitudinal
8 girts, and other associated components.
- 9 • Mitchell Unit 2 Air Heater Basket Replacement –The air heater baskets
10 were one year beyond their typical life cycle and were beginning to
11 deteriorate exponentially. As a result, Mitchell Unit 2 was beginning to
12 experience increases in its equivalent forced outage rate (“EFOR”)
13 associated with the baskets. The existing air heater baskets have been
14 replaced with new air heater baskets.

15 Environmental

- 16 • Mitchell Unit 2 ESP Upgrades – Upgrades required to comply with
17 particulate matter emission limits and the state of West Virginia 10%
18 opacity limit. The scope of the project included:
 - 19 ▪ the installation of a new heated purge air system;
 - 20 ▪ repair and replacement of corroded ESP sidewall casing, hopper
21 casing, and ductwork as needed;
 - 22 ▪ removal and replacement of the hot and cold roof, including
23 insulation, for approximately half of the precipitator;
 - 24 ▪ replacement of the discharge electrode support insulators as needed;
 - 25 ▪ repair of the collecting and discharge electrode rapper system; and
 - 26 ▪ replacement of the hopper level detection system.
- 27 • Mitchell Unit 1 SCR Catalyst Layer 4 Replacement – 4th layer SCR catalyst
28 replacement was required to maintain desirable NO_x removal effectiveness.
29 NO_x emissions are subject to the New Source Review (“NSR”) Consent

1 Decree and Cross-State Air Pollution Rule (“CSAPR”). The catalyst layer
2 replacement will also maintain effective mercury oxidation across the SCR
3 catalyst reactor.

- 4 • Mitchell Units 0 DSI Lime Conversion Project – Mitchell Plant currently
5 uses Trona for SO₃ mitigation. The project reconfigured the existing DSI
6 system for Mitchell Units 1 and 2 to more efficiently handle hydrated lime
7 in lieu of Trona, and reduce issues related to corrosion, as well as gain
8 benefits such as heat rate improvement, improved Equivalent Unplanned
9 Outage Rate (“EUOR”), and a lower minimum load. Conversion to lime
10 also allows for the use of a higher percentage of high sulfur coal which has
11 historically been cheaper than the lower sulfur coal, thereby resulting in
12 lower overall fuel costs. The project also installed a new distributed control
13 system for the DSI.

14 **Q. WHAT ARE PPB PROJECTS?**

15 A. PPB projects are capital projects necessary to provide for the safe, environmentally
16 responsible, reliable, and efficient operation of our generating units. They are
17 sometimes referred to as ‘Maintenance Capital’ projects. These projects are placed
18 into two categories, major or minor. Major plant blanket projects will have a total
19 cost of over \$1,000,000, but under \$3,000,000. Minor plant blanket projects, the
20 vast majority of which are smaller component replacements and installations, are
21 projects that have a total cost of under \$1,000,000.

22 When evaluating these PPB projects, Kentucky Power looks for cost
23 savings whenever possible without jeopardizing reliability and safety. All PPB
24 projects over \$1 million are also reviewed and approved through AEPSC’s
25 Strategic Capital Prioritization Process (“SCPP”) which includes review and
26 approval by AEP’s Vice President (VP) of Project Solutions, VP of Engineering

1 Service, VP of Generation Shared Services, VP of Appalachian Power Company/
2 Wheeling Power Company Generating Assets, and VP of Southwestern Power
3 Company Generating Assets.

4 **Q. PLEASE DESCRIBE SOME OF THE PPB CAPITAL ADDITIONS OVER**
5 **\$1 MILLION SINCE THE LAST BASE CASE AT KENTUCKY POWER**
6 **PLANTS.**

7 A. The major PPB projects for the Big Sandy and Mitchell Plants are listed below:

8 **Big Sandy Major PPB Capital Projects**

- 9 • Big Sandy Unit 1 Generator Stator Re-wedge – The generator stator was
10 last re-wedged in 2008 and upon inspection in fall 2022, it was
11 determined the stator required another re-wedge in order to mitigate the
12 potential risk of a premature stator failure and thereby enhance the
13 reliability of the generator. A stator failure would have left the Unit in
14 a forced state of being unable to operate for a period of one year or more
15 due to long lead time materials.

16 **Mitchell Plant Major PPB Capital Projects**

- 17 • Mitchell Unit 2 SCR Catalyst Layer 4 Replacement – Need for the
18 replacement of the catalyst 4th layer was due to normal deactivation over
19 thousands of hours of run time. SCR NO_x removal effectiveness
20 requires adequate activity levels. SCR NO_x performance is required for
21 compliance with the NSR Consent Decree requirements and CSAPR
22 regulations.

23 **Q. PLEASE SUMMARIZE THE INTANGIBLE CAPITAL INVESTMENTS**

24 A. Intangible capital projects are routine software updates and new programs that
25 increase the efficiency of Kentucky Power's Generation organization.

1 **Q. ARE EXPENSES RELATED TO ELG COMPLIANCE AT MITCHELL**
2 **INCLUDED UNDER PPB PROJECTS OR INCLUDED IN O&M**
3 **EXPENSES?**

4 A. No. As I stated earlier in my testimony, this Commission did not approve the CPCN
5 to execute ELG projects required by EPA to comply with its revisions to the ELG
6 rule effective October 2020 at the Mitchell Units; therefore, Kentucky Power is not
7 authorized to recover costs related to ELG compliance projects at Mitchell.

8 **Q. HOW DOES THE COMPANY ENSURE ELG-RELATED COSTS ARE**
9 **NOT CHARGED TO KENTUCKY POWER SINCE THIS COMMISSION**
10 **ONLY APPROVED COAL COMBUSTION RESIDUALS (“CCR”)**
11 **PROJECT UPGRADES?**

12 A. Pursuant to the September 1, 2022 Written Consent Action of the Mitchell
13 Operating Committee, which is included as Exhibit V of Section II of the
14 Company’s Application, the Company hired Burns & McDonnell, an independent
15 engineering, architecture construction, environmental consulting firm, to perform
16 an assessment of the scope of work directly related to the CCR and ELG projects
17 for the purpose of determining the appropriate allocation of CCR and ELG related
18 costs. As a result of and in accordance with Burns & McDonnell’s assessments,
19 the Company established work orders to ensure costs related to the scope of work
20 for each of the CCR and ELG projects are appropriately charged.

VII. GENERATION PERFORMANCE DURING WINTER STORM ELLIOTT.

1 **Q. PLEASE DESCRIBE WINTER STORM ELLIOTT.**

2 A. As explained further by Company Witness Vaughan, Winter Storm Elliott was a
3 bomb cyclone¹ that impacted the PJM region from December 23, 2022 through
4 December 27, 2022 (the “Winter Storm Elliott Period”), causing extreme cold
5 weather, including blizzards, high winds, and snow.

6 **Q. WERE THE COMPANY’S GENERATION ASSETS AVAILABLE AND**
7 **OPERATING DURING THE WINTER STORM ELLIOTT PERIOD?**

8 A. Both Mitchell Unit 1 and Unit 2 (collectively, the “Mitchell Units”) were available
9 and operating throughout the Winter Storm Elliott Period. As shown in Exhibit
10 TCK-1, Mitchell Unit 1 had a Net Capacity Factor² (“NCF”) of 80.3% and Mitchell
11 Unit 2 had an NCF of 74.1% during the Winter Storm Elliott Period. Big Sandy
12 Unit 1 was in a Planned Outage and was unavailable.

13 **Q. HOW DOES THE MITCHELL PLANT PREPARE FOR WINTER?**

14 A. In preparation for winter, the Mitchell Plant implements a “Winter Preparedness
15 Plan.” In 2022, the plant implemented the “Winter Preparedness Plan” starting on
16 October 3, 2022. The standard plan included employee training, completing
17 preventative maintenance work orders, performing equipment checks, replenishing
18 supplies, and other winter preparedness activities. Plant personnel completed a cold
19 weather site specific plan review on October 19, 2022 and completed training on
20 the North American Electric Reliability Council cold weather reliability standards

¹ A bomb cyclone is a large, intense storm that rapidly intensifies and is defined by a sudden and significant drop in atmospheric pressure.

² Net Capacity Factor is defined as the ratio of the generating unit’s ((net actual generation) to its net maximum capacity for the number of hours in the period being reported that the unit was in the active state) x 100%.

1 by October 31, 2022. Cold Weather Preparedness and Winterization checks
2 conducted as preventative maintenance activities were completed by November 2,
3 2022.

4 **Q. DID THE MITCHELL PLANT TAKE ANY ADDITIONAL**
5 **PREPARATORY STEPS IN ADVANCE OF WINTER STORM ELLIOTT?**

6 A. Yes. In anticipation of Winter Storm Elliott, Mitchell Plant staffing was increased
7 to at least one on-site member from the plant leadership team and additional plant
8 operations personnel and contractor support were brought on site.

9 **Q. HOW DID THE MITCHELL UNITS PERFORM DURING WINTER**
10 **STORM ELLIOTT?**

11 A. Both Mitchell Units performed well during the Winter Storm Elliott Period. Both
12 Units had a 0% forced outage factor³ and 0% maintenance outage factor⁴, meaning
13 at no point during the event were either of the Mitchell Units unavailable.

14 **Q. WAS EITHER UNIT'S OUTPUT REDUCED (OR DERATED) DURING**
15 **WINTER STORM ELLIOTT?**

16 A. Yes, at times, both Mitchell Units experienced derates due to operational issues. A
17 "derate" is defined as a decrease in the available capacity of an electric generating
18 unit, commonly due to a system or equipment modification or environmental,
19 operational, or reliability considerations. As demonstrated in Exhibit TCK-1, a
20 significant portion of the derates experienced at both Mitchell Units were required
21 to comply with particulate matter emission limits and the state of West Virginia's

³ Forced outage factor is the ratio of ((All hours experienced during forced outages) to the number of hours in the period being reported that the unit was in the active state) x 100%.

⁴ Maintenance outage factor is the ratio of ((All hours experienced during maintenance outages) to the number of hours in the period being reported that the unit was in the active state) x 100%.

1 10% opacity limit. The opacity-related derates were not driven by Winter Storm
2 Elliott. Mitchell Unit 1 also had a small 35 MW derate related to a boiler clinker
3 for the duration of the Winter Storm Elliott Period.

4 The remaining derates were caused by frozen coal causing the coal
5 conveyor to trip out, freezing of slurry feed tanks, and a pulverizer damper
6 operation issue. This group of derates lasted a combined total of only 20.31 of the
7 240 hours of operation between both Mitchell Units during the Winter Storm Elliott
8 Period.

9 During Winter Storm Elliott, Unit 1 had an equivalent availability factor⁵
10 (“EAF”) of 86.3%, and Unit 2 had an EAF of 78.4%.

11 **Q. HOW DOES THE MITCHELL PLANT’S PERFORMANCE DURING**
12 **WINTER STORM ELLIOTT COMPARE TO ITS HISTORICAL**
13 **PERFORMANCE?**

14 A. Both Mitchell Units performed favorably during Winter Storm Elliott as compared
15 to their historic performance, as Figure TCK-4 demonstrates.

⁵ Equivalent Availability factor is the ratio of ((Available hours – equivalent planned derated hours – equivalent unplanned derated hours – equivalent seasonal derated hours) to the number of hours in the period being reported that the unit was in the active state) x 100%.

**Figure TCK-4: Mitchell Unit Performance:
Winter Storm Elliott Period Compared to 2016-2021**

Mitchell Unit	Winter Storm Elliott Period Net Capacity Factor ("NCF")	Average NCF (2016-2021)	Highest NCF (2016-2021)	Winter Storm Elliott Period Average Availability Factor ("EAF")	Average EAF (2016-2021)	Highest EAF (2016-2021)
Unit 1	80.3%	36.9%	52.0%	86.3%	57.1%	68.1%
Unit 2	74.1%	46.6%	65.8%	78.4%	69.3%	84.4%

1 As demonstrated above, Unit 1's NCF and EAF and Unit 2's NCF during the
2 Winter Storm Elliott Period were higher during Winter Storm Elliott than their 6-
3 year highest annual levels. Both Units' NCF and EAF during the storm period far
4 exceeded their 6-year averages.

5 **Q. COULD THE COMPANY REASONABLY HAVE DONE ANYTHING**
6 **DURING THE WINTER STORM ELLIOTT PERIOD TO INCREASE THE**
7 **OUTPUT OF THE MITCHELL GENERATING FACILITIES?**

8 A. No. Again, it is important to reiterate that, although the Mitchell Units were derated
9 during Winter Storm Elliott, at no point was either Mitchell Unit unavailable to
10 serve customers. Furthermore, the Company cannot legally operate the Mitchell
11 Units in a manner that would violate the particulate matter emission limits and the
12 state of West Virginia's 10% opacity limit. The remaining non-opacity related
13 derates were short in duration but were required to allow for the necessary repairs
14 to be made while keeping the Units available. As such, when both Mitchell Units
15 were needed during this extreme event, they were available and performed well, to
16 the benefit of Kentucky Power customers.

1 **Q. PLEASE DESCRIBE THE PLANNED OUTAGE AT BIG SANDY DURING**
2 **WINTER STORM ELLIOTT.**

3 A. Big Sandy Unit 1 began a Planned Outage on September 109, 2022. The outage
4 was originally scheduled to be completed on December 4, 2022, but had to be
5 extended several times through January 14, 2023 for a number of reasons including
6 additional time required to repair the generator due to hot spots in the core,
7 replacement of the generator rotor collector end retaining ring due to a crack
8 discovered during the outage, the repair of the hydrogen seal housing at the exciter
9 due to a leak, and the need to repair an unexpected condenser leak identified at
10 start-up. The extensions to the outage were necessary to repair and/or replace
11 generator components to prevent the risk of a catastrophic failure of the generator
12 as well repair the condenser to allow the Unit to restart and avoid future forced
13 outages. The timeline for the Company's outage extension request to PJM is
14 discussed later in my testimony. Each extension for the Big Sandy fall 2022 outage
15 was approved by PJM.

16 **Q. WHAT IS A PLANNED OUTAGE?**

17 A. A Planned Outage is a generating unit outage of a predetermined duration that can
18 last for several weeks and occurs only once or twice a year. Typically, these events
19 consist of a known scope of work and duration that is estimated prior to the outage
20 being scheduled.

21 **Q. HOW ARE PLANNED OUTAGES SCHEDULED?**

22 A. Planned Outages are scheduled well in advance (months and sometimes even years)
23 due to significant scope, equipment lead time, engineering, and time out of
24 operation. Such outages are planned in conjunction with PJM and with PJM's

1 approval. The Company schedules Planned Outages during the shoulder months
2 attempting to avoid, to the extent practical, multiple units simultaneously in a
3 Planned Outage.

4 **Q. WHEN A UNIT IS IN A PLANNED OUTAGE, IS IT POSSIBLE TO**
5 **QUICKLY RETURN THE UNIT TO SERVICE IF MARKET CONDITIONS**
6 **CHANGE?**

7 A. Generally, it is not. During a Planned Outage, a generating unit is often at least
8 partly dismantled, often with pressure parts (parts that contain steam at very high
9 pressures and temperatures when operating, such as boilers, turbines, etc.) taken
10 apart to be inspected, maintained, and/or replaced. It is very difficult if not
11 impossible to safely and quickly return a unit to service or deviate from the work
12 plan for the outage, particularly when major equipment is disconnected or
13 dismantled for repair at that time.

14 **Q. PLEASE DESCRIBE THE SCOPE OF WORK THAT WAS TO BE**
15 **COMPLETED DURING THE PLANNED OUTAGE AT BIG SANDY UNIT**
16 **1.**

17 A. As originally scoped, the fall 2022 Planned Outage at Big Sandy Unit 1 included a
18 generator field out inspection and a possible re-wedge of the Unit's stator.⁶ The
19 Company was, in fact, required to completely re-wedge the stator as part of this
20 scope of work.

⁶ The stator is the stationary part of a rotary system found in electric generators. In an electric generator, the stator converts the rotating magnetic field to electric current.

1 **Q. WHY DID BIG SANDY'S OUTAGE EXTEND BEYOND ITS PLANNED**
2 **OUTAGE END DATE?**

3 A. In November 2022, the Company extended the Planned Outage at Big Sandy Unit
4 1 to December 12, 2022, as it needed additional time to complete the original scope
5 of work. Then, on November 13, 2022, the Company discovered a crack on the
6 generator rotor collection end retaining ring and determined that the retaining ring
7 required replacement prior to returning the Unit to service. In order to complete that
8 repair, on December 2, 2022, the Company requested the Planned Outage at Big
9 Sandy Unit 1 be extended through December 30, 2022. PJM approved the extension
10 on December 26, 2022. The Planned Outage was extended twice more for a
11 hydrogen seal leak identified during an air leakage test and a condenser leak
12 discovered during start up. These extensions were requested on December 22, 2022,
13 and January 10, 2023, and were approved by PJM on December 28, 2022, and
14 January 11, 2023, respectively.

15 **Q. COULD THE COMPANY HAVE PLACED BIG SANDY UNIT 1 IN**
16 **SERVICE WITHOUT ADDRESSING THE ITEMS THAT CAUSED THE**
17 **PLANNED OUTAGE TO BE EXTENDED THROUGH THE WINTER**
18 **STORM ELLIOTT PERIOD?**

19 A. No, it could not. First, as explained further above, extending the outage to replace
20 the retaining ring extended the Planned Outage through what became the Winter
21 Storm Elliott Period. If the Company had not replaced that retaining ring, Big Sandy
22 Unit 1 would have been at an increased risk of catastrophic failure. Therefore, the
23 Company could not have safely placed the Unit back in service and operated it

1 without replacing the retaining ring. It likewise could not have put the Unit safely
2 back in service without fixing the hydrogen seal and condenser leaks.

3 **Q. WAS THERE ANY WAY FOR THE COMPANY TO HAVE KNOWN**
4 **ABOUT THE WINTER STORM ELLIOTT EVENT WHEN IT**
5 **REQUESTED THE PLANNED OUTAGE EXTENSION ON DECEMBER 2,**
6 **2022.**

7 A. No.

8 **Q. WERE THE COMPANY'S ACTIONS RELATED TO EXTENDING THE**
9 **BIG SANDY UNIT 1 OUTAGE REASONABLE?**

10 A. Yes. The Company could not have brought Big Sandy Unit 1 back online to serve
11 customers during Winter Storm Elliott without risking a catastrophic failure of the
12 Unit as all the repairs described above were required to be completed in order to
13 safely operate the Plant. Therefore, it was reasonable to extend the planned outage
14 to ensure the Unit would be in good working order to service customers into the
15 future.

VIII. CONCLUSION

16 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

17 A. Yes, it does.

Kentucky Power Company
KPSC Case No. 2023-00145
Commission Staff's First Set of Data Requests
Dated May 10, 2023
Page 1 of 2

DATA REQUEST

KPSC 1_6 Provide a detailed explanation of how Kentucky Power's generating units were operating during Winter Storm Elliott. Include in the response a list and event description in chronological order showing by unit and date any scheduled, actual, and forced outage for the months of November and December 2022.

RESPONSE

Winter Storm Elliott began in the Pacific Northwest on December 20, 2022 and moved east at a rapid pace becoming a bomb cyclone, an area of low pressure that intensifies rapidly, and entering the PJM territory on December 23, 2022. Winter Storm Elliott impacted the PJM territory from December 23, 2022 until December 27, 2022. During that period, none of the Company's generating units were forced from service.

Big Sandy Unit 1 was in its Planned Outage (9/9/22 – 1/14/23) which was extended from its planned end date of 12/12/2022 due to emergent generator repair work discovered during its reassembly. The completion of this work was required so the unit could be returned to service and operated safely and reliably.

Both Mitchell units operated continuously throughout the Winter Storm Elliott period (12/23/2022 – 12/27/2022). At times during that period, each of units' output was reduced (or derated) due to operational issues. Those deratings resulted in Net Capacity Factors (NCF) of 80.3% and 74.1% for Units 1 and 2, respectively and were largely unrelated to the extreme weather.

Table 1 below describes the performance of the Company's generating units during the period.

Kentucky Power Company
 KPSC Case No. 2023-00145
 Commission Staff's First Set of Data Requests
 Dated May 10, 2023
 Page 2 of 2

Table 1. KPCo Unit Performance During the 5 day Winter Storm Elliott Period (12/23/2022 - 12/27/2022)

	Equivalent Forced Outage Rate (EFOR)	Equivalent Availability Factor (EAF)	Net Capacity Factor (NCF)
Big Sandy Unit 1	0.0%	0.0%	0.0%
Mitchell Unit 1	13.7%	86.3%	80.3%
Mitchell unit 2	21.6%	78.4%	74.1%

Performance Metric Definitions
Equivalent Forced Outage Rate (EFOR)¹ - The ratio of unit's forced outage hours + derates to the its forced outage hours + service hours expressed as a percentage.
Equivalent Availability (EAF)¹ - The ratio of the unit's available hours - all derate hours to the number of hours in the period.
Net Capacity Factor (NCF)¹ - The ratio of the unit's net generation to it maximum potential output for the period.
¹ Formal definitions and equations for performance metrics can be found in the <i>NERC 2023 Data Reporting Instructions - Appendix F</i>

Attachment KPCO_R_KPSC_1_6_Attachment1 lists the curtailing (derating) events for the period by unit and in chronological order.

Attachment KPCO_R_KPSC_1_6_Attachment2 lists the forced, maintenance and planned outages in chronological order for the months of November and December 2022.

Witness: Robert A. Jessee

KPSC Case No. 2023-00145
 Commission Staff's First Set of Data Requests
 Dated May 10, 2023
 Item No. 6
 Attachment 1
 Page 1 of 1

Unit Name	Event Type Code *		Event Start	Event End	Event Description	MW Reduction	Period Elapsed Loss (MWH)	Event Number	Event Elapsed Time (Hours)
	Outages	Curtail.							
Big Sandy 1	PO		09/09/22 11:00 PM	01/14/23 11:47 AM	Boiler i/r, Generator Field Out inspection/possible re wedge, Turbine Valve i/r, Corrosion Fatigue i/r, Cooling Tower i/r, ReHeat Attenuator i/r, Gas valve i/r, FD Fan and Motor i/r, High Energy Piping (HEP) i/r, Flow Accelerated Corrosion (FAC) i/r. Core Loop testing.	295	35,448	71	119.98
Mitchell 1		D3	12/22/22 12:00 AM	12/30/22 12:00 AM	Large clinker growing on North side of Boiler	35	4,200	948	119.98
Mitchell 1		D1	12/24/22 06:48 AM	12/24/22 07:06 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	465	140	949	0.30
Mitchell 1		D1	12/24/22 07:06 AM	12/24/22 07:43 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	97	60	950	0.62
Mitchell 1		D1	12/24/22 07:43 AM	12/24/22 08:20 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	465	287	951	0.62
Mitchell 1		D1	12/24/22 08:20 AM	12/24/22 12:00 PM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	140	514	952	3.67
Mitchell 1		D1	12/24/22 01:48 PM	12/24/22 07:34 PM	Opacity	80	462	953	5.77
Mitchell 1		D1	12/24/22 07:34 PM	12/25/22 09:00 AM	Opacity	90	1,210	954	13.43
Mitchell 1		D1	12/25/22 10:07 AM	12/25/22 12:31 PM	Frozen lumps of coal causing conveyor trip out outs	135	324	955	2.40
Mitchell 1		D1	12/26/22 12:20 AM	12/26/22 08:29 AM	Opacity	45	368	956	8.15
Mitchell 1		D1	12/26/22 08:29 AM	12/26/22 08:46 AM	Opacity	60	17	957	0.28
Mitchell 1		D1	12/26/22 08:46 AM	12/27/22 12:00 AM	Opacity	85	1,296	958	15.23
Mitchell 1		D3	12/27/22 12:00 AM	12/27/22 01:40 AM	Opacity	85	142	959	1.67
Mitchell 1		D3	12/27/22 01:40 AM	12/27/22 02:02 AM	Opacity	135	50	960	0.37
Mitchell 1		D3	12/27/22 02:02 AM	12/27/22 02:53 AM	Opacity	155	132	961	0.85
Mitchell 1		D3	12/27/22 02:53 AM	12/27/22 04:43 AM	Opacity	185	339	962	1.83
Mitchell 1		D3	12/27/22 04:43 AM	12/27/22 07:22 AM	Opacity	205	544	963	2.65
Mitchell 1		D3	12/27/22 07:22 AM	12/27/22 11:03 AM	Opacity	235	866	964	3.68
Mitchell 1		D3	12/27/22 11:03 AM	12/28/22 12:00 AM	Opacity	245	3,174	965	12.93
Mitchell 2		D1	12/23/22 10:10 AM	12/23/22 10:28 AM	25 Pulv issue	95	29	908	0.30
Mitchell 2		D1	12/23/22 10:28 AM	12/23/22 05:44 PM	25 Pulv issue, could not get dampers to operate	90	654	910	7.27
Mitchell 2		D1	12/23/22 12:07 PM	12/23/22 01:56 PM	Opacity	25	46	909	1.82
Mitchell 2		D1	12/23/22 01:56 PM	12/23/22 02:53 PM	Opacity	50	48	913	0.95
Mitchell 2		D1	12/23/22 02:53 PM	12/23/22 07:22 PM	Opacity	100	448	914	4.48
Mitchell 2		D1	12/23/22 07:22 PM	12/23/22 09:08 PM	Opacity	90	159	915	1.77
Mitchell 2		D1	12/23/22 09:08 PM	12/24/22 02:46 AM	Opacity	150	845	916	5.63
Mitchell 2		D1	12/24/22 02:46 AM	12/24/22 04:41 AM	Opacity	90	173	917	1.92
Mitchell 2		D1	12/24/22 04:41 AM	12/24/22 02:08 PM	Opacity	75	709	918	9.45
Mitchell 2		D1	12/24/22 06:48 AM	12/24/22 07:08 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	415	138	911	0.33
Mitchell 2		D1	12/24/22 07:08 AM	12/24/22 12:00 PM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	210	1,023	912	4.87
Mitchell 2		D1	12/24/22 02:08 PM	12/25/22 12:00 AM	Opacity	90	888	919	9.87
Mitchell 2		D3	12/25/22 12:00 AM	12/26/22 12:00 AM	Anticipated opacity	190	4,565	920	24.00
Mitchell 2		D3	12/26/22 12:00 AM	12/27/22 12:38 PM	Opacity	190	6,968	921	36.63
Mitchell 2		D3	12/27/22 12:38 PM	12/27/22 02:02 PM	Opacity	210	294	923	1.40
Mitchell 2		D3	12/27/22 02:02 PM	12/27/22 03:12 PM	Opacity	230	268	924	1.17
Mitchell 2		D3	12/27/22 03:12 PM	12/27/22 04:08 PM	Opacity	340	317	925	0.93
Mitchell 2		D3	12/27/22 04:08 PM	12/28/22 11:40 PM	Opacity	365	2,871	926	7.85

Event Type *

Outages

- FO Forced Outage
- MO Maintenance Outage
- PO Planned Outage
- RS Reserve Shutdown
- SF Startup Failure

Note: i/r = inspection and repair

Curtailment

- D1 Requires immediate reduction in capacity
- D2 Does not require an immediate reduction in capacity but requires a reduction within six (6) hours
- D3 Can be postponed beyond six (6) hours, but requires reduction in capacity before the end of the next weekend

KPSC Case No. 2023-00145
Commission Staff's First Set of Data Requests
Dated May 10, 2023
Item No. 6
Attachment 2
Page 1 of 1

Unit Name	Event Type *	Event Start	Event End	Event Description
Big Sandy 1	PO	09/09/22 11:00 PM	01/14/23 11:47 AM	Boiler i/r, Generator Field Out inspection/possible rewedge, Turbine Valve i/r, Corrosion Fatigue i/r, Cooling Tower i/r, ReHeat Attemperator i/r, Gas valve i/r, FD Fan and Motor i/r, High Energy Piping (HEP) i/r, Flow Accelerated Corrosion (FAC) i/r, Core Loop testing.
Mitchell 1	PO	10/07/22 11:00 PM	11/19/22 05:32 PM	Boiler i/r, Precip i/r, Pulverizer/Feeder MATS i/r, Economizer wash, Replace Precip Transformer power cables, Replace SCR XJ s 14,15 and 115, Replace Exit Duct XJ FGX-71009, Water Cannon upgrades, Ovation Evergreen upgrade, Inter-lock testing, HE Piping i/r.
Mitchell 1	RS	11/19/22 05:32 PM	11/29/22 11:45 AM	Reserve Shutdown
Mitchell 1	SF	11/29/22 11:45 AM	11/29/22 06:03 PM	Unable to get firing permissives.
Mitchell 1	MO	12/03/22 01:47 AM	12/08/22 09:18 AM	Economizer tube leak repair
Mitchell 1	FO	12/08/22 11:45 AM	12/09/22 12:00 AM	PH Issues
Mitchell 1	FO	12/09/22 12:00 AM	12/10/22 08:01 AM	due to Urea from Hydrolyzer system entering the Condensate Return System. Samples will be collected and tested once the unit cools. Hydrolyzer will need <u>pressurized to search for potential leaks.</u>
Mitchell 1	FO	12/10/22 01:07 PM	12/13/22 04:30 PM	Due to Primary Superheater Outlet valve . packing blew out. Superheater Bypass Control valve URV 4, controller failed closed due to burned up controller.
Mitchell 1	RS	12/13/22 04:30 PM	12/14/22 02:45 AM	Reserve Shutdown
Mitchell 1	SF	12/14/22 02:45 AM	12/14/22 07:15 PM	Start Failure
Mitchell 1	MO	12/30/22 12:00 AM	01/22/23 05:59 PM	Boiler i/r, Boiler Hydro, Duct repairs, Clinker Removal, IK Soot Blower Repairs, 12 ID Fan Stall margin probe i/r.
Mitchell 2	PO	09/09/22 11:00 PM	12/16/22 02:25 PM	Boiler i/r, Cooling Tower i/r, Low Pressure Turbine "A"&"B" Valve replacement, SCR Catalyst #4 layer replacement, AH Basket i/r, Precip i/r.
Mitchell 2	PO	12/16/22 02:52 PM	12/16/22 03:28 PM	Boiler i/r, Cooling Tower i/r, Low Pressure Turbine "A"&"B" Valve replacement, SCR Catalyst #4 layer replacement, AH Basket i/r, Precip i/r.
Mitchell 2	FO	12/17/22 02:12 PM	12/20/22 04:08 PM	A Bus Relay PA Fan

Event Type *

- FO Forced Outage
- MO Maintenance Outage
- PO Planned Outage
- RS Reserve Shutdown
- SF Startup Failure
- Note: i/r = inspection and repair

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

Electronic Application Of Kentucky Power Company)
For (1) A General Adjustment Of Its Rates For Electric)
Service; (2) Approval Of Tariffs And Riders; (3))
Approval Of Accounting Practices To Establish)
Regulatory Assets And Liabilities; (4) A)
Securitization Financing Order; And (5) All Other)
Required Approvals And Relief)

Case No. 2023-00159

DIRECT TESTIMONY OF
TIMOTHY C. KERNS
ON BEHALF OF KENTUCKY POWER COMPANY

**DIRECT TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2023-00159

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	BACKGROUND	1
III.	PURPOSE OF TESTIMONY	4
IV.	KENTUCKY POWER’S GENERATING ASSETS.....	5
V.	KENTUCKY POWER GENERATION O&M	9
VI.	GENERATION CAPITAL ADDITIONS	11
VII.	GENERATION PERFORMANCE DURING WINTER STORM ELLIOTT	17
VIII.	CONCLUSION.....	24

EXHIBITS

EXHIBIT	DESCRIPTION
Exhibit TCK-1	Company’s Response to Commission’s Staff Set 1, Question 6 in Case No. 2023-00145

**DIRECT TESTIMONY OF
TIMOTHY C. KERNS ON BEHALF OF
KENTUCKY POWER COMPANY
BEFORE THE PUBLIC SERVICE COMMISSION OF KENTUCKY**

CASE NO. 2023-00159

I. INTRODUCTION,

1 **Q. PLEASE STATE YOUR NAME, POSITION, AND BUSINESS ADDRESS.**

2 A. My name is Timothy C. Kerns. My business address is 200 Association Drive,
3 Charleston, WV, 25311. In March 2023, I accepted the position of Vice President
4 of Generating Assets for Appalachian Power Company (“Appalachian Power”) and
5 Wheeling Power Company (“Wheeling Power”) effective April 2023. Appalachian
6 Power and Wheeling Power are wholly owned subsidiaries of American Electric
7 Power Company, Inc. (“AEP”). Immediately prior to my current role, I was Vice
8 President of Generating Assets for Kentucky Power Company (“Kentucky Power”
9 or “the Company”) and Indiana Michigan Power Company (“I&M”) from 2020 to
10 2023.

II. BACKGROUND,

11 **Q. PLEASE BRIEFLY DESCRIBE YOUR EDUCATIONAL BACKGROUND**
12 **AND BUSINESS EXPERIENCE.**

13 A. I earned a Bachelor of Science in Mechanical Engineering Degree from West
14 Virginia Institute of Technology and have been employed by AEP system
15 companies for 34 years. I have worked at various power plants across the AEP
16 System since 1989 in various positions including as a Performance Engineer, a

1 Maintenance Engineer, and a Plant Manager where, among other things, I
2 performed, directed, and managed outage and non-outage maintenance and capital
3 work. Specifically, from 1989 to 1996 I was a Performance, Maintenance and
4 Environmental Engineer at the Philip Sporn Plant; from 1996-1998 I was an
5 Equipment Troubleshooting Specialist for the Regional Services Organization
6 (“RSO”); from 1998-1999 I was a Zone Superintendent for the RSO; from 1999-
7 2000 I was a Regional Engineer Manager; from 2001 to 2006 I was the RSO
8 Manager; from 2006-2011 I was the Plant Manager at the Tanners Creek and
9 Lawrenceburg Plants; from 2011 to 2017 I was the Plant Manager at the Rockport
10 Plant; from 2017 to 2020 I was the Managing Director of Generating Assets for
11 I&M; and from 2020 to 2023 I was the Vice President of Generating Assets for
12 Kentucky Power, Wheeling Power and I&M.

13 **Q. PLEASE BRIEFLY DESCRIBE YOUR DUTIES AND RESPONSIBILITIES**
14 **AS VICE PRESIDENT GENERATING ASSETS FOR APPALACHIAN**
15 **POWER AND WHEELING POWER.**

16 A. In my new role I am responsible for the safe, reliable, and economic operation of
17 the fossil-fueled generating assets owned and operated by the Companies. This
18 includes the Amos, Mitchell, and Mountaineer coal-fired power plants, as well as
19 the gas-fired Ceredo (simple-cycle combustion turbines), Clinch River (gas-fired
20 boiler), and Dresden (combined-cycle) power plants, and Appalachian Power’s
21 hydro facilities. Specifically, I plan, organize, coordinate, direct, and control plant
22 activities, including the operations, maintenance, engineering, and construction of
23 the plant facilities. I also oversee plant budgets and interface with other AEP
24 functional groups such as Accounting, Regulatory, and Commercial Operations to

1 ensure the needs of the generating plants are met. Additionally, I am responsible
2 for any decommissioning, demolition, and disposition of generating assets owned
3 or operated by the Companies.

4 **Q. PLEASE EXPLAIN YOUR FAMILIARITY WITH KENTUCKY POWER**
5 **GENERATING ASSETS.**

6 A. In my former role as Kentucky Power's Vice President of Generating Assets, I was
7 responsible for the safe and reliable operation of Big Sandy Unit 1 and Mitchell
8 Units 1 and 2 for over three years. More importantly, I was in the role throughout
9 the test year for this proceeding.

10 Prior to the adoption of the resolutions identified in the Written Consent
11 Action of the Mitchell Operating Committee, Kentucky Power was Mitchell Plant's
12 operator until September 1, 2022. Until that time, I also had overall responsibility
13 for the operation and maintenance of the Plant as the Company's Vice President of
14 Generating Assets. I continue to have these responsibilities in my current role on
15 behalf of Wheeling Power now that Wheeling Power is the operator for the Mitchell
16 Plant. I am familiar with the day to-day operation of the Mitchell Plant as a result
17 of my responsibilities in the oversight of Plant personnel in connection with the
18 safe, reliable, and economic operation of the Plant. In this regard, my
19 responsibilities include interacting on a regular basis with the Mitchell Plant
20 manager, who reports directly to me, as well as with other Plant personnel in
21 connection with both day-to-day and longer-term Plant activities. In addition, I
22 regularly review budgets, review investments, and help plan the safe and reliable
23 operation of that facility. I also continue to participate as a non-voting member of
24 Mitchell Plant Operating Committee.

1 Lastly, as part of Wheeling Power’s management team, I work in close
2 coordination with the American Electric Power Service Corporation (“AEPSC”)
3 and Kentucky Power’s Managing Director of Generating Assets to ensure the
4 Mitchell Plant is safe, reliable and provides benefit to customers through effective
5 management of O&M expenditures and capital investments.

6 **Q. HAVE YOU PREVIOUSLY TESTIFIED IN ANY REGULATORY**
7 **PROCEEDINGS?**

8 A. Yes. I have submitted testimony and testified on behalf of Kentucky Power before
9 this Commission in Case Nos. 2020-00174 (2020 base rate case) and 2021-00421
10 (Mitchell Plant operating agreements). I have also submitted testimony on behalf
11 of Wheeling Power before the West Virginia Public Service Commission
12 (“WVPSC”) in Case No. 21-0810-E-PC. In addition, I have submitted testimony
13 and testified on behalf of I&M before the Indiana Utility Regulatory Commission
14 in Cause Nos. 44967, 44511, and 45235, and the Michigan Public Service
15 Commission in Cause Nos. U-18370, U-20070, and U-20359. Finally, I submitted
16 testimony at the Federal Energy Regulatory Commission in AEP Generating
17 Company’s depreciation rate cases.

III. PURPOSE OF TESTIMONY

18 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**
19 **PROCEEDING?**

20 A. The purpose of my testimony is to:

- 21 • Describe Kentucky Power’s generation assets;

- 1 • Describe and support the reasonableness of Kentucky Power’s generation non-
2 fuel, non-labor operation and maintenance (“O&M”) expenses for the Mitchell
3 and Big Sandy Plants;
- 4 • Describe the retired Big Sandy generating assets;
- 5 • Describe capital investments placed in-service at Kentucky Power’s generating
6 assets since the Company’s last base case; and
- 7 • Describe the performance of the Company’s generation fleet during Winter
8 Storm Elliott.

9 **Q. WHAT IS THE TEST YEAR FOR THIS PROCEEDING?**

10 A. The test year in this proceeding is the twelve-month period from April 1, 2022
11 through March 31, 2023.

12 **Q. ARE YOU SPONSORING ANY EXHIBITS AS PART OF YOUR**
13 **TESTIMONY?**

14 A. Yes. I am sponsoring the following exhibits attached to my testimony:

15 EXHIBIT	DESCRIPTION
16 Exhibit TCK-1	Company’s Response to Commission’s Staff Set 1, 17 Question 6 In Case No. 2023-00145

IV. KENTUCKY POWER’S GENERATING ASSETS

18 **Q. PLEASE DESCRIBE KENTUCKY POWER’S GENERATION ASSETS.**

19 A. Kentucky Power’s generation assets consisted of both owned and contracted
20 generation capacity totaling 1,468 MW until December 7, 2022. Beginning
21 December 7, 2022 through the 2022/2023 PJM planning year ending May 31, 2023,
22 Kentucky Power’s owned and contracted generation capacity totaled approximately
23 1,227 MW under the terms and conditions of the Power Coordination Agreement
24 (“PCA”).

1 **Q. PLEASE BRIEFLY DESCRIBE KENTUCKY POWER’S OWNED**
 2 **GENERATION.**

3 A. Kentucky Power’s generation assets consist of a total of 1,075 MW of capacity
 4 from two generating plants, Big Sandy and Mitchell. The Company’s assets and
 5 their characteristics are listed in Figure TCK-1.

Figure TCK-1: Kentucky Power Generation Assets

Plant	Kentucky Power-Owned Capacity (MW)	No. of Units	Location	Fuel	Expected Retirement Date
Big Sandy	295	1	Louisa, KY	Natural Gas	2031
Mitchell	780	2	Moundsville, WV	Coal	2040

6 Kentucky Power owns and operates the Big Sandy Plant located near
 7 Louisa, Kentucky. The plant currently has a single operating unit with a generating
 8 capacity of 295 MW. Big Sandy Unit 1 was originally placed in service in 1963
 9 and operated as a 278 MW sub-critical coal-fired generating unit through mid-
 10 November 2015. As approved by the Commission in Case No. 2013-00430, and
 11 described later in my testimony, Big Sandy Unit 1 was converted to a natural gas-
 12 fired unit and returned to service May 31, 2016. The Unit is equipped with low
 13 nitrogen oxide (“NO_x”) burners with overfire air for reduction of NO_x emissions.

14 The Mitchell Plant is located approximately 12 miles south of Moundsville,
 15 West Virginia on the Ohio River. Kentucky Power owns an undivided 50% interest
 16 in the Mitchell Plant; the other 50% interest is owned, and operated, by Wheeling
 17 Power. The plant comprises two super-critical pulverized coal-fired baseload
 18 generating units. Mitchell Unit 1 has a capacity of 770 MW and Mitchell Unit 2

1 has a capacity of 790 MW for a total capacity of 1,560 MW. Both Units were
2 placed in service in 1971.

3 **Q. PLEASE DESCRIBE WHAT COMPRISES KENTUCKY POWER'S**
4 **CONTRACTED GENERATION.**

5 A. Kentucky Power was a party to a unit power agreement ("UPA") with AEP
6 Generating Company for power from the Rockport Plant that terminated December
7 7, 2022. The Rockport Plant is located along the Ohio River in southern Indiana
8 and consists of two supercritical pulverized coal-fired generating units. Kentucky
9 Power's contractual share of the Rockport output totaled 393 MW. Upon
10 termination of the Rockport UPA, the Company forecasted that it would require
11 152.4 MW of replacement capacity through the 2022/2023 PJM planning year
12 ending May 31, 2023 that would be obtained through the PCA between Kentucky
13 Power and AEP's Operating Companies.

14 **Q. HAVE THE RETIREMENT DATES FOR BIG SANDY UNIT 1 OR**
15 **MITCHELL GENERATING UNITS CHANGED?**

16 A. There have been no changes to the expected retirement dates of either Big Sandy
17 Unit 1 or the Mitchell Plant. With continued investment and maintenance, Big
18 Sandy Unit 1 is expected to reach its current retirement date of 2031 and the
19 Mitchell plant is expected to reach its retirement date of 2040. However, it is my
20 understanding that, based on its recently filed Integrated Resource Plan, the
21 Company is proposing to operate Big Sandy Unit 1 through 2041. Additionally, as
22 a result of the Commission's Order in Case No. 2021-00004 denying a Certificate
23 for Public Convenience and Necessity ("CPCN") for Effluent Limitation

1 Guidelines (“ELG”) projects at Mitchell Plant, Kentucky Power’s interest in
2 Mitchell will terminate in 2028.

3 **Q. PLEASE DESCRIBE THE KENTUCKY POWER GENERATING ASSETS**
4 **THAT HAVE BEEN RETIRED.**

5 A. Due to EPA’s Mercury and Air Toxics (“MATS”) Rule, Big Sandy Unit 2, an
6 800MW coal-fired generating asset, was retired in May 2015 and Big Sandy Unit
7 1 was converted from coal-fired to natural gas-fired in May 2016. The fuel
8 conversion allowed Big Sandy Unit 1 to continue to operate in compliance with the
9 stringent air emission requirements of MATS. There were coal-related assets for
10 Big Sandy Unit 1 that were retired since they were not required for its natural gas
11 operations.

12 Demolition activities at Big Sandy Unit 2 began in 2016. Since that time,
13 the dismantlement of coal handling equipment and the demolition of its cooling
14 tower, turbine building, boiler house, and environmental equipment have been
15 completed. Currently, fly ash pond post-closure monitoring activities and asbestos
16 abatement continue at the Big Sandy Plant. The going-forward coal-related
17 decommissioning ARO costs associated with the fly ash pond and asbestos
18 abatement for Big Sandy Unit 2 are identified by Company Witness Whitney.

19 Big Sandy Unit 1, although converted to a natural gas generating asset in
20 2016, had some equipment solely related to its operation as a coal-fired facility.
21 Examples of Big Sandy Unit 1’s coal-related assets included the coal yard and its
22 associated equipment, the conveyors and silos which transferred coal from the coal
23 yard to the plant, the coal pulverizers, the Electrostatic Precipitators (“ESP”), and
24 the fly ash and bottom ash handling systems. This equipment was no longer

1 necessary when the unit began operating as a natural gas unit and was retired once
2 the unit no longer operated as a coal-fired facility.

V. KENTUCKY POWER GENERATION O&M

3 **Q. WHAT ARE THE O&M REQUIREMENTS OF KENTUCKY POWER'S**
4 **GENERATION ASSETS?**

5 A. Kentucky Power's plants must provide safe, economical, and reliable generation
6 output to serve load and accommodate fluctuating customer needs. In addition, a
7 unit's maintenance needs vary based on its type, design, age, condition, and
8 operational characteristics. All units are maintained to maximize operations, and
9 to do so in a safe manner in compliance with all local, state, and federal regulations.

10 **Q. HOW ARE O&M COSTS CONTROLLED AT THE PLANTS?**

11 A. To minimize O&M expenses, Kentucky Power relies on a system of maintenance
12 and operations management programs to ensure optimal performance of the
13 generating assets. These maintenance programs are:

- 14 • Predictive Maintenance: monitoring, inspections, and/or data analyses
15 conducted to diagnose potential maintenance issues early and usually
16 while the equipment is running to minimize downtime.
- 17 • Preventive Maintenance: protocols, testing, and physical work
18 conducted on equipment to address anticipated or diagnosed
19 vulnerabilities.

20 In addition, continuous improvements are incorporated into the operations
21 and maintenance of the generating units to eliminate waste and increase process
22 efficiencies. Together, these maintenance and operations management programs
23 help to optimize operation of the assets and limit O&M cost escalations.

1 **Q. WHAT IS KENTUCKY POWER'S TEST YEAR LEVEL OF**
 2 **GENERATION O&M EXPENSE?**

3 A. Kentucky Power's non-fuel, non-consumables, non-labor test year Generation
 4 O&M expense is \$27.634 million. As shown in Figure TCK-2 below, Kentucky
 5 Power's test year Generation O&M expenses include steam maintenance and steam
 6 operations amounts for Big Sandy, the Company's 50% undivided interest in
 7 Mitchell, and shared plant costs not attributable to a specific generating unit (known
 8 as Non-Plant costs).

**TCK-2: Test Year Kentucky Power Non-Fuel, Non-Consumables, Non-
 Labor Test Year Generation O&M***

Category	Big Sandy Plant	Mitchell Plant	Non-Plant	Total
Steam Maintenance	\$5,954,613	\$12,408,247	\$212,067	\$18,522,160
Steam Operations	\$1,570,122	\$4,911,699	\$2,629,917	\$9,111,737
Total:	\$7,524,734	\$17,319,946	\$2,841,984	\$27,633,897

*Total may not sum due to rounding

9 **Q. DOES THE TOTAL AMOUNT OF \$27.634 MILLION REPRESENT AN**
 10 **APPROPRIATE AND REASONABLE ONGOING LEVEL FOR O&M FOR**
 11 **KENTUCKY POWER'S GENERATION ASSETS?**

12 A. Yes. This total level is reasonable and fairly reflects an appropriate level of O&M
 13 for Big Sandy and Kentucky Power's undivided 50% share of the Mitchell Plant.

VI. GENERATION CAPITAL ADDITIONS

1 **Q. PLEASE PROVIDE AN OVERVIEW OF GENERATION CAPITAL**
2 **ADDITIONS PLACED IN-SERVICE SINCE THE COMPANY'S LAST**
3 **BASE CASE.**

4 A. As shown in TCK-3 below, Kentucky Power had steam and other generation plant
5 related capital additions totaling approximately \$44.167 million placed in-service
6 since the Company's last base case. Of that amount, \$11.221 million is associated
7 with major fossil fuel generation capital projects and \$22.529 million that is
8 associated with Production Plant Blanket ("PPB") capital projects.

9 Allocations to Kentucky Power's fossil fuel generation organization for
10 intangible projects (information technology projects that are not associated with
11 physical capital additions at Kentucky Power's plants but provide benefits to
12 Kentucky Power) account for a combined total of approximately \$11.551 million.
13 General capital additions that support plant operations account for approximately
14 \$456 thousand. The remaining fossil fuel generation capital amounts include Asset
15 Retirement Obligation ("ARO") estimates that resulted in a reduction of
16 approximately \$1.590 million to capital additions.

17 Figure TCK-3 is inclusive of all environmental project capital additions
18 placed in-service since the last base case. However, all environmental project costs
19 associated with ESP, Selective Catalytic Converter Reduction ("SCR"), and Dry
20 Sorbent Injection ("DSI") capital additions are collected through Environmental
21 Compliance Plan ("ECP") Company filings as discussed by Company Witness
22 Kahn.

**Figure TCK-3: Generation Capital Additions
April 2020 – March 2023**

Plant	Project Description	Addition to Plant (\$)
Big Sandy Plant	Fossil Fuel Major Projects	
	(Non-Environmental)	
	North American Electric Reliability Corporation (NERC) Critical Infrastructure Protection (CIP) Physical Security Upgrade	\$519,594
		\$519,594
	(Environmental)	
	Repurpose Big Sandy Bottom Ash Pond (BAP)	\$417,077
		\$417,077
	Big Sandy Fossil Fuel Major Projects Sub-Total:	
		\$936,672
	Other Fossil Generation Capital Projects	
	Production Plant Blanket Projects:	\$5,811,279
	Non-Environmental	\$5,808,906
	Environmental	\$2,373
	ARO	\$2,752,924
	Big Sandy Other Fossil Generation Capital Projects Sub-Total:	
	\$8,564,203	
Big Sandy Plant Total		\$9,500,875
Mitchell Plant (Kentucky Power Share)	Fossil Fuel Major Projects	
	(Non-Environmental)	
	Mitchell Unit 2 Cooling Tower Components Replacement	\$2,772,398
	Mitchell Unit 2 Air Heater Basket Replacement	\$2,077,824
	Mitchell Unit 1 - Phase 2 Generator Step-up (GSU) Transformer Replacement	\$13,416
		\$4,863,638
	(Environmental)	
	Mitchell Unit 2 Electrostatic Precipitator (ESP)Upgrades	\$2,115,185
	Mitchell Unit 1 Selective Catalytic Converter (SCR) Catalyst Layer 4 Replacement	\$1,357,439
	Mitchell Unit 0 Dry Sorbent Injection (DSI) Lime Conversion	\$1,326,811
	Mitchell Landfill Expansion -Phase 3	\$587,858
	Mitchell Unit 1 SCR Catalyst Layer 3 Replacement	\$27,976
	Mitchell Unit 2 - SCR Catalyst Layer 3 Replacement	\$5,483
		\$5,420,752
	Mitchell Fossil Generation Capital Projects Sub-Total:	
		\$10,284,390
	Other Fossil Generation Capital Projects	
	Production Plant Blanket Projects	\$16,718,190
	Non-Environmental	\$13,365,463
	Environmental	\$3,352,727
ARO	(\$4,343,418)	
Mitchell Other Fossil Generation Capital Projects Sub-Total:		
	\$12,374,772	
Mitchell Plant Total		\$22,659,162
Various Facilities	Intangible Capital Projects	\$11,551,194
	General Capital Projects	\$456,050
Various Facilities Total		\$12,007,244
Total Kentucky Power Capital Additions		\$44,167,280

1 **Q. PLEASE SUMMARIZE INDIVIDUAL MAJOR FOSSIL FUEL**
2 **GENERATION CAPITAL PROJECT ADDITIONS OVER \$1 MILLION**
3 **INCLUDED IN FIGURE TCK-3 AND EXPLAIN WHY THEY WERE**
4 **NECESSARY.**

5 **A. A summary of individual major fossil fuel generation capital project additions over**
6 **\$1 million reflected in TCK-3 and associated necessities are summarized below.**

1 Mitchell Major Capital Projects

2 Non-Environmental

- 3 • Mitchell Unit 2 Cooling Tower Components – Some of the Cooling Tower
4 components had reached the end of their useful life after 30 years of service
5 and some components had deteriorated to a point where they would not last
6 another 5-years without failing. This project replaced the Hot Water
7 Distribution deck, louvers and louver columns, outer periphery longitudinal
8 girts, and other associated components.
- 9 • Mitchell Unit 2 Air Heater Basket Replacement –The air heater baskets
10 were one year beyond their typical life cycle and were beginning to
11 deteriorate exponentially. As a result, Mitchell Unit 2 was beginning to
12 experience increases in its equivalent forced outage rate (“EFOR”)
13 associated with the baskets. The existing air heater baskets have been
14 replaced with new air heater baskets.

15 Environmental

- 16 • Mitchell Unit 2 ESP Upgrades – Upgrades required to comply with
17 particulate matter emission limits and the state of West Virginia 10%
18 opacity limit. The scope of the project included:
 - 19 ▪ the installation of a new heated purge air system;
 - 20 ▪ repair and replacement of corroded ESP sidewall casing, hopper
21 casing, and ductwork as needed;
 - 22 ▪ removal and replacement of the hot and cold roof, including
23 insulation, for approximately half of the precipitator;
 - 24 ▪ replacement of the discharge electrode support insulators as needed;
 - 25 ▪ repair of the collecting and discharge electrode rapper system; and
 - 26 ▪ replacement of the hopper level detection system.
- 27 • Mitchell Unit 1 SCR Catalyst Layer 4 Replacement – 4th layer SCR catalyst
28 replacement was required to maintain desirable NOx removal effectiveness.
29 NOx emissions are subject to the New Source Review (“NSR”) Consent

1 Decree and Cross-State Air Pollution Rule (“CSAPR”). The catalyst layer
2 replacement will also maintain effective mercury oxidation across the SCR
3 catalyst reactor.

- 4 • Mitchell Units 0 DSI Lime Conversion Project – Mitchell Plant currently
5 uses Trona for SO₃ mitigation. The project reconfigured the existing DSI
6 system for Mitchell Units 1 and 2 to more efficiently handle hydrated lime
7 in lieu of Trona, and reduce issues related to corrosion, as well as gain
8 benefits such as heat rate improvement, improved Equivalent Unplanned
9 Outage Rate (“EUOR”), and a lower minimum load. Conversion to lime
10 also allows for the use of a higher percentage of high sulfur coal which has
11 historically been cheaper than the lower sulfur coal, thereby resulting in
12 lower overall fuel costs. The project also installed a new distributed control
13 system for the DSI.

14 **Q. WHAT ARE PPB PROJECTS?**

15 A. PPB projects are capital projects necessary to provide for the safe, environmentally
16 responsible, reliable, and efficient operation of our generating units. They are
17 sometimes referred to as ‘Maintenance Capital’ projects. These projects are placed
18 into two categories, major or minor. Major plant blanket projects will have a total
19 cost of over \$1,000,000, but under \$3,000,000. Minor plant blanket projects, the
20 vast majority of which are smaller component replacements and installations, are
21 projects that have a total cost of under \$1,000,000.

22 When evaluating these PPB projects, Kentucky Power looks for cost
23 savings whenever possible without jeopardizing reliability and safety. All PPB
24 projects over \$1 million are also reviewed and approved through AEPSC’s
25 Strategic Capital Prioritization Process (“SCPP”) which includes review and
26 approval by AEP’s Vice President (VP) of Project Solutions, VP of Engineering

1 Service, VP of Generation Shared Services, VP of Appalachian Power Company/
2 Wheeling Power Company Generating Assets, and VP of Southwestern Power
3 Company Generating Assets.

4 **Q. PLEASE DESCRIBE SOME OF THE PPB CAPITAL ADDITIONS OVER**
5 **\$1 MILLION SINCE THE LAST BASE CASE AT KENTUCKY POWER**
6 **PLANTS.**

7 A. The major PPB projects for the Big Sandy and Mitchell Plants are listed below:

8 **Big Sandy Major PPB Capital Projects**

- 9 • Big Sandy Unit 1 Generator Stator Re-wedge – The generator stator was
10 last re-wedged in 2008 and upon inspection in fall 2022, it was
11 determined the stator required another re-wedge in order to mitigate the
12 potential risk of a premature stator failure and thereby enhance the
13 reliability of the generator. A stator failure would have left the Unit in
14 a forced state of being unable to operate for a period of one year or more
15 due to long lead time materials.

16 **Mitchell Plant Major PPB Capital Projects**

- 17 • Mitchell Unit 2 SCR Catalyst Layer 4 Replacement – Need for the
18 replacement of the catalyst 4th layer was due to normal deactivation over
19 thousands of hours of run time. SCR NO_x removal effectiveness
20 requires adequate activity levels. SCR NO_x performance is required for
21 compliance with the NSR Consent Decree requirements and CSAPR
22 regulations.

23 **Q. PLEASE SUMMARIZE THE INTANGIBLE CAPITAL INVESTMENTS**

24 A. Intangible capital projects are routine software updates and new programs that
25 increase the efficiency of Kentucky Power's Generation organization.

1 **Q. ARE EXPENSES RELATED TO ELG COMPLIANCE AT MITCHELL**
2 **INCLUDED UNDER PPB PROJECTS OR INCLUDED IN O&M**
3 **EXPENSES?**

4 A. No. As I stated earlier in my testimony, this Commission did not approve the CPCN
5 to execute ELG projects required by EPA to comply with its revisions to the ELG
6 rule effective October 2020 at the Mitchell Units; therefore, Kentucky Power is not
7 authorized to recover costs related to ELG compliance projects at Mitchell.

8 **Q. HOW DOES THE COMPANY ENSURE ELG-RELATED COSTS ARE**
9 **NOT CHARGED TO KENTUCKY POWER SINCE THIS COMMISSION**
10 **ONLY APPROVED COAL COMBUSTION RESIDUALS (“CCR”)**
11 **PROJECT UPGRADES?**

12 A. Pursuant to the September 1, 2022 Written Consent Action of the Mitchell
13 Operating Committee, which is included as Exhibit V of Section II of the
14 Company’s Application, the Company hired Burns & McDonnell, an independent
15 engineering, architecture construction, environmental consulting firm, to perform
16 an assessment of the scope of work directly related to the CCR and ELG projects
17 for the purpose of determining the appropriate allocation of CCR and ELG related
18 costs. As a result of and in accordance with Burns & McDonnell’s assessments,
19 the Company established work orders to ensure costs related to the scope of work
20 for each of the CCR and ELG projects are appropriately charged.

VII. GENERATION PERFORMANCE DURING WINTER STORM ELLIOTT.

1 **Q. PLEASE DESCRIBE WINTER STORM ELLIOTT.**

2 A. As explained further by Company Witness Vaughan, Winter Storm Elliott was a
3 bomb cyclone¹ that impacted the PJM region from December 23, 2022 through
4 December 27, 2022 (the “Winter Storm Elliott Period”), causing extreme cold
5 weather, including blizzards, high winds, and snow.

6 **Q. WERE THE COMPANY’S GENERATION ASSETS AVAILABLE AND**
7 **OPERATING DURING THE WINTER STORM ELLIOTT PERIOD?**

8 A. Both Mitchell Unit 1 and Unit 2 (collectively, the “Mitchell Units”) were available
9 and operating throughout the Winter Storm Elliott Period. As shown in Exhibit
10 TCK-1, Mitchell Unit 1 had a Net Capacity Factor² (“NCF”) of 80.3% and Mitchell
11 Unit 2 had an NCF of 74.1% during the Winter Storm Elliott Period. Big Sandy
12 Unit 1 was in a Planned Outage and was unavailable.

13 **Q. HOW DOES THE MITCHELL PLANT PREPARE FOR WINTER?**

14 A. In preparation for winter, the Mitchell Plant implements a “Winter Preparedness
15 Plan.” In 2022, the plant implemented the “Winter Preparedness Plan” starting on
16 October 3, 2022. The standard plan included employee training, completing
17 preventative maintenance work orders, performing equipment checks, replenishing
18 supplies, and other winter preparedness activities. Plant personnel completed a cold
19 weather site specific plan review on October 19, 2022 and completed training on
20 the North American Electric Reliability Council cold weather reliability standards

¹ A bomb cyclone is a large, intense storm that rapidly intensifies and is defined by a sudden and significant drop in atmospheric pressure.

² Net Capacity Factor is defined as the ratio of the generating unit’s ((net actual generation) to its net maximum capacity for the number of hours in the period being reported that the unit was in the active state) x 100%.

1 by October 31, 2022. Cold Weather Preparedness and Winterization checks
2 conducted as preventative maintenance activities were completed by November 2,
3 2022.

4 **Q. DID THE MITCHELL PLANT TAKE ANY ADDITIONAL**
5 **PREPARATORY STEPS IN ADVANCE OF WINTER STORM ELLIOTT?**

6 A. Yes. In anticipation of Winter Storm Elliott, Mitchell Plant staffing was increased
7 to at least one on-site member from the plant leadership team and additional plant
8 operations personnel and contractor support were brought on site.

9 **Q. HOW DID THE MITCHELL UNITS PERFORM DURING WINTER**
10 **STORM ELLIOTT?**

11 A. Both Mitchell Units performed well during the Winter Storm Elliott Period. Both
12 Units had a 0% forced outage factor³ and 0% maintenance outage factor⁴, meaning
13 at no point during the event were either of the Mitchell Units unavailable.

14 **Q. WAS EITHER UNIT'S OUTPUT REDUCED (OR DERATED) DURING**
15 **WINTER STORM ELLIOTT?**

16 A. Yes, at times, both Mitchell Units experienced derates due to operational issues. A
17 "derate" is defined as a decrease in the available capacity of an electric generating
18 unit, commonly due to a system or equipment modification or environmental,
19 operational, or reliability considerations. As demonstrated in Exhibit TCK-1, a
20 significant portion of the derates experienced at both Mitchell Units were required
21 to comply with particulate matter emission limits and the state of West Virginia's

³ Forced outage factor is the ratio of ((All hours experienced during forced outages) to the number of hours in the period being reported that the unit was in the active state) x 100%.

⁴ Maintenance outage factor is the ratio of ((All hours experienced during maintenance outages) to the number of hours in the period being reported that the unit was in the active state) x 100%.

1 10% opacity limit. The opacity-related derates were not driven by Winter Storm
2 Elliott. Mitchell Unit 1 also had a small 35 MW derate related to a boiler clinker
3 for the duration of the Winter Storm Elliott Period.

4 The remaining derates were caused by frozen coal causing the coal
5 conveyor to trip out, freezing of slurry feed tanks, and a pulverizer damper
6 operation issue. This group of derates lasted a combined total of only 20.31 of the
7 240 hours of operation between both Mitchell Units during the Winter Storm Elliott
8 Period.

9 During Winter Storm Elliott, Unit 1 had an equivalent availability factor⁵
10 (“EAF”) of 86.3%, and Unit 2 had an EAF of 78.4%.

11 **Q. HOW DOES THE MITCHELL PLANT’S PERFORMANCE DURING**
12 **WINTER STORM ELLIOTT COMPARE TO ITS HISTORICAL**
13 **PERFORMANCE?**

14 A. Both Mitchell Units performed favorably during Winter Storm Elliott as compared
15 to their historic performance, as Figure TCK-4 demonstrates.

⁵ Equivalent Availability factor is the ratio of ((Available hours – equivalent planned derated hours – equivalent unplanned derated hours – equivalent seasonal derated hours) to the number of hours in the period being reported that the unit was in the active state) x 100%.

**Figure TCK-4: Mitchell Unit Performance:
Winter Storm Elliott Period Compared to 2016-2021**

Mitchell Unit	Winter Storm Elliott Period Net Capacity Factor ("NCF")	Average NCF (2016-2021)	Highest NCF (2016-2021)	Winter Storm Elliott Period Average Availability Factor ("EAF")	Average EAF (2016-2021)	Highest EAF (2016-2021)
Unit 1	80.3%	36.9%	52.0%	86.3%	57.1%	68.1%
Unit 2	74.1%	46.6%	65.8%	78.4%	69.3%	84.4%

1 As demonstrated above, Unit 1's NCF and EAF and Unit 2's NCF during the
2 Winter Storm Elliott Period were higher during Winter Storm Elliott than their 6-
3 year highest annual levels. Both Units' NCF and EAF during the storm period far
4 exceeded their 6-year averages.

5 **Q. COULD THE COMPANY REASONABLY HAVE DONE ANYTHING**
6 **DURING THE WINTER STORM ELLIOTT PERIOD TO INCREASE THE**
7 **OUTPUT OF THE MITCHELL GENERATING FACILITIES?**

8 A. No. Again, it is important to reiterate that, although the Mitchell Units were derated
9 during Winter Storm Elliott, at no point was either Mitchell Unit unavailable to
10 serve customers. Furthermore, the Company cannot legally operate the Mitchell
11 Units in a manner that would violate the particulate matter emission limits and the
12 state of West Virginia's 10% opacity limit. The remaining non-opacity related
13 derates were short in duration but were required to allow for the necessary repairs
14 to be made while keeping the Units available. As such, when both Mitchell Units
15 were needed during this extreme event, they were available and performed well, to
16 the benefit of Kentucky Power customers.

1 **Q. PLEASE DESCRIBE THE PLANNED OUTAGE AT BIG SANDY DURING**
2 **WINTER STORM ELLIOTT.**

3 A. Big Sandy Unit 1 began a Planned Outage on September 10, 2022. The outage was
4 originally scheduled to be completed on December 4, 2022, but had to be extended
5 several times through January 14, 2023 for a number of reasons including additional
6 time required to repair the generator due to hot spots in the core, replacement of the
7 generator rotor collector end retaining ring due to a crack discovered during the
8 outage, the repair of the hydrogen seal housing at the exciter due to a leak, and the
9 need to repair an unexpected condenser leak identified at start-up. The extensions
10 to the outage were necessary to repair and/or replace generator components to
11 prevent the risk of a catastrophic failure of the generator as well repair the
12 condenser to allow the Unit to restart and avoid future forced outages. The timeline
13 for the Company's outage extension request to PJM is discussed later in my
14 testimony. Each extension for the Big Sandy fall 2022 outage was approved by
15 PJM.

16 **Q. WHAT IS A PLANNED OUTAGE?**

17 A. A Planned Outage is a generating unit outage of a predetermined duration that can
18 last for several weeks and occurs only once or twice a year. Typically, these events
19 consist of a known scope of work and duration that is estimated prior to the outage
20 being scheduled.

21 **Q. HOW ARE PLANNED OUTAGES SCHEDULED?**

22 A. Planned Outages are scheduled well in advance (months and sometimes even years)
23 due to significant scope, equipment lead time, engineering, and time out of
24 operation. Such outages are planned in conjunction with PJM and with PJM's

1 approval. The Company schedules Planned Outages during the shoulder months
2 attempting to avoid, to the extent practical, multiple units simultaneously in a
3 Planned Outage.

4 **Q. WHEN A UNIT IS IN A PLANNED OUTAGE, IS IT POSSIBLE TO**
5 **QUICKLY RETURN THE UNIT TO SERVICE IF MARKET CONDITIONS**
6 **CHANGE?**

7 A. Generally, it is not. During a Planned Outage, a generating unit is often at least
8 partly dismantled, often with pressure parts (parts that contain steam at very high
9 pressures and temperatures when operating, such as boilers, turbines, etc.) taken
10 apart to be inspected, maintained, and/or replaced. It is very difficult if not
11 impossible to safely and quickly return a unit to service or deviate from the work
12 plan for the outage, particularly when major equipment is disconnected or
13 dismantled for repair at that time.

14 **Q. PLEASE DESCRIBE THE SCOPE OF WORK THAT WAS TO BE**
15 **COMPLETED DURING THE PLANNED OUTAGE AT BIG SANDY UNIT**
16 **1.**

17 A. As originally scoped, the fall 2022 Planned Outage at Big Sandy Unit 1 included a
18 generator field out inspection and a possible re-wedge of the Unit's stator.⁶ The
19 Company was, in fact, required to completely re-wedge the stator as part of this
20 scope of work.

⁶ The stator is the stationary part of a rotary system found in electric generators. In an electric generator, the stator converts the rotating magnetic field to electric current.

1 **Q. WHY DID BIG SANDY'S OUTAGE EXTEND BEYOND ITS PLANNED**
2 **OUTAGE END DATE?**

3 A. In November 2022, the Company extended the Planned Outage at Big Sandy Unit
4 1 to December 12, 2022, as it needed additional time to complete the original scope
5 of work. Then, on November 13, 2022, the Company discovered a crack on the
6 generator rotor collection end retaining ring and determined that the retaining ring
7 required replacement prior to returning the Unit to service. In order to complete that
8 repair, on December 2, 2022, the Company requested the Planned Outage at Big
9 Sandy Unit 1 be extended through December 30, 2022. PJM approved the extension
10 on December 2, 2022. The Planned Outage was extended twice more for a
11 hydrogen seal leak identified during an air leakage test and a condenser leak
12 discovered during start up. These extensions were requested on December 22, 2022,
13 and January 10, 2023, and were approved by PJM on December 28, 2022, and
14 January 11, 2023, respectively.

15 **Q. COULD THE COMPANY HAVE PLACED BIG SANDY UNIT 1 IN**
16 **SERVICE WITHOUT ADDRESSING THE ITEMS THAT CAUSED THE**
17 **PLANNED OUTAGE TO BE EXTENDED THROUGH THE WINTER**
18 **STORM ELLIOTT PERIOD?**

19 A. No, it could not. First, as explained further above, extending the outage to replace
20 the retaining ring extended the Planned Outage through what became the Winter
21 Storm Elliott Period. If the Company had not replaced that retaining ring, Big Sandy
22 Unit 1 would have been at an increased risk of catastrophic failure. Therefore, the
23 Company could not have safely placed the Unit back in service and operated it

1 without replacing the retaining ring. It likewise could not have put the Unit safely
2 back in service without fixing the hydrogen seal and condenser leaks.

3 **Q. WAS THERE ANY WAY FOR THE COMPANY TO HAVE KNOWN**
4 **ABOUT THE WINTER STORM ELLIOTT EVENT WHEN IT**
5 **REQUESTED THE PLANNED OUTAGE EXTENSION ON DECEMBER 2,**
6 **2022.**

7 A. No.

8 **Q. WERE THE COMPANY'S ACTIONS RELATED TO EXTENDING THE**
9 **BIG SANDY UNIT 1 OUTAGE REASONABLE?**

10 A. Yes. The Company could not have brought Big Sandy Unit 1 back online to serve
11 customers during Winter Storm Elliott without risking a catastrophic failure of the
12 Unit as all the repairs described above were required to be completed in order to
13 safely operate the Plant. Therefore, it was reasonable to extend the planned outage
14 to ensure the Unit would be in good working order to service customers into the
15 future.

VIII. CONCLUSION

16 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

17 A. Yes, it does.

Kentucky Power Company
KPSC Case No. 2023-00145
Commission Staff's First Set of Data Requests
Dated May 10, 2023
Page 1 of 2

DATA REQUEST

KPSC 1_6 Provide a detailed explanation of how Kentucky Power's generating units were operating during Winter Storm Elliott. Include in the response a list and event description in chronological order showing by unit and date any scheduled, actual, and forced outage for the months of November and December 2022.

RESPONSE

Winter Storm Elliott began in the Pacific Northwest on December 20, 2022 and moved east at a rapid pace becoming a bomb cyclone, an area of low pressure that intensifies rapidly, and entering the PJM territory on December 23, 2022. Winter Storm Elliott impacted the PJM territory from December 23, 2022 until December 27, 2022. During that period, none of the Company's generating units were forced from service.

Big Sandy Unit 1 was in its Planned Outage (9/9/22 – 1/14/23) which was extended from its planned end date of 12/12/2022 due to emergent generator repair work discovered during its reassembly. The completion of this work was required so the unit could be returned to service and operated safely and reliably.

Both Mitchell units operated continuously throughout the Winter Storm Elliott period (12/23/2022 – 12/27/2022). At times during that period, each of units' output was reduced (or derated) due to operational issues. Those deratings resulted in Net Capacity Factors (NCF) of 80.3% and 74.1% for Units 1 and 2, respectively and were largely unrelated to the extreme weather.

Table 1 below describes the performance of the Company's generating units during the period.

Kentucky Power Company
 KPSC Case No. 2023-00145
 Commission Staff's First Set of Data Requests
 Dated May 10, 2023
 Page 2 of 2

Table 1. KPCo Unit Performance During the 5 day Winter Storm Elliott Period (12/23/2022 - 12/27/2022)

	Equivalent Forced Outage Rate (EFOR)	Equivalent Availability Factor (EAF)	Net Capacity Factor (NCF)
Big Sandy Unit 1	0.0%	0.0%	0.0%
Mitchell Unit 1	13.7%	86.3%	80.3%
Mitchell unit 2	21.6%	78.4%	74.1%

Performance Metric Definitions
Equivalent Forced Outage Rate (EFOR)¹ - The ratio of unit's forced outage hours + derates to the its forced outage hours + service hours expressed as a percentage.
Equivalent Availability (EAF)¹ - The ratio of the unit's available hours - all derate hours to the number of hours in the period.
Net Capacity Factor (NCF)¹ - The ratio of the unit's net generation to it maximum potential output for the period.
¹ Formal definitions and equations for performance metrics can be found in the <i>NERC 2023 Data Reporting Instructions - Appendix F</i>

Attachment KPCO_R_KPSC_1_6_Attachment1 lists the curtailing (derating) events for the period by unit and in chronological order.

Attachment KPCO_R_KPSC_1_6_Attachment2 lists the forced, maintenance and planned outages in chronological order for the months of November and December 2022.

Witness: Robert A. Jessee

KPSC Case No. 2023-00145
Commission Staff's First Set of Data Requests
Dated May 10, 2023
Item No. 6
Attachment 1
Page 1 of 1

Unit Name	Event Type Code *		Event Start	Event End	Event Description	MW Reduction	Period Elapsed Loss (MWH)	Event Number	Event Elapsed Time (Hours)
	Outages	Curtailed							
Big Sandy 1	PO		09/09/22 11:00 PM	01/14/23 11:47 AM	Boiler i/r, Generator Field Out inspection/possible rewedged, Turbine Valve i/r, Corrosion Fatigue i/r, Cooling Tower i/r, ReHeat Attenuator i/r, Gas valve i/r, FD Fan and Motor i/r, High Energy Piping (HEP) i/r, Flow Accelerated Corrosion (FAC) i/r, Core Loop testing.	295	35,448	71	119.98
Mitchell 1		D3	12/22/22 12:00 AM	12/30/22 12:00 AM	Large clinker growing on North side of Boiler	35	4,200	948	119.98
Mitchell 1		D1	12/24/22 06:48 AM	12/24/22 07:06 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	465	140	949	0.30
Mitchell 1		D1	12/24/22 07:06 AM	12/24/22 07:43 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	97	60	950	0.62
Mitchell 1		D1	12/24/22 07:43 AM	12/24/22 08:20 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	465	287	951	0.62
Mitchell 1		D1	12/24/22 08:20 AM	12/24/22 12:00 PM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	140	514	952	3.67
Mitchell 1		D1	12/24/22 01:48 PM	12/24/22 07:34 PM	Opacity	80	462	953	5.77
Mitchell 1		D1	12/24/22 07:34 PM	12/25/22 09:00 AM	Opacity	90	1,210	954	13.43
Mitchell 1		D1	12/25/22 10:07 AM	12/25/22 12:31 PM	Frozen lumps of coal causing conveyor trip out outs	135	324	955	2.40
Mitchell 1		D1	12/26/22 12:20 AM	12/26/22 08:29 AM	Opacity	45	368	956	8.15
Mitchell 1		D1	12/26/22 08:29 AM	12/26/22 08:46 AM	Opacity	60	17	957	0.28
Mitchell 1		D1	12/26/22 08:46 AM	12/27/22 12:00 AM	Opacity	85	1,296	958	15.23
Mitchell 1		D3	12/27/22 12:00 AM	12/27/22 01:40 AM	Opacity	85	142	959	1.67
Mitchell 1		D3	12/27/22 01:40 AM	12/27/22 02:02 AM	Opacity	135	50	960	0.37
Mitchell 1		D3	12/27/22 02:02 AM	12/27/22 02:53 AM	Opacity	155	132	961	0.85
Mitchell 1		D3	12/27/22 02:53 AM	12/27/22 04:43 AM	Opacity	185	339	962	1.83
Mitchell 1		D3	12/27/22 04:43 AM	12/27/22 07:22 AM	Opacity	205	544	963	2.65
Mitchell 1		D3	12/27/22 07:22 AM	12/27/22 11:03 AM	Opacity	235	866	964	3.68
Mitchell 1		D3	12/27/22 11:03 AM	12/28/22 12:00 AM	Opacity	245	3,174	965	12.93
Mitchell 2		D1	12/23/22 10:10 AM	12/23/22 10:28 AM	25 Pulv issue	95	29	908	0.30
Mitchell 2		D1	12/23/22 10:28 AM	12/23/22 05:44 PM	25 Pulv issue, could not get dampers to operate	90	654	910	7.27
Mitchell 2		D1	12/23/22 12:07 PM	12/23/22 01:56 PM	Opacity	25	46	909	1.82
Mitchell 2		D1	12/23/22 01:56 PM	12/23/22 02:53 PM	Opacity	50	48	913	0.95
Mitchell 2		D1	12/23/22 02:53 PM	12/23/22 07:22 PM	Opacity	100	448	914	4.48
Mitchell 2		D1	12/23/22 07:22 PM	12/23/22 09:08 PM	Opacity	90	159	915	1.77
Mitchell 2		D1	12/23/22 09:08 PM	12/24/22 02:46 AM	Opacity	150	845	916	5.63
Mitchell 2		D1	12/24/22 02:46 AM	12/24/22 04:41 AM	Opacity	90	173	917	1.92
Mitchell 2		D1	12/24/22 04:41 AM	12/24/22 02:08 PM	Opacity	75	709	918	9.45
Mitchell 2		D1	12/24/22 06:48 AM	12/24/22 07:08 AM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	415	138	911	0.33
Mitchell 2		D1	12/24/22 07:08 AM	12/24/22 12:00 PM	Reagent slurry feed tanks have frozen level indications and tanks were lower than expected	210	1,023	912	4.87
Mitchell 2		D1	12/24/22 02:08 PM	12/25/22 12:00 AM	Opacity	90	888	919	9.87
Mitchell 2		D3	12/25/22 12:00 AM	12/26/22 12:00 AM	Anticipated opacity	190	4,565	920	24.00
Mitchell 2		D3	12/26/22 12:00 AM	12/27/22 12:38 PM	Opacity	190	6,968	921	36.63
Mitchell 2		D3	12/27/22 12:38 PM	12/27/22 02:02 PM	Opacity	210	294	923	1.40
Mitchell 2		D3	12/27/22 02:02 PM	12/27/22 03:12 PM	Opacity	230	268	924	1.17
Mitchell 2		D3	12/27/22 03:12 PM	12/27/22 04:08 PM	Opacity	340	317	925	0.93
Mitchell 2		D3	12/27/22 04:08 PM	12/28/22 11:40 PM	Opacity	365	2,871	926	7.85

Event Type *

Outages

- FO Forced Outage
- MO Maintenance Outage
- PO Planned Outage
- RS Reserve Shutdown
- SF Startup Failure

Note: i/r = inspection and repair

Curtailed

- D1 Requires immediate reduction in capacity
- D2 Does not require an immediate reduction in capacity but requires a reduction within six (6) hours
- D3 Can be postponed beyond six (6) hours, but requires reduction in capacity before the end of the next weekend

KPSC Case No. 2023-00145
Commission Staff's First Set of Data Requests
Dated May 10, 2023
Item No. 6
Attachment 2
Page 1 of 1

Unit Name	Event Type *	Event Start	Event End	Event Description
Big Sandy 1	PO	09/09/22 11:00 PM	01/14/23 11:47 AM	Boiler i/r, Generator Field Out inspection/possible rewedge, Turbine Valve i/r, Corrosion Fatigue i/r, Cooling Tower i/r, ReHeat Attemperator i/r, Gas valve i/r, FD Fan and Motor i/r, High Energy Piping (HEP) i/r, Flow Accelerated Corrosion (FAC) i/r, Core Loop testing.
Mitchell 1	PO	10/07/22 11:00 PM	11/19/22 05:32 PM	Boiler i/r, Precip i/r, Pulverizer/Feeder MATS i/r, Economizer wash, Replace Precip Transformer power cables, Replace SCR XJ s 14,15 and 115, Replace Exit Duct XJ FGX-71009, Water Cannon upgrades, Ovation Evergreen upgrade, Inter-lock testing, HF Piping i/r.
Mitchell 1	RS	11/19/22 05:32 PM	11/29/22 11:45 AM	Reserve Shutdown
Mitchell 1	SF	11/29/22 11:45 AM	11/29/22 06:03 PM	Unable to get firing permissives.
Mitchell 1	MO	12/03/22 01:47 AM	12/08/22 09:18 AM	Economizer tube leak repair
Mitchell 1	FO	12/08/22 11:45 AM	12/09/22 12:00 AM	PH Issues
Mitchell 1	FO	12/09/22 12:00 AM	12/10/22 08:01 AM	due to Urea from Hydrolyzer system entering the Condensate Return System. Samples will be collected and tested once the unit cools. Hydrolyzer will need pressurized to search for potential leaks.
Mitchell 1	FO	12/10/22 01:07 PM	12/13/22 04:30 PM	Due to Primary Superheater Outlet valve . packing blew out. Superheater Bypass Control valve URV 4, controller failed closed due to burned up controller.
Mitchell 1	RS	12/13/22 04:30 PM	12/14/22 02:45 AM	Reserve Shutdown
Mitchell 1	SF	12/14/22 02:45 AM	12/14/22 07:15 PM	Start Failure
Mitchell 1	MO	12/30/22 12:00 AM	01/22/23 05:59 PM	Boiler i/r, Boiler Hydro, Duct repairs, Clinker Removal, IK Soot Blower Repairs, 12 ID Fan Stall margin probe i/r.
Mitchell 2	PO	09/09/22 11:00 PM	12/16/22 02:25 PM	Boiler i/r, Cooling Tower i/r, Low Pressure Turbine "A"&"B" Valve replacement, SCR Catalyst #4 layer replacement, AH Basket i/r, Precip i/r.
Mitchell 2	PO	12/16/22 02:52 PM	12/16/22 03:28 PM	Boiler i/r, Cooling Tower i/r, Low Pressure Turbine "A"&"B" Valve replacement, SCR Catalyst #4 layer replacement, AH Basket i/r, Precip i/r.
Mitchell 2	FO	12/17/22 02:12 PM	12/20/22 04:08 PM	A Bus Relay PA Fan

Event Type *

- FO Forced Outage
- MO Maintenance Outage
- PO Planned Outage
- RS Reserve Shutdown
- SF Startup Failure
- Note: i/r = inspection and repair

