

COOPER 1

		Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17
31a	Eq. Avail. Factor	99.41	100	100	46.67	78.29	100	77.53	100	99.79	99.97	100	100
31b	Eq. Forced Out. Rate	4.75	0	0	0	0	0	94.82	0	1.16	0.2	0	0
31e	Net Capacity Factor	7.72	-0.76	18.86	-0.67	3.56	14.95	0.32	16.08	11.91	6.99	4	37.11
31f	Net Ht Rt(btu/kwh)	10925.02	0	10288.59	0	12456.19	12272	41709.97	11057.92	12926.02	11944.28	12151.96	10783.21
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
31a	Eq. Avail. Factor	100	99.79	100	28.15	94.2	100	99.9	98.89	99.64	99.94	100	100
31b	Eq. Forced Out. Rate	0	0.75	0	0	19.49	0	0.41	2.4	1.79	0.32	0	0
31e	Net Capacity Factor	62.43	14.68	-0.72	-0.69	18.75	25.3	13.74	25.29	12.53	12.31	5.01	-0.98
31f	Net Ht Rt(btu/kwh)	10570.85	11258.06	0	0	10401.78	10680.37	10906.31	10748.69	12604.64	10888.82	11736.33	0
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19
31a	Eq. Avail. Factor	89.72	100	91.25	100	100	100	99.68	100	20	47.49	93.34	100
31b	Eq. Forced Out. Rate	28.92	0	0	0	0	0	2.69	0	0	0	43.39	0
31e	Net Capacity Factor	13.4	1.04	-0.67	-0.31	-0.29	8.01	6.65	11.78	-0.92	3.57	4.33	3.16
31f	Net Ht Rt(btu/kwh)	10956.73	22379.19	0	0	0	8134.73	11331.46	11205.27	0	14824.9	10416.49	13150.09
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20
31a	Eq. Avail. Factor	100	100	100	100	100	100	87.27	95.55	100	48.39	58.53	90.89
31b	Eq. Forced Out. Rate	0	0	0	0	0	0	16.56	33.33	0	0	0	33.32
31e	Net Capacity Factor	-0.82	-0.78	-0.64	-0.77	0	0.42	35.11	5.05	1.12	-0.81	-0.6	11.09
31f	Net Ht Rt(btu/kwh)	0	0	0	0	0	29885.2	10582.66	11586.32	17077.46	0	0	10805.09
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21
31a	Eq. Avail. Factor	100	92.57	100	97.3	100	84.17	100	99.92	56.67	0	0	50.44
31b	Eq. Forced Out. Rate	0	9.68	0	10.85	0	0	0	0.22	0	0	0	0
31e	Net Capacity Factor	4.21	46.48	-1.07	15.02	11.27	9.07	30.11	23.33	7.09	-0.83	-0.67	3.1
31f	Net Ht Rt(btu/kwh)	12685.83	10597.92	0	8085.81	11040.04	11172.58	10588.78	0	11940.87	0	0	0
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22
31a	Eq. Avail. Factor	100	100	100	26.67	96.77	99.71	100	84.8	45.72	95.93	100	95.11
31b	Eq. Forced Out. Rate	0	0	0	0	0	1.38	0	49.44	2.41	8.12	0	15.73
31e	Net Capacity Factor	49.48	25.75	-1.22	0	1.28	12.79	23.06	6.89	26.05	7.13	-1.05	23.15
31f	Net Ht Rt(btu/kwh)	10837.25	11158.68	0	0	17827.82	12048.9	10470.88	12035.48	10591.74	11334.31	0	10822.85
31h	Unit Rating	116	116	116	116	116	116	116	116	116	116	116	116
		Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23					
31a	Eq. Avail. Factor	100	97.49	100	99.55	67.74	100	99.68					
31b	Eq. Forced Out. Rate	0	18.5	0	0.93	0	0	0.62					
31e	Net Capacity Factor	-1.16	5.48	-1	33.9	-1	-0.9	31.22					
31f	Net Ht Rt(btu/kwh)	0	12354.27	0	9818.88	0	0	10441.76					
31h	Unit Rating	116	116	116	116	116	116	116					

COOPER 2

		Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17
31a	Eq. Avail. Factor	100	100	84.69	0	81.72	100	99.78	100	100	98.16	73.19	100
31b	Eq. Forced Out. Rate	0	0	29.28	0	0	0	0.61	0	0	8.79	100	0
31e	Net Capacity Factor	26.16	7.34	24.57	-0.66	26.42	9.48	24.28	36.28	21.53	11.48	-0.85	21.12
31f	Net Ht Rt(btu/kwh)	10132.61	11052.57	10611.31	0	10328.71	11061.15	0	10367.18	10101.94	10723.9	0	10765.87
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
31a	Eq. Avail. Factor	99.46	99.77	100	43.34	24.45	100	100	100	100	99.89	100	100
31b	Eq. Forced Out. Rate	0.79	0.83	0	0	0	0	0	0	0	0.46	0	0
31e	Net Capacity Factor	54.26	18.3	-0.64	-0.55	10.22	59.35	15.1	29.43	21.86	15.23	8.63	15.85

31f	Net Ht Rt(btu/kwh)	10431.06	10677.11	0	0	10587.81	9798.79	10699.7	10479.19	14514.98	11007.53	11597.1	10702.16
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Dec-19
31a	Eq. Avail. Factor	100	100	92.87	100	100	100	100	100	69.22	61.29	93.34	100
31b	Eq. Forced Out. Rate	0	0	0	0	0	0	0	0	4.16	0	31.76	0
31e	Net Capacity Factor	24.44	1.81	8.52	-0.88	-0.83	8.76	3.78	13.44	10.25	-0.77	8.5	-0.7
31f	Net Ht Rt(btu/kwh)	10448.06	14169.48	11263.97	0	0	10761.09	12557.34	11365.98	11817.6	0	12831.01	0
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20
31a	Eq. Avail. Factor	100	100	100	100	100	100	99.21	100	100	100	81.97	100
31b	Eq. Forced Out. Rate	0	0	0	0	0	0	1.15	0	0	0	0	0
31e	Net Capacity Factor	-0.76	-0.76	-0.72	-0.56	0	-0.52	40.77	13.24	-0.51	-0.48	-0.64	11.89
31f	Net Ht Rt(btu/kwh)	0	0	0	0	0	0	10868.27	7072.13	0	0	0	11129.06
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21
31a	Eq. Avail. Factor	99.94	93.58	100	100	100	90.83	100	99.76	100	16.13	0	83.87
31b	Eq. Forced Out. Rate	0.78	9.15	0	0	0	0	0	0.44	0	0	0	0
31e	Net Capacity Factor	4.73	52.28	-0.62	8.5	15.69	5.71	54.81	37.15	31.75	10.96	-0.69	-0.83
31f	Net Ht Rt(btu/kwh)	12477.55	10619.56	0	11572.9	11083.29	11542.41	10349.04	0	11065.87	11148.34	0	0
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22
31a	Eq. Avail. Factor	93.12	100	100	26.67	96.77	93.33	100	98.38	29.29	0	0	0
31b	Eq. Forced Out. Rate	7.69	0	0	0	0	0	0	3.18	2.38	0	0	0
31e	Net Capacity Factor	57.73	31.31	-0.48	0	13.01	47.73	50.21	32.09	17.7	-0.68	-0.5	-1.33
31f	Net Ht Rt(btu/kwh)	10642.95	11015.76	0	0	10743.9	10701.09	10014.79	11083.38	10863.83	0	0	0
31h	Unit Rating	225	225	225	225	225	225	225	225	225	225	225	225
		Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23					
31a	Eq. Avail. Factor	57.21	97.24	99.35	100	67.74	100	100					
31b	Eq. Forced Out. Rate	0.17	15.09	0.79	0	0	0	0					
31e	Net Capacity Factor	17.64	10.15	48.14	23.81	-0.51	15.81	56.65					
31f	Net Ht Rt(btu/kwh)	10832.07	10928.9	10201.75	10656.6	0	10396.04	9992.23					
31h	Unit Rating	225	225	225	225	225	225	225					