

## **Exhibit B**

Discharge Quality Report (quarterly)

Yung Farm  
KY0092843  
Quarterly

| Sample Date | CBOD 25 monthly / 37.5 weekly mg/L | TSS 30 monthly / 45 weekly mg/L | E.coli 130 monthly / 240 weekly | NH3 Nov - Apr 4 monthly / 6 weekly May - Oct 10 monthly / 15 weekly mg/L | pH 6-9 | DO >7.0 mg/L | TRC .011 monthly / .019 weekly mg/L | O&G report annually |
|-------------|------------------------------------|---------------------------------|---------------------------------|--|--------|--------------|-------------------------------------|---------------------|
| 1/5/2024    | 8 mg/L                             | 288 mg/L                        | <1                              | <.2 mg/L   | 7.1    | 9.15         | <.01                                |                     |
| 5/10/2024   | Below Detection Limit              | Below Detection Limit           | Below Detection Limit           | 0.561 mg/L   | 7.79   | 8.35         | Below Detection Limit               |                     |
| 7/26/2024   | BDL                                | 7                               | 63                              | 0.26   | 7.5    | 7.92         | BDL                                 |                     |
| 7/30/2024   |                                    |                                 |                                 |  |        |              |                                     | 5.88 mg/L           |
| 10/24/2024  | BDL                                | 2                               | BDL                             | 0.11   | 7.99   | 7.78         | BDL                                 |                     |

# of Service Interruptions:

0

Employee/Contractor Response Times:

0

Violations/Citations:

0

None Observed/Received