



**KENERGY CORP  
HENDERSON, KENTUCKY**

**CONSTRUCTION WORK PLAN  
FOR 2016 – 2020  
(July 1-June 30)**

**KY-65 KENTUCKY**



Clemson Office:  
110 Liberty Dr., Ste 101  
Clemson, SC 29631  
Phone: (864) 654-7798

Corporate Office:  
1616 E. Millbrook Road, Ste. 210  
Raleigh, NC 27609  
Phone: (919) 256-5900  
Fax: (919) 256-5939



**KENERGY CORP  
HENDERSON, KENTUCKY**

**CONSTRUCTION WORK PLAN  
FOR 2016 – 2020**

**KY-65 KENTUCKY**



*Engineering & Management Services®*

Corporate Office:

1616 E. Millbrook Road, Suite 210

Raleigh, North Carolina 27609

Phone: (919) 256-5900 | Fax: (919) 256-5939

Clemson Office:

110 Liberty Dr., Ste 101

Clemson, SC 29631

Phone: (864) 654-7798

I hereby certify this 2016-2020 Construction Work Plan was prepared by me or under my direct supervision. I also certify I am a duly registered professional engineer under the laws of the Commonwealth of Kentucky, Registration No. PE 25427.

Electronic Version- Original Signed Copy  
maintained in PowerServices Office.

February 29, 2016  
Micheal W White Jr, PE

# TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
<b>1 EXECUTIVE SUMMARY</b>		
A.	Introduction and Purpose of Report	1-1
B.	General Basis of Study	1-1
C.	Present System Analysis	
	1. <i>Service Area</i>	1-3
	2. <i>Power Supply</i>	1-3
	3. <i>Transmission System</i>	1-4
	4. <i>Substations</i>	1-4
	5. <i>Distribution Circuits</i>	1-5
	6. <i>System Energy Losses</i>	1-5
	7. <i>Service Reliability</i>	1-6
D.	Historical System Data	1-8
E.	Projected System Loads	1-8
F.	Existing and Project Distribution System Analysis	1-9
G.	Summary of 2016-2020 Construction Work Plan Costs	1-11
<b>2 DESIGN CRITERIA</b>		
<b>3 CONSTRUCTION PROGRAM</b>		
A.	Status of Previous Work Plan Projects	3-2
B.	Summary of 2016-2020 Recommended Plan	3-3
	1. <i>Service to New Members</i>	3-3
	2. <i>Service Changes</i>	3-5
	3. <i>Sectionalizing</i>	3-6
	4. <i>Pole Replacement</i>	3-6
	5. <i>Miscellaneous Construction</i>	3-7
	6. <i>Security Lights</i>	3-7
	7. <i>New Tie Lines</i>	3-7
	8. <i>Line Conversions</i>	3-8
	9. <i>New Substations</i>	3-9
	10. <i>Increased Substation Capacity</i>	3-9
	11. <i>Sectionalizing- Location Specific</i>	3-11
	12. <i>Line Voltage Regulators</i>	3-13
	13. <i>Distribution Capacitors</i>	3-14
	14. <i>System Wide- RUS 371-372</i>	3-15
C.	2016-2020 CWP Detailed Cost Estimate Summary	3-16
<b>4 DESCRIPTIONS AND JUSTIFICATIONS</b>		
A.	Summary of System Improvements	4-1
B.	Conversion and Line Change Projects	4-7
C.	Sectionalizing	4-36
D.	Regulators	4-62
E.	Capacitors	4-63

# TABLE OF CONTENTS

---

## 5 EXHIBITS

### Figures

- Figure F-1 2015 Load Forecast Excerpt
- Figure F-2 CWP 740C Sample
- Figure F-3 RUS Form 300
- Figure F-4 System Loss Calculation and Conductor Optimization
- Figure F-5 Weaverton Station Exploratory Cost Analysis

### Tables

- Table T-1 Substation Transformers Loading Analysis
- Table T-2 CWP Substation Load Forecasts
- Table T-3 Work Plan Construction Unit Costs

## 6 APPENDICES

- Milsoft Substation Diagrams – Existing System
- Milsoft Substation Diagrams – With Improvements
- CWP System Improvement Map

**EXECUTIVE  
SUMMARY**

# 1 EXECUTIVE SUMMARY

---

## A. Introduction and Purpose of Report

The 2016–2020 Construction Work Plan ("CWP") was developed for Kenergy Corp ("Kenergy") as an analysis of the existing system, evaluation of the status of the last Construction Work Plan's project completion, and a recommended plan for the improvements required for accommodating anticipated system peak loads during the four-year period including the summer peak of 2019 and the 2019-2020 winter peak. This CWP was prepared recognizing the need to achieve optimum asset management, while maintaining and improving service reliability. PowerServices was retained to assist Kenergy in the preparation of the CWP and included within this report is the engineering support for a loan application to RUS to finance the proposed construction program.

The system improvements recommended herein are consistent with those proposed in the Long-Range Plan prepared in February 2010. The anticipated demands, member owner growth, average usage, and peak usage are consistent with the most recent Load Forecast, as prepared by Big Rivers Electric Corporation and approved by the Cooperative's Board of Directors. The improvements recommended by this Work Plan are recommended and designed in accordance to the Design Criteria contained herein. The system improvements to be financed by a loan are tabulated in Section 3, Construction Program.

The system improvements in the 2016-2020 Construction Work Plan are those needed to provide service for 57,976 member owners at an annual average monthly residential consumption of 1,300 kWh per member owner with total annual Rural System sales of 1,147,198 MWh at the end of the plan period. On completion of the proposed construction program, the system will adequately service the 2019 summer peak NCP load of 319.2 MW and the 2019-2020 winter peak NCP load of 340.3 MW as projected in accordance with the 2015 BREC Load Forecast, including the Tyson, Valley Grain, and future spot loads.

## B. General Basis of Study

The engineering basis of this CWP report included the review of Kenergy's historical system data and relevant system studies. The projected system peak load and number of member owners served used in this report were based on the 2015 Load Forecast,

# 1 EXECUTIVE SUMMARY

---

developed by GDS Associates, Inc. in cooperation with Big Rivers Electric Corporation ("BREC") and Kenergy and the CWP Substation Forecast, developed by PowerServices and Kenergy. An excerpt from the 2015 BREC Load Forecast and the CWP Substation Forecast are provided in the Exhibit section of this report.

The Cooperative's 2015 Operations and Maintenance review, RUS Form 300, was used to determine construction required to replace physically deteriorated equipment and material, and improve reliability and quality of service, combined with discussions and consensus with the Cooperative engineering and operations staff.

New distribution and power supply construction requirements were evaluated simultaneously as a "one system" approach for the orderly and economic development of the total system. All of the proposed construction and recommendations herein, relative to the power supply and delivery, were discussed with Kenergy's power supplier, BREC.

The details and estimated costs of the line, equipment, and additional requirements to serve 2,370 new member owners (1,570 net new members) during the work plan period are in Section 3- Construction Program.

An analysis, using RUS guidelines and the design criteria herein, of thermal loading, voltages, physical conditions, and reliability was performed on all of the substations, distribution lines, and major equipment of Kenergy's existing electric system. The electric distribution system for Kenergy is modeled using Milsoft Windmil® Distribution Analysis software. The engineering analysis software was used to analyze the distribution circuits to obtain future circuit loading, voltage, and current. Based upon the engineering analysis and Design Criteria, areas of deficiency were identified and improvements proposed to address these areas. Additionally, management and engineering staff reviewed every improvement recommended for inclusion in this CWP to assure its necessity and the accuracy of routing and physical constraints that may impact construction cost.

# 1 EXECUTIVE SUMMARY

---

## C. Present System Analysis

The following Present System Analysis discusses features of the existing distribution system, as well as current operational conditions as they apply to the current CWP.

### 1. Service Area

Kenergy is an electric distribution cooperative headquartered in Henderson, Kentucky. The Cooperative was established in July 1999 through the consolidation of Henderson-Union Electric Cooperative (organized in 1936) and Green River Electric (organized in 1937). Kenergy provides services to approximately 56,000 homes and businesses in Breckinridge, Caldwell, Crittenden, Daviess, Hancock, Henderson, Hopkins, Livingston, Lyon, McLean, Muhlenberg, Ohio, Union and Webster counties. The Cooperative maintains more than 7,000 miles of power line. A map showing the Members' service territory is provided in Figure 1.1.

**Figure 1.1- Kenergy Service Territory**




Figure 1.1: KENERGY Service Territory. Source: 2015 BREC Load Forecast.

### 2. Power Supply



# 1 EXECUTIVE SUMMARY

---

Kenergy purchases power from Big Rivers Electric Corporation (“BREC”) pursuant to a power supply contract covering the rural system and all commercial and industrial member owners. Approximately 81% of the accounts served by Kenergy are residential; however, a high proportion of total system energy sales correspond to the large commercial class. Kenergy is unique among electric cooperatives as Kenergy secures the market energy requirements and electric service through BREC’s transmission system to two aluminum smelters with a combined load currently exceeding 850 MW. The Kenergy peak system loading in this report refers to the “Rural System” only which represents member owners directly connected to the Kenergy distribution system. A tabulation of general operating statistics is shown in Table 1-1.

**Table 1-1 – General Rural System Operating Statistics\***

	2014	2015
Miles of Distribution Line	7,113	7,130
Year-End Customers per Month Served	55,932	56,406
Customers per Mile	7.86	7.91
Average Residential Consumption (kWh/month)	1,394	1,317
Total Rural System MWh Purchased	1,240,267	1,193,057
Total Rural System MWh Sold	1,178,466	1,137,157
Percent System Losses for Rural System	4.77%	4.48%

NOTE: Statistics provided by Kenergy Corp

### 3. Transmission System

BREC constructs, owns, and operates the 69-kV transmission system supply power to the 50 delivery points on the Kenergy system.

### 4. Substations

Kenergy owns the substations serving the distribution system. There are forty-seven (47) 69 kV to 12.47 kV substations in operation and three (3) 69 kV to 24.9 kV substations in operation. Table T-1, Substation Transformers and Voltage Regulators without Improvements, in the Exhibit section shows the primary and secondary voltage rating and the existing transformer capacity at each substation.

# 1 EXECUTIVE SUMMARY

---

## 5. Distribution Circuits

The distribution system includes 189 circuits operated at 24.9/14.4 kV or 12.47/7.2 kV. The installed overhead conductor sizes range from #8 CWC to 795 kcmil ACSR, and the underground cable sizes range from #2 AL to 750 MCM AL. Overall, the distribution system is, as noted on the O&M Survey, in satisfactory condition. The individual substation area Present System Analysis engineering model shows the existing loading and voltage problems. These problem areas were verified with the Cooperative's engineer. The CWP without Improvements WindMil® maps illustrate how projected Work Plan loads are expected to affect the existing distribution system voltage and load characteristics.

Voltage regulators are being used on a number of feeders to maintain acceptable voltage levels at system extremities, while deferring costly capital investment as long as feasible without excessive power line losses. In most instances, voltage regulators are used to correct the voltage drop caused by long distances from the source, rather than by large loads. In some instances, voltage regulation is relocated downline from an existing location as an interim step to defer longer line conversions or reconductoring. All voltage is to be maintained within the standards recommended by RUS.

Reconductoring, multi-phasing, and circuit load shifts are recommended where required to provide adequate capacity and voltage levels. The basis for the decision process is found in the Design Criteria Section, and follows prudent utility practice and economics. The individual substation WindMil® diagrams show the calculated voltage drops (120V base) at line extremities and at voltage regulator installations, along with the proposed system improvements.

## 6. System Energy Losses

The system annual energy losses from 2007 through 2014 are as follows:

# 1 EXECUTIVE SUMMARY

---

Table 1-2 – Rural System Energy Losses

Year	MWh Losses	MWh Purchases	Percent Losses
2007	58,703	1,235,849	4.75%
2008	58,494	1,218,628	4.80%
2009	45,192	1,144,107	3.95%
2010	32,588	1,270,263	2.57%
2011	52,906	1,214,795	4.36%
2012	58,025	1,192,208	4.87%
2013	54,488	1,221,667	4.46%
2014	59,166	1,240,267	4.77%
2015	53,391	1,193,057	4.48%
<b>Average</b>	<b>52,445</b>	<b>1,217,223</b>	<b>4.31%</b>

Total system annual energy losses have averaged 4.31% over the past nine years. These losses are attributed to, but not limited to, line losses on circuit feeders, substation transformers, distribution voltage regulators, single-phase taps, and loading on distribution transformers. The system losses are expected to reduce marginally as the 2016-2020 Construction Work Plan improvements are implemented. Special care was taken in addressing heavily loaded equipment and sizing this equipment to reduce losses. It is important to recognize that weather has a substantial impact on line loss variation.

## 7. Service Reliability

Service reliability and power quality are important factors used to measure quality of service provided to the member owner. Although weather and delivery point (power supply) related outages are difficult to control, some measures can be taken to promote enhanced resiliency. The Cooperative should continue to maintain a vigorous program of right-of-way clearing to alleviate problematic tree conditions and should continue working with the power supplier for enhanced delivery point reliability. Trees and brush in rights-of-way create hazards that cause outages and obstruct the movement of line crews during storms, thereby increasing outage hours.

# 1 EXECUTIVE SUMMARY

---

The upgrade of inter-substation tie lines will improve reliability by providing available capacity for load shifts, as well as eliminating old, deteriorated conductors from the system. In addition, replacement of old and deteriorated poles and aging wire in accordance with asset management focused replacement programs will lower material failures. These programs will also aid in reducing weather-related outages, particularly those caused by strong winds and ice storms.

The need for increased evaluation of pole attachments by telecommunications and cable companies has recently become apparent. These pole attachers are not always notifying the Cooperative of attachment or following NESC minimum requirements. Better enforcement of pole attachment agreements will also improve reliability by addressing poles that are structurally deficient due to unpermitted communications attachments.

Multi-phasing and load balancing will significantly reduce the number of member owners interrupted during a single-phase outage and will reduce outage time. In many areas where multi-phasing is required, the existing sectionalizing devices cannot be sized to pick up the entire cold load. This significantly increases the outage times, since the line crews must re-energize the line in sections. Continued multi-phasing and the addition of new sectionalizing points will substantially reduce outage hours per member owner.

Table 1-3 provides a service interruption summary based on information derived from the Cooperative's RUS Form 7 and data supplied by the Cooperative from 2007 to 2014. The average annual hour outages per member owner per year are at acceptable levels and within the IEEE 1366-2003 standards. RUS recommends that there be no more than an average of 200 member owner outage minutes (3.3 hours), per member owner, per year, excluding outages caused by major storms or the power supplier, for the last 5 consecutive years in any specific area.

# 1 EXECUTIVE SUMMARY

---

**Table 1-3 - Service Interruption Summary**

Average Minutes per Member Owner by Cause(1)

Year	Power Supplier	Major Storm	Planned	All Other	Total	Total (less Power Supplier & Major Events)
2007	13.3	46.4	7	114.6	181.3	121.6
2008(2)	50.4	268.2	2.5	134.4	455.5	136.9
2009(2)	95.3	372.5	4.1	179.2	651.1	183.3
2010	12.3	0	1.6	97.2	111.1	98.8
2011(3)	13.4	0.4	5.1	204.4	223.3	209.5
2012	20.3	42.0	1.1	108.9	172.3	110.0
2013	13.8	27.7	3.9	90.9	136.3	94.8
2014	1.8	27.5	6.1	90.6	126	96.74
<b>Average</b>	<b>27.6</b>	<b>98.1</b>	<b>3.9</b>	<b>127.5</b>	<b>257.1</b>	<b>131.5</b>

Note: 1. All data from RUS Form 7.  
2. Major Storms: 2008 February ice storm and September Hurricane. 2009 January ice storm  
3. 2011 total minutes is due to storms that could not be classified as major events. RUS Form 300.

## D. Historical System Data

The Exhibits included in this CWP illustrate historical system data utilized in the detailed analysis of system operations. System historical data was provided by the Cooperative in regard to system peak loads, energy purchased, energy sales, member owners billed, service interruptions, service extensions, commercial loads and circuit loads. This data was compiled and analyzed to identify operational trends, positive and negative, to be addressed in the 2016-2020 Construction Work Plan. Table 1-4 of this section provides a summary of demand and energy projected data and the historical data for the past three years. The 2015 Load Forecast contains substantial historical perspective, with an excerpt provided in the Exhibit section.

## E. Projected System Loads

Substation load projections were based on historical growth rates and proposed load additions, including new subdivisions, commercial loads, large power additions, demographics and economy. The diversity of circuit loads and substation loads are considered when evaluating the peak loads on each component of the system. Proposed

# 1 EXECUTIVE SUMMARY

substation and distribution line improvements are based upon need at projected load levels in their respective areas.

Table 1-4 reflects demand and energy forecasts for the Kenergy system. These projections are based upon historical system data and the 2015 Load Forecast.

**Table 1-4 - Historical and Projected System Data**

Year	Energy Purchased (1)		Energy Sold (2)		Energy Loss (3)		NCP Peak Demand (4)		Customers (5)	
	MWh	Percent Change	MWh	Percent Change	MWh	Percent of Purchase	Summer (MW)	Winter (MW)	Average	Percent Change
2011	1,214,795	-4.37%	1,159,289		52,906	4.36%	274.8	262.7	55,210	0.40%
2012	1,192,208	-1.86%	1,131,847	-2.37%	58,025	4.87%	308.3	255.1	55,419	0.38%
2013	1,221,667	2.47%	1,164,706	2.90%	54,488	4.46%	266.2	265.3	55,677	0.47%
2014	1,240,267	1.52%	1,178,466	1.18%	59,166	4.77%	277.6	329.7	55,932	0.46%
2015	1,193,057	-3.81%	1,137,157	-3.51%	52,445	4.40%	282.8	308.8	56,406	0.85%
2016	1,193,057	0.00%	1,135,791	-0.12%	57,267	4.80%	313.1	333.3	56,519	0.20%
2017	1,194,250	0.10%	1,136,926	0.10%	57,324	4.80%	313.5	334.1	56,632	0.20%
2018	1,195,564	0.11%	1,138,177	0.11%	57,387	4.80%	313.9	334.9	56,915	0.50%
2019	1,206,324	0.90%	1,148,421	0.90%	57,904	4.80%	314.4	335.9	57,256	0.60%
2020	1,212,356	0.50%	1,154,163	0.50%	58,193	4.80%	319.2	340.3	57,715	0.80%

1. Projected data based on 2015 BREC Load Forecast and historical data provided by Kenergy on RUS Form 325.

2. Projected energy sales based on 2015 BREC Load Forecast percent change and historical data provided by Kenergy on RUS Form 325.

3. Projected energy loss based upon 2015 BREC Load Forecast.

4. Projected NCP is based on historical Kenergy metered peaks based upon the CWP Station Loading analysis, Exhibit Table T-2.

5. Project customer growth based on 2015 BREC Load Forecast and historical data provided by Kenergy.

## F. Existing and Projected Distribution System Analysis

A distribution system model was provided by Kenergy and is modeled using the Milsoft Distribution Analysis software (WindMil®). The most recent system digital map database and peak system loading data was used to prepare this model. A present system analysis was completed. The Cooperative verified that voltage problems identified in the model were recently experienced on the system. Projected substation and circuit loads were allocated to the model to obtain calculated voltage and loading profiles for each distribution circuit. Recommendations included in the Construction Work Plan were based predominantly on the WindMil® computer analysis. In each case where the distribution model indicated a potential voltage or capacity problem,

# 1 EXECUTIVE SUMMARY

---

management and operations personnel at the Cooperative were involved in the final recommended solutions development. Additionally, these interviews identified problem areas that did not show up on the computer analysis due to local knowledge of proposed subdivisions, increased commercial loads, or poor condition of distribution facilities. The Construction Work Plan recommendations are based on analysis, multiple communications with Cooperative management and engineering and construction personnel, a meeting with Cooperative management and engineering, and an iterative process of developing the most economical plan that will allow the Cooperative to adequately serve the existing and new member owners through CWP planning period. Engineering model results for before and after recommended improvements are given in the Exhibit section.

Each of the distribution circuits was analyzed with respect to adequate voltage and loading conditions based on the Design Criteria. The analysis of the 2019-2020 winter system peak with the existing system configuration revealed the following:

Substations with voltage levels lower than 118 volts or conductor loading greater than 70% along line sections:

- Centertown, Dermont, Geneva, Guffie, Hanson, Lyon, Marion, Morganfield, Niagara, Nuckols, Onton, Race Creek, Sullivan, Weaverton, Weberstown.

The analysis of the 2019 summer peak with the existing system configuration revealed the following:

Substations with voltage levels lower than 118 volts or conductor loading greater than 70% along line sections:

- Beda, Caldwell Springs, Centertown, Dermont, Geneva, Guffie, Hanson, Lewisport, Lyon, Marion, Niagara, Nuckols, St. Joe, Sullivan, Weaverton, Weberstown, Whitesville.

# 1 EXECUTIVE SUMMARY

## G. Summary of 2016-2020 Construction Work Plan Costs

Following is a summary of the total cost for this 2016-2020 Construction Work Plan with a comparison to the previous CWP . The total cost for the Construction Work Plan is \$48,665,421.

**Figure 1-2- CWP System Improvements Cost Summary**

RUS Code	Item	2016-2020	2013-2017	Difference	Percent Diff
		Estimated Cost	Previous CWP		
100	New Customer Extensions	\$11,382,928	\$10,354,617	\$1,028,311	10%
200	New Tie Lines	\$20,092	\$0	\$20,092	
300	Line Conversions	\$10,852,724	\$9,259,500	\$1,593,224	17%
400	New Substations	\$0	\$0	\$0	0%
500	Substation Improvements	\$1,175,000	\$2,043,000	(\$868,000)	-42%
600	Miscellaneous Distribution Equipment				
601	Transformers	\$5,160,074	\$3,958,444	\$1,201,630	30%
601	Meters	\$1,100,335	\$554,820	\$545,515	98%
602	Service Upgrades	\$1,456,669	\$906,754	\$549,915	61%
603	Sectionalizing Equipment	\$2,218,635	\$2,606,400	(\$387,765)	-15%
604	Line Regulators	\$162,000	\$548,600	(\$386,600)	-70%
605	Capacitors	\$45,000	\$0	\$45,000	
606	Pole Replacements	\$6,984,975	\$8,010,750	(\$1,025,775)	-13%
608	Misc Construction	\$4,534,942	\$6,682,412	(\$2,147,470)	-32%
700	Security Lights	\$3,572,047	\$1,615,680	\$1,956,367	121%
<b>TOTAL CWP Improvements</b>		<b>\$48,665,421</b>	<b>\$46,540,977</b>	<b>\$2,124,444</b>	<b>4.6%</b>



**DESIGN  
CRITERIA**

## 2 DESIGN CRITERIA

---

Construction proposed herein must meet the following minimum standards for voltage, thermal load, safety, and system reliability. Conditions may require actions that exceed the design criteria given below:

1. Corrective action is required for voltages less than 118 volts on a primary distribution line, assuming a system base of 120 volts. System improvements based on the voltage's calculated value shall be proven in the field before construction approval. (Extrapolation to peak is allowed). The following criteria will be used to evaluate the voltage on the distribution system:
  - a. Substation regulation shall be set at 125 volts with a 2 volt bandwidth.
  - b. Down-line regulators will be coordinated with substation regulators such that they operate within the range stipulated in Kenergy's Tariffs.
  - c. More than one line voltage regulator in series on the main feeder is intended as a temporary solution for voltage correction.
2. All single-phase lines should be reviewed if the peak load exceeds 288 kVA. Multi-phasing or load transfers should be considered if the peak load current exceeds 40 ampere (288 kVA) on the 7.2-kV system or 20 ampere (288 kVA) on the 14.4-kV system.
3. Conversions of single-phase to multiphase can be implemented to correct voltage drop, balance, sectionalizing problem or a combination. Distribution lines are subject to multi-phasing if:
  - Voltage levels do not conform to Criteria #1.
  - The limit of Criteria #2 is exceeded and load transfer is not possible or advantageous.

## 2 DESIGN CRITERIA

---

- The number of consumers exceeds 60 on a single-phase tap.
4. The following loading standards are recommended for thermal protection of Kenergy Corp's equipment. Loading of power transformers is calculated from the base MVA(OA) nameplate rating at 55° C rise and metered power factor. If the actual power factor is not known, 90% will be assumed.
- Power Transformer 130% winter; 100% summer (ANSI C57)
  - Regulators 120% at 7.5% rise
  - Reclosers 80%
  - Line Fuses 80%
  - Current Limiting Fuses 80%
5. System studies flag conductors loaded to 50% of capacity. Conductors used for primary lines loaded more than 70% of thermal rating will be evaluated for replacement or an alternative action.
6. Any deteriorated conductor is subject to replacement if any or all of the following conditions exist:
- A section of line has experience repeated damage and repairs to the point of replacement.
  - Records indicate the section of overhead conductor has experienced an outage more than three times in the last year for reasons other than right-of-way or storm.
  - Records indicate the section of underground cable has been repaired or spliced a total of three times.
  - The conductor is copper (CWC or hard drawn) or steel wire. (Larger copper conductors will be evaluated on an individual basis.)

## 2 DESIGN CRITERIA

---

7. A primary distribution line will be rebuilt or relocated if a condition exists in which the line fails to meet applicable National Electric Safety Code requirements.
  
8. Annual SAIDI, CAIDI, SAIFI targets, number of outages, number of customers and an estimate of lost revenue are used to identify the worst performing feeders. If improvements do not adequately address these sections, additional analysis may be performed.
  
9. New primary conductor shall be sized on a case by case basis using Economic Conductor Analysis. Kenergy Corp's system cost at the time of the study will be used in the program and their standard conductor sizes for primary follows:
  - #2 ACSR
  - #1/0 ACSR
  - #4/0 ACSR
  - 336.4 ACSR
  - 795 MCM ACSR
  - #2 Aluminum 15 KV URD Cable
  - #4/0 Aluminum 15 KV URD Cable
  - 500 MCM Aluminum 15 KV URD Cable
  - 750 MCM Aluminum 15 KV URD Cable
  - #1/0 Aluminum 25 KV URD Cable
  - #4/0 Aluminum 25 KV URD Cable
  - 500 MCM Aluminum 25 KV URD Cable
  
10. All new primary construction shall be overhead except new feeders exiting a substation, or in case of favorable conditions such as a subdivision, to meet government agency requirements or ordinances.

## 2 DESIGN CRITERIA

---

11. New substations or upgrades to existing substations will be coordinated with Big Rivers Electric.
12. All construction shall be designed and built according to NESC and RUS construction guidelines or equivalent Kenergy Corp standards.
13. With the exception of dedicated circuits, feeders with a peak load exceeding 5,000 kW will be evaluated for:
  - Load transfer to an adjacent feeder
  - New feeder constructed to serve a portion of load
14. Sectionalizing studies are completed on a rotating cycle. It is Kenergy's intent to study one-fifth of the substation service areas each year. Substation or feeder upgrades may require interim studies.
15. Capacitors are placed on the system based on peak feeder reading from SCADA system. Summer and winter conditions are both studied. A power factor less than 90% is a flag to install a capacitor bank. The capacitor bank will be sized so that leading power factor will not fall below 95% at a load level of 60% of the winter peak loading condition.
16. The installation of a 10 MVA (OA base rating) transformer at a new or existing substation shall be fused on the high side for overcurrent protection. If the installed transformer is larger than 10 MVA, the high side overcurrent protection will be a breaker with relay controls.
17. Reliability of Kenergy system design shall consider single contingency planning. The system shall have the ability to maintain adequate service with loss of a major system element such as a substation transformer or three-phase feeder during non-extreme conditions.

## 2 DESIGN CRITERIA

---

The scope of system improvements will include (when applicable) provision of capacity to meet the single contingency criteria:

- a. Critical loads will have first priority.
- b. Non-extreme load conditions shall be defined as the average of the minimum and maximum monthly peaks, for each substation transformer during the calendar year.
- c. Each substation should have reserve transformer capacity available to support an adjacent substation (OA/FA capacity) equal to projected non-extreme load of both substations if distribution ties are available.
- d. Three-phase feeder capacity between two adjoining substations shall be adequate to allow backfeeding during non-extreme load conditions.
- e. Planning shall consider minimum tie-line conductor to be 336.4 kcmil ACSR at 12.5/7.2 kV and #4/0 ACSR at 24.9/14.4 kV. Minimum conductor for single-phase taps is 1/0 ACSR, if two-way feed is possible.

**CONSTRUCTION  
PROGRAM**

### 3 CONSTRUCTION PROGRAM

---

The estimated construction costs necessary to support the forecasted new customer additions, historical periodic replacements, proposed system improvements recommended in the 2016-2020 Construction Work Plan are listed herein. Section 4-Description and Justification includes a discussion of individual project need, project completion schedule, and estimated cost. New line extensions for additional consumers, increased capacity of existing services, and system improvements included are those required for the four-year period of 2016-2020, and are based on Kenergy's historical records for the two-year period ending December 2015 and are increased annually at a rate corresponding to the growth rates from the 2015 BREC Load Forecast.

Periodic replacement of existing poles, crossarms, conductor, cutouts, guys, etc., is required for numerous reasons. When such replacement is made, it is often necessary to install units with greater height or strength requirements, particularly due to newer NESC requirements. When lines are relocated due to road changes or to eliminate cross-country sections, the Cooperative should install poles of strengths suitable for the long-range conductor size and, in some instances, install line conductors in accordance with the Long Range Plan. Normal operations require the routine addition of poles for existing lines, either for telephone attachment or to improve clearance. The cost estimate in this CWP includes estimated loan funds to be expended for these purposes during the work plan period.

Increased cost of construction is a significant and continuing factor that must be considered, particularly as rising Producer Price Indices are reflected in raw materials pricing which in turn causes construction material cost increases. The estimates included in the Construction Work Plan were arrived at considering all the market swings and historical costs based on Kenergy's most recent construction projects. For this reason, cost estimates for construction during 2016-2020 are adjusted to reflect an annual 2% increase in construction labor and materials. Unit costs for proposed projects are shown in Exhibit section of this report. The recommended system improvements are summarized to conform to RUS Form 740c; however, to facilitate discussion and ease of identification, they are listed in the detailed portion of the estimate by substation area. The RUS Form 740c accounting code for each improvement is included in the cost estimate. Projects from the 2013-2017 Construction Work Plan that are being carried forward have been noted with an asterisk using the code number from the previous Construction Work Plan. The 740c code numbering



### 3 CONSTRUCTION PROGRAM

scheme in this Plan is continued from the previous Construction Work Plan and begins with the next available number under each code series.

#### A. Status of Previous Work Plan Projects

The following summary is a list of improvements proposed in the previous Construction Work Plan and Construction Work Plan Amendment and the status of each.

Table 3-1: Status of 2013-2017 Construction Work Plan Projects

CFR Code	Eng Status	Substation/Feeder	Description
<b>New Construction/Tie Lines/Distribution- Code 300</b>			
<b>Closed</b>			
358	Closed	Caldwell Springs - Circuit 60-3/Marion - Circuit 70-3	Multi-Phase 1ph ACSR2 to 3ph ACSR2
381	Closed	Caldwell Springs F2	Multi-Phase 1 Phase to 3 ph 2ACSR
359	Closed	Centertown - Circuit 40-3	Multi-Phase 1ph ACSR1/0 to 3ph ACSR1/0
380	Closed	Geneva - Circuit 63-3	Reconductor 3ph ACSR1/0 to 3ph ACSR4/0
309	Closed	Marion - Circuit 70-3	Multi-Phase 1ph ACSR2 to 3ph ACSR2
365	Closed	Niagara - Circuit 80-1	Multi-Phase 1ph ACSR2 to 3ph ACSR2
366	Closed	Nuckols - Circuit 42-3	Reconductor 3ph CU2 to 3ph ACSR336
312	Closed	Pleasant Ridge - Circuit 26-3	Multi-Phase and Reconductor 1ph ACSR4 to 3ph ACSR1/0
369	Closed	Providence - Circuit 81-4	Conversion from 12.47kV to 24.9kV
317	Closed	Race Creek - Circuit 82-3	Multi-Phase 1ph ACSR2 to 3ph ACSR2, Extension of 1ph ACSR1/0
375	Closed	South Hanson 2 - Circuit 53-3	Multi-Phase 1ph ACSR1/0 to 3ph ACSR1/0
337	Closed	South Hanson 2 - Circuit 53-6	Multi-Phase 1ph to 3ph ACSR2, Extension of UG1/0 AL
376	Closed	St. Joe - Circuit 32-1	Extension of 3ph ACSR2, Multi-Phase 1ph ACSR2 to 3ph ACSR2
377	Closed	Thruston 1 - Circuit 11-5	Extension of 1ph ACSR2
379	Closed	Weberstown - Circuit 14-1	Multi-Phase 1ph ACSR2 to 3ph ACSR2
<b>Carryover</b>			
370	Carryover	Providence - Circuit 81-1	Multi-Phase 1ph ACSR2 to 3ph ACSR2
364	Carryover	Masonville - Circuit 23-2	Reconductor 3ph CU1/0 to 3ph ACSR336
360	Carryover	Guffie - Circuit 31-1	Reconductor 3ph CU1/0 & ACSR3/0 to ACSR336
361	Carryover	Hanson - Circuit 51-4	Reconductor 3ph ACSR1/0 to 3ph ACSR4/0
374	Deferred	South Dermont 1 - Circuit 18-2	Reconductor 3ph CU1/0 to 3ph ACSR336

### 3 CONSTRUCTION PROGRAM

Substation Upgrades-Code 500			
502	Closed	Guffie	Substation Upgrades
503	Closed	St. Joe	Substation Upgrades

#### B. Summary of 2016-2020 Recommended Plan

This section is a summary of the recommended improvements for this 2016-2020 Construction Work Plan. This section will discuss the high growth areas and the types of improvements recommended for resolving all voltage and capacity problems through CWP time period. A detailed description and justification for each recommended improvement can be found in Section 4.

##### 1. Service to New Members- RUS 100 & 601

Historical information was reviewed for a 24-month period from 2014 to 2015 to project new member services and meter requirements for the 2016-2020 CWP-period. While the most recent period data was used to reflect the current economic factors, Kenergy did review the historical growth and cost trends for the past 10 years in the future projections. The historical number of services was increased approximately 0.5% per year for the 2016-2020 CWP based on the 2015 Load Forecast. Member overhead, underground, single phase transformer, and three phase transformer requirements were projected based on past experience. The historical costs were inflated by 2.0 percent per year. The cost per service has increased significantly since the past work plan period due mainly to increases in the customer meter and transformer material costs.

Table 3-2: Summary of Costs to Serve a New Member

RUS Code	Category Description	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
	Underground Lines- New					
101	Members	\$983,249	\$1,008,031	\$1,033,411	\$1,059,403	\$4,324,093
102	Overhead Lines- New Members	\$1,699,421	\$1,742,253	\$1,786,119	\$1,831,042	\$7,058,835
103	Construction New Service- URD	\$240,000				
<b>100</b>	<b>Total New Line Extensions</b>	<b>\$2,922,670</b>	<b>\$2,750,284</b>	<b>\$2,819,529</b>	<b>\$2,890,445</b>	<b>\$11,382,928</b>
	Single Phase Transformers- New					
601	Members	\$1,118,497	\$1,147,423	\$1,177,060	\$1,207,422	\$4,650,402
	Three Phase Transformers- New					
601	Members	\$88,478	\$90,248	\$92,053	\$93,894	\$364,672
601	Meters- New Members	\$266,254	\$272,056	\$277,984	\$284,040	\$1,100,335
<b>601</b>	<b>Total New Transformers and Meters</b>	<b>\$1,473,229</b>	<b>\$1,509,727</b>	<b>\$1,547,096</b>	<b>\$1,585,356</b>	<b>\$6,115,409</b>

### 3 CONSTRUCTION PROGRAM

Table 3-3: Construction to Serve New Members- Code 100

2016-2020 CWP Summary of Code 100

New Members	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>CONSTRUCTION-NEW SERVICES-OH-103</b>						
<b>CONSTRUCTION-NEW SERVICES-UG-103*</b>		\$240,000				
<b>TOTAL NEW SERVICES</b>	<b>586</b>	<b>588</b>	<b>591</b>	<b>594</b>	<b>597</b>	<b>2,370</b>
TOTAL UNDERGROUND SERVICES		240	242	243	244	969
TOTAL OVERHEAD SERVICES		348	349	351	353	1401
<b>AVERAGE COST PER SERVICE</b>	<b>\$4,473</b>	<b>\$4,562</b>	<b>\$4,654</b>	<b>\$4,747</b>	<b>\$4,842</b>	<b>\$4,701</b>
<b>AVERAGE SERVICE LENGTH (FT/SERVICE)</b>	<b>262</b>	<b>264</b>	<b>265</b>	<b>266</b>	<b>267</b>	<b>265</b>
<b>TOTAL NEW LINE FOR SERVICES-UG (MILE)</b>		<b>10.5</b>	<b>10.6</b>	<b>10.7</b>	<b>10.8</b>	<b>42.7</b>
<b>TOTAL NEW LINE FOR SERVICES-OH (MILE)</b>		<b>18.9</b>	<b>19.1</b>	<b>19.3</b>	<b>19.4</b>	<b>76.7</b>
<b>TOTAL NEW LINE FOR SERVICES-FOOTAGE</b>	<b>153,444.9</b>	<b>155,148.0</b>	<b>156,500.9</b>	<b>157,861.6</b>	<b>159,230.1</b>	<b>628,741</b>
<b>TOTAL NEW LINE FOR SERVICES-MILES</b>	<b>29.1</b>	<b>29.4</b>	<b>29.6</b>	<b>29.9</b>	<b>30.2</b>	<b>119.1</b>
<b>TOTAL COST NEW UG LINES-SERVICES</b>		<b>\$1,223,249</b>	<b>\$1,008,031</b>	<b>\$1,033,411</b>	<b>\$1,059,403</b>	<b>\$4,324,093</b>
<b>TOTAL COST NEW OH LINES- SERVICES</b>		<b>\$1,699,421</b>	<b>\$1,742,253</b>	<b>\$1,786,119</b>	<b>\$1,831,042</b>	<b>\$7,058,835</b>
<b>AVERAGE COST- FOOTAGE- SERVICES</b>	<b>\$17.07</b>	<b>\$17.29</b>	<b>\$17.57</b>	<b>\$17.86</b>	<b>\$18.15</b>	<b>\$17.72</b>
<b>TOTAL COST NEW LINES FOR SERVICES</b>	<b>\$2,618,886</b>	<b>\$2,922,670</b>	<b>\$2,750,284</b>	<b>\$2,819,529</b>	<b>\$2,890,445</b>	<b>\$11,382,928</b>

\* Construction costs for a new underground member

Table 3-4: Construction to Serve New Members- Code 601

New Members	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>New Single Phase Transformers</b>						
Number of New Transformers	692	696	700	704	708	2,808
Number of New 1-PH Underground		285	286	288	289	1,148
Number of New 1-PH Overhead		411	414	416	419	1,660
Single Phase Underground Transformer-Cost		\$458,005	\$468,804	\$481,524	\$492,860	\$1,901,194

### 3 CONSTRUCTION PROGRAM

Single Phase Overhead Transformer- Cost		\$660,492	\$678,619	\$695,535	\$714,562	\$2,749,208
Avg Cost/Transformer	\$1,576	\$1,607	\$1,639	\$1,672	\$1,705	\$1,656
<b>New Three Phase Transformers-Pad Mount</b>						
Number of New Transformers	10	10	10	10	10	40
Avg Cost/Transformer	\$8,674	\$8,848	\$9,025	\$9,205	\$9,389	\$9,117
<b>New Meters</b>						
Number of New Meters	20,177	1708	1711	1714	1717	6,850
Number of New Meters- Underground		698	699	701	702	2,800
Number of New Meters- Overhead		1010	1012	1013	1015	4,050
Underground Meter- Cost		\$108,809	\$111,144	\$113,691	\$116,131	\$449,775
Overhead Meter- Cost		\$157,445	\$160,912	\$164,293	\$167,910	\$650,560
Avg Cost/Meter	\$153	\$156	\$159	\$162	\$165	\$161
<b>TOTAL COST NEW TRANSFORMERS-1PH</b>	<b>\$1,090,263</b>	<b>\$1,118,497</b>	<b>\$1,147,423</b>	<b>\$1,177,060</b>	<b>\$1,207,422</b>	<b>\$4,650,402</b>
<b>TOTAL COST NEW TRANSFORMERS-3PH PAD</b>	<b>\$86,743</b>	<b>\$88,478</b>	<b>\$90,248</b>	<b>\$92,053</b>	<b>\$93,894</b>	<b>\$364,672</b>
<b>TOTAL COST NEW METERS</b>	<b>\$3,083,574</b>	<b>\$266,254</b>	<b>\$272,056</b>	<b>\$277,984</b>	<b>\$284,040</b>	<b>\$1,100,335</b>
<b>TOTAL COST NEW TRANSFORMERS &amp; METERS</b>	<b>\$4,260,581</b>	<b>\$1,473,229</b>	<b>\$1,509,727</b>	<b>\$1,547,096</b>	<b>\$1,585,356</b>	<b>\$6,115,409</b>

#### 2. Service Changes to Existing Members-RUS 602

Historical information was reviewed for a 24-month period from 2014-2015 to project service upgrades to existing members for the CWP period. The historical number of services was increased approximately 0.5% per for the 2016-2020 CWP period, based on the 2015 BREC Load Forecast. The historical costs were inflated by 2.0 percent.

Table 3-5: Service Changes to Existing Members- Code 602

	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>Service Upgrades- RUS 602</b>						
Number of Services	92	93	94	95	96	378
Average Cost/Service	\$3,666	\$3,739	\$3,814	\$3,890	\$3,968	\$3,853
<b>Total Service Upgrades- RUS 602</b>	<b>\$337,238</b>	<b>\$347,722</b>	<b>\$358,490</b>	<b>\$369,550</b>	<b>\$380,908</b>	<b>\$1,456,669</b>

### 3 CONSTRUCTION PROGRAM

#### 3. Sectionalizing- RUS 603

Sectionalizing costs were based on the combination of historical work order, specific equipment purchases, and location specific sectionalizing equipment installations. The historical costs were inflated by 2.0 percent annually. The specific projects are totaled using the CWP cost of construction. A detailed description and justification for each recommended improvement can be found in Section 4.

Table 3-6: Sectionalizing Equipment- Code 603

	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>Sectionalizing WO- RUS 603</b>						
Number of Work Orders	13	14	15	16	17	62
Average Total Cost	\$465,656	\$474,969	\$484,468	\$494,157	\$504,041	\$489,409
<b>Total Designated Projects- 603-X</b>	\$0	\$65,250	\$65,250	\$65,250	\$65,250	\$261,000
<b>Total Sectionalizing WO- RUS 603</b>	<b>\$465,656</b>	<b>\$540,219</b>	<b>\$549,718</b>	<b>\$559,407</b>	<b>\$569,291</b>	<b>\$2,218,635</b>

#### 4. Pole Replacements-RUS 606

Historical information was reviewed for a 24-month period from 2014-2015 to project pole replacement costs for the CWP period. The historical costs were inflated by 2.0 percent.

Table 3-7: Pole Replacements- Code 606

	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>Pole Replacements- RUS 606</b>						
Number of Poles	600	603	607	611	615	2,436
Average Cost/Pole	\$2,728	\$2,782	\$2,838	\$2,895	\$2,953	\$2,867
<b>Total Pole Replacements- RUS 606</b>	<b>\$1,636,671</b>	<b>\$1,677,751</b>	<b>\$1,722,658</b>	<b>\$1,768,691</b>	<b>\$1,815,875</b>	<b>\$6,984,975</b>

### 3 CONSTRUCTION PROGRAM

5. Miscellaneous Construction- RUS 608

Historical information was reviewed for a 24-month period from 2014-2015 to project conductor replacement costs for the CWP period. The historical costs were inflated by 2.0 percent.

Table 3-8: Miscellaneous Construction- Code 608

	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>Misc Construction - RUS 608</b>						
Number of Projects	761	765	769	773	777	3,084
Average Total Cost	\$1,078,710	\$1,100,285	\$1,122,290	\$1,144,736	\$1,167,631	\$1,133,736
<b>Total Misc Construction- RUS 608</b>	<b>\$1,078,710</b>	<b>\$1,100,285</b>	<b>\$1,122,290</b>	<b>\$1,144,736</b>	<b>\$1,167,631</b>	<b>\$4,534,942</b>

6. Security Lights- RUS 701

Historical information was reviewed for a 24-month period from 2014-2015 to security light costs for the CWP period. The historical costs were inflated by 2.0 percent.

Table 3-9: Security Lights- Code 701

	2-Year Average	Estimated 48-Month Work Plan Period				
	2014-2015	2016-2017	2017-2018	2018-2019	2019-2020	TOTAL
<b>Security Lights- RUS 701</b>						
Number of Lights	1281	1288	1295	1302	1309	5,194
Average Cost/Light	\$654	\$667	\$681	\$694	\$708	\$688
<b>Total Security Lights- RUS 701</b>	<b>\$838,107</b>	<b>\$859,541</b>	<b>\$881,496</b>	<b>\$903,986</b>	<b>\$927,023</b>	<b>\$3,572,047</b>

7. New Tie Lines-RUS 200

The following tie lines are part of the construction plan. Total tie line construction is estimated at \$20,092.

### 3 CONSTRUCTION PROGRAM

CWP CODE	RUS CAT	DISTRICT	STATION	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
201	200	HENDERSON	64	WEAVERTON	NEW CONSTRUCTION SINGLE PHASE 1/0 ACSR	0.1	\$6,700
202	200	OWENSBORO	40	CENTERTOWN	NEW CONSTRUCTION THREE PHASE 336 ACSR	0.1	\$13,392

#### 8. Line Conversions- RUS 300

As discussed in the Executive Summary, Kenergy's entire distribution system is modeled in WindMil®. For each section of line that had capacity or voltage problems based on the year 2019-2020 projections, alternatives were developed and reviewed by Kenergy. There was an iterative planning process which included management, engineering, and this consultant in the decisions of selected improvements. Some feeders with voltage drop problems were addressed by means of voltage regulators and/or capacitors. In areas where feeder regulation already existed, or where design criteria dictated, the lines were reconducted or multi-phased, as required. Where conductor capacity was insufficient, the conductor was replaced. Phase balancing to relieve voltage design criteria violations was evaluated and documented external to the CWP. A detailed description and justification for each recommended improvement can be found in Section 4.

Table 3-10: Line Conversion and Changes- RUS 300

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
301	LYON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
302	LYON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.1	\$130,680
303	LYON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
304	BEDA	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.3	\$273,240
305	CENTERTOWN	CONVERSION UNDERGROUND	0.4	\$90,000
306	EAST OWENSBORO	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	0.75	\$168,750
307	EAST OWENSBORO	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	0.2	\$23,760
310	PHILPOT	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.4	\$33,480
312	SOUTH OWENSBORO	UNDERGROUND IMPROVEMENT	0.1	\$70,000
313	ADAMS LANE	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850

### 3 CONSTRUCTION PROGRAM

314	GENEVA	VOLTAGE CONVERSION TO 25KV- UPGRADE TRANSFORMER	1	\$45,000
360*	GUFFIE	CARRYOVER. CONVERSION THREE PHASE CU 1/0 TO THREE PHASE 336 ACSR	1.43	\$169,884
361*	HANSON	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.2	\$261,360
364*	MASONVILLE	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.7	\$201,960
370*	PROVIDENCE	CARRYOVER. CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.9	\$75,330
371	ALL	SYSTEM WIDE- UNDERGROUND CABLE REPLACEMENT	8	\$1,600,000
372	ALL	SYSTEM WIDE- OVERHEAD CONDUCTOR REPLACEMENT	100	\$5,400,000
374*	SOUTH DERMONT	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.2	\$142,560
383	HANSON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
384	MORGANFIELD	VOLTAGE CONVERSION TO 25KV	13.5	\$398,860
385	MORGANFIELD	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	2.1	\$175,770
386	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
387	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
388	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.8	\$66,960
390	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
391	ONTON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.5	\$297,000
392	WEAVERTON	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	1.1	\$247,500
393	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 336 ACSR	2	\$217,620
394	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	1.4	\$117,180
395	WEAVERTON	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,920
396	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
397	ZION	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,110
398	CALDWELL SPRINGS	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.1	\$283,500
399	LYON	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.4	\$34,560

9. New Substations-RUS 400

No new substations are recommended in this plan.

10. Increased Substation Capacity-RUS 500

Based on the projected substation loading analysis, provided in the Exhibit section of this report, there are no substation transformers or station regulators that need to be upgraded during this work plan. However, additional capacity is necessary in support of other system improvement projects or to address backfeed capacity issues. The Horse Fork station will require the construction of an additional transformer bay in addition to repairing damage to the existing



### 3 CONSTRUCTION PROGRAM

transformer bay 1. Horse Fork station provides vital backfeed capacity to a number of adjacent stations; in addition the station load is becoming more difficult to backfeed from other stations necessitating station transformer redundancy. Total station changes construction is estimated at \$1,175,000.

Table 3-11: Substation Changes- RUS 500

CWP CODE	RUS CAT	DISTRICT	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
504	500	HENDERSON	WEAVERTON	STATION UPGRADE FOR NEW CIRCUIT	1	\$200,000
505	500	OWENSBORO	EAST OWENSBORO	STATION UPGRADE FOR NEW CIRCUIT	1	\$150,000
506	500	OWENSBORO	HORSE FORK	REBUILD STATION TRANSFORMER BAY 1 \$1,100,000	1	\$0
507	500	OWENSBORO	HORSE FORK	STATION UPGRADE TO DUAL STATION TRANSFORMER CAPACITY	1	\$825,000

Substation Changes- Code 500 Details:

- Weaverton Circuit Upgrade. The Weaverton Station area has a number of voltage and conductor capacity issues and to address these issues, a new circuit will be constructed to divide the existing distribution load. In order to support the new circuit, an existing open circuit bay at the station will be made-ready to serve the new distribution lines. The additional circuit bay will require the necessary foundations, switches, and station feeder protective equipment.
- East Owensboro Circuit Upgrade. The East Owensboro Station area will serve a new large commercial customer load, Gateway Commons, which is projected to be a 1 MW load. The addition of this large customer will create conductor loading, voltage, and contingency issues and to address these issues, a new circuit will be constructed to divide the existing distribution load. In order to support the new circuit, an existing open circuit bay at the station will be made-ready to serve the new distribution lines. The additional

### 3 CONSTRUCTION PROGRAM

---

circuit bay will require the necessary foundations, switches, and station feeder protective equipment.

- Horse Fork Station. The Horse Fork Station was already planned in this CWP to be converted into a dual transformer station due to the loading and lack of spare capacity in contingency situations due to the station's existing single transformer. However, in late 2015, a catastrophic failure occurred within the Horse Fork Station (cause unknown) which completely destroyed the station's single bay. Therefore, the station will be rebuilt as a two transformer bay station. At this time, the rebuilding cost of station bay 1 (\$1,100,000) will be reimbursed by the Cooperative's insurance and as such is not listed as a Code 500 cost. The construction of station bay 2 will be completed in coordination with the bay 1 rebuild and will require the purchase and installation of a new station transformer, 2-circuit low side structure, high side protection, grounding grid, oil containment, and foundations. The estimated cost for the station bay 2 project is \$825,000.

#### 11. Sectionalizing and Arc Flash Hazard Mitigation- RUS 603

System protection through fault interrupting and sectionalizing is critical for human life and property protection, and improved reliability. In addition, properly selected and sized devices will reduce the number of consumers interrupted during a power outage and reduce the outage time. The 2012 NESC now requires Arc Flash Hazard assessment, and an important component of assessment and hazard mitigation is the speed of fault and arc interruption. This is an important consideration in system sectionalizing and device application. During the evaluation of the Kenergy distribution system, specific protective devices were noted for upgrade, removal, installation, or to have control setting changes. A detailed description and justification for each recommended improvement can be found in Section 4. Total Sectionalizing construction, Code 603, is estimated at \$2,218,635 with \$261,000 in designated projects shown in Table 3-12.

### 3 CONSTRUCTION PROGRAM

Table 3-12: Sectionalizing Specific Locations- RUS 603

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
603-2	SULLIVAN	UPGRADE RECLOSER. 35A.	1	\$4,500
603-3	SULLIVAN	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-4	DIXON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-5	DIXON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-6	SEBREE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-7	ONTON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-8	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-9	ONTON	RECLOSER CHANGE. RELOCATE.		\$0
603-10	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-11	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-12	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-13	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-14	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-15	HANSON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-16	HANSON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-17	HANSON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-18	SOUTH HANSON2	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-19	SOUTH HANSON2	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-20	SOUTH HANSON1	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-21	SOUTH HANSON1	INSTALL RECLOSER. 50A.	1	\$4,500
603-22	GENEVA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-23	WEAVERTON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-24	ADAMS LANE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-25	RACE CREEK	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-26	ZION	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-27	ZION	UPGRADE RECLOSER. 50A.	1	\$4,500
603-28	NIAGARA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-29	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-30	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS. INSTALL RECLOSERS. 50A.	2	\$9,000
603-31	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-32	NIAGARA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-33	GUFFIE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-34	GUFFIE	UPGRADE RECLOSER. 70A.	1	\$4,500
603-35	UTICA	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-36	UTICA	UPGRADE RECLOSER. 50A.	1	\$4,500

### 3 CONSTRUCTION PROGRAM

603-37	UTICA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-38	UTICA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-39	PLEASANT RIDGE	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-40	WHITESVILLE	INSTALL RECLOSERS. 70A.	6	\$27,000
603-41	SACRAMENTO	UPGRADE RECLOSER. 50A.	1	\$4,500
603-42	NUCKOLS	UPGRADE RECLOSER. 70A.	1	\$4,500
603-43	CENTERTOWN	UPGRADE RECLOSER. 50A.	1	\$4,500
603-44	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-45	BEDA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-46	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-47	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-48	BEDA	UPGRADE RECLOSER. 35A.	1	\$4,500
603-49	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-50	BEDA	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-51	WEST OWENSBORO	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-52	MASONVILLE	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-53	EAST OWENSBORO	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-54	DERMONT	UPGRADE RECLOSER. 50A.	1	\$4,500
603-55	PHILPOT	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-56	PHILPOT	UPGRADE RECLOSER. 50A.	1	\$4,500
603-57	HAWESVILLE	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-58	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.		\$0

#### 12. Distribution Line Voltage Regulators- RUS 604

Voltage regulators are utilized throughout the Kenergy system to correct potential low voltages. Additional voltage regulators have been recommended as a short-term least cost alternative to extensive multi-phasing or line reconductoring improvements. Additionally, some existing voltage regulators are recommended for replacement because they will become overloaded during the CWP period. A detailed description and justification for each recommended improvement can be found in Section 4. Total Voltage Regulator construction, Code 604, is estimated at \$162,000 in designated projects shown in Table 3-13.

### 3 CONSTRUCTION PROGRAM

Table 3-13: Line Regulators- RUS 604

CWP CODE	RUS CAT	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
604-19	604	LYON	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000
604-21	604	HANSON	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
604-22	604	WEAVERTON	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
604-23	604	ZION	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000

#### 13. Distribution Line Capacitors-RUS 605

Capacitors have been recommended as needed throughout the Kenergy system to address voltage issues along heavily loaded feeders and to address station power factor issues. A detailed description and justification for each recommended improvement can be found in Section 4. Total Capacitor construction, Code 605, is estimated at \$45,000 in designated projects shown in Table 3-14.

Table 3-14: Distribution Capacitors- RUS 605

CWP CODE	RUS CAT	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
605-2	605	MARION	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-3	605	MARION	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-4	605	MORGANFIELD	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-5	605	DIXON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-6	605	LITTLE DIXIE	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-7	605	ONTON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-8	605	HANSON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-9	605	GUFFIE	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-10	605	NUCKOLS	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000

**TOTAL RUS CODE 605 \$45,000**

### 3 CONSTRUCTION PROGRAM

---

#### 14. System Wide- RUS 371 & RUS 372

- RUS CODE 371. Replace approximately 2.0 miles/year of underground cable on the Kenergy system. Based on existing records, Kenergy is beginning to experience an increase in failures on vintage XLP, unjacketed underground cable with concentric neutrals. Underground sections with three failures are replaced as indicated in the Design Criteria: Item 5. Kenergy is projecting eight miles of underground cable should be replaced over the 4-year CWP period. Since the last CWP period, Kenergy's experience has been that similar project construction is approximately \$200,000 per mile.
- RUS CODE 372. Reconductor approximately 25 miles per year of single-phase and three phase copper and #4 ACSR (or smaller aluminum conductors) with new overhead ACSR sized by load requirements, to replace aging conductor and improve reliability. It is estimated that 33% of the total conductor replacement is three phase, and the remaining is single phase based on the previous CWP. Since the last CWP period, Kenergy's experience has been that similar project construction is approximately \$54,000 per mile, which a blended cost incorporating the single phase and three phase replacement costs.

#### C. 2016-2020 CWP DETAILED COST ESTIMATE SUMMARY

Shown below is a summary of the 2016-2020 CWP showing all RUS category codes.

### 3 CONSTRUCTION PROGRAM

Kenergy Cost Estimate Summary 2016-2020 Construction Work Plan						
RUS CODE	Description	Quantity	Projected Cost			
			2016-2018	2018-2020	Total	
100	<u>Consumer Additions</u>					
101	Underground	969	42.72 Mi.	\$2,231,280	\$2,092,813	\$4,324,093
102	Overhead	1401	76.75 Mi.	\$3,441,673	\$3,617,161	\$7,058,835
	total	2,370	119.46			
	<b>Subtotal - New Line- Code 100</b>			<b>\$5,672,953</b>	<b>\$5,709,974</b>	<b>\$11,382,928</b>
200	<u>New Tie Lines</u>		0.2 Mi.	\$6,700	\$13,392	\$20,092
300	<u>Line Changes</u>		152.4 Mi.	\$5,406,240	\$5,446,484	\$10,852,724
400	<u>New Substations</u>					
500	<u>Increased Substation Capacity</u>			\$350,000	\$825,000	\$1,175,000
601	<u>Distribution Equipment</u>					
	Transformers- Customer Additions					
	Underground	1,188	Qty	\$1,105,535	\$1,160,331	\$2,265,866
	Overhead	1,660	Qty	\$1,339,110	\$1,410,097	\$2,749,208
	Total	2,848	Qty			
	Transformers- Voltage Conversion					
	Underground	4	Qty	\$10,000		\$10,000
	Overhead	75	Qty	\$135,000		\$135,000
	<b>Subtotal- Transformers</b>					
	Underground	1,192	Qty	\$1,115,535	\$1,160,331	\$2,275,866
	Overhead	1,735	Qty	\$1,474,110	\$1,410,097	\$2,884,208
	Total	2,927	Qty	\$2,589,646	\$2,570,428	\$5,160,074
	<b>Subtotal Meters</b>					
	Underground	2,800	Qty	\$219,953	\$229,822	\$449,775
	Overhead	4,050	Qty	\$318,358	\$332,202	\$650,560
	Total	6,850	Qty	\$538,311	\$562,024	\$1,100,335
	<b>Subtotal - Distribution Equipment-601</b>			<b>\$3,127,956</b>	<b>\$3,132,452</b>	<b>\$6,260,409</b>
602	<u>Increased Service Capacity</u>		378 Qty	\$706,211	\$750,458	\$1,456,669
603	<u>Sectionalizing</u>			\$1,089,937	\$1,128,698	\$2,218,635
604	<u>Voltage Regulators</u>			\$162,000		\$162,000
605	<u>Capacitors</u>		2700 kVAR	\$45,000		\$45,000
606	<u>Pole Replacement</u>			\$3,400,410	\$3,584,566	\$6,984,975
607	<u>Autotransformers-Work Order</u>					
608	<u>Misc Construction</u>			\$2,222,575	\$2,312,367	\$4,534,942
	<b>Subtotal - All 600 Codes</b>			<b>\$10,754,089</b>	<b>\$10,908,541</b>	<b>\$21,662,630</b>
701	<u>Security Lights</u>		5,194 Qty	\$1,741,037	\$1,831,010	\$3,572,047
	<b>Subtotal - Other Distribution- All 700 Codes</b>			<b>\$1,741,037</b>	<b>\$1,831,010</b>	<b>\$3,572,047</b>
				2016-2018	2018-2020	
	<b>SUBTOTAL 2016-2020</b>			<b>\$23,931,020</b>	<b>\$24,734,401</b>	
	<b>TOTAL 2016-2020</b>					<b>\$48,665,421</b>

**DESCRIPTION AND  
JUSTIFICATION**



## 4 DESCRIPTION AND JUSTIFICATION

### A. Summary of System Improvements

The following pages provide a description and justification for the proposed construction work plan projects. The improvements proposed are those necessary to maintain adequate voltage and capacity through the end of the CWP period. These recommended projects are associated with the rehabilitation of the existing system and the integration of the new consumers into the Kenergy system, including enhancements to meet the Kenergy reliability goals. Alternate projects were considered and included additional line regulation, switching load to other electric lines or stations, and power factor correction. Phase balancing to relieve line voltage issues was evaluated and documented externally to the projects listed in the CWP report. Line and equipment costs used in the construction cost estimates are given in the report's Exhibit section. Costs of carry-over projects were updated based on this CWP's cost factors. Projects from the 2013-2017 Construction Work Plan that are being carried forward have been noted with an asterisk using the code number from the previous Construction Work Plan. The following listings Table 4-1 and 4-2 detail the specific construction projects recommended for the 2016-2020 CWP:

**Table 4-1: 2016-2020 Construction Work Plan- System Improvements By Project Code**

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
201	WEAVERTON	NEW CONSTRUCTION SINGLE PHASE 1/0 ACSR	0.1	\$6,700
202	CENTERTOWN	NEW CONSTRUCTION THREE PHASE 336 ACSR	0.1	\$13,392
301	LYON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
302	LYON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.1	\$130,680
303	LYON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
304	BEDA	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.3	\$273,240
305	CENTERTOWN	CONVERSION UNDERGROUND	0.4	\$90,000
306	EAST OWENSBORO	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	0.75	\$168,750
307	EAST OWENSBORO	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	0.2	\$23,760
310	PHILPOT	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.4	\$33,480
312	SOUTH OWENSBORO	UNDERGROUND IMPROVEMENT	0.1	\$70,000
313	ADAMS LANE	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
314	GENEVA	VOLTAGE CONVERSION TO 25KV- UPGRADE TRANSFORMER	1	\$45,000
360*	GUFFIE	CARRYOVER. CONVERSION THREE PHASE CU 1/0 TO THREE PHASE 336 ACSR	1.43	\$169,884
361*	HANSON	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.2	\$261,360

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
364*	MASONVILLE	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.7	\$201,960
370*	PROVIDENCE	CARRYOVER. CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.9	\$75,330
371	ALL	SYSTEM WIDE- UNDERGROUND CABLE REPLACEMENT	8	\$1,600,000
372	ALL	SYSTEM WIDE- OVERHEAD CONDUCTOR REPLACEMENT	100	\$5,400,000
374*	SOUTH DERMONT	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.2	\$142,560
383	HANSON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
384	MORGANFIELD	VOLTAGE CONVERSION TO 25KV	13.5	\$398,860
385	MORGANFIELD	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	2.1	\$175,770
386	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
387	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
388	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.8	\$66,960
390	NIAGARA	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
391	ONTON	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.5	\$297,000
392	WEAVERTON	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	1.1	\$247,500
393	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 336 ACSR	2	\$217,620
394	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	1.4	\$117,180
395	WEAVERTON	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,920
396	WEAVERTON	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
397	ZION	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,110
398	CALDWELL SPRINGS	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.1	\$283,500
399	LYON	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.4	\$34,560
504	WEAVERTON	STATION UPGRADE FOR NEW CIRCUIT	1	\$200,000
505	EAST OWENSBORO	STATION UPGRADE FOR NEW CIRCUIT	1	\$150,000
506	HORSE FORK	REBUILD BAY 1	1	\$0
507	HORSE FORK	STATION UPGRADE TO DUAL STATION TRANSFORMER CAPACITY	1	\$825,000
603-2	SULLIVAN	UPGRADE RECLOSER. 35A.	1	\$4,500
603-3	SULLIVAN	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-4	DIXON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-5	DIXON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-6	SEBREE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-7	ONTON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-8	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-9	ONTON	RECLOSER CHANGE. RELOCATE.		\$0
603-10	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-11	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-12	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-13	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
603-14	ONTON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-15	HANSON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-16	HANSON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-17	HANSON	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-18	SOUTH HANSON2	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-19	SOUTH HANSON2	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-20	SOUTH HANSON1	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-21	SOUTH HANSON1	INSTALL RECLOSER. 50A.	1	\$4,500
603-22	GENEVA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-23	WEAVERTON	UPGRADE RECLOSER. 50A.	1	\$4,500
603-24	ADAMS LANE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-25	RACE CREEK	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-26	ZION	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-27	ZION	UPGRADE RECLOSER. 50A.	1	\$4,500
603-28	NIAGARA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-29	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-30	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS. INSTALL RECLOSERS. 50A.	2	\$9,000
603-31	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-32	NIAGARA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-33	GUFFIE	UPGRADE RECLOSER. 50A.	1	\$4,500
603-34	GUFFIE	UPGRADE RECLOSER. 70A.	1	\$4,500
603-35	UTICA	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-36	UTICA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-37	UTICA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-38	UTICA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-39	PLEASANT RIDGE	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-40	WHITESVILLE	INSTALL RECLOSERS. 70A.	6	\$27,000
603-41	SACRAMENTO	UPGRADE RECLOSER. 50A.	1	\$4,500
603-42	NUCKOLS	UPGRADE RECLOSER. 70A.	1	\$4,500
603-43	CENTERTOWN	UPGRADE RECLOSER. 50A.	1	\$4,500
603-44	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-45	BEDA	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-46	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-47	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-48	BEDA	UPGRADE RECLOSER. 35A.	1	\$4,500
603-49	BEDA	UPGRADE RECLOSER. 50A.	1	\$4,500
603-50	BEDA	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
603-51	WEST OWENSBORO	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-52	MASONVILLE	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
603-53	EAST OWENSBORO	LOAD SHIFT. CHANGE OPEN POINTS.		\$0

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
603-54	DERMONT	UPGRADE RECLOSER. 50A.	1	\$4,500
603-55	PHILPOT	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-56	PHILPOT	UPGRADE RECLOSER. 50A.	1	\$4,500
603-57	HAWESVILLE	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
603-58	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
604-19	LYON	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000
604-21	HANSON	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
604-22	WEAVERTON	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
604-23	ZION	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000
605-2	MARION	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-3	MARION	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-4	MORGANFIELD	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-5	DIXON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-6	LITTLE DIXIE	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-7	ONTON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-8	HANSON	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-9	GUFFIE	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
605-10	NUCKOLS	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000

\* Carry over projects from previous work plan.

**Table 4-2: 2016-2020 Construction Work Plan- System Improvements By Station**

STATION NAME	CWP CODE	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
ADAMS LANE	313	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
ADAMS LANE	603-24	UPGRADE RECLOSER. 50A.	1	\$4,500
BEDA	304	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.3	\$273,240
BEDA	603-44	UPGRADE RECLOSER. 50A.	1	\$4,500
BEDA	603-45	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
BEDA	603-46	UPGRADE RECLOSER. 50A.	1	\$4,500
BEDA	603-47	UPGRADE RECLOSER. 50A.	1	\$4,500
BEDA	603-48	UPGRADE RECLOSER. 35A.	1	\$4,500
BEDA	603-49	UPGRADE RECLOSER. 50A.	1	\$4,500
BEDA	603-50	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
CALDWELL SPRINGS	398	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.1	\$283,500
CENTERTOWN	202	NEW CONSTRUCTION THREE PHASE 336 ACSR	0.1	\$13,392
CENTERTOWN	305	CONVERSION UNDERGROUND	0.4	\$90,000
CENTERTOWN	603-43	UPGRADE RECLOSER. 50A.	1	\$4,500
DERMONT	603-54	UPGRADE RECLOSER. 50A.	1	\$4,500
DIXON	603-4	UPGRADE RECLOSER. 50A.	1	\$4,500

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
DIXON	603-5	UPGRADE RECLOSER. 50A.	1	\$4,500
DIXON	605-5	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
EAST OWENSBORO	306	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	0.75	\$168,750
EAST OWENSBORO	307	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	0.2	\$23,760
EAST OWENSBORO	505	STATION UPGRADE FOR NEW CIRCUIT	1	\$150,000
EAST OWENSBORO	603-53	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
GENEVA	314	VOLTAGE CONVERSION TO 25KV- UPGRADE TRANSFORMER	1	\$45,000
GENEVA	603-22	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
GUFFIE	360*	CARRYOVER. CONVERSION THREE PHASE CU 1/0 TO THREE PHASE 336 ACSR	1.43	\$169,884
GUFFIE	603-33	UPGRADE RECLOSER. 50A.	1	\$4,500
GUFFIE	603-34	UPGRADE RECLOSER. 70A.	1	\$4,500
GUFFIE	605-9	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
HANSON	361*	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.2	\$261,360
HANSON	383	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
HANSON	603-15	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
HANSON	603-16	UPGRADE RECLOSER. 50A.	1	\$4,500
HANSON	603-17	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
HANSON	604-21	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
HANSON	605-8	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
HAWESVILLE	603-57	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
HORSE FORK	506	REBUILD BAY 1	1	\$0
HORSE FORK	507	STATION UPGRADE TO DUAL STATION TRANSFORMER CAPACITY	1	\$825,000
LITTLE DIXIE	605-6	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
LYON	301	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
LYON	302	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.1	\$130,680
LYON	303	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1	\$118,800
LYON	399	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.4	\$34,560
LYON	604-19	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000
MARION	605-2	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
MARION	605-3	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
MASONVILLE	364*	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.7	\$201,960
MASONVILLE	603-52	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
MORGANFIELD	384	VOLTAGE CONVERSION TO 25KV	13.5	\$398,860
MORGANFIELD	385	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	2.1	\$175,770
MORGANFIELD	605-4	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
NIAGARA	386	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850
NIAGARA	387	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.5	\$41,850

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
NIAGARA	388	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.8	\$66,960
NIAGARA	390	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
NIAGARA	603-28	UPGRADE RECLOSER. 50A.	1	\$4,500
NIAGARA	603-29	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
NIAGARA	603-30	LOAD SHIFT. CHANGE OPEN POINTS. INSTALL RECLOSERS. 50A.	2	\$9,000
NIAGARA	603-31	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
NIAGARA	603-32	UPGRADE RECLOSER. 50A.	1	\$4,500
NUCKOLS	603-42	UPGRADE RECLOSER. 70A.	1	\$4,500
NUCKOLS	605-10	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
ONTON	391	CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	2.5	\$297,000
ONTON	603-10	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
ONTON	603-11	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
ONTON	603-12	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
ONTON	603-13	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
ONTON	603-14	INSTALL ELECTRONIC RECLOSER.	1	\$18,000
ONTON	603-58	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
ONTON	603-7	UPGRADE RECLOSER. 50A.	1	\$4,500
ONTON	603-8	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
ONTON	603-9	RECLOSER CHANGE. RELOCATE.		\$0
ONTON	605-7	INSTALL THREE PHASE 300 KVAR CAPACITOR BANK	1	\$5,000
PHILPOT	310	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.4	\$33,480
PHILPOT	603-55	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
PHILPOT	603-56	UPGRADE RECLOSER. 50A.	1	\$4,500
PLEASANT RIDGE	603-39	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
PROVIDENCE	370*	CARRYOVER. CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.9	\$75,330
RACE CREEK	603-25	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
SACRAMENTO	603-41	UPGRADE RECLOSER. 50A.	1	\$4,500
SEBREE	603-6	UPGRADE RECLOSER. 50A.	1	\$4,500
SOUTH DERMONT	374*	CARRYOVER. CONVERSION THREE PHASE TO THREE PHASE 336 ACSR	1.2	\$142,560
SOUTH HANSON1	603-20	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
SOUTH HANSON1	603-21	INSTALL RECLOSER. 50A.	1	\$4,500
SOUTH HANSON2	603-18	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
SOUTH HANSON2	603-19	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
SOUTH OWENSBORO	312	UNDERGROUND IMPROVEMENT	0.1	\$70,000
SULLIVAN	603-2	UPGRADE RECLOSER. 35A.	1	\$4,500
SULLIVAN	603-3	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
UTICA	603-35	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	QTY	COST ESTIMATE
UTICA	603-36	UPGRADE RECLOSER. 50A.	1	\$4,500
UTICA	603-37	UPGRADE RECLOSER. 50A.	1	\$4,500
UTICA	603-38	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
WEAVERTON	201	NEW CONSTRUCTION SINGLE PHASE 1/0 ACSR	0.1	\$6,700
WEAVERTON	392	CONVERSION THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSR	1.1	\$247,500
WEAVERTON	393	CONVERSION SINGLE PHASE TO THREE PHASE 336 ACSR	2	\$217,620
WEAVERTON	394	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	1.4	\$117,180
WEAVERTON	395	CONVERSION TWO PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,920
WEAVERTON	396	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.1	\$8,370
WEAVERTON	504	STATION UPGRADE FOR NEW CIRCUIT	1	\$200,000
WEAVERTON	603-23	UPGRADE RECLOSER. 50A.	1	\$4,500
WEAVERTON	604-22	INSTALL REGULATORS- THREE PHASE- 100A	3	\$36,000
WEST OWENSBORO	603-51	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.		\$0
WHITESVILLE	603-40	INSTALL RECLOSERS. 70A.	6	\$27,000
ZION	397	CONVERSION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.3	\$25,110
ZION	603-26	LOAD SHIFT. CHANGE OPEN POINTS.		\$0
ZION	603-27	UPGRADE RECLOSER. 50A.	1	\$4,500
ZION	604-23	INSTALL REGULATORS- THREE PHASE- 150A	3	\$45,000

### **B. Project Descriptions and Justifications- New Customers, Conversions and Line Changes**

The following pages provide a description and justification for the proposed construction work plan projects specifically the Code 100 New Customers, Code 200 Tie Lines, and Code 300 Line Conversions.

## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

<b>SUBSTATION AREA:</b>	EAST OWENSBORO
<b>LOCATION</b>	PLEASANT VALLEY RD. @ HAYDEN RD.
<b>740C CODE</b>	103
<b>ESTIMATED COST:</b>	\$240,000
<b>COMPLETION YEAR</b>	2016
<b>DESCRIPTION:</b>	CONSTRUCT 0.8 MILES OF THREE PHASE 500 MCM UNDERGROUND. OH13110001 TO OH715266. CONSTRUCTION TO SERVE NEW CUSTOMERS. GATEWAY COMMONS.

### ASSOCIATED PROJECTS:

### ALTERNATES:





## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON  
**LOCATION** SUTTON DR. @ WILSON DR.

**740C CODE** 201


**ESTIMATED COST:** \$6,700

**COMPLETION YEAR** 2017

**DESCRIPTION:** CONSTRUCT NEW 1PH, 1/0 ACSR TIE LINE FROM END OF LINE CONVERSION PROJECT AT SECTION # OH332203 TO EXISTING LINE # OH332214. CONNECT TIE LINE TO PHASE "C".

**ASSOCIATED PROJECTS:** OPEN SECTION # OH332154 AT END OF # OH4095350 AND CLOSE # OH332214 TO END OF NEW TIE LINE ON PHASE "C".

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** CENTERTOWN  
**LOCATION** CENTERTOWN SUB  
**740C CODE** 202  
**ESTIMATED COST:** \$13,392  
**COMPLETION YEAR** 2019

**DESCRIPTION:** .1 MILE 336 ACSR THREE PHASE TIE LINE- CIRCUIT 1 TO CIRCUIT 3. INSTALL GOAB SWITCHES ON BOTH CIRCUITS AND NEW TIE LINE. NEW LINE TO BE USED FOR STATION CIRCUIT INNER-TIE.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** REBUILD STATION LOWSIDE BUS TO IMPROVE CIRCUIT TIE AND TRANSFER CAPACITY



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** LYON  
**LOCATION:** KY-810 @ Chestnut Oak Rd.  
**740C CODE:** 301  
**ESTIMATED COST:** \$41,850  
**COMPLETION YEAR:** 2018

**DESCRIPTION:** CONVERT 0.5 MILES OF SINGLE PHASE 2 ACSR TO THREE PHASE 1/0 ACSR. OH307763 TO OH306612. LOW VOLTAGE AT END OF LINE. DIFFICULT TO PHASE BALANCE.

**ASSOCIATED PROJECTS:** CWP 399. REMOVE SINGLE PHASE OCR AND INSTALL THREE 35 A OCRS. PUT THREE MAIN TAPS ON DIFFERENT PHASES.

**ALTERNATES:** NONE.




## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

<b>SUBSTATION AREA:</b>	LYON
<b>LOCATION</b>	LYON SUBSTATION TO HAYDEN RD.
<b>740C CODE</b>	302
<b>ESTIMATED COST:</b>	\$130,680
<b>COMPLETION YEAR</b>	2018
<b>DESCRIPTION:</b>	CONVERT 1.1 MILES OF 1/0 ACSR THREE PHASE TO THREE PHASE 336 ACSR. OH306654 TO OH306401. SINGLE LOSS CONTINGENCY PROJECT TO ADDRESS BACKFEED ISSUES BETWEEN LYON AND CALDWELL SPRINGS STATIONS.

### ASSOCIATED PROJECTS:

**ALTERNATES:** NONE.



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** LYON

**LOCATION** KY-93 @ POPLAR CREEK RD.

**740C CODE** 303


**ESTIMATED COST:** \$118,800

**COMPLETION YEAR** 2017

**DESCRIPTION:** CONVERT 1 MILES OF 2 ACSR THREE PHASE TO THREE PHASE 336 ACSR. OH306351 TO OH307238. SINGLE LOSS CONTINGENCY PROJECT TO ADDRESS BACKFEED ISSUES BETWEEN LYON AND CALDWELL SPRINGS STATIONS.

**ASSOCIATED PROJECTS:** CWP 604-19

**ALTERNATES:** NONE.



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** BEDA

**LOCATION** JOHNSON SCHOOL RD

**740C CODE** 304


**ESTIMATED COST:** \$273,240

**COMPLETION YEAR** 2018

**DESCRIPTION:** 2.3 MILES THREE PHASE 4A TO 336 ACSR THREE PHASE. OH701292 TO OH702219. SINGLE LOSS CONTINGENCY UPGRADE TO ADDRESS VOLTAGE ISSUES BACKFEEDING CENTERTOWN LOAD.

**ASSOCIATED PROJECTS:** INSTALL THREE PHASE RECLOSER.

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** CENTERTOWN  
**LOCATION** N MAIN ST AND OLD HARTFORD RD  
**740C CODE** 305  
**ESTIMATED COST:** \$90,000  
**COMPLETION YEAR** 2016  
**DESCRIPTION:** .4 MILE THREE PHASE 2 AL UG TO 4/0 AL UG. UG703785. OLDER UNDERGROUND CABLE PROVIDING BACKFEED CAPABILITY TO COMMERCIAL CUSTOMERS.  
**ASSOCIATED PROJECTS:** NONE  
**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** EAST OWENSBORO

**LOCATION** HAYDEN RD

**740C CODE** 306


**ESTIMATED COST:** \$168,750

**COMPLETION YEAR** 2018

**DESCRIPTION:** .75 MILE THREE PHASE 336 ACSR TO DUAL CIRCUIT 336 ACSR. EAST OWENSBORO STATION TO OH1873888833. CIRCUIT LOADING AND CONTINGENCY FOR NEW GATEWAY COMMONS LOAD.

**ASSOCIATED PROJECTS:** CWP 103

**ALTERNATES:** NONE





## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** EAST OWENSBORO

**LOCATION** LEITCHFIELD ROAD

**740C CODE** 307


**ESTIMATED COST:** \$23,760

**COMPLETION YEAR** 2018

**DESCRIPTION:** 0.2 MILES OF THREE PHASE 6 ACSR TO THREE PHASE 336 ACSR. OH715266 TO OH715263. CONTINUATION OF THE CWP 103 UNDERGROUND EXTENSION TO TIE INTO EXISTING OVERHEAD THREE PHASE LINES FOR FUTURE CONTINGENCY AND TO ALLEVIATE LINE LOADING.

**ASSOCIATED PROJECTS:** CWP 306

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** PHILPOT

**LOCATION** KNOTTSVILLE MT ZION RD

**740C CODE** 310

**ESTIMATED COST:** \$33,480

**COMPLETION YEAR** 2018

**DESCRIPTION:** CONVERT 0.4 MILES OF SINGLE PHASE TO THREE PHASE 1/0 ACSR. TAP WITH 41A. OH726313 TO OH724526. ADDRESSES LOAD BALANCE ISSUE ON CIRCUIT AND LOW VOLTAGE AT REGULATOR.

**ASSOCIATED PROJECTS:** INSTALL THREE 35A OCRS.

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** SOUTH OWENSBORO

**LOCATION** MLK LOOP

**740C CODE** 312


**ESTIMATED COST:** \$70,000

**COMPLETION YEAR** 2016

**DESCRIPTION:** REWORK URD SWITCHGEAR AT UG1723311857 & UG1363250682. CURRENT EQUIPMENT IS LOCATED IN AN AREA WITH RECENT FLOODING AND IS LIVE FRONT.

### ASSOCIATED PROJECTS:

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ADAMS LANE  
**LOCATION** KY-812 AT AIRLINE RD  
**740C CODE** 313  
**ESTIMATED COST:** \$41,850  
**COMPLETION YEAR** 2020  
**DESCRIPTION:** CONVERT 0.5 MILES OF SINGLE PHASE 2 ACSR TO THREE PHASE 1/0 ACSR. OH-1191869708 TO OH335948. TAP HAS OVER 40A.

**ASSOCIATED PROJECTS:** INSTALL 50A RECLOSERS ON ALL PHASES.

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** GENEVA

**LOCATION:** GENEVA SUB CIRCUIT 3

**740C CODE:** 314


**ESTIMATED COST:** \$45,000

**COMPLETION YEAR:** 2016

**DESCRIPTION:** UPGRADE STEP UP TRANSFORMER FROM 1000KVA TO 1667KVA. TRANSFORMER LOADED AT 113% DURING WINTER PEAK.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** INSTALL 1000KVA UNITS DOWNLINE FROM CURRENT LOCATION TO OH331142. COMPLETE VOLTAGE CONVERSION FROM OH-843759569 TO OH331142.



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** GUFFIE  
**LOCATION** GUFFIE SUB TO HWY 815  
**740C CODE** 360\*  
**ESTIMATED COST:** \$169,884  
**COMPLETION YEAR** 2020

**DESCRIPTION:** CARRY OVER PROJECT. CONVERT 1.43 MILES OF THREE PHASE 1/0 CU AND 3/0 ACSR TO THREE PHASE 336 ACSR ON SECTIONS OH500790 TO OH529147. THE PROJECT IS RECOMMENDED TO IMPROVE LOW VOLTAGE BELOW 117V AT MULTIPLE END POINTS ALONG CIRCUIT 1. CIRCUIT CONDUCTOR LOADING OF 1/0 SECTIONS WILL ALSO BE REDUCED TO ACCEPTABLE LEVELS.

**ASSOCIATED PROJECTS:** CWP 605-9 CAPACITOR

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** HANSON  
**LOCATION** BROWN RD. @ KY-862  
**740C CODE** 361\*  
**ESTIMATED COST:** \$261,360  
**COMPLETION YEAR** 2019

**DESCRIPTION:** CARRY OVER PROJECT. CONVERT 2.2 MILES OF THREE PHASE 1/0 ACSR TO 336 ACSR. OH100419 TO OH102277. LOW VOLTAGE AT OH100235 LOAD ON 1/0 ACSR OF 114.5V. MAINLINE LOADING OF 1/0 ACSR CONDUCTOR OVER 70%, VOLTAGE LOW COMING INTO LINE REGULATORS AT HICKLIN RD.

**ASSOCIATED PROJECTS:** CWP 383

**ALTERNATES:** ADDITIONAL PF CORECTION WILL NOT CORRECT VOLTAGE ISSUES AT LINE END. SHIFTING LOAD BY NEW TIE LINE TO SOUTH HANSON CREATES VOLTAGE ISSUES ON SOUTH HANSON THAT WILL REQUIRE 336 CONVERSION.



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** MASONVILLE  
**LOCATION** HWY 298/OLD HARTFORD RD  
**740C CODE** 364\*  
**ESTIMATED COST:** \$201,960  
**COMPLETION YEAR** 2019

**DESCRIPTION:** CARRY OVER PROJECT. 1.7 MILES OF THREE PHASE 1/0 CU TO 336 ACSR. OH704163 TO OH704247. CAPACITY FLAG ON 1/0 THREE PHASE. ADDED CAPACITY FOR LOSS CONTINGENCIES. PROJECT WILL ALSO REDUCE CONDUCTOR LOADING ON 1/0 CU MAINLINE.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE






## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

<b>SUBSTATION AREA:</b>	PROVIDENCE
<b>LOCATION</b>	HWY 1672 ALONG BOB HATLEY ROAD; OLD PROVIDENCE CLAY ROAD
<b>740C CODE</b>	370*
<b>ESTIMATED COST:</b>	\$75,330
<b>COMPLETION YEAR</b>	2019
<b>DESCRIPTION:</b>	CARRY OVER PROJECT. MULTI-PHASE 1PH ACSR2 TO 3PH ACSR2. IMPROVE CONDUCTOR LOADING AND LOAD BALANCE OF MAINLINE.
<b>ASSOCIATED PROJECTS:</b>	REMOVE SINGLE OCR AND INSTALL THREE 35A RE ClosERS.
<b>ALTERNATES:</b>	NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** SOUTH DERMONT

**LOCATION** HWY 54 (LEITCHFIELD ROAD)

**740C CODE** 374\*

**ESTIMATED COST:** \$142,560

**COMPLETION YEAR** 2019

**DESCRIPTION:** CARRY OVER PROJECT. CONVERT 1.2 MILES OF THREE PHASE 1/0 CU TO THREE PHASE 336 ACSR. OH97418525 TO OH728689. PROJECT TO IMPROVE LINE LOADING ON MAINLINE CONDUCTOR AND IMPROVE BACKFEED CONTINGENCIES.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** HANSON  
**LOCATION** CASNER RD. @ HICKLIN RD.  
**740C CODE** 383  
**ESTIMATED COST:** \$118,800  
**COMPLETION YEAR** 2017  
**DESCRIPTION:** CONVERT 1 MILE OF 1/0 ACSR TO 336 ACSR. OH102187 TO OH102199. VOLTAGE SUPPORT AT END OF LINE NEAR SPOT LOAD. OH1590839207.

**ASSOCIATED PROJECTS:** CWP 361\*

**ALTERNATES:** SECOND SET OF CIRCUIT REGULATION.




## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** MORGANFIELD  
**LOCATION** MORGANFIELD CIRCUIT 2  
**740C CODE** 384  
**ESTIMATED COST:** \$398,860  
**COMPLETION YEAR** 2017

**DESCRIPTION:** VOLTAGE CONVERSION TO 25KV. REMOVE 3-1000KVA STEP DOWN TRANSFORMERS AT OH327435 OVER CAPACITY. INSTALL TWO NEW SETS OF 1000KVA TRANSFORMERS DOWNLINE TO OH319980 AND OH320375. REMOVE REGULATORS REG41925049. CONVERSION OF 22.5 MILES OF SINGLE PHASE, 11.1 MILES OF THREE PHASE, 188 OVERHEAD TRANSFORMERS, AND 6 PADMOUNT TRANSFORMERS. ESTIMATED 40% OF LINES AND TRANSFORMERS WILL NEED TO BE REINSULATED. PROJECT WILL IMPROVE SERVICE TO 194 CUSTOMERS.

**ALTERNATES:** UPGRADE STEP TRANSFORMERS, RECONDUCTOR TO IMPROVE LINE CAPACITY.



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** MORGANFIELD  
**LOCATION** MCFALL RD. @ US-60  
**740C CODE** 385  
**ESTIMATED COST:** \$175,770  
**COMPLETION YEAR** 2018

**DESCRIPTION:** CONVERT 2.1 MILES OF 2 ACSR SINGLE PHASE TO 1/0 ACSR THREE PHASE. OH320941 TO OH320939. PROJECT IS PART OF THE LOSS CONTINGENCY PLANNING FOR MORGANFIELD CIRCUIT 2 WHICH AFTER THE 25KV CONVERSION WILL NOW TIE HOT WITH THIS AREA OF MORGANFIELD CIRCUIT 3.

**ASSOCIATED PROJECTS:** CWP 384

**ALTERNATES:** CURRENT LOSS CONTINGENCY USES SULLIVAN STATION, WHICH IS A LONG DISTANCE AND MUST USE STEP TRANSFORMERS DUE TO THE VOLTAGE DIFFERENCE.




## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA  
**LOCATION** KY-416 @ S PLEASANT VALLEY RD.  
**740C CODE** 386  
**ESTIMATED COST:** \$41,850  
**COMPLETION YEAR** 2018  
**DESCRIPTION:** CONVERT 0.5 MILES OF SINGLE PHASE TO 1/0 ACSR THREE PHASE FROM OH325155 TO OH325123. SINGLE PHASE TAP WITH 52A, PROJECT WILL ALLEVIATE CONDUCTOR LOADING AND IMPROVE CIRCUIT LOSSES.

**ASSOCIATED PROJECTS:** CHANGE LINE FEED TO OH325205 AND OH325113.

**ALTERNATES:** NONE, NO OTHER LINE CHANGES POSSIBLE, OTHER SINGLE PHASE TIE LOADED AT 40A.



## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA  
**LOCATION** CHERRY HILL RD. @ KY-1299  
**740C CODE** 387  
**ESTIMATED COST:** \$41,850  
**COMPLETION YEAR** 2020  
**DESCRIPTION:** CONVERT 0.5 MILES OF SINGLE PHASE TO THREE PHASE 1/0 ACSR. TAP WITH 42A. OH325631 TO OH325646.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE, RADIAL TAPS.



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA

**LOCATION** KY-416 @ N PLEASANT VALLEY RD.

**740C CODE** 388

**ESTIMATED COST:** \$66,960

**COMPLETION YEAR** 2019

**DESCRIPTION:** SINGLE LOSS CONTINGENCY. CONVERT 0.8 MILES SINGLE PHASE TO THREE PHASE 1/0 ACSR. THREE PHASE PROJECT IMPROVES BACKFEED TO 1.2 MW OF RADIAL LOAD ON CIRCUIT 2 BY ADDING BACKUP CIRCUIT 1 FEED.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE






## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA  
**LOCATION** US-41 NEAR WILLETT LN.  
**740C CODE** 390  
**ESTIMATED COST:** \$8,370  
**COMPLETION YEAR** 2018  
**DESCRIPTION:** CONVERT 0.1 MILES OF SINGLE PHASE TO THREE PHASE 1/0 ACSR. TAP WITH 42A. OH325193.  
**ASSOCIATED PROJECTS:** NONE  
**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ONTON  
**LOCATION** PENNYRILE PARKWAY  
**740C CODE** 391  
**ESTIMATED COST:** \$297,000  
**COMPLETION YEAR** 2017

**DESCRIPTION:** CONVERT 2.5 MILES OF 4A & 1/0 ACSR TO 336 ACSR. OH519183 TO OH520034. SINGLE LOSS CONTINGENCY PROJECT FOR BACKFEED CAPACITY TO SOUTH HANSON.

**ASSOCIATED PROJECTS:** SHIFT LOAD OPEN AT OH270834123 AND CLOSE AT OH519967, 575 KW FROM SOUTH HANSON. REMOVE 70A RECLOSERS.

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON  
**LOCATION** WEAVERTON SUBSTATION  
**740C CODE** 392  
**ESTIMATED COST:** \$247,500  
**COMPLETION YEAR** 2016

**DESCRIPTION:** CONVERT 1.1 MILES 3PH, 3/0 ACSR CIRCUIT (6402) TO DOUBLE CIRCUIT, 336 ACSR FROM THE SUBSTATION TO SECTION # OH332265 TO REDUCE FEEDER LOADING OF 228 AMPS, OVERLOAD OF EXISTING CONDUCTOR AND RESULTING END OF LINE LOW VOLTAGE AND REDUCES LOSSES. ALSO PROVIDES BACKFEED CONTINGENCY BETWEEN 6402 AND 6404.

**ASSOCIATED PROJECTS:** CWP 393

**ALTERNATES:** CONSTRUCT NEW STATION AT LOAD CENTER. WAS EVALUATED AND DETERMINED DISTRIBUTION PROJECTS ARE MORE COST EFFECTIVE. ANALYSIS IN FIGURE F-5.



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON  
**LOCATION** OLD MADISONVILLE RD. @ KY-1299  
**740C CODE** 393  
**ESTIMATED COST:** \$217,620  
**COMPLETION YEAR** 2017

**DESCRIPTION:** CONVERT 2 MILES 1PH, 4 ACSR TO 3PH, 336 ACSR FROM SECTION OH332250 TO OH332730. TRANSFER LOAD FROM CIRCUIT 6402 TO NEW 6404 AS PART OF THE 6402/6404 DOUBLE CIRCUIT PROJECT FOR REDUCING 6402 FEEDER LOADING AND END OF LINE LOW VOLTAGE AND REDUCES LOSSES. OPEN SECTION # OH332586, CLOSE OH332856 TO OH332255 FOR LOAD SWITCH FROM 6402 TO NEW 6404 FEEDER. RETIRE THREE EXISTING 70-L RECLOSERS, DEVICE REC409740.

**ASSOCIATED PROJECTS:** RETIRE THREE EXISTING 70-L RECLOSERS, DEVICE REC409740.

**ALTERNATES:** RECONDUCTOR AT CURRENT LINE END TO 336 ACSR.  
ANALYSIS IN FIGURE F-5 COMPARING STATION RELOCATION TO DISTRIBUTION UPGRADES.



## 4 DESCRIPTION AND JUSTIFICATION

---


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON  
**LOCATION** HWY 41A @ RUDY RD.  
**740C CODE** 394  
**ESTIMATED COST:** \$117,180  
**COMPLETION YEAR** 2018

**DESCRIPTION:** CONVERT 1.4 MILES 1PH, 2 ACSR TO 3PH, 1/0 ACSR FROM SECTION # OH325331 TO OH325367. THE EXISTING 1PH LINE IS OVER 40 AMPS. THE PROJECT WILL IMPROVE SYSTEM LOAD BALANCE, REDUCE END OF LINE LOW VOLTAGE AND REDUCE LOSSES.

**ASSOCIATED PROJECTS:** RETIRE SINGLE PHASE DEVICE AT REC41502002. INSTALL THREE NEW 50-L, 1PH RECLOSERS AS PART OF 3PH CONVERSION PROJECT AT SECTION OH325331.

**ALTERNATES:** NONE, OTHER SINGLE PHASE FEED AT 40A.



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON

**LOCATION** COUNTRY DR. @ PEGGY DR.

**740C CODE** 395

**ESTIMATED COST:** \$25,920

**COMPLETION YEAR** 2018

**DESCRIPTION:** CONVERT 0.3 MILE 2PH, 4 ACSR TO 3PH, 1/0 ACSR FROM SECTION #OH332173 TO OH332180. PROJECT IS NEEDED FOR LOAD BALANCE, IMPROVED VOLTAGE DROP, REDUCED LOSSES AND TO SUPPORT LOAD SHIFT FROM OVERLOADED 1PH LINE # OH332143.

**ASSOCIATED PROJECTS:** CWP 396

**ALTERNATES:** NONE.



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WEAVERTON

**LOCATION** WILSON DR. @ BRENDA DR.

**740C CODE** 396


**ESTIMATED COST:** \$8,370

**COMPLETION YEAR** 2019

**DESCRIPTION:** CONVERT 0.1 MILE 1PH, 4 ACSR TO 3PH, 1/0 ACSR FROM #OH298234926 TO #OH332203. THIS PROJECT IS PART OF THE PREVIOUS PROJECT NEEDED FOR LOAD BALANCE AND SHIFTING LOAD FROM OVERLOADED 1 PH LINE OH332143.

**ASSOCIATED PROJECTS:** RETIRE 50-L RECLOSER AT SECTION # REC40955003.

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ZION

**LOCATION** KY-1078 @ RIDGEWOOD RD.

**740C CODE** 397


**ESTIMATED COST:** \$25,110

**COMPLETION YEAR** 2020

**DESCRIPTION:** CONVERT 0.3 MILES OF SINGLE PHASE TO 1/0 ACSR  
THREE PHASE FROM OH334116 TO OH334928.  
SINGLE PHASE LINE HAS 42A.

**ASSOCIATED PROJECTS:** INSTALL 3-35A RECLOSERS.

**ALTERNATES:** NONE





## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** CALDWELL SPRINGS

**LOCATION** CALDWELL SPRINGS SUBSTATION/TABOR RD

**740C CODE** 398


**ESTIMATED COST:** \$283,500

**COMPLETION YEAR** 2017

**DESCRIPTION:** CONVERT 2.1 MILES OF 1/0 ACSR THREE PHASE TO THREE PHASE 336.4 ACSR. OH300532 TO OH300120. SINGLE LOSS CONTINGENCY PROJECT TO ADDRESS BACKFEED CAPACITY TO LYON CIRCUIT 1. PROJECT WILL ALSO ADDRESS LOW VOLTAGE BELOW 117V.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE. NO OTHER STATIONS TIE TO LYON STATION.



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** LYON

**LOCATION** KY-810 @ Mt Zion Rd.

**740C CODE** 399


**ESTIMATED COST:** \$34,560

**COMPLETION YEAR** 2018

**DESCRIPTION:** CONVERT 0.4 MILES OF TWO PHASE TO THREE PHASE 1/0 ACSR. OH307427 TO OH307431. LOW VOLTAGE AT END OF THE LINE BELOW 117V. DIFFICULT TO PHASE BALANCE DUE TO LOADED SINGLE PHASE TAPS.

**ASSOCIATED PROJECTS:** CWP 301

**ALTERNATES:** VOLTAGE REGULATION. NO CORRECTION FROM ADDITIONAL POWER FACTOR CAPACITORS.



## 4 DESCRIPTION AND JUSTIFICATION

### C. Project Descriptions and Justifications- Sectionalizing

The following pages provide a description and justification for the proposed Code 603 Sectionalizing construction work plan projects. The following Table 4-3 is a listing of all sectionalizing projects and included in this Section are the detailed descriptions for selected projects.

**Table 4-3: Sectionalizing Projects- Code 603**

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION-DETAIL
603-2	SULLIVAN	UPGRADE RECLOSER. 35A.	\$4,500	2016	CHANGE 25A TO 35A OCR. REC42527001. 24A
603-3	SULLIVAN	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2016	SHIFT LOAD. LOW VOLTAGE. SINGLE PHASE LINE WITH 45A. OPEN AT SW43028001 AND CLOSE FUS41982001.
603-4	DIXON	UPGRADE RECLOSER. 50A.	\$4,500	2016	CHANGE 35A TO 50A OCR. REC42048001. 38A
603-5	DIXON	UPGRADE RECLOSER. 50A.	\$4,500	2016	CHANGE 35A TO 50A OCR. REC42029001. 33A.
603-6	SEBREE	UPGRADE RECLOSER. 50A.	\$4,500	2016	CHANGE 35A TO 50A OCR. REC42173001. 28A.
603-7	ONTON	UPGRADE RECLOSER. 50A.	\$4,500	2016	CHANGE 25A TO 50A OCR. REC24314001. 34A
603-8	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2016	LOAD SHIFT. SHIFT 8A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A. OPEN AT OH1921722003 AND CLOSE AT OH420216430.
603-9	ONTON	RECLOSER CHANGE. RELOCATE.	\$0	2016	REMOVE 70A OCRS. LOADING FROM LOAD SHIFT MOVE OCRS DOWNLINE FOR SECTIONALIZING. REC26423001.
603-10	ONTON	INSTALL ELECTRONIC RECLOSER.	\$18,000	2016	INSTALL 3- 70HVT. OH519995.
603-11	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2016	INSTALL 3- 50A OCR. OH520019.
603-12	ONTON	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2016	CHANGE SETTINGS. 70HVT DUE TO LOADING. REC26310001.
603-13	ONTON	INSTALL ELECTRONIC RECLOSER.	\$18,000	2016	UPGRADE 70A OCR TO ELECTRONIC. REC20235001.

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION-DETAIL
603-14	ONTON	INSTALL ELECTRONIC RECLOSER.	\$18,000	2017	UPGRADE 70A OCR TO ELECTRONIC. REC22314001.
603-15	HANSON	INSTALL ELECTRONIC RECLOSER.	\$18,000	2017	UPGRADE 70A OCR TO ELECTRONIC. REC32515001. 96A LOAD. ALTERNATIVE INSTALL GOAB WITH FAULT INDICATORS.
603-16	HANSON	UPGRADE RECLOSER. 50A.	\$4,500	2017	INSTALL 50A OCR. 28A. FUS2073591908.
603-17	HANSON	INSTALL ELECTRONIC RECLOSER.	\$18,000	2017	UPGRADE 50A OCR TO 70HVT. REC34514001. 76A LOAD.
603-18	SOUTH HANSON2	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2017	LOAD SHIFT. SHIFT 1 MW OF LOAD FROM HANSON TO SOUTH HANSON 2. COORDINATE LOAD SHIFT WITH SOUTH HANSON 2 TO ONTON PROJECTS. OPEN POINT AT OH100308 AND CLOSE AT SW32405001. SECTIONALIZING AND REGULATOR PROJECTS ARE ASSIGNED TO HANSON.
603-19	SOUTH HANSON2	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2018	CHANGE SETTINGS. 70HVT DUE TO LOADING. REC32404004. 105A.
603-20	SOUTH HANSON1	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2018	CHANGE SETTINGS. 80HVT DUE TO LOADING. REC30322001. 120A.
603-21	SOUTH HANSON1	INSTALL RECLOSER. 50A.	\$4,500	2018	INSTALL 50A OCR. 32A. FUS482517087.
603-22	GENEVA	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LOAD SHIFT. SHIFT 17A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A. OPEN AT OH331672 AND CLOSE AT OH332048.
603-23	WEAVERTON	UPGRADE RECLOSER. 50A.	\$4,500	2018	Replace Existing 35-H Recloser To 50-L Recloser At Device REC41502002 Due To Overload
603-24	ADAMS LANE	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE 35A TO 50A OCR. REC40977001. 32A.
603-25	RACE CREEK	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	40A ON SINGLE PHASE LINE AT OH337347. CHANGE POINTS TO SHIFT LOAD. NEW OPEN AT UG2112910937 AND CLOSE AT UG2109877059.
603-26	ZION	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LOAD SHIFT. SHIFT 5A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A REC41042001. OPEN AT OH335821 AND CLOSE AT OPN301459.
603-27	ZION	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE 35A TO 50A OCR. REC41024001. 39A.

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION-DETAIL
603-28	NIAGARA	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE 35A TO 50A OCR. REC41549002. 32A.
603-29	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LOAD SHIFT. SHIFT 22A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A OH322726. OPEN AT OH322762 AND CLOSE AT OPN301920.
603-30	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS. INSTALL RECLOSERS. 50A.	\$9,000	2018	LOAD SHIFT. SHIFT 10A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A ON OH325630 . OPEN AT OH325135 AND CLOSE AT SW41526001. INSTALL 50A RECLOSERS ON BOTH SIDES OF SINGLE PHASE LINE CHANGE.
603-31	NIAGARA	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LOAD SHIFT. SHIFT 5A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A ON OH336398 . OPEN AT OH336062 AND CLOSE AT OH336066.
603-32	NIAGARA	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE 35A TO 50A OCR. REC41508002. 38A.
603-33	GUFFIE	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE OCR FROM 35 TO 50. REC22812001. 30A.
603-34	GUFFIE	UPGRADE RECLOSER. 70A.	\$4,500	2018	SUMMER. CHANGE OCR TO 70A. REC18823001
603-35	UTICA	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2018	CHANGE SETTINGS.OCR 50HVT DUE TO LOADING. REC21212001.
603-36	UTICA	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE OCR 35A TO 50A. REC23203002. 35A
603-37	UTICA	UPGRADE RECLOSER. 50A.	\$4,500	2018	CHANGE OCR 35A TO 50A. REC23203002
603-38	UTICA	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LINE LOADING. LINE CHANGE. SHIFT 10A. OPEN LINE AT OH531389 AND CLOSE SWITCH SW23009001.
603-39	PLEASANT RIDGE	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2018	LINE LOADING. LINE CHANGE. OPEN SW23312001 AND CLOSE SW23307001. LOAD ON SAME CIRCUIT.
603-40	WHITESVILLE	INSTALL RECLOSERS. 70A.	\$27,000	2019	REC21606001 70L LOADING. REMOVE RECLOSERS AND ADD 70'S DOWNLINE ON EACH LEG OF SPLIT. OH713218 AND OH1074352354.
603-41	SACRAMENTO	UPGRADE RECLOSER. 50A.	\$4,500	2019	35A OCR TO 50A. REC30710002.
603-42	NUCKOLS	UPGRADE RECLOSER. 70A.	\$4,500	2019	CHANGE OCR 50A TO 70A. REC25116003
603-43	CENTERTOWN	UPGRADE RECLOSER. 50A.	\$4,500	2019	35A OCR TO 50A. REC31322002.
603-44	BEDA	UPGRADE RECLOSER. 50A.	\$4,500	2019	35A TO 50A. REC25407001. 29A

## 4 DESCRIPTION AND JUSTIFICATION

CWP CODE	STATION NAME	DESCRIPTION SUMMARY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION-DETAIL
603-45	BEDA	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2019	LOAD SHIFT. SHIFT 7A BEDA TO UTICA CIRCUIT 2. CREATE OPEN POINT AT OH700119. CLOSE AT SWITCH SW-492206413. ALLEVIATE 40A SINGLE PHASE LINE. UPGRADE UTICA OCR.
603-46	BEDA	UPGRADE RECLOSER. 50A.	\$4,500	2019	35A TO 50A. REC25319004. 36A.
603-47	BEDA	UPGRADE RECLOSER. 50A.	\$4,500	2019	35A TO 50A. REC25308002.29A
603-48	BEDA	UPGRADE RECLOSER. 35A.	\$4,500	2019	25A TO 35A. REC25423001. 21A
603-49	BEDA	UPGRADE RECLOSER. 50A.	\$4,500	2020	35 TO 50A. REC25308001. 36A AFTER LOAD SHIFT.
603-50	BEDA	INSTALL ELECTRONIC RECLOSER.	\$18,000	2020	REC27410002. 70A TO ELECTRONIC OCR. LOADING. TWO PHASES 70+, ONE AT 50A.
603-51	WEST OWENSBORO	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2020	LINE LOADING. CHANGE SETTINGS. OCR 75HVT. REC14924004.
603-52	MASONVILLE	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2020	LOAD SHIFT. CREATE OPEN AT FUS700416. CLOSE AT UG1330823758. ALLEVIATE 40A SINGLE PHASE LINE.
603-53	EAST OWENSBORO	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2020	LOAD SHIFT. SHIFT 1.2 MW LOAD FROM SOUTH DERMONT 2 TO EAST OWENSBORO. LOAD SHIFT AFTER NEW CIRCUIT, UNDERGROUND TIE, AND THREE PHASE CONVERSION PROJECTS. OPEN AT OH715263 AND CLOSE AT OH715266 .
603-54	DERMONT	UPGRADE RECLOSER. 50A.	\$4,500	2020	35 TO 50A. REC11220002. 39A.
603-55	PHILPOT	RECLOSER CHANGE. CHANGE CONTROL SETTINGS.	\$0	2020	LINE LOADING. CHANGE SETTINGS. OCR HVT. REC13305001.
603-56	PHILPOT	UPGRADE RECLOSER. 50A.	\$4,500	2020	35 TO 50A. REC13409001. 31A.
603-57	HAWESVILLE	RECLOSER CHANGE. CONTROL SETTINGS.	\$0	2020	LINE LOADING. CHANGE SETTINGS. OCR HVT. REC05723001.
603-58	ONTON	LOAD SHIFT. CHANGE OPEN POINTS.	\$0	2016	LOAD SHIFT. 450KW FROM ONTON CIRCUIT 2 TO BEECH GROVE CIRCUIT 1. LOW VOLTAGE BELOW 117 V ALONG LONG TWO PHASE LINES DUE TO ONTON VOLTAGE DROP.

## 4 DESCRIPTION AND JUSTIFICATION

---

**Protective Equipment Summary**

<b>Size</b>	<b>Quantity</b>	<b>Cost</b>
35A	2	\$9,000
50A	24	\$108,000
70A	8	\$36,000
ELECTRONIC	6	\$108,000
Total	12	\$261,000

## 4 DESCRIPTION AND JUSTIFICATION

---

**NEW DISTRIBUTION CONSTRUCTION ITEM:**

**SUBSTATION AREA:** SULLIVAN

**LOCATION**


**740C CODE** 603-3

**ESTIMATED COST:** \$0

**COMPLETION YEAR** 2016

**DESCRIPTION:** SHIFT LOAD. LOW VOLTAGE. SINGLE PHASE LINE WITH 45A. OPEN AT SW43028001 AND CLOSE FUS41982001.

**ASSOCIATED PROJECTS:** NONE





## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ONTON

**LOCATION** BRETON RD @ KY-1835

**740C CODE** 603-8


**ESTIMATED COST:** \$0

**COMPLETION YEAR** 2016

**DESCRIPTION:** LOAD SHIFT. SHIFT 8A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A. OPEN AT OH1921722003 AND CLOSE AT OH420216430.

**ASSOCIATED PROJECTS:** NONE


**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

SUBSTATION AREA:	ONTON
LOCATION	VANDETTA RD. @ EASTWOOD RD.
740C CODE	603-9
ESTIMATED COST:	\$0
COMPLETION YEAR	2016
DESCRIPTION:	REMOVE 70A OCRS. LOADING FROM LOAD SHIFT MOVE OCRS DOWNLINE FOR SECTIONALIZING. REC26423001.
ASSOCIATED PROJECTS:	NONE
ALTERNATES:	NONE



## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ONTON  
**LOCATION** DAME ROAD  
**740C CODE** 603-10  
**ESTIMATED COST:** \$18,000  
**COMPLETION YEAR** 2016  
**DESCRIPTION:** INSTALL 3- 70HVT. OH519995.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ONTON  
**LOCATION:** DAME RD  
**740C CODE:** 603-11  
**ESTIMATED COST:** \$4,500  
**COMPLETION YEAR:** 2016  
**DESCRIPTION:** INSTALL 3- 50A OCR. OH520019.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** HANSON  
**LOCATION** CARROLL GENTRY RD. @ BROWN RD.  
**740C CODE** 603-16  
**ESTIMATED COST:** \$4,500  
**COMPLETION YEAR** 2017  
**DESCRIPTION:** INSTALL 50A OCR. 28A. FUS2073591908.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** SOUTH HANSON2  
**LOCATION** LENIN RD. @ BROWN RD.  
**740C CODE** 603-18  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2017

**DESCRIPTION:** LOAD SHIFT. SHIFT 1 MW OF LOAD FROM HANSON TO SOUTH HANSON 2. COORDINATE LOAD SHIFT WITH SOUTH HANSON 2 TO ONTON PROJECTS. OPEN POINT AT OH100308 AND CLOSE AT SW32405001. SECTIONALIZING AND REGULATOR PROJECTS ARE ASSIGNED TO HANSON.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** SOUTH HANSON1  
**LOCATION** WOLF HOLLOW RD @ LEROY RD  
**740C CODE** 603-21  
**ESTIMATED COST:** \$4,500  
**COMPLETION YEAR** 2018  
**DESCRIPTION:** INSTALL 50A OCR. 32A. FUS482517087.

**ASSOCIATED PROJECTS:** NONE


**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** GENEVA  
**LOCATION** CORYDON-GENEVA RD  
**740C CODE** 603-22  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2018  
**DESCRIPTION:** LOAD SHIFT. SHIFT 17A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A. OPEN AT OH331672 AND CLOSE AT OH332048.  
**ASSOCIATED PROJECTS:** NONE  
**ALTERNATES:** NONE





## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** RACE CREEK  
**LOCATION** JUDITH ANN DR  
**740C CODE** 603-25  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2018

**DESCRIPTION:** 40A ON SINGLE PHASE LINE AT OH337347. CHANGE POINTS TO SHIFT LOAD. NEW OPEN AT UG2112910937 AND CLOSE AT UG2109877059.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ZION  
**LOCATION** AUDUBON PKY  
**740C CODE** 603-26  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2018

**DESCRIPTION:** LOAD SHIFT. SHIFT 5A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A REC41042001. OPEN AT OH335821 AND CLOSE AT OPN301459.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA

**LOCATION** PLEASANT VALLEY RD

**740C CODE** 603-29


**ESTIMATED COST:** \$0

**COMPLETION YEAR** 2018

**DESCRIPTION:** LOAD SHIFT. SHIFT 22A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A OH322726. OPEN AT OH322762 AND CLOSE AT OPN301920.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION


### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** NIAGARA  
**LOCATION:** BUSBY STATION  
**740C CODE:** 603-30  
**ESTIMATED COST:** \$9,000  
**COMPLETION YEAR:** 2018

**DESCRIPTION:** LOAD SHIFT. SHIFT 10A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A ON OH325630 . OPEN AT OH325135 AND CLOSE AT SW41526001. INSTALL 50A RECLOSERS ON BOTH SIDES OF SINGLE PHASE LINE CHANGE.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

---

### NEW DISTRIBUTION CONSTRUCTION ITEM:

SUBSTATION AREA: NIAGARA

LOCATION: KY-1078

740C CODE: 603-31


ESTIMATED COST: \$0

COMPLETION YEAR: 2018

DESCRIPTION: LOAD SHIFT. SHIFT 5A SINGLE PHASE LOAD TO RELIEVE LINE LOADING OVER 40A ON OH336398 . OPEN AT OH336062 AND CLOSE AT OH336066.

ASSOCIATED PROJECTS: NONE


ALTERNATES: NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** UTICA  
**LOCATION:** HAMILTON FERRY RD  
**740C CODE:** 603-38  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR:** 2018  
**DESCRIPTION:** LINE LOADING. LINE CHANGE. SHIFT 10A. OPEN LINE AT OH531389 AND CLOSE SWITCH SW23009001.  
**ASSOCIATED PROJECTS:** NONE  
**ALTERNATES:** NONE




## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** PLEASANT RIDGE  
**LOCATION** US HWY 231 @ DAME DR.  
**740C CODE** 603-39  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2018  
**DESCRIPTION:** LINE LOADING. LINE CHANGE. OPEN SW23312001 AND CLOSE SW23307001. LOAD ON SAME CIRCUIT.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** WHITESVILLE

**LOCATION** KY-1414 @ MORGANTOWN RD.

**740C CODE** 603-40


**ESTIMATED COST:** \$27,000

**COMPLETION YEAR** 2019

**DESCRIPTION:** REC21606001 70L LOADING. REMOVE RECLOSERS AND ADD 70'S DOWNLINE ON EACH LEG OF SPLIT. OH713218 AND OH1074352354.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE





## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** BEDA

**LOCATION** BELLTOWN RD. @ NEW BETHEL CHURCH RD.

**740C CODE** 603-45


**ESTIMATED COST:** \$0

**COMPLETION YEAR** 2019

**DESCRIPTION:** LOAD SHIFT. SHIFT 7A BEDA TO UTICA CIRCUIT 2. CREATE OPEN POINT AT OH700119. CLOSE AT SWITCH SW-492206413. ALLEVIATE 40A SINGLE PHASE LINE. UPGRADE UTICA OCR.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** MASONVILLE  
**LOCATION** CRESENT HILL DR. @ LOFTWOOD DR.  
**740C CODE** 603-52  
**ESTIMATED COST:** \$0  
**COMPLETION YEAR** 2020  
**DESCRIPTION:** LOAD SHIFT. CREATE OPEN AT FUS700416. CLOSE AT UG1330823758. ALLEVIATE 40A SINGLE PHASE LINE.

**ASSOCIATED PROJECTS:** NONE


**ALTERNATES:** NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

<b>SUBSTATION AREA:</b>	EAST OWENSBORO
<b>LOCATION</b>	LEITCHFIELD RD @ WIMSATT CT
<b>740C CODE</b>	603-53
<b>ESTIMATED COST:</b>	\$0
<b>COMPLETION YEAR</b>	2020
<b>DESCRIPTION:</b>	LOAD SHIFT. SHIFT 1.2 MW LOAD FROM SOUTH DERMONT 2 TO EAST OWENSBORO. LOAD SHIFT AFTER NEW CIRCUIT, UNDERGROUND TIE, AND THREE PHASE CONVERSION PROJECTS. OPEN AT OH715263 AND CLOSE AT OH715266.
<b>ASSOCIATED PROJECTS:</b>	NONE
<b>ALTERNATES:</b>	NONE



## 4 DESCRIPTION AND JUSTIFICATION

### NEW DISTRIBUTION CONSTRUCTION ITEM:

**SUBSTATION AREA:** ONTON

**LOCATION** KY-370

**740C CODE** 603-58


**ESTIMATED COST:** \$0

**COMPLETION YEAR** 2016

**DESCRIPTION:** LOAD SHIFT. 450KW FROM ONTON CIRCUIT 2 TO BEECH GROVE CIRCUIT 1. LOW VOLTAGE BELOW 117 V ALONG LONG TWO PHASE LINES DUE TO ONTON VOLTAGE DROP.

**ASSOCIATED PROJECTS:** NONE

**ALTERNATES:** UPGRADE MAINLINE CIRCUIT 1 REGULATORS TO 200A AND INSTALL SECOND SET OF REGULATION ON TWO PHASE LINE.



## 4 DESCRIPTION AND JUSTIFICATION

### D. Project Descriptions and Justifications- Regulators

The following pages provide a description and justification for the proposed Code 604 Regulator construction work plan projects. The following Table 4-4 is a listing of all line regulation projects proposed.

**Table 4-4: Regulator Projects- Code 604**

CWP CODE	STATION NAME	QTY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION-DETAIL
604-19	LYON	3	\$45,000	2016	REMOVE REGULATORS. INSTALL 150A REGULATORS AT SECTION WITH BI-DIRECTIONAL CONTROLS. OH307258
LOCATION					THOMASON RD/KY 819
604-21	HANSON	3	\$36,000	2016	INSTALL 100A REGULATORS ON SECTION OH100270. LOW VOLTAGE 117.3 V. 988KW FED ON 2 ACSR 119V INCOMING. ALSO WOULD ASSIST ANY BACKFEED WITH SOUTH HANSON.
LOCATION					BROWN RD @ LENIN RD
604-22	WEAVERTON	3	\$36,000	2016	REMOVE EXISTING 3PH, 100A REGULATOR BANK REG409831 AND INSTALL 3-100A AT THE END OF SECTION #OH332683. THE 100A REGULATORS ARE OVERLOADED AT EXISTING LOCATION BUT WITH THE 6402 DOUBLE CIRCUIT PROJECT, THE UPLINE VOLTAGE DROP IS REDUCED ALLOWING THE REGULATORS TO BE MOVED DOWNLINE, WITHIN LOADING LIMITS BUT ARE STILL NEEDED FOR END OF LINE VOLTAGE IMPROVEMENTS.
LOCATION					US HIGHWAY 41A BEFORE CAMELOT DR
604-23	ZION	3	\$45,000	2016	REMOVE 100A REGULATORS AND INSTALL 150A REGULATORS. REG41076003.
LOCATION					EXISTING LOCATION

**Regulator Equipment Summary**

Size	Quantity	Cost
100A	6	\$72,000
150A	6	\$90,000
200A	0	\$0
Total	12	\$162,000

## 4 DESCRIPTION AND JUSTIFICATION

### E. Project Descriptions and Justifications- Capacitors

The following pages provide a description and justification for the proposed Code 605 Capacitor construction work plan projects. The following Table 4-5 is a listing of all capacitor projects proposed.

**Table 4-5: Capacitor Projects- Code 605**

CWP CODE	STATION NAME	QTY	COST ESTIMATE	COMPLETION YEAR	DESCRIPTION- DETAIL	LOCATION
605-2	MARION	1	\$5,000	2016	LOW VOLTAGE. INSTALL 300 KVAR. LOAD BALANCE. OH313613	KY-91 @ HILLSIDE DR
605-3	MARION	1	\$5,000	2016	LOW VOLTAGE. INSTALL 300 KVAR. OH316820	CHICKADEE LN
605-4	MORGANFIELD	1	\$5,000	2016	INSTALL 300KVAR AT OH328508. VOLTAGE LOW AT REGULATOR.	HILLTOP RD NEAR KY-947
605-5	DIXON	1	\$5,000	2016	INSTALL 300KVAR AT OH308946. SOME PHASE IMBALANCE FROM LARGE TAPS. PF 98.9 TO 99.5.	KY-132, .75 MILES FROM CARVILLE CLARK RD
605-6	LITTLE DIXIE	1	\$5,000	2016	UPGRADE EXISTING 150KVAR. INSTALL 300KVAR AT CAP41464004.	EXISTING
605-7	ONTON	1	\$5,000	2016	INSTALL 300KVAR AT OH528218. SUMMER PF=93.	KY-370 @ FRED EASTWOOD RD
605-8	HANSON	1	\$5,000	2016	INSTALL 300KVAR AT OH521378. STATION WINTER 96PF TO 98PF.	KY-862 @ BROWN RD
605-9	GUFFIE	1	\$5,000	2016	INSTALL 300KVAR AT OH527429. STATION WINTER.	KY-554 @ GREENBACK RD
605-10	NUCKOLS	1	\$5,000	2016	INSTALL 300 KVAR AT OH518047. LOW VOLTAGE AT OH521526.	NUCKOLS-OLD BUCK CREEK RD

#### Capacitor Equipment Summary

Size	QTY	Cost
300 KVAR	9	\$45,000

# EXHIBITS

**FIGURE F-1: 2015 LOAD FORECAST EXCERPT**

**KENERGY CORP.**  
**2015 LONG-TERM LOAD FORECAST - BASE CASE FORECAST**  
*RURAL SYSTEM REQUIREMENTS - NO DSM ADJUSTMENT*

Year	Actual Energy (MWh)	Normal Energy (MWh)	Percent Growth	Summer NCP (kW)	Summer Normal NCP (kW)	Summer Percent Growth	Load Factor	Winter NCP (kW)	Winter Normal NCP (kW)	Winter Percent Growth	Load Factor
1999	995,896	926,630		242,135			47.0%	197,919			57.4%
2000	1,039,824	943,057	1.8%	232,705		-3.9%	51.0%	196,037		-1.0%	60.6%
2001	1,042,643	1,030,224	9.2%	231,219		-0.6%	51.5%	218,282		11.3%	54.5%
2002	1,097,150	1,046,863	1.6%	242,810		5.0%	51.6%	196,821		-9.8%	63.6%
2003	1,081,171	1,062,447	1.5%	236,194		-2.7%	52.3%	235,479		19.6%	52.4%
2004	1,109,089	1,066,335	0.4%	244,804		3.6%	51.7%	220,873		-6.2%	57.3%
2005	1,172,365	1,114,166	4.5%	260,280		6.3%	51.4%	230,890		4.5%	58.0%
2006	1,155,880	1,141,486	2.5%	262,625		0.9%	50.2%	226,742		-1.8%	58.2%
2007	1,235,849	1,168,613	2.4%	274,843		4.7%	51.3%	247,169		9.0%	57.1%
2008	1,218,628	1,190,460	1.9%	261,136		-5.0%	53.3%	257,119		4.0%	54.1%
2009	1,144,107	1,197,549	0.6%	257,112		-1.5%	50.8%	279,942		8.9%	46.7%
2010	1,270,263	1,209,637	1.0%	276,957		7.7%	52.4%	251,992		-10.0%	57.5%
2011	1,214,795	1,199,189	-0.9%	274,841		-0.8%	50.5%	262,704		4.3%	52.8%
2012	1,192,208	1,204,575	0.4%	283,792		3.3%	48.0%	230,936		-12.1%	58.9%
2013	1,221,667	1,209,619	0.4%	258,490		-8.9%	54.0%	242,793		5.1%	57.4%
2014	1,240,267	1,189,007	-1.7%	248,964	265,964	-3.7%	56.9%	309,978	258,978	27.7%	45.7%
2015		1,214,627	2.2%		275,793	3.7%	50.3%		262,950	1.5%	52.7%
2016		1,215,030	0.0%		276,811	0.4%	50.1%		265,374	0.9%	52.3%
2017		1,216,288	0.1%		277,964	0.4%	50.0%		266,459	0.4%	52.1%
2018		1,229,651	1.1%		279,252	0.5%	50.3%		267,680	0.5%	52.4%
2019		1,240,439	0.9%		280,675	0.5%	50.5%		269,035	0.5%	52.6%
2020		1,246,722	0.5%		282,234	0.6%	50.4%		270,526	0.6%	52.6%
2021		1,256,191	0.8%		283,927	0.6%	50.5%		272,152	0.6%	52.7%
2022		1,269,367	1.0%		285,756	0.6%	50.7%		273,914	0.6%	52.9%
2023		1,283,756	1.1%		287,721	0.7%	50.9%		275,811	0.7%	53.1%
2024		1,295,522	0.9%		289,821	0.7%	51.0%		277,843	0.7%	53.2%
2025		1,308,249	1.0%		292,055	0.8%	51.1%		280,010	0.8%	53.3%
2026		1,321,460	1.0%		294,426	0.8%	51.2%		282,312	0.8%	53.4%
2027		1,332,793	0.9%		296,931	0.9%	51.2%		284,750	0.9%	53.4%
2028		1,348,820	1.2%		299,572	0.9%	51.4%		287,323	0.9%	53.6%
2029		1,363,116	1.1%		302,348	0.9%	51.5%		290,032	0.9%	53.7%

ANNUAL GROWTH RATES						
1999-2004	2.2%	2.8%	0.2%			2.2%
2004-2009	0.6%	2.3%	1.0%		-0.4%	4.9%
2009-2014	1.6%	-0.1%	-0.6%		2.3%	2.1%
2014-2019		0.9%		1.1%	-2.4%	0.8%
2019-2024		0.9%		0.6%	0.2%	0.6%
2024-2029		1.0%		0.8%	0.2%	0.9%
2014-2029		0.9%		0.9%	-0.7%	0.8%

Energy includes distribution losses

NCP values represent the highest 1-hour peak at the rural system level in each season and include distribution losses.



**FIGURE F-1: 2015 LOAD FORECAST EXCERPT**

**KENERGY CORP**  
**2015 LONG-TERM LOAD FORECAST - RANGE FORECASTS**  
*RURAL SYSTEM REQUIREMENTS*

Year	Base Case (MWh)	Weather Adjusted (MWh)	ECONOMIC SCENARIOS		WEATHER SCENARIOS	
			Optimistic (MWh)	Pessimistic (MWh)	Extreme (MWh)	Mild (MWh)
1999	995,896	926,630				
2000	1,039,824	943,057				
2001	1,042,643	1,030,224				
2002	1,097,150	1,046,863				
2003	1,081,171	1,062,447				
2004	1,109,089	1,066,335				
2005	1,172,365	1,114,166				
2006	1,155,880	1,141,486				
2007	1,235,849	1,168,613				
2008	1,218,628	1,190,460				
2009	1,144,107	1,197,549				
2010	1,270,263	1,209,637				
2011	1,214,795	1,199,189				
2012	1,192,208	1,204,575				
2013	1,221,667	1,209,619				
2014	1,240,267	1,189,007				
2015		1,209,065	1,296,536	1,132,391	1,279,281	1,140,012
2016		1,206,483	1,311,504	1,117,002	1,276,722	1,137,738
2017		1,204,657	1,328,007	1,103,850	1,274,709	1,136,077
2018		1,214,839	1,351,586	1,106,477	1,285,382	1,145,839
2019		1,222,504	1,371,608	1,108,666	1,293,229	1,153,092
2020		1,225,611	1,384,858	1,108,494	1,296,948	1,155,708
2021		1,232,881	1,401,926	1,109,939	1,304,545	1,162,863
2022		1,243,235	1,422,271	1,115,984	1,315,441	1,172,165
2023		1,254,746	1,443,676	1,123,270	1,327,759	1,183,448
2024		1,263,550	1,463,623	1,126,999	1,336,461	1,191,785
2025		1,273,113	1,482,922	1,132,979	1,346,922	1,200,746
2026		1,282,872	1,503,036	1,139,505	1,356,828	1,209,786
2027		1,290,486	1,521,592	1,144,190	1,365,249	1,217,418
2028		1,302,431	1,542,699	1,154,711	1,377,587	1,228,361
2029		1,312,648	1,564,075	1,162,398	1,388,289	1,238,257

ANNUAL GROWTH RATES						
1999-2004	2.2%	2.8%				
2004-2009	0.6%	2.3%				
2009-2014	1.6%	-0.1%				
2014-2019		0.6%	2.9%	-1.4%	1.7%	-0.6%
2019-2024		0.7%	1.3%	0.3%	0.7%	0.7%
2024-2029		0.8%	1.3%	0.6%	0.8%	0.8%
2014-2029		0.7%	1.8%	-0.2%	1.0%	0.3%

**FIGURE F-1: 2015 LOAD FORCAST EXCERPT**

**KENERGY CORP.**  
**PEAK DAY WEATHER SCENARIOS**  
**TOTAL & RURAL SYSTEM DEMANDS**

<i>Extreme Total Degree Days - Evansville, IN</i>				
	<b>Normal</b>		<b>Extreme</b>	
Degree Days	5,893	6,179	6,407	6,580
Probability	50%	20%	10%	5%
Occurs Once Every	2 Years	5 Years	10 Years	20 Years

**TOTAL SYSTEM NCP DEMAND**

<b>Year</b>	<b>SUMMER NCP KW</b>				<b>WINTER NCP KW</b>			
	<b>Base Case (50%)</b>	<b>Extreme (20%)</b>	<b>Extreme (10%)</b>	<b>Extreme (5%)</b>	<b>Base Case (50%)</b>	<b>Extreme (20%)</b>	<b>Extreme (10%)</b>	<b>Extreme (5%)</b>
2015	1,294,656	1,298,526	1,303,772	1,308,256	1,293,052	1,316,591	1,330,765	1,343,576
2016	1,317,954	1,320,709	1,325,946	1,330,421	1,309,062	1,330,005	1,344,151	1,356,937
2017	1,326,689	1,328,041	1,333,259	1,337,717	1,326,526	1,346,152	1,360,255	1,373,000
2018	1,327,631	1,330,152	1,335,399	1,339,884	1,327,527	1,348,495	1,362,689	1,375,516
2019	1,328,610	1,331,687	1,336,959	1,341,464	1,328,485	1,350,135	1,364,402	1,377,294
2020	1,329,722	1,332,047	1,337,319	1,341,824	1,329,572	1,350,608	1,364,884	1,377,784
2021	1,331,183	1,333,405	1,338,697	1,343,218	1,331,131	1,352,092	1,366,430	1,379,385
2022	1,332,634	1,335,622	1,340,952	1,345,507	1,332,552	1,354,414	1,368,861	1,381,913
2023	1,334,217	1,338,112	1,343,486	1,348,078	1,334,103	1,357,013	1,371,583	1,384,745
2024	1,335,918	1,339,875	1,345,277	1,349,893	1,335,812	1,358,898	1,373,551	1,386,788
2025	1,337,724	1,341,806	1,347,239	1,351,881	1,337,641	1,360,956	1,375,701	1,389,020
2026	1,339,622	1,343,779	1,349,244	1,353,913	1,339,579	1,363,058	1,377,897	1,391,300
2027	1,341,624	1,345,262	1,350,749	1,355,438	1,341,643	1,364,657	1,379,565	1,393,030
2028	1,343,707	1,347,731	1,353,260	1,357,983	1,343,809	1,367,270	1,382,297	1,395,869
2029	1,345,927	1,349,812	1,355,375	1,360,127	1,346,111	1,369,483	1,384,609	1,398,270

**RURAL SYSTEM CP DEMAND**

<b>Year</b>	<b>SUMMER CP KW</b>				<b>WINTER CP KW</b>			
	<b>Base Case (50%)</b>	<b>Extreme (20%)</b>	<b>Extreme (10%)</b>	<b>Extreme (5%)</b>	<b>Base Case (50%)</b>	<b>Extreme (20%)</b>	<b>Extreme (10%)</b>	<b>Extreme (5%)</b>
2015	274,896	278,766	284,012	288,496	262,165	285,704	299,878	312,689
2016	275,448	278,203	283,440	287,915	264,175	285,118	299,264	312,050
2017	276,129	277,481	282,699	287,157	264,839	284,465	298,568	311,313
2018	276,940	279,461	284,708	289,193	265,633	286,601	300,795	313,622
2019	277,919	280,996	286,268	290,773	266,591	288,241	302,508	315,400
2020	279,031	281,356	286,628	291,133	267,678	288,714	302,990	315,890
2021	280,492	282,714	288,006	292,527	269,237	290,198	304,536	317,491
2022	281,943	284,931	290,261	294,816	270,658	292,520	306,967	320,019
2023	283,526	287,421	292,795	297,387	272,209	295,119	309,689	322,851
2024	285,227	289,184	294,586	299,202	273,918	297,004	311,657	324,894
2025	287,033	291,115	296,548	301,190	275,747	299,062	313,807	327,126
2026	288,931	293,088	298,553	303,222	277,685	301,164	316,003	329,406
2027	290,933	294,571	300,058	304,747	279,749	302,763	317,671	331,136
2028	293,016	297,040	302,569	307,292	281,915	305,376	320,403	333,975
2029	295,236	299,121	304,684	309,436	284,217	307,589	322,715	336,376

THIS PAGE WAS INTENTIONALLY LEFT BLANK.

# FIGURE F-2: CWP 740C SAMPLE

According to the Paperwork Reduction Act of 1995, an agency may not conduct or sponsor, and a person is not required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0572-0032. The time required to complete this information collection is estimated to average 10 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information.

This data will be used by RUS to review your financial situation. Your response is required (7 USC 901 et seq.) and is not confidential.

USDA-RUS			Form Approved OMB No. 0572-0032	
COST ESTIMATES AND LOAN BUDGET			BORROWER AND LOAN DESIGNATION Kentucky 65, Kentucky	
FOR ELECTRIC BORROWERS			COST ESTIMATES AS OF: (Month, Year)	
To: U.S. Dept. of Agriculture, RUS, Washington, D. C. 20250				
<b>INSTRUCTIONS</b> See tabs "Pg1 Instr" through "Pg4 Instr"				
<b>SECTION A. COST ESTIMATES</b>			<b>LOAN PERIOD <u>4</u> YEARS</b>	
1. DISTRIBUTION			BORROWER'S COST ESTIMATES	RUS USE ONLY
100	a. New Line: (Excluding Tie-Lines)			
	Construction Consumers	Miles		
101	Underground 969	43.0	\$ 4,324,093	
102	Overhead 1401	76.7	\$ 7,058,835	
	Total Consumers . 2370	Total Miles . . . . . 119.7	\$ 11,382,928	
		Less Contributions . . . . .	\$ -	
	Subtotal (New Line - code 100) . . . . .		\$ 11,382,928	
200 b. New Tie-Lines				
	Line Designation	Miles		
201	WEAVERTON NEW CONSTRUCTION SINGLE PHASE 1/0 ACSR	0.10	\$ 6,700	
202	CENTERTOWN NEW CONSTRUCTION THREE PHASE 336 ACSR	0.10	\$ 13,392	
203			\$ -	
204			\$ -	
205			\$ -	
206			\$ -	
	Subtotal from page 1A . . . . . Miles . . . . .	0.00	\$ -	
	Subtotal (Includes subtotals from pages 1A) . . . . . Miles . . . . .	0.20	\$ 20,092	
300 c. Conversion and Line Changes				
	Line Designation	Miles		
360*	GUFFIE THREE PHASE CU 1/0 TO THREE PHASE 336 ACSR	1.43	\$ 169,884	
361*	HANSON THREE PHASE TO THREE PHASE 336 ACSR	2.20	\$ 261,360	
364*	MASONVILLE THREE PHASE TO THREE PHASE 336 ACSR	1.70	\$ 201,960	
370*	PROVIDENCE SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.90	\$ 75,330	
374*	SOUTH DERMONT THREE PHASE TO THREE PHASE 336 ACSR	1.20	\$ 142,560	
301	LYON SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.50	\$ 41,850	
302	LYON THREE PHASE TO THREE PHASE 336 ACSR	1.10	\$ 130,680	
303	LYON THREE PHASE TO THREE PHASE 336 ACSR	1.00	\$ 118,800	
304	BEDA THREE PHASE TO THREE PHASE 336 ACSR	2.30	\$ 273,240	
305	CENTERTOWN UPGRADE THREE PHASE URD TO 4/0 AL 25KV	0.40	\$ 90,000	
	Subtotal from page 1A . . . . . Miles . . . . .	138.65	\$ 9,347,060	
	Subtotal (Includes subtotals from pages 1A) . . . . . Miles . . . . .	151.38	\$ 10,852,724	
400 d. New Substations, Switching Stations, Metering Points, etc.				
	Station Designation	kVA	kV to kV	
401				\$ -
402				\$ -
403				\$ -
404				\$ -
405				\$ -
406				\$ -
	Subtotal . . . . .			\$ -

\* These are projects Carried Forward from the last CWP.

COST ESTIMATE AND LOAN BUDGET FOR ELECTRIC BORROWERS		BORROWER AND LOAN DESIGNATION	Kentucky 65, Kentucky
SECTION A. COST ESTIMATES (Page 1 Continuation Sheet)		BORROWER'S COST ESTIMATES	RUS USE ONLY
200	b. New Tie-Lines (Continued)		
	Line Designation	Miles	
215			\$ -
216			\$ -
217			\$ -
218			\$ -
219			\$ -
220			\$ -
221			\$ -
222			\$ -
223			\$ -
224			\$ -
	Miles.....	0.00	
	Subtotal (transfers to page 1).....		\$ -
300	c. Conversion and Line Changes (Continued)		
	Line Designation	Miles	
306	EAST OWENSBORO THREE PHASE TO DUAL CIRCUIT 3PH 336 ACSR	0.75	\$ 168,750
307	EAST OWENSBORO THREE PHASE TO THREE PHASE 336 ACSR	0.20	\$ 23,760
310	PHILPOT SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.40	\$ 33,480
312	SOUTH OWENSBORO UNDERGROUND UPGRADE	0.10	\$ 70,000
313	ADAMS LANE SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.50	\$ 41,850
314	GENEVA VOLTAGE CONVERSION TO 25KV	0.00	\$ 45,000
371	SYSTEM WIDE- UNDERGROUND CABLE REPLACEMENT	8.00	\$ 1,600,000
372	SYSTEM WIDE- OVERHEAD CONDUCTOR REPLACEMENT	100.00	\$ 5,400,000
383	HANSON THREE PHASE TO THREE PHASE 336 ACSR	1.00	\$ 118,800
384	MORGANFIELD VOLTAGE CONVERSION TO 25KV	13.50	\$ 253,860
385	MORGANFIELD SINGLE PHASE TO THREE PHASE 1/0 ACSR	2.10	\$ 175,770
386	NIAGARA SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.50	\$ 41,850
387	NIAGARA SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.50	\$ 41,850
388	NIAGARA SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.80	\$ 66,960
390	NIAGARA SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.10	\$ 8,370
391	ONTON THREE PHASE TO THREE PHASE 336 ACSR	2.50	\$ 297,000
392	WEAVERTON THREE PHASE TO DUAL CIRCUIT 336 ACSR	1.10	\$ 247,500
393	WEAVERTON SINGLE PHASE TO THREE PHASE 336 ACSR	2.00	\$ 217,620
394	WEAVERTON SINGLE PHASE TO THREE PHASE 1/0 ACSR	1.40	\$ 117,180
395	WEAVERTON TWO PHASE TO THREE PHASE 1/0 ACSR	0.30	\$ 25,920
396	WEAVERTON SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.10	\$ 8,370
397	ZION SINGLE PHASE TO THREE PHASE 1/0 ACSR	0.30	\$ 25,110
398	CALDWELL SPRINGS THREE PHASE TO THREE PHASE 336 ACSR	2.10	\$ 283,500
399	LYON TWO PHASE TO THREE PHASE 1/0 ACSR	0.40	\$ 34,560
316			\$ -
317			\$ -
318			\$ -
319			\$ -
320			\$ -
321			\$ -
322			\$ -
323			\$ -
324			\$ -
325			\$ -
326			\$ -
327			\$ -
328			\$ -
329			\$ -
330			\$ -
331			\$ -
332			\$ -
333			\$ -
334			\$ -
335			\$ -
	Subtotal (transfers to page 1).....	M 138.65	\$ 9,347,060

SECTION A. COST ESTIMATES (cont.)				BORROWER'S COST ESTIMATES	RUS USE ONLY
500	e. Substation, Switching Station, Metering Point Changes				
	<u>Station Designation</u>	<u>Description of Changes</u>			
504	WEAVERTON	STATION UPGRADE FOR NEW CIRCUIT		\$ 200,000	
505	EAST OWENSBORO	STATION UPGRADE FOR NEW CIRCUIT		\$ 150,000	
507	HORSE FORK	STATION UPGRADE TO DUAL TRANSFORMER CAPACITY		\$ 825,000	
508					
509				\$ -	
510				\$ -	
511				\$ -	
512				\$ -	
513				\$ -	
	<i>Subtotal From Page 2A</i> .....			\$ -	
	<i>Subtotal</i> .....			\$ 1,175,000	
600	f. Miscellaneous Distribution Equipment				
601	(1) Transformers and Meters				
	Construction	<u>Transformers</u>	<u>Meters</u>		
	Underground	1,192	2,800	\$ 2,725,641	
	Overhead	1,735	4,050	\$ 3,534,768	
	AMR Meters			\$ -	
	<i>Subtotal code 601 ... (included in total of all 600 codes below)</i>			\$ 6,260,409	
602	(2) Sets of Service Wires to increase Capacity			\$ 1,456,669	
603	(3) Sectionalizing Equipment			\$ 2,218,635	
604	(4) Regulators			\$ 162,000	
605	(5) Capacitors			\$ 45,000	
606	(6) Pole Replacements			\$ 6,984,975	
607	(7) Miscellaneous Replacements				
608	(8) Conductor Replacements			\$ 4,534,942	
609	(9) Rehabilitation				
610	(10) Cutout Replacements				
	(11)			\$ -	
	<i>Subtotal ALL 600 codes</i> .....			\$ 21,662,630	
700	g. Other Distribution Items				
701	(1) Engineering Fees			\$ -	
702	(2) Security Lights			\$ 3,572,047	
703	(3) Reimbursement of General Funds (see attached)			\$ -	
704	(4) SCADA & AMR Infrastructure			\$ -	
	<i>Subtotal</i> .....			\$ 3,572,047	
<b>TOTAL DISTRIBUTION.....</b>				<b>\$ 48,665,420</b>	
800	2. Transmission				
	a. New Line				
	<u>Line Designation</u>	<u>Voltage</u>	<u>Wire Size</u>	<u>Miles</u>	
801					
802					\$ -
803					\$ -
804					\$ -
805					\$ -
806					\$ -
807					\$ -
808					\$ -
809					\$ -
810					\$ -
	<i>Subtotal - Miles from Page 2A</i> .....				
	<i>Total Miles</i> .....				
	<i>Subtotal From Page 2A</i> .....			\$ -	
	<i>Subtotal</i> .....			\$ -	

THIS PAGE WAS INTENTIONALLY LEFT BLANK.

# FIGURE F-3: RUS FORM 300

According to the Paperwork Reduction Act of 1995, an agency may not conduct or sponsor, and a person is not required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0572-0025. The time required to complete this information collection is estimated to average 4 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information.

UNITED STATES DEPARTMENT OF AGRICULTURE RURAL UTILITIES SERVICE  <b>REVIEW RATING SUMMARY</b>		BORROWER DESIGNATION  KY 65  DATE PREPARED  August 5, 2015																																											
Ratings on form are:      0: Unsatisfactory -- No Records      2: Acceptable, but Should be Improved -- See Attached Recommendations NA: Not Applicable      1: Corrective Action Needed      3: Satisfactory -- No Additional Action Required at this Time																																													
<b>PART I. TRANSMISSION and DISTRIBUTION FACILITIES</b>																																													
<b>1. Substations (Transmission and Distribution)</b> <span style="float: right;">(Rating)</span> a. Safety, Clearance, Code Compliance <span style="float: right;">3</span> b. Physical Conditions: Structure, Major Equipment, Appearance <span style="float: right;">3</span> c. Inspection Records - Each Substation <span style="float: right;">3</span> d. Oil Spill Prevention <span style="float: right;">3</span>		<b>4. Distribution - Underground Cable</b> <span style="float: right;">(Rating)</span> a. Grounding and Corrosion Control <span style="float: right;">3</span> b. Surface Grading, Appearance <span style="float: right;">3</span> c. Riser Pole: Hazards, Guying, Condition <span style="float: right;">3</span>																																											
<b>2. Transmission Lines</b> a. Right-of-Way: Clearing, Erosion, Appearance, Intrusions <span style="float: right;">N/A</span> b. Physical Condition: Structure, Conductor, Guying <span style="float: right;">N/A</span> c. Inspection Program and Records <span style="float: right;">N/A</span>		<b>5. Distribution Line Equipment: Conditions and Records</b> a. Voltage Regulators <span style="float: right;">2</span> b. Sectionalizing Equipment <span style="float: right;">3</span> c. Distribution Transformers <span style="float: right;">3</span> d. Pad Mounted Equipment Safety: Locking, Dead Front, Barriers <span style="float: right;">3</span> Appearance: Settlement, Condition <span style="float: right;">3</span> Other <span style="float: right;">2</span> e. Kilowatt-hour and Demand Meter Reading and Testing <span style="float: right;">3</span>																																											
<b>3. Distribution Lines - Overhead</b> a. Inspection Program and Records <span style="float: right;">3</span> b. Compliance with Safety Codes: Clearances <span style="float: right;">3</span> Foreign Structures <span style="float: right;">3</span> Attachments <span style="float: right;">2</span> c. Observed Physical Condition from Field Checking: Right-of-Way <span style="float: right;">2</span> Other <span style="float: right;">3</span>																																													
<b>PART II. OPERATIONS and MAINTENANCE</b>																																													
<b>6. Line Maintenance and Work Order Procedures</b> <span style="float: right;">(Rating)</span> a. Work Planning & Scheduling <span style="float: right;">3</span> b. Work Backlogs: Right-of-Way Maintenance <span style="float: right;">3</span> Poles <span style="float: right;">3</span> Retirement of Idle Services <span style="float: right;">3</span> Other <span style="float: right;">3</span>		<b>8. Power Quality</b> <span style="float: right;">(Rating)</span> a. General Freedom from Complaints <span style="float: right;">3</span>																																											
<b>7. Service Interruptions</b> a. Average Annual Minutes/Consumer by Cause (Complete for each of the previous 5 years)		<b>9. Loading and Load Balance</b> a. Distribution Transformer Loading <span style="float: right;">3</span> b. Load Control Apparatus <span style="float: right;">3</span> c. Substation and Feeder Loading <span style="float: right;">3</span>																																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>PREVIOUS 5 YEARS (Year)</th> <th>POWER SUPPLIER a.</th> <th>MAJOR EVENT b.</th> <th>PLANNED c.</th> <th>ALL OTHER d.</th> <th>TOTAL e.</th> <th>(Rating)</th> </tr> </thead> <tbody> <tr> <td>2010</td> <td>0.15</td> <td></td> <td>2.06</td> <td>92.94</td> <td>107.15</td> <td>3</td> </tr> <tr> <td>2011</td> <td>5.80</td> <td>77.11</td> <td>5.25</td> <td>135.43</td> <td>223.59</td> <td>3</td> </tr> <tr> <td>2012</td> <td>20.34</td> <td>41.98</td> <td>1.07</td> <td>108.94</td> <td>172.33</td> <td>3</td> </tr> <tr> <td>2013</td> <td>13.75</td> <td>27.71</td> <td>3.94</td> <td>90.88</td> <td>136.28</td> <td>3</td> </tr> <tr> <td>2014</td> <td>1.80</td> <td>27.46</td> <td>6.11</td> <td>90.63</td> <td>126.00</td> <td>3</td> </tr> </tbody> </table>		PREVIOUS 5 YEARS (Year)	POWER SUPPLIER a.	MAJOR EVENT b.	PLANNED c.	ALL OTHER d.	TOTAL e.	(Rating)	2010	0.15		2.06	92.94	107.15	3	2011	5.80	77.11	5.25	135.43	223.59	3	2012	20.34	41.98	1.07	108.94	172.33	3	2013	13.75	27.71	3.94	90.88	136.28	3	2014	1.80	27.46	6.11	90.63	126.00	3	<b>10. Maps and Plant Records</b> a. Operating Maps: Accurate and Up-to-Date <span style="float: right;">3</span> b. Circuit Diagrams <span style="float: right;">3</span> c. Staking Sheets <span style="float: right;">3</span>	
PREVIOUS 5 YEARS (Year)	POWER SUPPLIER a.	MAJOR EVENT b.	PLANNED c.	ALL OTHER d.	TOTAL e.	(Rating)																																							
2010	0.15		2.06	92.94	107.15	3																																							
2011	5.80	77.11	5.25	135.43	223.59	3																																							
2012	20.34	41.98	1.07	108.94	172.33	3																																							
2013	13.75	27.71	3.94	90.88	136.28	3																																							
2014	1.80	27.46	6.11	90.63	126.00	3																																							
b. Emergency Restoration Plan <span style="float: right;">3</span>																																													
<b>PART III. ENGINEERING</b>																																													
<b>11. System Load Conditions and Losses</b> <span style="float: right;">(Rating)</span> a. Annual System Losses <span style="float: right;">4.51%</span> <span style="float: right;">3</span> b. Annual Load Factor <span style="float: right;">45.4%</span> <span style="float: right;">3</span> c. Power Factor at Monthly Peak <span style="float: right;">94.0%</span> <span style="float: right;">3</span> d. Ratios of Individual Substation Annual Peak kW to kVA <span style="float: right;">3</span>		<b>13. Load Studies and Planning</b> <span style="float: right;">(Rating)</span> a. Long Range Engineering Plan <span style="float: right;">3</span> b. Construction Work Plan <span style="float: right;">3</span> c. Sectionalizing Study <span style="float: right;">3</span> d. Load Data for Engineering Studies <span style="float: right;">3</span> e. Load Forecasting Data <span style="float: right;">3</span>																																											
<b>12. Voltage Conditions</b> a. Voltage Surveys <span style="float: right;">3</span> b. Substation Transformer Output Voltage Spread <span style="float: right;">3</span>																																													



**PART IV. OPERATION AND MAINTENANCE BUDGETS**




YEAR	For Previous 2 Years		For Present Year	For Future 3 Years		
	2013	2014	2015	2016	2017	2018
	Actual \$ Thousands	Actual \$ Thousands	Budget \$ Thousands	Budget \$ Thousands	Budget \$ Thousands	Budget \$ Thousands
Normal Operation	4,172	4,133	4,020	4,277	4,362	4,449
Normal Maintenance	8,633	8,749	9,226	9,858	10,055	10,256
Additional (Deferred) Maintenance						
<b>Total</b>	<b>12,805</b>	<b>12,882</b>	<b>13,246</b>	<b>14,135</b>	<b>14,417</b>	<b>14,705</b>

14. Budgeting: Adequacy of Budgets for Needed Work 3 (Rating)

15. Date Discussed with Board of Directors 9/8/2015 (Date)

**EXPLANATORY NOTES**

ITEM NO.	COMMENTS
Part I Sec 3b	Telephone and cable attachments need to be transferred from abandoned poles and be more timely in responding to transfer notices
Part I, Sec 3c	Some trees in yards in need of trimming for better clearance from lines
Part II, Sec 7a	The 2011 "All Other" category score was 204.39 minutes. This exceeds the 200 minutes or less recommended by this section for a "satisfactory" rating. On May 26, 2011 Kenergy was dealing with a minor storm on the heels of a major event (Tmed) storm on May 25, 2011. The storm of May 26, 2011 did not reach a magnitude as to be classified as a major event and therefore contributed 28.3 minutes to the 2011 "All Other" category. Had this minor event not occurred, Kenergy's 2011 "All Other" category would have been 176.09 which would be in-line with previous years. Kenergy continues to evaluate it's reliability through the AAR After Action Review process for major and minor events. Kenergy is in the process of installing a new radio system which brings with it vehicle GPS capabilities. Kenergy believes this will greatly enhance our ability to respond. Kenergy is also investigating an AMI solution that would bring quicker clarity to our OMS Outage Management System and thereby further increase our reliability and response capabilities.

	TITLE	DATE
RATED BY: 	V. P. Engineering V. P. Operations	08/05/15
REVIEWED BY: 	President & CEO	08/05/15
REVIEWED BY: 	RUS GFR	08/05/15

THIS PAGE WAS INTENTIONALLY LEFT BLANK.

## FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

The data contained in this Section details the calculations for the cost of losses and the economic conductor evaluation.

### A. Cost of Losses

The cost of losses was calculated based on the wholesale power costs obtained from Kenergy of \$0.045 per kWh for energy and \$13.81 per kW for demand. The calculated load factor was based on average of 2012, 2013, and 2014 monthly billing demands yielding an average annual load factor of 46.5% for the Rural System. The cost of losses for one kW of loss at peak is \$233.00. The calculation is present below.

FIGURE F-4: SYSTEM LOSS CALCULATION 2016-2020 KENERGY CWP ANNUAL COST OF LOSS PER KW						
LOAD LOSS CALCULATION						
COST FOR DEMAND	1KW*DR*DF					
COST FOR ENERGY	(.84(LF^2)+.16(LF))*1KW*ER*8760					
DR EXISTING POWER DEMAND RATE						13.81
LF THREE YEAR AVERAGE LOAD FACTOR						46.5%
ER EXISTING POWER ENERGY RATE						0.045
DF= THREE YEAR ANNUAL DEMAND FACTOR						9.57
LOAD LOSS						
COST FOR DEMAND						\$ 132.18
COST FOR ENERGY						\$ 100.82
ANNUAL COST FOR 1KW OF PEAK LOSS						\$ 233.00
LOAD FACTOR CALCULATION				DEMAND FACTOR*		
Month	Peak Load (kW)			Three Year Average	Percent of Peak	Percent of Peak Squared
	2014	2013	2012			
January	329,679	255,843	255,147	280,223	99.46%	0.99
February	293,368	265,274	239,132	265,925	94.39%	0.89
March	254,682	240,101	206,463	233,749	82.97%	0.69
April	198,609	203,161	197,787	199,852	70.94%	0.50
May	226,875	224,123	259,735	236,911	84.09%	0.71
June	263,706	266,546	300,161	276,805	98.25%	0.97
July	270,780	266,146	308,272	281,733	100.00%	1.00
August	277,640	266,181	291,231	278,351	98.80%	0.98
September	261,329	256,646	260,209	259,395	92.07%	0.85
October	218,513	216,783	200,303	211,866	75.20%	0.57
November	249,748	229,379	225,411	234,846	83.36%	0.69
December	234,161	255,905	238,293	242,786	86.18%	0.74
System Peak	329,679	266,546	308,272	281,733		9.57
Ann. MWh Purch.	1,240,267	1,221,667	1,192,208	1,218,048		
Ann. Load Factor	42.95%	52.32%	44.15%	46.5%		
Notes : (1) Data from Kenergy and 2015 Load Forecast						
Notes : (*) PEAK RESPONSIBILITY FACTORS (% OF PEAK=LOAD, % OF PEAK SQUARED=LOSS)						

## FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

---

### B. Economic Conductor Selection

Economic conductor selection includes the consideration of the initial construction costs and the associated losses of selected conductors to be compared. Each conductor was analyzed at different load levels. Alternative conductors will have a different evaluation cost for each load level which is comprised of the construction cost plus the variable costs related to line losses. In addition, since a distribution line is used for many years, economic factors are also considered such as load growth, cost of losses, power cost increases, and the present worth. The analysis was broken down into overhead conductors and underground cables. For overhead conductors, an analysis was completed for both 12.47kV and 25kV considering both new and reconductor construction. The underground analysis focused on new 12.47kV construction only.

#### 12.47kV Operating Voltage

The following general guidelines were developed based upon the analysis for overhead and underground conductors operating at 12.47/7.2kV.

#### Single Phase Overhead

New and reconducted single phase lines should be generally constructed with 1/0 ACSR unless there is no possibility of load growth. If load growth is limited 2 ACSR should be used. 2 ACSR is adequate for loads up to 288 kW (40 Amps)

#### Three Phase Overhead-New Construction

New three phase 12.47 kV distribution lines should be constructed with the following conductors:

- For loads less than 750kW: 2 ACSR
- For loads between 750-1800kW: 1/0 ACSR
- For loads between 1800-2100kW: 4/0 ACSR
- For load greater than 2100kW: 336 ACSR

#### Three Phase Overhead-Conversion of Existing Construction

## FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

Existing three phase distribution lines should be reconducted based on the following:

- For loads less than 750kW: 2 ACSR
- For loads between 750-1800kW: 1/0 ACSR
- For loads between 1800-2550kW: 4/0 ACSR
- For load greater than 2550kW: 336 ACSR


### Underground Construction

New underground distribution lines should be constructed based on the following:

- For loads less than 600kW: 2 AL URD
- For loads between 600-2100kW: 1/0 AL URD
- For loads between 2100-4050kW: 4/0 AL URD
- For load greater than 4050kW: 500 AL URD

The economic conductor selection curves for 12.47kV construction are presented below:

**Figure F-4: Overhead Conductor Optimization  
New Construction-12.47kV  
Kenergy**



# FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

Figure F-4: Overhead Conductor Optimization  
Reconductor-12.47kV  
Kenergy





Figure F-4: Underground Conductor Optimization  
New Construction-12.47kV  
Kenergy



## FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

---

### 25kV Operating Voltage

The following general guidelines were developed based upon the analysis for overhead and underground conductors operating at 24.9/14.4 kV.

### Single Phase Overhead

New and recondored single phase lines should be generally constructed with 1/0 ACSR unless there is no possibility of load growth. If load growth is limited 2 ACSR should be used. 2 ACSR is adequate for loads up to 288 kW (40 Amps)

### Three Phase Overhead-New Construction

New three phase 25 kV distribution lines should be constructed with the following conductors:

- For loads less than 1500kW: 2 ACSR
- For loads between 1500-3600kW: 1/0 ACSR
- For loads between 3600-4350kW: 4/0 ACSR
- For load greater than 4350kW: 336 ACSR

### Three Phase Overhead-Conversion of Existing Construction

Existing three phase 25 kV distribution lines should be recondored based on the following:

- For loads less than 1500kW: 2 ACSR
- For loads between 1500-3450kW: 1/0 ACSR
- For loads between 3450-5250kW: 4/0 ACSR
- For load greater than 5250kW: 336 ACSR

# FIGURE 4: SYSTEM LOSS AND ECONOMIC CONDUCTOR

Figure F-4: Overhead Conductor Optimization  
New Construction-25kV  
Kenergy





Figure F-4: Overhead Conductor Optimization  
Reconductor-25kV  
Kenergy





THIS PAGE WAS INTENTIONALLY LEFT BLANK.

# FIGURE F-5: WEAVERTON STATION EXPLORATORY COST ANALYSIS

## EXPLORATORY STUDY 1: WEAVERTON STATION RELOCATION

(ALL COSTS ARE THE THE ACCUMULATED PRESENT WORTH OF THE INFLATED COST)


COMPARISON OF PRESENT WORTH ANALYSIS PLAN 1 VS PLAN 2

### TOTAL COSTS (\$)


(Capitalized Costs + Losses)

	PLAN 1	PLAN 2
2016	77,500	77,500
2017	233,200	163,500
2018	383,000	247,100
2019	527,100	328,400
2020	665,900	407,300
2021	799,600	484,100
2025	1,287,200	771,100
2030	1,805,600	1,090,100
2035	2,241,400	1,371,800
2040	2,610,900	1,622,600
2045	2,926,700	1,847,400

For first 6 years, favors **PLAN 2 by 39.5%**




At 30 years, favors **PLAN 2 by 36.9%**




### TOTAL CAPITALIZED COSTS (\$)

	PLAN 1	PLAN 2
2016	0	0
2017	112,800	40,000
2018	220,300	78,100
2019	322,600	114,400
2020	420,000	149,000
2021	512,900	181,900
2025	842,000	298,700
2030	1,172,600	415,900
2035	1,431,600	507,800
2040	1,634,600	579,800
2045	1,793,600	636,200

For first 6 years, favors **PLAN 2 by 64.5%**




At 30 years, favors **PLAN 2 by 64.5%**




### TOTAL COST OF LOSSES (\$)

	PLAN 1	PLAN 2
2016	77,500	77,500
2017	120,300	123,500
2018	162,700	169,000
2019	204,500	213,900
2020	245,900	258,300
2021	286,700	302,200
2025	445,300	472,500
2030	633,000	674,100
2035	809,800	864,000
2040	976,300	1,042,800
2045	1,133,100	1,211,200

For first 6 years, favors **PLAN 1 by 5.1%**




At 30 years, favors **PLAN 1 by 6.4%**




### TOTAL ACCUMULATED LOSSES (MWh)

	PLAN 1	PLAN 2
2016	910	910
2017	1,430	1,470
2018	1,970	2,040
2019	2,510	2,630
2020	3,070	3,230
2021	3,640	3,840
2025	6,040	6,420
2030	9,360	9,990
2035	13,070	13,960
2040	17,200	18,400
2045	21,800	23,350

For first 6 years, favors **PLAN 1 by 5.2%**



At 30 years, favors **PLAN 1 by 6.6%**



- 6.19% Fixed Charge Rate
- 2.00% Annual cost inflation rate - Construction
- 5.00% Annual present worth rate - Cost of construction
- 1.10% Annual growth rate - kW demand
- 1.50% Annual cost inflation rate of energy - kWh
- 5.00% Annual present worth rate - Cost of kWh losses

PLAN 1  
 PLAN 2

WEAVERTON STATION RELOCATION  
 WEAVERTON DISTRIBUTION UPGRADES

**EXPLORATORY STUDY 1: WEAVERTON STATION RELOCATION**  
 COMPARISON OF PRESENT WORTH ANALYSIS PLAN 1 vs PLAN 2

ENGINEER: POWERSERVICES

COMPANY: KENERGY

PLAN 1: WEAVERTON STATION RELOCATION

NOTE: AREA (OR CIRCUIT) GROWTH RATE GIVEN AT 1.10%  
 THUS, LOSSES INCREASE ANNUALLY AT 2.21%

YEAR	DESCRIPTION of CONSTRUCTION	CHANGES PEAK kW LOSSES	ESTIMATED COST of NEW CONSTRUCTION				DEMAND and ENERGY LOSSES and COSTS			
			PRESENT YEAR EST. COST	INFLATED COST 2.00%	PRESENT WORTH 5.00%	FIXED CHARGES 6.19%	kW LOSSES		INFLATED COST OF:	
							Ann. Peak	kWh Annual	ANNUAL kW 1.50%	ANNUAL kWh 1.50%
2016						260.0	911,664	36,465	41,025	
						221.0	911,664			
	\$ 77,490 TOTAL for Year				\$ 0			\$ 36,465	\$ 41,025	
	\$ 77,490 ACCUMULATED through Year End				\$ 0			\$ 36,465	\$ 41,025	
2017	NEW STATION CONSTRUCTION	-117.0	1,000,000	1,020,000	971,429	148.8	521,582	21,175	23,823	
	NEW TRANSMISSION CONSTRUCTION		825,000	841,500	801,429	126.4	1,433,246			
	NEW STATION EXITS		50,000	51,000	48,571					
	155,673 TOTAL for Year		1,875,000	1,912,500	1,821,429			20,167	22,689	
	233,163 ACCUM. thru Year		1,875,000		112,818			56,632	63,714	
2018						152.0	533,120	21,968	24,716	
						129.2	1,966,366			
	149,789 TOTAL for Year				107,445			19,926	22,418	
	382,952 ACCUM. thru Year		1,875,000		220,263			76,558	86,131	
2019						155.4	544,913	22,791	25,641	
						132.1	2,511,279			
	144,167 TOTAL for Year				102,329			19,688	22,150	
	527,119 ACCUM. thru Year		1,875,000		322,592			96,246	108,281	
2020						158.8	556,967	23,645	26,602	
						135.0	3,068,247			
	138,794 TOTAL for Year				97,456			19,453	21,885	
	665,913 ACCUM. thru Year		1,875,000		420,048			115,698	130,166	
2021						162.4	569,288	24,530	27,598	
						138.0	3,637,534			
	133,659 TOTAL for Year				92,815			19,220	21,624	
	799,572 ACCUM. thru Year		1,875,000		512,864			134,919	151,790	
2022						165.9	581,881	25,449	28,631	
						141.1	4,219,416			
	128,751 TOTAL for Year				88,396			18,990	21,365	
	928,323 ACCUM. thru Year		1,875,000		601,259			153,909	173,155	
2023						169.6	594,753	26,402	29,704	
						144.2	4,814,168			
	124,060 TOTAL for Year				84,186			18,764	21,110	
	1,052,383 ACCUM. thru Year		1,875,000		685,445			172,673	194,265	
2024						173.4	607,909	27,391	30,816	
						147.4	5,422,078			
	119,574 TOTAL for Year				80,177			18,539	20,858	
	1,171,958 ACCUM. thru Year		1,875,000		765,623			191,212	215,123	
2025						177.2	621,357	28,417	31,970	
						150.6	6,043,435			
	115,286 TOTAL for Year				76,359			18,318	20,608	
	1,287,243 ACCUM. thru Year		1,875,000		841,982			209,530	235,731	

Complete 30 year analysis was completed but not included in printed document.

**EXPLORATORY STUDY 1: WEAVERTON STATION RELOCATION**  
 COMPARISON OF PRESENT WORTH ANALYSIS PLAN 1 vs PLAN 2

ENGINEER: POWERSERVICES

COMPANY: KENERGY

PLAN 2: WEAVERTON DISTRIBUTION UPGRADES

NOTE: AREA (OR CIRCUIT) GROWTH RATE GIVEN AT 1.10%  
 THUS, LOSSES INCREASE ANNUALLY AT 2.21%

YEAR	DESCRIPTION of CONSTRUCTION	CHANGES PEAK kW LOSSES	ESTIMATED COST of NEW CONSTRUCTION				DEMAND and ENERGY LOSSES and COSTS			
			PRESENT YEAR EST. COST	INFLATED COST 2.00%	PRESENT WORTH 5.00%	FIXED CHARGES 6.19%	kW LOSSES Ann. Peak	kWh LOSSES Annual	INFLATED COST OF:	
			Month Avg.	Accumulated	1.50%	1.50%				
2016						260.0	911,664	36,465	41,025	
	\$ 77,490 TOTAL COST for Year				\$ 0	221.0	911,664			
	\$ 77,490 ACCUMULATED through Year End				\$ 0			\$ 36,465	\$ 41,025	
2017	CWP 504- NEW CIRCUIT EXIT CWP 392 DUAL CIRCUIT CWP 393 LINE CONVERSION	-106.0	200,000 247,500 217,620	204,000 252,450 221,972	194,286 240,429 211,402	12,034 14,892 13,094	159.8 135.8	560,153 1,471,817	22,741	25,585
	86,045 TOTAL for Year		665,120	678,422	646,117	40,020			21,658	24,367
	163,535 ACCUMULATED thru Year		665,120			40,020			58,123	65,392
2018							163.3 138.8	572,544 2,044,360	23,593	26,543
	83,589 TOTAL for Year		0	0	0	38,114			21,399	24,075
	247,124 ACCUMULATED thru Year		665,120			78,134			79,523	89,467
2019							166.9 141.9	585,209 2,629,569	24,477	27,537
	81,231 TOTAL for Year		0	0	0	36,299			21,144	23,788
	328,355 ACCUMULATED thru Year		665,120			114,433			100,667	113,255
2020							170.6 145.0	598,154 3,227,723	25,393	28,569
	78,965 TOTAL for Year		0	0	0	34,571			20,891	23,504
	407,320 ACCUMULATED thru Year		665,120			149,004			121,558	136,758
2021							174.4 148.2	611,386 3,839,109	26,344	29,639
	76,789 TOTAL for Year		0	0	0	32,924			20,641	23,223
	484,108 ACCUMULATED thru Year		665,120			181,928			142,199	159,981
2022							178.2 151.5	624,911 4,464,020	27,331	30,749
	74,697 TOTAL for Year		0	0	0	31,357			20,395	22,945
	558,805 ACCUMULATED thru Year		665,120			213,285			162,594	182,926
2023							182.2 154.8	638,734 5,102,754	28,355	31,900
	72,686 TOTAL for Year		0	0	0	29,863			20,151	22,671
	631,491 ACCUMULATED thru Year		665,120			243,149			182,745	205,597
2024							186.2 158.3	652,864 5,755,618	29,417	33,095
	70,752 TOTAL for Year		0	0	0	28,441			19,910	22,400
	702,242 ACCUMULATED thru Year		665,120			271,590			202,655	227,997
2025							190.3 161.8	667,306 6,422,923	30,518	34,335
	68,892 TOTAL for Year		0	0	0	27,087			19,672	22,132
	771,134 ACCUMULATED thru Year		665,120			298,677			222,328	250,129

Complete 30 year analysis was completed but not included in printed document.

THIS PAGE WAS INTENTIONALLY LEFT BLANK.

**Table T-1: Substation Transformers Loading Analysis- Summer  
2016-2020 Kenergy CWP**

Substation Transformer	Summer Capacity (MVA)	Peak Load (KW)			Power Factor @Peak	Percent Loaded	
		2012 Actual	2019 Forecast	CWP Projected (1)		2012	CWP
Adams Lane	10	5,242	5,379		92.8%	52%	54%
Beda	10	7,731	7,751		94.4%	77%	78%
Beech Grove	10	4,193	4,204	4,654	93.9%	42%	47%
Bon Harbor	10	8,029	8,085		93.5%	80%	81%
Caldwell Springs	10	1,957	2,388		94.7%	20%	24%
Centertown	3.75	1,827	1,832		93.7%	49%	49%
Crossroads	10	5,197	5,211		97.7%	52%	52%
Dermont	10	7,588	7,769		94.0%	76%	78%
Dixon	10	4,190	4,201		93.5%	42%	42%
East Owensboro	10	4,815	7,200		94.0%	48%	72%
Geneva	10	5,978	6,180		93.4%	60%	62%
Guffie	10	7,284	7,335		93.8%	73%	73%
Hanson	5	2,635	3,495	2,507	90.7%	53%	50%
Hawesville	10	7,899	7,955		93.1%	79%	80%
Horse Fork	15	12,053	12,270		91.5%	80%	82%
Hudson #1	10	8,541	8,373		90.8%	85%	84%
Hudson #2(Tyson)	10	9,273	9,790		89.9%	93%	98%
Lewisport #1	10	6,648	6,597		92.4%	66%	66%
Lewisport #2	10	2,780	2,759		92.4%	28%	28%
Little Dixie	7.5	3,218	3,487		96.1%	43%	46%
Lyon	10	6,251	6,343		95.8%	63%	63%
Maceo	10	3,428	3,437		93.6%	34%	34%
Madisonville	10	5,197	5,234		98.4%	52%	52%
Marion	10	6,707	6,725		92.4%	67%	67%
Masonville	10	4,847	7,169		96.5%	48%	72%
Morganfield	10	8,761	9,423		95.7%	88%	94%
Niagara	10	6,499	6,545		95.0%	65%	65%
Nuckols	10	4,841	4,853		95.4%	48%	49%
Onton	10	4,374	4,924	5,049	90.5%	44%	50%
Philpot #1	10	5,618	5,587		94.3%	56%	56%
Philpot #2	10	4,037	4,015		94.3%	40%	40%
Pleasant Ridge	10	4,789	4,823		95.5%	48%	48%
Providence	10	4,799	4,833		94.9%	48%	48%
Race Creek	10	5,936	5,977		95.7%	59%	60%
Riverport	10	3,623	4,122		86.2%	36%	41%
Sacramento	3.75	3,023	3,203		94.7%	81%	85%
Sebree	5	4,400	4,412		94.7%	88%	88%
South Dermont #1	10	10,705	9,132		93.8%	107%	91%
South Dermont #2	10	8,910	7,403		87.4%	89%	74%
South Hanson #1	10	4,724	4,525		93.3%	47%	45%
South Hanson #2	10	6,026	5,772	7,335	93.3%	60%	73%
South Owensboro #1	10	5,417	6,182		94.8%	54%	62%
South Owensboro #2	10	6,020	6,990		94.8%	60%	70%
Stanley	5	2,887	2,894		94.8%	58%	58%
St. Joe	7.5	5,103	5,545		96.1%	68%	74%
Sullivan	10	2,618	2,878		92.0%	26%	29%
Thruston #1	10	5,436	4,489		93.0%	54%	45%
Thruston #2	10	5,391	4,452		93.0%	54%	45%
Utica	10	6,227	6,244		95.0%	62%	62%
Weaverton	10	4,918	4,953		92.2%	49%	50%
Weberstown	10	5,806	5,847		94.1%	58%	58%
West Owensboro	12	7,860	8,275		92.4%	66%	69%
Whitesville	10	7,407	7,426		93.5%	74%	74%
Wolf Hills	10	3,258	3,429		93.2%	33%	34%
Yager	5	119	119		75.4%	2%	2%
Zion	10	7,329	7,380		96.4%	73%	74%

(1) CWP Load Shifts: 450kW from Onton to Beech Grove Station- CWP 603-58  
988kW from Hanson to South Hanson2- CWP 603-18  
575kW from South Hanson2 to Onton- CWP 391

**Table T-1: Substation Transformers Loading Analysis- Winter  
2016-2020 Kenergy CWP**

Substation Transformer	Winter Capacity (MVA)	Peak Load (KW)			Power Factor @Peak	Percent Loaded	
		2014 Actual	Projected 2019-2020	CWP Projected (1)		2014	CWP
Adams Lane	13	5,830	6,022		99.7%	45%	46%
Beda	13	9,390	9,444		99.5%	72%	73%
Beech Grove	13	5,087	5,116	5,566	99.1%	39%	43%
Bon Harbor	13	6,493	6,595		99.3%	50%	51%
Caldwell Springs	13	2,683	2,773		100.2%	21%	21%
Centertown	4.875	3,126	3,144		99.0%	64%	64%
Crossroads	13	7,063	7,104		100.0%	54%	55%
Dermont	13	6,435	6,566		98.6%	49%	51%
Dixon	13	5,668	5,700		98.9%	44%	44%
East Owensboro	13	4,011	5,732		98.6%	31%	44%
Geneva	13	7,876	8,000		99.7%	61%	62%
Guffie	13	8,143	8,271		98.9%	63%	64%
Hanson	6.5	4,434	4,960	3,972	97.2%	68%	61%
Hawesville	13	8,191	8,319		98.8%	63%	64%
Horse Fork	19.5	7,284	7,530		98.1%	37%	39%
Hudson #1	13	7,795	8,220		94.7%	60%	63%
Hudson #2(Tyson)	13	7,309	8,408		92.3%	56%	65%
Lewisport #1	13	6,299	6,038		97.4%	48%	46%
Lewisport #2	13	2,709	2,597		97.4%	21%	20%
Little Dixie	9.75	4,005	4,080		99.7%	41%	42%
Lyon	13	5,828	5,967		99.6%	45%	46%
Maceo	13	4,050	4,073		99.1%	31%	31%
Madisonville	13	5,430	5,515		97.1%	42%	42%
Marion	13	7,970	8,016		99.0%	61%	62%
Masonville	13	4,536	4,818		100.0%	35%	37%
Morganfield	13	11,029	11,802		98.5%	85%	91%
Niagara	13	9,221	9,366		99.7%	71%	72%
Nuckols	13	5,618	5,716		99.0%	43%	44%
Onton	13	7,400	7,543	7,668	98.6%	57%	59%
Philpot #1	13	4,627	4,723		99.4%	36%	36%
Philpot #2	13	3,720	3,797		99.4%	29%	29%
Pleasant Ridge	13	6,486	6,588		99.8%	50%	51%
Providence	13	6,721	6,826		99.4%	52%	53%
Race Creek	13	6,953	7,062		99.5%	53%	54%
Riverport	13	4,162	4,186		88.4%	32%	32%
Sacramento	4.875	4,251	4,275		99.1%	87%	88%
Sebree	6.5	4,588	4,614		98.3%	71%	71%
South Dermont #1	13	4,335	4,760		98.7%	33%	37%
South Dermont #2	13	4,931	5,126		98.7%	38%	39%
South Hanson #1	13	7,815	7,922		98.8%	60%	61%
South Hanson #2	13	8,897	9,019	10,582	98.8%	68%	81%
South Owensboro #1	13	3,668	3,696		98.9%	28%	28%
South Owensboro #2	13	4,601	4,756		98.9%	35%	37%
Stanley	6.5	3,778	3,800		99.9%	58%	58%
St. Joe	9.75	4,857	4,985		99.2%	50%	51%
Sullivan	13	3,182	3,767		98.4%	24%	29%
Thruston #1	13	5,560	5,626		99.1%	43%	43%
Thruston #2	13	4,750	4,806		99.1%	37%	37%
Utica	13	8,145	8,192		99.4%	63%	63%
Weaverton	13	5,890	5,983		98.9%	45%	46%
Weberstown	13	8,299	8,429		99.2%	64%	65%
West Owensboro	15.6	6,895	7,330		98.9%	44%	47%
Whitesville	13	8,567	8,616		98.5%	66%	66%
Wolf Hills	13	3,059	3,107		99.8%	24%	24%
Yager	6.5	108	123		76.1%	2%	2%
Zion	13	9,901	10,057		99.9%	76%	77%

(1) CWP Load Shifts: 450kW from Onton to Beech Grove Station- CWP 603-58  
988kW from Hanson to South Hanson2- CWP 603-18  
575kW from South Hanson2 to Onton- CWP 391

THIS PAGE WAS INTENTIONALLY LEFT BLANK.





Table T-2: CWP Total System and Substation NCP Load Forecast- Winter  
2016-2020 Kenergy CWP

Substation	Winter Station Billing Data (6)							Maximum Station Peak 2012-15	2016 LF GR	2016 LF GR-ADJ	2016 GR-KW	2017 LF GR	2017 LF GR-ADJ	2017 GR-KW	2018 LF GR	2018 LF GR-ADJ	2018 GR-KW	2019 LF GR	2019 LF GR-ADJ	2019 GR-KW	Growth Code- Adjust Factor	CWP Load Growth- KW	Future Station NCP Analysis- CWP			
	Jan-12	Feb-12	Jan-13	Feb-13	Jan-14	Jan-15	Feb-15																Growth Adjusted- Station Peak	Spot Loads-KW	Final CWP- Station Peak	
ADAMS LANE	5811	4525	5082	5696	5830	5331.2	5446	5830	0.9%	0.6%	36.55	0.4%	0.3%	16.31	0.5%	0.3%	18.32	0.5%	0.3%	20.31	A	0.68	92	5922	100	6022
BEDA	6357	6402	6409	6636	9390	7853.8	7964	9390	0.9%	0.2%	21.64	0.4%	0.1%	9.62	0.5%	0.1%	10.79	0.5%	0.1%	11.94	L	0.25	54	9444		9444
BEECH GROVE	4439	3681	3797	4050	5087	4801.6	4847	5087	0.9%	0.2%	11.73	0.4%	0.1%	5.21	0.5%	0.1%	5.84	0.5%	0.1%	6.47	L	0.25	29	5116		5116
BON HARBOR	4957	4523	4730	4802	6493	5819	5534	6493	0.9%	0.6%	40.71	0.4%	0.3%	18.16	0.5%	0.3%	20.41	0.5%	0.3%	22.62	A	0.68	102	6595		6595
CALDWELL SPRINGS	1918	1840	1925	2022	2683	2540.2	2657	2683	0.9%	0.2%	6.18	0.4%	0.1%	2.75	0.5%	0.1%	3.08	0.5%	0.1%	3.41	L	0.25	15	2698	75	2773
CANNELTON	586	616	661	619	557	395.2	735	735	0.9%	0.2%	1.70	0.4%	0.1%	0.75	0.5%	0.1%	0.84	0.5%	0.1%	0.93	L	0.25	4	740		740
CENTERTOWN	2335	2380	2307	2478	3126	2690	2800	3126	0.9%	0.2%	7.20	0.4%	0.1%	3.20	0.5%	0.1%	3.59	0.5%	0.1%	3.97	L	0.25	18	3144		3144
CROSSROADS	4860	4886	5016	5352	7063	6544.8	6512	7063	0.9%	0.2%	16.28	0.4%	0.1%	7.24	0.5%	0.1%	8.11	0.5%	0.1%	8.98	L	0.25	41	7104		7104
DERMONT	5210	4128	4622	4640	6435	5663.6	5502	6435	0.9%	0.6%	40.34	0.4%	0.3%	18.00	0.5%	0.3%	20.22	0.5%	0.3%	22.42	A	0.68	101	6536	30	6566
DIXON	4143	3884	4247	4380	5668	5572.8	5491	5668	0.9%	0.2%	13.06	0.4%	0.1%	5.81	0.5%	0.1%	6.51	0.5%	0.1%	7.20	L	0.25	33	5700		5700
EAST OWENSBORO	3370	2825	2812	2722	4011	4555.4	4322	4555	0.9%	0.6%	28.56	0.4%	0.3%	12.74	0.5%	0.3%	14.32	0.5%	0.3%	15.87	A	0.68	71	4627	1105	5732
GENEVA	6017	5184	5949	6279	7876	7393.6	6525	7876	0.9%	0.6%	49.38	0.4%	0.3%	22.03	0.5%	0.3%	24.75	0.5%	0.3%	27.44	A	0.68	124	8000		8000
GUFFIE	5858	5832	6216	6458	8143	7382.8	7305	8143	0.9%	0.6%	51.05	0.4%	0.3%	22.78	0.5%	0.3%	25.59	0.5%	0.3%	28.37	A	0.68	128	8271		8271
HANSON	3069	3041	3218	3164	4434	4374	4290	4434	0.9%	0.2%	43.74	0.4%	0.1%	10.22	0.5%	0.1%	4.54	0.5%	0.1%	5.64	L	0.25	25	4460	500	4960
HAWESVILLE	5910	5676	6305	6188	8191	7426	7491	8191	0.9%	0.6%	51.35	0.4%	0.3%	22.91	0.5%	0.3%	25.74	0.5%	0.3%	28.54	A	0.68	129	8319		8319
HORSE FORK	7163	7698	6445	6644	7284	7179.8	6748	7284	0.9%	0.6%	45.67	0.4%	0.3%	20.37	0.5%	0.3%	22.89	0.5%	0.3%	25.38	A	0.68	114	7398	132	7530
HUDSON	14975	14651	16102	15688	15146	15675	15682	15682	0.9%	0.6%	98.32	0.4%	0.3%	43.87	0.5%	0.3%	49.28	0.5%	0.3%	54.64	A	0.68	246	15928	700	16628
LEWISPORT	7063	6655	7024	7018	8586	7711.2	7970	8586	0.9%	0.2%	19.79	0.4%	0.1%	8.80	0.5%	0.1%	9.86	0.5%	0.1%	10.91	L	0.25	49	8635		8635
LITTLE DIXIE	3192	2808	3102	3162	4005	4056.4	3936	4056	0.9%	0.2%	9.35	0.4%	0.1%	4.16	0.5%	0.1%	4.66	0.5%	0.1%	5.16	L	0.25	23	4080		4080
LYON COUNTY	4177	4044	4091	4303	5828	7888.4	5404	5828	0.9%	0.6%	36.54	0.4%	0.3%	16.30	0.5%	0.3%	18.31	0.5%	0.3%	20.30	A	0.68	91	5919	48	5967
MACEO	2948	2851	3162	3065	4050	3635.2	3661	4050	0.9%	0.2%	9.34	0.4%	0.1%	4.15	0.5%	0.1%	4.65	0.5%	0.1%	5.15	L	0.25	23	4073		4073
MADISONVILLE	4335	3843	4983	4990	5430	5093.2	5340	5430	0.9%	0.6%	34.05	0.4%	0.3%	15.19	0.5%	0.3%	17.07	0.5%	0.3%	18.92	A	0.68	85	5515		5515
MARION	6143	5586	5761	6318	7970	7445.6	7355	7970	0.9%	0.2%	18.37	0.4%	0.1%	8.16	0.5%	0.1%	9.16	0.5%	0.1%	10.13	L	0.25	46	8016		8016
MASONVILLE	2456	2300	3493	3104	4536	4024	3933	4536	0.9%	0.2%	10.46	0.4%	0.1%	4.65	0.5%	0.1%	5.21	0.5%	0.1%	5.77	L	0.25	26	4562	256	4818
MORGANFIELD	8081	7296	8126	8443	11029	10180	9474	11029	0.9%	0.6%	69.15	0.4%	0.3%	30.85	0.5%	0.3%	34.66	0.5%	0.3%	38.43	A	0.68	173	11202	600	11802
NIAGARA	6687	6059	6480	7147	9221	8210.2	8268	9221	0.9%	0.6%	57.81	0.4%	0.3%	25.79	0.5%	0.3%	28.98	0.5%	0.3%	32.13	A	0.68	145	9366		9366
NUCKOLS	4504	4290	4692	5087	5618	5631.2	5683	5683	0.9%	0.2%	13.10	0.4%	0.1%	5.82	0.5%	0.1%	6.53	0.5%	0.1%	7.22	L	0.25	33	5716		5716
ONTON	4844	4717	4847	5187	7400	7141	7099	7400	0.9%	0.2%	17.06	0.4%	0.1%	7.58	0.5%	0.1%	8.50	0.5%	0.1%	9.41	L	0.25	43	7443	100	7543
PHILPOT	6506	6098	6856	6869	8327	7477.8	7471	8327	0.9%	0.9%	76.77	0.4%	0.4%	34.35	0.5%	0.5%	38.65	0.5%	0.5%	42.91	H	1.00	193	8519		8519
PLEASANT RIDGE	4581	4419	4536	4964	6486	5909.8	5605	6486	0.9%	0.6%	40.67	0.4%	0.3%	18.14	0.5%	0.3%	20.38	0.5%	0.3%	22.60	A	0.68	102	6588		6588
PROVIDENCE	4948	4892	5041	5419	6721	6448	6411	6721	0.9%	0.6%	42.14	0.4%	0.3%	18.80	0.5%	0.3%	21.12	0.5%	0.3%	23.42	A	0.68	105	6826		6826
RACE CREEK	4977	4504	4925	5268	6953	5922.8	5670	6953	0.9%	0.6%	43.59	0.4%	0.3%	19.45	0.5%	0.3%	21.85	0.5%	0.3%	24.23	A	0.68	109	7062		7062
RIVERPORT	4266	4263	4375	4863	4162	4158	3957	4162	0.9%	0.2%	41.58	0.4%	0.1%	9.59	0.5%	0.1%	4.26	0.5%	0.1%	5.29	L	0.25	24	4186		4186
S. OWENSBORO	7426	6908	7232	7141	8204	7944.4	7614	8204	0.9%	0.6%	51.43	0.4%	0.3%	22.95	0.5%	0.3%	25.78	0.5%	0.3%	28.58	A	0.68	129	8332	120	8452
SACRAMENTO	2906	2790	2952	3159	4251	3709.8	3807	4251	0.9%	0.2%	9.80	0.4%	0.1%	4.35	0.5%	0.1%	4.88	0.5%	0.1%	5.40	L	0.25	24	4275		4275
SEBREE	4193	3969	4082	4478	4588	4273.6	4251	4588	0.9%	0.2%	10.57	0.4%	0.1%	4.70	0.5%	0.1%	5.27	0.5%	0.1%	5.83	L	0.25	26	4614		4614
SOUTH DERMONT	9532	8929	8476	8139	9266	9266.4	9318	9318	0.9%	0.9%	85.91	0.4%	0.4%	38.44	0.5%	0.5%	43.25	0.5%	0.5%	48.02	H	1.00	216	9534	352	9886
SOUTH HANSON	11288	10666	12001	12999	16679	16284.4	16103	16679	0.9%	0.6%	104.57	0.4%	0.3%	46.66	0.5%	0.3%	52.42	0.5%	0.3%	58.11	A	0.68	262	16941		16941
ST. JOE	3366	3532	3775	3872	4857	4655.8	4452	4857	0.9%	0.2%	11.19	0.4%	0.1%	4.98	0.5%	0.1%	5.58	0.5%	0.1%	6.17	L	0.25	28	4885	100	4985
STANLEY	2667	2527	2563	2686	3778	3308	3198	3778	0.9%	0.2%	8.71	0.4%	0.1%	3.87	0.5%	0.1%	4.34	0.5%	0.1%	4.80	L	0.25	22	3800		3800
SULLIVAN	2534	2262	2404	2586	3182	3745.4	2929	3745	0.9%	0.2%	8.63	0.4%	0.1%	3.84	0.5%	0.1%	4.30	0.5%	0.1%	4.76	L	0.25	22	3767		3767
THRUSTON	7562	6804	7471	7938	10271	8592.6	8191	10271	0.9%	0.6%	64.39	0.4%	0.3%	28.73	0.5%	0.3%	32.28	0.5%	0.3%	35.79	A	0.68	161	10432		10432
UTICA	5683	5236	5890	6357	8145	7257.6	7011	8145	0.9%	0.2%	18.78	0.4%	0.1%	8.34	0.5%	0.1%	9.36	0.5%	0.1%	10.35	L	0.25	47	8192		8192
W. OWENSBORO	5171	4633	5119	5249	6895	6143	5903	6895	0.9%	0.9%	63.57	0.4%	0.4%	28.45	0.5%	0.5%	32.00	0.5%	0.5%	35.53	H	1.00	160	7054	276	7330
WEAVERTON	4413	3933	4335	4614	5890	4691.6	4737	5890	0.9%	0.6%	36.93	0.4%	0.3%	16.48	0.5%	0.3%	18.51	0.5%	0.3%	20.52	A	0.68	92	5983		5983
WEBERSTOWN	5970	5849	6147	6087	8299	7603.2	7512	8299	0.9%	0.6%	52.03	0.4%	0.3%	23.21	0.5%	0.3%	26.08	0.5%	0.3%	28.91	A	0.68	130	8429		8429
WHITESVILLE	6214	6150	6402	6966	8567	7769.6	7614	8567	0.9%	0.2%	19.75	0.4%	0.1%	8.78	0.5%	0.1%	9.84	0.5%	0.1%	10.89	L	0.25	49	8616		8616
WOLF HILLS	2054	1946	2323	2458	3059	2732.8	2579	3059	0.9%	0.6%	19.18	0.4%	0.3%	8.56	0.5%	0.3%	9.61	0.5%	0.3%	10.66	A	0.68	48	3107		3107
YEAGER	114	109	124	122	108	119.6	122	122	0.9%	0.2%	0.28	0.4%	0.1%	0.13	0.5%	0.1%	0.14	0.5%	0.1%	0.16	L	0.25	1	123		123
ZION	7368	6493	7141	7400	9901	8566.6	8515	9901	0.9%	0.6%	62.08	0.4%	0.3%	27.70	0.5%	0.3%	31.12	0.5%	0.3%	34.50	A	0.68	155	10057		10057
TOTAL STATIONS NCP	255,147	239,132	255,843	265,274	329,679	308,796	300,946	331,683	0.9%	0.5%		0.4%	0.2%		0.5%	0.2%										


THIS PAGE WAS INTENTIONALLY LEFT BLANK.

**TABLE T-3: CONSTRUCTION WORK PLAN UNIT COSTS  
2016-2020 KENERGY CWP**

<b>NEW CONSTRUCTION- TIE LINES</b>		
	SIZE	COST/MILE
NEW SINGLE PHASE	2ACSR	\$60,300
NEW SINGLE PHASE	1/0 ACSR	\$67,000
NEW THREE PHASE	1/0 ACSR	\$92,880
NEW THREE PHASE	4/0 ACSR	\$120,528
NEW THREE PHASE	336 ACSR	\$133,920
NEW SINGLE PHASE UNDERGROUND	1/0 AL	\$125,000
NEW THREE PHASE UNDERGROUND	500 MCM	\$300,000
<b>LINE CONVERSION</b>		
	SIZE	COST/MILE
SINGLE PHASE TO SINGLE PHASE	1/0 ACSR	\$59,400
SINGLE PHASE TO VEE PHASE	1/0 ACSR	\$75,000
SINGLE PHASE TO THREE PHASE	1/0 ACSR	\$83,700
SINGLE PHASE TO THREE PHASE	336 ACSR	\$108,810
VEE PHASE TO THREE PHASE	2 ACSR	\$60,300
VEE PHASE TO THREE PHASE	1/0 ACSR	\$86,400
VEE PHASE TO THREE PHASE	336 ACSR	\$112,320
THREE PHASE TO THREE PHASE	4/0 ACSR	\$106,920
THREE PHASE TO THREE PHASE	336 ACSR	\$118,800
THREE PHASE TO DUAL CIRCUIT THREE PHASE	336 ACSR	\$225,000
RECONDUCTOR: SINGLE PHASE	2 ACSR	\$51,000
RECONDUCTOR: THREE PHASE	1/0 ACSR	\$80,000
SWITCHGEAR REPLACEMENT	THREE PHASE	\$35,000
UNDERGROUND CABLE REPLACEMENT-1PH	1/0 AL 25KV	\$150,000
UNDERGROUND CABLE REPLACEMENT-3PH	THREE PHASE	\$225,000
<b>VOLTAGE CONVERSION</b>		
REINSULATE SINGLE PHASE	PER MILE	\$8,500
REINSULATE THREE PHASE	PER MILE	\$25,000
INSTALL LINE SU/SD TRANSFORMER	(3)-1000 KVA	\$35,000
INSTALL LINE SU/SD TRANSFORMER	(3)-1667 KVA	\$45,000
UPGRADE LINE SU/SD TRANSFORMER	(1)-3000 KVA PAD	\$50,000
UPGRADE LINE SU/SD TRANSFORMER	(1)-5000 KVA PAD	\$65,000
INSTALL (1) DUAL VOLTAGE TRANSFORMER	POLE	\$1,800
INSTALL (1) DUAL VOLTAGE TRANSFORMER	PAD	\$2,500
<b>MISCELLANEOUS- EQUIPMENT</b>		
SINGLE POLE MOUNT RECLOSER	1	\$4,500
THREE PHASE RECLOSER-ELECTRONIC	1	\$18,000
FIXED CAPACITOR BANK	300 KVAR	\$5,000
FIXED CAPACITOR BANK	600 KVAR	\$7,500
VOLTAGE REGULATOR	(1)-100A	\$12,000
VOLTAGE REGULATOR	(1)-150A	\$15,000
VOLTAGE REGULATOR	(1)-200A	\$18,000

# **APPENDICES**

106-ADAMS LANE  
 Load KW 6027.75  
 0.00 99.66



REC40977001  
 Device  
 B Phase  
 (B) 124.465 V  
 (B) 32.295 A  
 (B) 0.000 VD

OH335942  
 Overhead  
 ABC Phase  
 (A) 122.381 V  
 (B) 124.901 V  
 (C) 120.231 V  
 (A) 0.000 A  
 (B) 0.000 A  
 (C) 14.400 A  
 (A) -0.010 VD  
 (B) 0.007 VD  
 (C) 0.012 VD

REC41082001  
 Device  
 A Phase  
 (A) 122.361 V  
 (A) 40.039 A  
 (A) 0.000 VD

OH521476	
Overhead	
AC Phase	
(A)	123.767 V
(C)	116.463 V
(A)	2.901 A
(C)	0.000 A
(A)	0.006 VD
(C)	0.001 VD

REC27313001	
Device	
ABC Phase	
(A)	124.392 V
(B)	123.561 V
(C)	120.496 V
(A)	39.449 A
(B)	28.886 A
(C)	82.752 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD


REG25415006	
Regulator	
ABC Phase	
(A)	124.281 V
(B)	124.179 V
(C)	123.850 V
(A)	47.259 A
(B)	33.262 A
(C)	30.914 A
(A)	-3.107 VD
(B)	-0.776 VD
(C)	-2.322 VD

OH701660	
Overhead	
ABC Phase	
(A)	124.967 V
(B)	123.812 V
(C)	123.961 V
(A)	19.806 A
(B)	49.875 A
(C)	54.788 A
(A)	0.003 VD
(B)	0.045 VD
(C)	0.028 VD

41-BEDA	
Load KW6024.00	
0.00	93.34


OH703265	
Overhead	
C Phase	
(C)	115.866 V
(C)	0.000 A
(C)	0.000 VD

1" = 12891.801 ft



1" = 11576.570 ft





SW43662001-B	
Switch	
ABC Phase	
(A)	122.388 V
(B)	123.199 V
(C)	122.703 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

FUS1665790100	
Device	
A Phase	
(A)	119.414 V
(A)	2.611 A
(A)	0.000 VD

OH301669	
Overhead	
A Phase	
(A)	122.267 V
(A)	0.000 A
(A)	0.000 VD

OH300335	
Overhead	
ABC Phase	
(A)	124.852 V
(B)	124.886 V
(C)	124.712 V
(A)	36.642 A
(B)	27.849 A
(C)	51.327 A
(A)	0.010 VD
(B)	0.009 VD
(C)	0.022 VD

OH305436	
Overhead	
C Phase	
(C)	122.518 V
(C)	0.000 A
(C)	0.000 VD


60-CALDWELL SPRINGS	
Load KW	2462.73
0.00	94.97


SPOT LOAD- IRRIGATION  
PUMPS- 75 KW SINGLE PHASE


OH306122	
Overhead	
B Phase	
(B)	117.531 V
(B)	1.498 A
(B)	0.004 VD


FUS507156298	
Device	
A Phase	
(A)	123.227 V
(A)	0.346 A
(A)	0.000 VD

1" = 15549.063 ft










OH729525	
Overhead	
ABC Phase	
(A)	124.710 V
(B)	124.947 V
(C)	124.850 V
(A)	113.499 A
(B)	50.198 A
(C)	76.574 A
(A)	0.060 VD
(B)	-0.001 VD
(C)	0.047 VD

OH729415	
Overhead	
ABC Phase	
(A)	124.513 V
(B)	124.520 V
(C)	124.671 V
(A)	194.795 A
(B)	217.683 A
(C)	190.099 A
(A)	0.169 VD
(B)	0.158 VD
(C)	0.102 VD

SPOT LOAD- GATEWAY  
COMMONS- 1MW- THREE PH,  
RDPF



SPOT LOAD- STERLING PARK  
15KW SINGLE PH

2 way feed bypassed

SPOT LOAD- BROWNWOOD  
10KW- 10KW- SINGLE PH

19-EAST OWENSBORO	
Load KW	7216.51
0.00	93.38

OH729418	
Overhead	
ABC Phase	
(A)	124.565 V
(B)	124.689 V
(C)	125.041 V
(A)	41.966 A
(B)	46.422 A
(C)	6.547 A
(A)	0.049 VD
(B)	0.032 VD
(C)	-0.008 VD

1" = 3928.644 ft

OH1928863067	
Overhead	
ABC Phase	
(A)	124.055 V
(B)	123.343 V
(C)	123.590 V
(A)	0.159 A
(B)	0.160 A
(C)	0.160 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH330157	
Overhead	
B Phase	
(B)	121.983 V
(B)	2.865 A
(B)	0.003 VD

OH327153	
Overhead	
ABC Phase	
(A)	123.199 V
(B)	121.265 V
(C)	121.567 V
(A)	0.205 A
(B)	6.107 A
(C)	0.207 A
(A)	0.002 VD
(B)	0.008 VD
(C)	-0.002 VD


63-GENEVA	
Load KW	7978.41
	0.00
	99.70

OH332019	
Overhead	
ABC Phase	
(A)	122.469 V
(B)	124.153 V
(C)	122.845 V
(A)	118.725 A
(B)	89.345 A
(C)	93.926 A
(A)	0.070 VD
(B)	0.025 VD
(C)	0.066 VD

REG40878022	
Regulator	
A Phase	
(A)	124.152 V
(A)	46.013 A
(A)	-5.432 VD

1" = 20986.057 ft





31-GUFFIE  
Load KW 8266.31  
0.00 98.91

OH897069815  
Overhead  
A Phase  
(A) 117.855 V  
(A) 0.518 A  
(A) 0.001 VD


OH125908.1  
Overhead  
A Phase  
(A) 116.815 V  
(A) 0.037 A  
(A) 0.000 VD


REC18823001  
Device  
ABC Phase  
(A) 119.257 V  
(B) 121.126 V  
(C) 121.299 V  
(A) 34.834 A  
(B) 43.296 A  
(C) 25.624 A  
(A) 0.000 VD  
(B) 0.000 VD  
(C) 0.000 VD

OH500790  
Overhead  
ABC Phase  
(A) 124.916 V  
(B) 124.933 V  
(C) 124.928 V  
(A) 169.817 A  
(B) 172.564 A  
(C) 171.301 A  
(A) 0.036 VD  
(B) 0.032 VD  
(C) 0.030 VD

OH530781  
Overhead  
C Phase  
(C) 117.652 V  
(C) 1.150 A  
(C) 0.002 VD

1" = 15665.965 ft






UG533608	
Underground	
ABC Phase	
(A)	122.821 V
(B)	123.598 V
(C)	123.952 V
<u>(A) way feed bypassed</u>	
(B)	32.351 A
(C)	9.402 A
(A)	0.159 VD
(B)	0.124 VD
(C)	0.013 VD

UG-1662077499	
Underground	
ABC Phase	
(A)	124.781 V
(B)	124.763 V
(C)	124.721 V
(A)	144.451 A
(B)	163.024 A
(C)	176.526 A
(A)	0.185 VD
(B)	0.207 VD
(C)	0.253 VD

UG1525705781	
Underground	
ABC Phase	
(A)	124.773 V
(B)	124.756 V
(C)	124.855 V
(A)	145.431 A
(B)	149.178 A
(C)	107.631 A
(A)	0.193 VD
(B)	0.214 VD
(C)	0.123 VD

SPOT LOAD- HARTFORD RD-  
172 KW



OH704085	
Overhead	
ABC Phase	
(A)	124.065 V
(B)	124.124 V
(C)	124.249 V
(A)	0.805 A
(B)	0.000 A
(C)	0.000 A
(A)	0.001 VD
(B)	-0.000 VD
(C)	0.000 VD

OH521633	
Overhead	
ABC Phase	
(A)	124.968 V
(B)	124.976 V
(C)	124.981 V
(A)	2.324 A
(B)	1.575 A
(C)	0.000 A
(A)	0.001 VD
(B)	-0.001 VD
(C)	-0.000 VD


OH533180	
Overhead	
ABC Phase	
(A)	124.940 V
(B)	124.995 V
(C)	124.981 V
(A)	2.324 A
(B)	1.207 A
(C)	0.000 A
(A)	0.001 VD
(B)	-0.000 VD
(C)	0.000 VD

20-HORSE FORK	
Load KW	12278.21
0.00	91.49

UG2080616908	
Underground	
ABC Phase	
(A)	124.812 V
(B)	124.784 V
(C)	124.831 V
(A)	187.509 A
(B)	207.965 A
(C)	178.929 A
(A)	0.152 VD
(B)	0.183 VD
(C)	0.143 VD

UG1086319853	
Underground	
ABC Phase	
(A)	124.884 V
(B)	124.892 V
(C)	124.884 V
(A)	114.219 A
(B)	114.268 A
(C)	121.041 A
(A)	0.084 VD
(B)	0.081 VD
(C)	0.093 VD

1" = 2800.598 ft



OH323479	
Overhead	
ABC Phase	
(A)	124.823 V
(B)	124.550 V
(C)	124.304 V
(A)	50.180 A
(B)	81.294 A
(C)	112.237 A
(A)	0.028 VD
(B)	0.087 VD
(C)	0.149 VD


OH323621	
Overhead	
ABC Phase	
(A)	124.828 V
(B)	124.852 V
(C)	124.859 V
(A)	128.318 A
(B)	128.278 A
(C)	128.264 A
(A)	0.028 VD
(B)	0.025 VD
(C)	0.023 VD

UG-135803778	
Underground	
ABC Phase	
(A)	124.852 V
(B)	124.683 V
(C)	124.549 V
(A)	12.471 A
(B)	13.108 A
(C)	12.509 A
(A)	0.014 VD
(B)	0.015 VD
(C)	0.014 VD


65-HUDSON2	
Load KW	8417.53
0.00	88.73


65-HUDSON1	
Load KW	8230.80
0.00	89.17

1" = 5252.474 ft



1" = 9240.697 ft





44709004	
Consumer	
B Phase	
(B)	119.828 V
(B)	0.656 A
(B)	0.000 VD

REC44832001	
Device	
ABC Phase	
(A)	123.204 V
(B)	123.699 V
(C)	123.977 V
(A)	38.405 A
(B)	7.101 A
(C)	18.886 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

44747004	
Consumer	
B Phase	
(B)	123.207 V
(B)	0.416 A
(B)	0.000 VD

69-LYON	
Load KW6297.94	
0.00	95.68

OH306585	
Overhead	
ABC Phase	
(A)	123.809 V
(B)	124.838 V
(C)	124.403 V
(A)	0.000 A
(B)	1.897 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.003 VD
(C)	-0.001 VD


OH307585	
Overhead	
ABC Phase	
(A)	124.598 V
(B)	124.486 V
(C)	124.067 V
(A)	143.782 A
(B)	133.293 A
(C)	215.622 A
(A)	0.059 VD
(B)	0.077 VD
(C)	0.140 VD


44882287	
Consumer	
C Phase	
(C)	117.912 V
(C)	0.217 A
(C)	0.000 VD

44892011	
Consumer	
C Phase	
(C)	117.443 V
(C)	0.000 A
(C)	0.000 VD

1" = 10188.828 ft







1" = 4016.814 ft

OH312523	
Overhead	
A Phase	
(A)	119.938 V
(A)	0.799 A
(A)	0.001 VD

OH313853	
Overhead	
B Phase	
(B)	117.698 V
(B)	0.667 A
(B)	0.001 VD

REC43053002	
Device	
B Phase	
(B)	120.519 V
(B)	30.895 A
(B)	0.000 VD

OH314009	
Overhead	
ABC Phase	
(A)	121.493 V
(B)	123.079 V
(C)	122.529 V
(A)	12.116 A
(B)	3.290 A
(C)	1.309 A
(A)	0.039 VD
(B)	-0.000 VD
(C)	0.004 VD

6724.15	
92.40	

OH314183	
Overhead	
C Phase	
(C)	117.941 V
(C)	0.000 A
(C)	0.000 VD

OH-1393537512	
Overhead	
ABC Phase	
(A)	124.134 V
(B)	123.889 V
(C)	123.614 V
(A)	74.753 A
(B)	81.329 A
(C)	84.017 A
(A)	0.045 VD
(B)	0.056 VD
(C)	0.067 VD

OH315457	
Overhead	
C Phase	
(C)	120.018 V
(C)	1.876 A
(C)	0.004 VD


REC43539002	
Device	
ABC Phase	
(A)	123.568 V
(B)	123.477 V
(C)	123.656 V
(A)	61.496 A
(B)	25.386 A
(C)	53.193 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH316333	
Overhead	
ABC Phase	
(A)	124.192 V
(B)	124.235 V
(C)	124.589 V
(A)	46.620 A
(B)	54.600 A
(C)	37.166 A
(A)	0.032 VD
(B)	0.030 VD
(C)	0.015 VD

OH316411	
Overhead	
ABC Phase	
(A)	124.577 V
(B)	124.732 V
(C)	124.506 V
(A)	81.460 A
(B)	47.604 A
(C)	77.218 A
(A)	0.020 VD
(B)	0.013 VD
(C)	0.024 VD

OH300634	
Overhead	
ABC Phase	
(A)	124.133 V
(B)	123.882 V
(C)	124.232 V
(A)	1.473 A
(B)	5.075 A
(C)	0.328 A
(A)	0.001 VD
(B)	0.003 VD
(C)	-0.001 VD

1" = 20535.116 ft



REC15109004	
Device	
C Phase	
(C)	121.645 V
(C)	42.555 A
(C)	0.000 VD

OH26904025	
Overhead	
ABC Phase	
(A)	124.651 V
(B)	123.553 V
(C)	124.358 V
(A)	91.756 A
(B)	166.543 A
(C)	162.278 A
(A)	0.015 VD
(B)	0.111 VD
(C)	0.025 VD


23-MASONVILLE	
Load KW	7141.68
0.00	96.45


SPOT LOAD- DEER VALLEY  
BUNDY- 214 KW- PLACED ON  
THREE PHASES

UG-90124285	
Underground	
A Phase	
(A)	124.262 V
(A)	0.862 A
(A)	0.006 VD

OH708763	
Overhead	
ABC Phase	
(A)	121.332 V
(B)	122.142 V
(C)	123.769 V
(A)	0.000 A
(B)	0.821 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.001 VD
(C)	-0.000 VD

1" = 7240.799 ft





OH530926	
Overhead	
ABC Phase	
(A)	123.810 V
(B)	122.113 V
(C)	123.841 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH517973	
Overhead	
ABC Phase	
(A)	116.860 V
(B)	122.363 V
(C)	121.880 V
(A)	92.918 A
(B)	52.201 A
(C)	35.860 A
(A)	0.109 VD
(B)	0.027 VD
(C)	0.027 VD

OH531251	
Overhead	
ABC Phase	
(A)	122.887 V
(B)	124.098 V
(C)	124.001 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH522622	
Overhead	
ABC Phase	
(A)	124.145 V
(B)	124.517 V
(C)	124.435 V
(A)	144.036 A
(B)	116.720 A
(C)	116.637 A
(A)	0.123 VD
(B)	0.068 VD
(C)	0.080 VD

42-NUCKOLS	
Load KW	4848.81
0.00	95.41

OH522619	
Overhead	
ABC Phase	
(A)	124.285 V
(B)	124.833 V
(C)	124.618 V
(A)	120.135 A
(B)	75.139 A
(C)	94.149 A
(A)	0.100 VD
(B)	0.022 VD
(C)	0.053 VD


OH518648	
Overhead	
ABC Phase	
(A)	120.620 V
(B)	122.035 V
(C)	122.429 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH519685	
Overhead	
A Phase	
(A)	117.402 V
(A)	0.000 A
(A)	0.000 VD

REC25116003	
Device	
ABC Phase	
(A)	122.548 V
(B)	124.702 V
(C)	123.284 V
(A)	60.778 A
(B)	25.190 A
(C)	16.090 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH518142	
Overhead	
ABC Phase	
(A)	122.273 V
(B)	124.847 V
(C)	122.934 V
(A)	18.314 A
(B)	0.000 A
(C)	0.000 A
(A)	0.040 VD
(B)	0.010 VD
(C)	0.010 VD

1" = 6966.735 ft



SW42173001-B	
Switch	
ABC Phase	
(A)	122.829 V
(B)	120.916 V
(C)	124.992 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH517267	
Overhead	
B Phase	
(B)	116.486 V
(B)	2.688 A
(B)	0.006 VD


OH519942	
Overhead	
ABC Phase	
(A)	119.283 V
(B)	121.475 V
(C)	124.008 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH528309	
Overhead	
C Phase	
(C)	117.591 V
(C)	1.188 A
(C)	0.002 VD

OH517320	
Overhead	
ABC Phase	
(A)	124.306 V
(B)	124.494 V
(C)	123.939 V
(A)	150.184 A
(B)	113.750 A
(C)	180.703 A
(A)	0.072 VD
(B)	0.054 VD
(C)	0.112 VD


OH517533	
Overhead	
A Phase	
(A)	117.336 V
(A)	10.069 A
(A)	0.046 VD

52-ONTON	
Load KW	7557.72
	0.00 98.53



1" = 11781.610 ft





1" = 10548.504 ft

PHILPOT  
2016-2020 WITH NO IMPROVEMENTS

OH-819959119	
Overhead	
ABC Phase	
(A)	123.583 V
(B)	124.815 V
(C)	123.711 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH712316	
Overhead	
ABC Phase	
(A)	124.895 V
(B)	124.994 V
(C)	124.876 V
(A)	47.905 A
(B)	17.474 A
(C)	39.826 A
(A)	0.011 VD
(B)	-0.001 VD
(C)	0.021 VD

19315023	
Consumer	
A Phase	
(A)	122.763 V
(A)	0.470 A
(A)	0.000 VD

OH710370	
Overhead	
A Phase	
(A)	123.158 V
(A)	0.000 A
(A)	0.000 VD

26-PLEASANT RIDGE	
Load KW	6591.99
0.00	99.79

SW21506001-B	
Switch	
ABC Phase	
(A)	121.857 V
(B)	123.167 V
(C)	124.107 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH712071	
Overhead	
ABC Phase	
(A)	124.771 V
(B)	124.555 V
(C)	124.355 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH714038	
Overhead	
B Phase	
(B)	124.311 V
(B)	0.442 A
(B)	0.002 VD

REC21417001	
Device	
ABC Phase	
(A)	122.256 V
(B)	123.093 V
(C)	124.344 V
(A)	29.389 A
(B)	45.280 A
(C)	11.907 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD


OH714182	
Overhead	
B Phase	
(B)	122.531 V
(B)	1.221 A
(B)	0.004 VD

OH712217	
Overhead	
ABC Phase	
(A)	124.566 V
(B)	124.625 V
(C)	124.799 V
(A)	65.439 A
(B)	69.065 A
(C)	52.721 A
(A)	0.065 VD
(B)	0.051 VD
(C)	0.028 VD

OH714610	
Overhead	
B Phase	
(B)	121.678 V
(B)	2.616 A
(B)	0.005 VD

1" = 8519.522 ft

PLEASANT RIDGE  
2016-2020 WITH NO IMPROVEMENTS



OH310769	
Overhead	
C Phase	
(C)	121.081 V
(C)	1.273 A
(C)	0.002 VD

OH1394	
Overhead	
ABC Phase	
(A)	124.817 V
(B)	124.940 V
(C)	124.591 V
(A)	63.275 A
(B)	33.305 A
(C)	43.712 A
(A)	0.008 VD
(B)	0.003 VD
(C)	0.019 VD

STEP1014337785	
Transformer	
A Phase	
(A)	123.528 V
(A)	0.000 A
(A)	0.000 VD

SW42785001-B	
Switch	
ABC Phase	
(A)	123.634 V
(B)	124.368 V
(C)	122.074 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD


81-PROVIDENCE	
Load KW	4837.59
0.00	94.87

OH1411	
Overhead	
ABC Phase	
(A)	124.882 V
(B)	124.718 V
(C)	124.524 V
(A)	25.773 A
(B)	28.462 A
(C)	46.031 A
(A)	0.012 VD
(B)	0.025 VD
(C)	0.041 VD

SW43274001-B	
Switch	
ABC Phase	
(A)	124.348 V
(B)	123.793 V
(C)	123.123 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH23	
Overhead	
C Phase	
(C)	123.883 V
(C)	0.605 A
(C)	0.001 VD

1" = 17289.308 ft



1" = 7258.408 ft

OH-1350897224	
Overhead	
ABC Phase	
(A)	124.866 V
(B)	124.746 V
(C)	124.865 V
(A)	23.439 A
(B)	67.977 A
(C)	23.430 A
(A)	0.029 VD
(B)	0.073 VD
(C)	-0.007 VD


83-RIVERPORT	
Load KW	4186.88
0.00	88.91


VALLEY GRAIN- MODELED AT  
1320 KW. REMOVED FROM  
RIVERPORT LOAD ALLOCATE.

OH332397	
Overhead	
ABC Phase	
(A)	124.953 V
(B)	124.921 V
(C)	125.003 V
(A)	13.225 A
(B)	37.762 A
(C)	-0.071 A
(A)	0.013 VD
(B)	0.024 VD
(C)	-0.011 VD

OH332403	
Overhead	
ABC Phase	
(A)	124.854 V
(B)	124.698 V
(C)	124.881 V
(A)	7.625 A
(B)	52.098 A
(C)	7.618 A
(A)	0.012 VD
(B)	0.048 VD
(C)	-0.015 VD

1" = 931.085 ft






OH715280	
Overhead	
A Phase	
(A)	122.183 V
(A)	5.530 A
(A)	0.007 VD

OH883495517	
Overhead	
ABC Phase	
(A)	124.099 V
(B)	123.934 V
(C)	124.568 V
(A)	168.464 A
(B)	181.845 A
(C)	119.766 A
(A)	0.088 VD
(B)	0.070 VD
(C)	0.030 VD

OH704432	
Overhead	
ABC Phase	
(A)	123.412 V
(B)	124.188 V
(C)	124.161 V
(A)	0.000 A
(B)	1.181 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.001 VD
(C)	-0.000 VD

OH705050	
Overhead	
ABC Phase	
(A)	124.545 V
(B)	124.506 V
(C)	124.336 V
(A)	0.088 A
(B)	0.414 A
(C)	0.088 A
(A)	0.000 VD
(B)	0.000 VD
(C)	-0.000 VD




18-SOUTH DERMONT2	
Load KW	7407.59
0.00	94.78

18-SOUTH DERMONT1	
Load KW	9148.96
0.00	94.75

1" = 4247.586 ft





OH2682	
Overhead	
ABC Phase	
(A)	119.404 V
(A)	1.119 A
(A)	0.003 VD

REC28325002	
Device	
ABC Phase	
(A)	122.228 V
(B)	122.376 V
(C)	121.638 V
(A)	21.913 A
(B)	27.615 A
(C)	46.035 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH518951	
Overhead	
A Phase	
(A)	122.018 V
(A)	1.504 A
(A)	0.004 VD

OH101049	
Overhead	
ABC Phase	
(A)	121.881 V
(B)	122.627 V
(C)	122.204 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH100555	
Overhead	
ABC Phase	
(A)	123.747 V
(B)	124.127 V
(C)	125.063 V
(A)	124.343 A
(B)	148.959 A
(C)	55.149 A
(A)	0.121 VD
(B)	0.070 VD
(C)	-0.016 VD

OH100473	
Overhead	
ABC Phase	
(A)	124.539 V
(B)	124.632 V
(C)	124.555 V
(A)	92.884 A
(B)	79.282 A
(C)	90.520 A
(A)	0.021 VD
(B)	0.017 VD
(C)	0.020 VD

REC182378198	
Device	
ABC Phase	
(A)	121.263 V
(B)	123.111 V
(C)	122.787 V
(A)	32.293 A
(B)	3.066 A
(C)	6.276 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

53-SOUTH HANSON1	
Load KW	7791.95
0.00	98.89

53-SOUTH HANSON2	
Load KW	9025.06
0.00	98.89

REG42776095	
Regulator	
ABC Phase	
(A)	123.708 V
(B)	123.708 V
(C)	124.196 V
(A)	114.370 A
(B)	113.245 A
(C)	110.676 A
(A)	-3.093 VD
(B)	-3.093 VD
(C)	-1.552 VD

REC30322001	
Device	
ABC Phase	
(A)	121.668 V
(B)	121.197 V
(C)	123.243 V
(A)	127.372 A
(B)	114.309 A
(C)	120.767 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH103490	
Overhead	
ABC Phase	
(A)	124.618 V
(B)	124.431 V
(C)	124.654 V
(A)	138.485 A
(B)	179.015 A
(C)	158.752 A
(A)	0.070 VD
(B)	0.093 VD
(C)	0.035 VD

OH103440	
Overhead	
ABC Phase	
(A)	123.945 V
(B)	124.525 V
(C)	124.466 V
(A)	149.025 A
(B)	119.351 A
(C)	110.343 A
(A)	0.086 VD
(B)	0.035 VD
(C)	0.044 VD

1" = 10461.060 ft



58-SOUTH OWENSBORO2	
Load KW	6997.51
0.00	93.78
58-SOUTH OWENSBORO1	
Load KW	6184.78
0.00	93.78

1" = 2353.075 ft

REG14706025	
Regulator	
ABC Phase	
(A)	124.092 V
(B)	124.232 V
(C)	123.606 V
(A)	133.476 A
(B)	128.463 A
(C)	57.751 A
(A)	-6.205 VD
(B)	-3.882 VD
(C)	0.000 VD

UG808223293	
Underground	
ABC Phase	
(A)	114.881 V
(B)	119.334 V
(C)	123.022 V
(A)	2.231 A
(B)	2.146 A
(C)	2.080 A
(A)	0.007 VD
(B)	0.006 VD
(C)	0.006 VD

OH524427	
Overhead	
ABC Phase	
(A)	123.689 V
(B)	124.151 V
(C)	124.720 V
(A)	180.699 A
(B)	182.552 A
(C)	91.986 A
(A)	0.152 VD
(B)	0.097 VD
(C)	0.030 VD

OH525551	
Overhead	
ABC Phase	
(A)	124.025 V
(B)	124.836 V
(C)	124.795 V
(A)	36.644 A
(B)	1.321 A
(C)	4.028 A
(A)	0.052 VD
(B)	-0.021 VD
(C)	0.011 VD


32-ST. JOE	
Load KW 5558.14	
0.00 94.74	

OH531753	
Overhead	
C Phase	
(C)	123.229 V
(C)	0.697 A
(C)	0.002 VD

OH509928	
Overhead	
ABC Phase	
(A)	123.744 V
(B)	123.046 V
(C)	122.177 V
(A)	0.853 A
(B)	0.014 A
(C)	0.014 A
(A)	0.004 VD
(B)	-0.001 VD
(C)	0.000 VD

OH525761	
Overhead	
ABC Phase	
(A)	124.464 V
(B)	124.804 V
(C)	124.881 V
(A)	61.063 A
(B)	40.477 A
(C)	22.029 A
(A)	0.096 VD
(B)	0.030 VD
(C)	0.019 VD

OH1717583347	
Overhead	
C Phase	
(C)	121.083 V
(C)	0.000 A
(C)	0.000 VD



1" = 6965.551 ft

OH337024	
Overhead	
ABC Phase	
(A)	122.161 V
(B)	121.417 V
(C)	123.115 V
(A)	0.531 A
(B)	0.557 A
(C)	4.691 A
(A)	-0.002 VD
(B)	0.003 VD
(C)	0.014 VD

OH1162554277	
Overhead	
B Phase	
(B)	121.792 V
(B)	1.059 A
(B)	0.003 VD

OH523012	
Overhead	
ABC Phase	
(A)	124.146 V
(B)	124.043 V
(C)	124.637 V
(A)	81.383 A
(B)	122.208 A
(C)	88.526 A
(A)	0.031 VD
(B)	0.044 VD
(C)	0.012 VD

SEC41019001	
Device	
B Phase	
(B)	121.386 V
(B)	28.619 A
(B)	0.000 VD

21-STANLEY	
Load KW	3803.37
0.00	99.89


OH522983	
Overhead	
C Phase	
(C)	122.988 V
(C)	3.419 A
(C)	0.008 VD

OH523414	
Overhead	
ABC Phase	
(A)	124.725 V
(B)	124.991 V
(C)	124.839 V
(A)	21.203 A
(B)	9.268 A
(C)	11.505 A
(A)	0.019 VD
(B)	0.000 VD
(C)	0.013 VD

OH531696	
Overhead	
C Phase	
(C)	121.864 V
(C)	2.947 A
(C)	0.010 VD

OH523515	
Overhead	
ABC Phase	
(A)	124.762 V
(B)	124.868 V
(C)	124.770 V
(A)	43.539 A
(B)	32.170 A
(C)	41.991 A
(A)	0.035 VD
(B)	0.022 VD
(C)	0.039 VD

1" = 11625.682 ft



OH310267	
Overhead	
ABC Phase	
(A)	124.782 V
(B)	123.540 V
(C)	124.570 V
(A)	12.399 A
(B)	41.208 A
(C)	25.791 A
(A)	0.008 VD
(B)	0.049 VD
(C)	0.016 VD

OH-1812527729	
Overhead	
C Phase	
(C)	116.973 V
(C)	1.371 A
(C)	0.002 VD

OH308365	
Overhead	
ABC Phase	
(A)	124.544 V
(B)	123.114 V
(C)	123.442 V
(A)	0.000 A
(B)	8.900 A
(C)	3.750 A
(A)	-0.001 VD
(B)	0.017 VD
(C)	0.001 VD

85-SULLIVAN	
Load KW	2879.82
0.00	91.99

REC42527001	
Device	
A Phase	
(A)	119.508 V
(A)	24.387 A
(A)	0.000 VD

OH314291	
Overhead	
ABC Phase	
(A)	123.451 V
(B)	122.133 V
(C)	120.172 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

REG42576044	
Regulator	
ABC Phase	
(A)	123.525 V
(B)	123.750 V
(C)	123.943 V
(A)	15.407 A
(B)	25.727 A
(C)	25.487 A
(A)	-0.772 VD
(B)	-0.773 VD
(C)	-2.324 VD

OH310316	
Overhead	
ABC Phase	
(A)	124.188 V
(B)	124.740 V
(C)	124.147 V
(A)	53.703 A
(B)	33.997 A
(C)	45.664 A
(A)	0.073 VD
(B)	0.022 VD
(C)	0.075 VD

OH314838	
Overhead	
ABC Phase	
(A)	123.405 V
(B)	122.034 V
(C)	120.759 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

1" = 19198.358 ft

OH721067	
Overhead	
ABC Phase	
(A)	120.910 V
(B)	120.416 V
(C)	122.587 V
(A)	0.000 A
(B)	0.000 A
(C)	1.113 A
(A)	-0.001 VD
(B)	0.000 VD
(C)	0.002 VD

OH721120	
Overhead	
ABC Phase	
(A)	121.334 V
(B)	120.897 V
(C)	123.148 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH721809	
Overhead	
B Phase	
(B)	122.295 V
(B)	0.030 A
(B)	0.000 VD

REC11206001	
Device	
ABC Phase	
(A)	120.754 V
(B)	123.677 V
(C)	123.416 V
(A)	80.566 A
(B)	35.306 A
(C)	35.260 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH723425	
Overhead	
ABC Phase	
(A)	124.492 V
(B)	124.661 V
(C)	124.795 V
(A)	214.187 A
(B)	197.125 A
(C)	194.457 A
(A)	0.137 VD
(B)	0.088 VD
(C)	0.051 VD

OH723406	
Overhead	
ABC Phase	
(A)	124.808 V
(B)	124.886 V
(C)	124.855 V
(A)	46.725 A
(B)	35.650 A
(C)	37.743 A
(A)	0.015 VD
(B)	0.006 VD
(C)	0.010 VD


11-THRUSTON2	
Load KW	4809.71
	0.00 99.08

11-THRUSTON1	
Load KW	5630.04
	0.00 99.08


OH723438	
Overhead	
ABC Phase	
(A)	124.556 V
(B)	124.786 V
(C)	124.666 V
(A)	85.757 A
(B)	56.674 A
(C)	66.138 A
(A)	0.068 VD
(B)	0.022 VD
(C)	0.048 VD


REC09417002	
Device	
ABC Phase	
(A)	123.770 V
(B)	123.542 V
(C)	123.673 V
(A)	7.964 A
(B)	38.338 A
(C)	31.868 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH721745	
Overhead	
ABC Phase	
(A)	123.763 V
(B)	122.744 V
(C)	123.814 V
(A)	0.000 A
(B)	0.000 A
(C)	0.225 A
(A)	-0.000 VD
(B)	0.000 VD
(C)	0.000 VD





1" = 7154.163 ft











REC12815001	
Device	
ABC Phase	
(A)	121.807 V
(B)	121.710 V
(C)	121.279 V
(A)	20.462 A
(B)	56.637 A
(C)	21.657 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

SPOT LOAD- RIDGELAND	
EUREDIVISION 90KW	

SPOT LOAD- WHISPERING	
MEADOWS 126 KW	

SPOT LOAD- WYNTHROP HALL	
60 KW	

OH532257	
Overhead	
ABC Phase	
(A)	124.380 V
(B)	124.503 V
(C)	124.107 V
(A)	155.694 A
(B)	122.667 A
(C)	192.483 A
(A)	0.110 VD
(B)	0.089 VD
(C)	0.161 VD

22-WEST OWENSBORO	
Load KW	8282.93
	0.00
	94.08

OH532278	
Overhead	
ABC Phase	
(A)	124.790 V
(B)	125.091 V
(C)	124.781 V
(A)	59.588 A
(B)	4.500 A
(C)	37.966 A
(A)	0.051 VD
(B)	-0.027 VD
(C)	0.054 VD

REC14924004	
Device	
ABC Phase	
(A)	123.938 V
(B)	123.724 V
(C)	123.596 V
(A)	73.685 A
(B)	73.835 A
(C)	76.234 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD


OH84175186	
Overhead	
ABC Phase	
(A)	124.576 V
(B)	124.631 V
(C)	124.791 V
(A)	144.928 A
(B)	155.556 A
(C)	134.044 A
(A)	0.066 VD
(B)	0.058 VD
(C)	0.031 VD


OH-772441925	
Overhead	
ABC Phase	
(A)	124.790 V
(B)	124.931 V
(C)	124.901 V
(A)	57.306 A
(B)	39.727 A
(C)	35.328 A
(A)	0.031 VD
(B)	0.009 VD
(C)	0.013 VD

FUS-1012557160	
Device	
C Phase	
(C)	121.362 V
(C)	3.510 A
(C)	0.000 VD

OH527871	
Overhead	
C Phase	
(C)	121.690 V
(C)	4.025 A
(C)	0.015 VD

1" = 8413.892 ft






OH329011	
Overhead	
ABC Phase	
(A)	124.804 V
(B)	124.834 V
(C)	124.936 V
(A)	56.406 A
(B)	67.337 A
(C)	45.844 A
(A)	0.062 VD
(B)	0.051 VD
(C)	0.018 VD

OH328934	
Overhead	
ABC Phase	
(A)	124.627 V
(B)	124.983 V
(C)	124.578 V
(A)	131.400 A
(B)	62.336 A
(C)	110.264 A
(A)	0.043 VD
(B)	0.004 VD
(C)	0.049 VD

91-WOLF HILLS	
Load KW	3428.93
0.00	93.21

REC40909001	
Device	
AC Phase	
(A)	124.140 V
(C)	123.896 V
(A)	35.414 A
(C)	42.535 A
(A)	0.000 VD
(C)	0.000 VD

1" = 6318.330 ft



1" = 14372.364 ft

106-ADAMS LANE  
 Load KW 6073.07  
 0.00 99.66

SPOT LOAD- ASSISTED  
 LIVING- 100KW SINGLE PH

2 way feed bypassed.

CHANGE B PHASE TO A  
 PHASE.

NOT 1/0 HERE

OPEN

LOAD BALANCE.


Disconnected

CLOSE

603-24: CHANGE 35A TO  
 50A.

CWP 313:  
 TAP OVER 40A. CONVERT  
 SINGLE PHASE TO THREE  
 PHASE 1/0.


1" = 6653.930 ft



41-BEDA  
Load KW9392.88  
0.00 99.48

PROJECT 304:  
SYSTEM IMPROVEMENT. THREE  
PHASE 4A TO THREE PHASE  
336 ACSR. ADD RECLOSER.

1" = 12451.106 ft





SW43662001-B	
Switch	
ABC Phase	
(A)	122.490 V
(B)	122.819 V
(C)	122.987 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH302136	
Overhead	
A Phase	
(A)	119.763 V
(A)	0.711 A
(A)	0.002 VD

OH301800	
Overhead	
A Phase	
(A)	122.649 V
(A)	0.623 A
(A)	0.001 VD

OH305802	
Overhead	
C Phase	
(C)	122.154 V
(C)	0.725 A
(C)	0.002 VD

60-CALDWELL SPRINGS	
Load KW	2385.98
0.00	94.97

OH305434	
Overhead	
C Phase	
(C)	123.578 V
(C)	0.000 A
(C)	0.000 VD

SPOT LOAD- IRRIGATION  
EPPERS- 75 KW SINGLE PHASE

NO PROJECT CURRENTLY IN  
PROGRESS.

OH307018	
Overhead	
ABC Phase	
(A)	122.794 V
(B)	123.061 V
(C)	123.297 V
(A)	15.286 A
(B)	15.286 A
(C)	15.286 A
(A)	0.022 VD
(B)	0.021 VD
(C)	0.020 VD

OH300051	
Overhead	
B Phase	
(B)	121.634 V
(B)	18.669 A
(B)	0.097 VD

1" = 15549.063 ft

CALDWELL SPRINGS  
2016-2020 WITH IMPROVEMENTS


40-CENTERTOWN	
Load KW	3138.72
0.00	99.03

PROJECT 202:  
SYSTEM IMPROVEMENT.  
INSTALL CIRCUIT TIE AND  
GOAB SWITCH. CIRCUIT 1  
AND 3.


PROJECT 305:  
SYSTEM IMPROVEMENT. THR  
PHASE 2 AL URD TO 4/0 A  
URD.

603-43:  
SECT- CHANGE OCR TO 50A.


1" = 8539.910 ft




1" = 3661.743 ft



1" = 14780.272 ft



51-HANSON  
 Load KW 3930.35  
 0.00 98.29



605-8: INSTALL 300KVAR,  
 MAINLINE VOLTAGE SUPPORT.

CWP 361\*  
 SYSTEM IMPROV. CONVERT  
 1/0 TO 336 ACSR. 2.2  
 MILES.

603-15: UPGRADE OCR TO  
 ELECTRONIC FROM 70L.

LOAD BALANCE.

CWP 383:  
 CONVERT THREE PHASE 1/0  
 TO 336 ACSR. VOLTAGE  
 SUPPORT FOR SPOT LOAD. 1  
 MILE.


603-17: UPGRADE OCR TO  
 ELECTRONIC OR REMOVE OCR.


34513021  
 Consumer  
 A Phase  
 (A) 117.619 V  
 (A) 0.006 A  
 (A) 0.000 VD

SPOT LOAD- COMMERCIAL-  
 500KW THREE PHASE

CHANGE PHASE A TO C.  
 2 way feed bypassed.

1" = 10391.567 ft






23-MASONVILLE  
 Load KW 7141.30  
 0.00 96.28

OH797997197	
Overhead	
ABC Phase	
(A)	124.526 V
(B)	123.516 V
(C)	124.383 V
(A)	98.176 A
(B)	166.581 A
(C)	156.027 A
(A)	0.020 VD
(B)	0.087 VD
(C)	0.019 VD

OH708763	
Overhead	
ABC Phase	
(A)	121.265 V
(B)	122.078 V
(C)	123.717 V
(A)	0.000 A
(B)	0.822 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.001 VD
(C)	-0.000 VD

1" = 7240.799 ft





CWP 385:  
 CONVERT SINGLE PHASE LINE  
 TO 1/0 ACSR THREE PHASE  
 FOR LOSS CONTINGENCY ON  
 NEW 25KV SECTION.

SPOT LOAD- MEAT  
 PROCESSING- 600KW

60A PER PHASE. MONITOR  
 LOAD.

MONITOR LOAD. 88% ON TWO  
 PHASES DUE TO SPOT.

605-4: INSTALL 300KVAR  
 CAPACITOR

71-MORGANFIELD	
Load KW	1181.97
0.00	98.75

Changed to 1000kVA from  
 1667kVA

2 way feed bypassed.

REMOVE REGULATORS


LOAD BALANCE


CWP 384:  
 VOLTAGE CONVERSION. MOVE  
 1000KVA TRANSFORMER.  
 CONVERT OH LINES TO 25KV.  
 MAKE NEW OPEN POINTS AS  
 SHOWN.

OH320375	
Load KW	696.35
0.00	-89.18

1" = 21763.464 ft


80-NIAGARA  
 Load KW 9248.50  
 0.00 99.74






25-PHILPOT2	
Load KW	4017.89
0.00	94.11

25-PHILPOT1	
Load KW	5586.35
0.00	94.23



1" = 10251.099 ft



OH310765	
Overhead	
C Phase	
(C)	121.008 V
(C)	1.293 A
(C)	0.001 VD

OH1400	
Overhead	
ABC Phase	
(A)	124.824 V
(B)	124.944 V
(C)	124.601 V
(A)	63.270 A
(B)	33.417 A
(C)	44.224 A
(A)	0.008 VD
(B)	0.003 VD
(C)	0.020 VD

OH1012	
Overhead	
ABC Phase	
(A)	123.640 V
(B)	124.386 V
(C)	121.990 V
(A)	0.000 A
(B)	0.000 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.000 VD
(C)	0.000 VD

OH1357	
Overhead	
ABC Phase	
(A)	124.784 V
(B)	124.725 V
(C)	124.663 V
(A)	30.256 A
(B)	33.268 A
(C)	37.994 A
(A)	0.010 VD
(B)	0.013 VD
(C)	0.017 VD

81-PROVIDENCE	
Load KW	4838.01
	0.00
	94.28

OH590	
Overhead	
C Phase	
(C)	124.165 V
(C)	0.005 A
(C)	0.000 VD

OH18	
Overhead	
B Phase	
(B)	123.788 V
(B)	0.345 A
(B)	0.000 VD

1" = 17252.928 ft

SPOT LOAD- HIGHLAND  
POINTE ZOUER THREE PH

IMP 174\*  
EVS IMP  
THREE PHASE TO THREE  
PHASE 11V ACB


18-SOUTH DERMONT2	
Load KW	5836.07
	95.11

18-SOUTH DERMONT1	
Load KW	9150.16
	94.15


LOADING WILL BE ADDRESSED  
BY SYSTEM IMPROVEMENTS.


OH704432	
Overhead	
ABC Phase	
(A)	123.392 V
(B)	124.180 V
(C)	124.157 V
(A)	0.000 A
(B)	1.181 A
(C)	0.000 A
(A)	0.000 VD
(B)	0.001 VD
(C)	-0.000 VD

OH705045	
Overhead	
ABC Phase	
(A)	124.556 V
(B)	124.494 V
(C)	124.341 V
(A)	0.000 A
(B)	0.000 A
(C)	0.596 A
(A)	-0.000 VD
(B)	0.000 VD
(C)	0.001 VD



1" = 4149.765 ft






58-SOUTH OWENSBORO1	
Load KW	6181.68
0.00	93.80

58-SOUTH OWENSBORO2	
Load KW	6995.92
0.00	93.79

1" = 3807.263 ft





CWP 201:INSTALL SINGLE PHASE TIE LINE.

CWP 396:SYS IMP: CONVERT SINGLE PHASE TO THREE PHASE 1/0.

CWP 395:CONVERT 2PH TO THREE PHASE 1/0 ACSE. REMOVE OCB DUE TO LINE CONVERSION.

64-WEAVERTON	
Load KW	5862.69
	99.22

CWP 392:CONVERT THREE PHASE TO DUAL CIRCUIT THREE PHASE 336 ACSE. EXPRESS FEEDER PICKS UP STRAIGHT AHEAD.

CWP 393:SYSTEM IMP: CONVERT SINGLE PHASE TO THREE PHASE 336 ACSE.

THIS LINE FEED ON NEW CIRCUIT FEED.

NEW OPEN POINT. REMOVE OCB. INSTALL OCB.

MOVE REGULATORS DOWNLINE.


CLOSE BACKFEED LINES.

REMOVE SOB. INSTALL 3 SO-E DEVICES.

ISA TO SOB.

CWP 394:CONVERT SINGLE PHASE TO THREE PHASE 1/0 ACSE.

1" = 9545.780 ft



1" = 13827.420 ft