

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: January Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	50,279,000	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	50,279,000	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	14,027,800	
8	Commercial	2,442,370	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) <u>Water produced and stored but not sold</u>	3,000,000	
13	TOTAL WATER SOLD	19,470,170	38.7%
14	TOTAL WATER NOT SOLD	30,808,830	61.3%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	3,799,097	#VALUE!
18	Fire Department Usage	49,411	#VALUE!
19	DBP Flushing <u>DBP Maintenance</u>	0	
20	TOTAL USAGE	6,848,508	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		47.7%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	400,000	#VALUE!
23	Excavation Breaks	0	
24	Repaired Line Breaks	16,786,050	#VALUE!
25	Unknown Loss	6,774,273	13.5%
26	TOTAL WATER NOT SOLD OR USED	23,960,322	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:	
28	"Unknown Loss" 6,774,273
29	% "Unknown Loss" 13.5%
30	(insert days of operation during month) Number of Days in Period
31	"Unknown Loss" per Day (Gallons per Day)
32	"Unknown Loss" per Minute (GPM)
33	"Unknown Loss" Cost for Month #VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District

PWSID: Ky0220555

For the Month of: Feb

Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,063,700	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,063,700	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	12,553,510	
8	Commercial		
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) _____ Water stored but not sold	3,000,000	
13	TOTAL WATER SOLD	17,887,280	34.4%
14	TOTAL WATER NOT SOLD	34,176,420	65.6%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	1,610,630	#VALUE!
18	Fire Department Usage	53,661	#VALUE!
19	DBP Flushing _____ DBP Maintenance	0	
20	TOTAL USAGE	4,664,291	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		56.7%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	8,494,001	#VALUE!
25	Unknown Loss	21,018,128	40.4%
26	TOTAL WATER NOT SOLD OR USED	29,512,129	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	21,018,128	
29	% "Unknown Loss"	40.4%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month	#VALUE!	

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: March Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	12,444,509	
8	Commercial	2,561,511	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Water stored in tanks and lines	3,000,000	
13	TOTAL WATER SOLD	18,006,020	34.4%
14	TOTAL WATER NOT SOLD	34,306,592	65.6%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	0	
18	Fire Department Usage	0	
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	3,000,000	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		59.8%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)		
23	Excavation Breaks	0	
24	Repaired Line Breaks	9,198,591	#VALUE!
25	Unknown Loss	22,108,001	42.3%
26	TOTAL WATER NOT SOLD OR USED	31,306,592	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	22,108,001	
29	% "Unknown Loss"	42.3%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: April Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	13,888,050	
8	Commercial	2,741,109	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Water stored but not sold	3,000,000	
13	TOTAL WATER SOLD	19,629,159	37.5%
14	TOTAL WATER NOT SOLD	32,683,453	62.5%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	2,600,000	#VALUE!
18	Fire Department Usage	58,887	#VALUE!
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	5,658,887	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		51.7%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	0	
25	Unknown Loss	27,024,566	51.7%
26	TOTAL WATER NOT SOLD OR USED	27,024,566	
27	COST OF WATER NOT SOLD OR USED		#VALUE!

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	27,024,566	
29	% "Unknown Loss"	51.7%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: May Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	11,665,460	
8	Commercial	5,500,890	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain)		
13	TOTAL WATER SOLD	17,166,350	32.8%
14	TOTAL WATER NOT SOLD	35,146,262	67.2%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	2,500,000	
16	Wastewater Treatment Plant		
17	System Flushing	1,425,885	#VALUE!
18	Fire Department Usage	0	
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	3,925,885	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		59.7%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)		
23	Excavation Breaks	0	
24	Repaired Line Breaks	5,551,701	#VALUE!
25	Unknown Loss	25,668,676	49.1%
26	TOTAL WATER NOT SOLD OR USED	31,220,377	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:		
28	"Unknown Loss"	25,668,676
29	% "Unknown Loss"	49.1%
30	(insert days of operation during month) Number of Days in Period	
31	"Unknown Loss" per Day (Gallons per Day)	
32	"Unknown Loss" per Minute (GPM)	
33	"Unknown Loss" Cost for Month	#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District

PWSID: Ky0220555

For the Month of: June

Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	13,888,050	
8	Commercial	2,741,109	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) <u> </u> Water stored in tanks and lines	3,000,000	
13	TOTAL WATER SOLD	19,629,159	37.5%
14	TOTAL WATER NOT SOLD	32,683,453	62.5%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	2,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	535,272	#VALUE!
18	Fire Department Usage	0	
19	DBP Flushing <u> </u> DBP Maintenance	0	
20	TOTAL USAGE	2,535,272	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		57.6%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)		
23	Excavation Breaks	0	
24	Repaired Line Breaks	2,500,000	#VALUE!
25	Unknown Loss	27,648,181	52.9%
26	TOTAL WATER NOT SOLD OR USED	30,148,181	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:	
28	"Unknown Loss" 27,648,181
29	% "Unknown Loss" 52.9%
30	(insert days of operation during month) Number of Days in Period
31	"Unknown Loss" per Day (Gallons per Day)
32	"Unknown Loss" per Minute (GPM)
33	"Unknown Loss" Cost for Month #VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: July Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	13,888,050	
8	Commercial	2,741,109	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Water stored but not sold	3,000,000	
13	TOTAL WATER SOLD	19,629,159	37.5%
14	TOTAL WATER NOT SOLD	32,683,453	62.5%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	2,030,522	#VALUE!
18	Fire Department Usage	49,888	#VALUE!
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	5,080,410	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		52.8%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	6,945,133	#VALUE!
25	Unknown Loss	20,657,911	39.5%
26	TOTAL WATER NOT SOLD OR USED	27,603,043	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	20,657,911	
29	% "Unknown Loss"	39.5%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District

PWSID: Ky0220555

For the Month of: August

Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)

2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	52,312,612	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	52,312,612	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	13,888,050	
8	Commercial	2,741,109	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Water stored in Tanks	300,000	
13	TOTAL WATER SOLD	16,929,159	32.4%
14	TOTAL WATER NOT SOLD	35,383,453	67.6%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	0	
18	Fire Department Usage	0	
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	3,000,000	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		61.9%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	0	
25	Unknown Loss	32,383,453	61.9%
26	TOTAL WATER NOT SOLD OR USED	32,383,453	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:		
28	"Unknown Loss"	32,383,453
29	% "Unknown Loss"	61.9%
30	(insert days of operation during month) Number of Days in Period	
31	"Unknown Loss" per Day (Gallons per Day)	
32	"Unknown Loss" per Minute (GPM)	
33	"Unknown Loss" Cost for Month	#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: September Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	46,616,500	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	46,616,500	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	12,335,269	
8	Commercial	4,426,321	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Stored in lines and tanks	3,000,000	
13	TOTAL WATER SOLD	19,761,590	42.4%
14	TOTAL WATER NOT SOLD	26,854,910	57.6%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	1,371,241	#VALUE!
18	Fire Department Usage	70,284	#VALUE!
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	4,441,525	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		48.1%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)		
23	Excavation Breaks	0	
24	Repaired Line Breaks	12,400,772	#VALUE!
25	Unknown Loss	10,012,613	21.5%
26	TOTAL WATER NOT SOLD OR USED	22,413,385	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	10,012,613	
29	% "Unknown Loss"	21.5%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: October Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	41,567,600	100.0%
4	Water Purchased	 	0.0%
5	TOTAL PRODUCED AND PURCHASED	41,567,600	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	10,911,010	
8	Commercial	3,640,230	
9	Industrial	 	
10	Bulk Loading Stations	 	
11	Wholesale	 	
12	Other Sales (explain) Water stored in lines and tanks	3,000,000	
13	TOTAL WATER SOLD	17,551,240	42.2%
14	TOTAL WATER NOT SOLD	24,016,360	57.8%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant	 	
17	System Flushing	2,286,051	#VALUE!
18	Fire Department Usage	43,650	#VALUE!
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	5,329,701	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		45.0%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	7,676,357	#VALUE!
25	Unknown Loss	11,010,302	26.5%
26	TOTAL WATER NOT SOLD OR USED	18,686,659	
27	COST OF WATER NOT SOLD OR USED		#VALUE!

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	11,010,302	
29	% "Unknown Loss"	26.5%	
30	(insert days of operation during month) Number of Days in Period	 	
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: November Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	43,142,500	100.0%
4	Water Purchased		0.0%
5	TOTAL PRODUCED AND PURCHASED	43,142,500	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	15,164,550	
8	Commercial	4,256,120	
9	Industrial		
10	Bulk Loading Stations		
11	Wholesale		
12	Other Sales (explain) Water stored in lines and tanks	3,000,000	
13	TOTAL WATER SOLD	22,420,670	52.0%
14	TOTAL WATER NOT SOLD	20,721,830	48.0%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,000,000	
16	Wastewater Treatment Plant		
17	System Flushing	510,632	#VALUE!
18	Fire Department Usage	58,262	#VALUE!
19	DBP Flushing DBP Maintenance	0	
20	TOTAL USAGE	3,568,894	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		39.8%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)		
23	Excavation Breaks	0	
24	Repaired Line Breaks	2,303,174	#VALUE!
25	Unknown Loss	14,849,762	34.4%
26	TOTAL WATER NOT SOLD OR USED	17,152,936	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:			
28	"Unknown Loss"	14,849,762	
29	% "Unknown Loss"	34.4%	
30	(insert days of operation during month) Number of Days in Period		
31	"Unknown Loss" per Day (Gallons per Day)		
32	"Unknown Loss" per Minute (GPM)		
33	"Unknown Loss" Cost for Month		#VALUE!

Monthly Water Use Report

Water Utility: Rattlesnake Ridge Water District PWSID: Ky0220555

For the Month of: December Year: 2022

1 PRODUCTION COST PER THOUSAND (insert cost)
 2 PURCHASE COST PER THOUSAND (insert cost)

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	48,804,000	100.0%
4	Water Purchased	 	0.0%
5	TOTAL PRODUCED AND PURCHASED	48,804,000	
6	TOTAL COST #VALUE!		

WATER SOLD			
7	Residential	11,329,970	
8	Commercial	2,899,500	
9	Industrial	 	
10	Bulk Loading Stations	 	
11	Wholesale	 	
12	Other Sales (explain) _____ water stored in tanks and lines	3,000,000	
13	TOTAL WATER SOLD	17,229,470	35.3%
14	TOTAL WATER NOT SOLD	31,574,530	64.7%

BREAKDOWN OF WATER USAGE			
15	Water Treatment Plant	3,500,000	
16	Wastewater Treatment Plant	 	
17	System Flushing	1,041,405	#VALUE!
18	Fire Department Usage	42,688	#VALUE!
19	DBP Flushing _____ DBP Maintenance	0	
20	TOTAL USAGE	4,584,093	
21	WATER LOSS PERCENTAGE FOR RATE PURPOSES		55.3%

BREAKDOWN OF WATER LOST			
22	Tank Overflows (other than for DBP maintenance)	 	
23	Excavation Breaks	0	
24	Repaired Line Breaks	4,080,013	#VALUE!
25	Unknown Loss	22,910,424	46.9%
26	TOTAL WATER NOT SOLD OR USED	26,990,437	
27	COST OF WATER NOT SOLD OR USED	#VALUE!	

"UNKNOWN LOSS" FLOW RATE AND COST:	
28	"Unknown Loss" 22,910,424
29	% "Unknown Loss" 46.9%
30	(insert days of operation during month) Number of Days in Period
31	"Unknown Loss" per Day (Gallons per Day)
32	"Unknown Loss" per Minute (GPM)
33	"Unknown Loss" Cost for Month #VALUE!