

54	1/25/2024	60104150	422176.6	422185.4	88.00%	-12.00%	SLOW	422195.5	101.00%	1.00%	FAST	422295.3	99.80%	-0.20%	SLOW	FAIL	5/8" x 3/4"
55	1/25/2024	67869911	469129.1	469137.4	83.00%	-17.00%	SLOW	469147.6	102.00%	2.00%	FAST	469247.2	99.60%	-0.40%	SLOW	FAIL	5/8" x 3/4"
56	1/25/2024	43953009	61224.8	61234.1	93.00%	-7.00%	SLOW	61244.2	101.00%	1.00%	FAST	61344.6	100.40%	0.40%	FAST	FAIL	5/8" x 3/4"
57	1/25/2024	71808007	201674.4	201682.8	84.00%	-16.00%	SLOW	201692.8	100.00%	0.00%	NORMAL	201792.1	99.30%	-0.70%	SLOW	FAIL	5/8" x 3/4"
58	1/25/2024	69899740	353767.6	353776.2	86.00%	-14.00%	SLOW	353786.3	101.00%	1.00%	FAST	353885.6	99.30%	-0.70%	SLOW	FAIL	5/8" x 3/4"
59	1/25/2024	52498936	382346.5	382355.6	91.00%	-9.00%	SLOW	382365.8	102.00%	2.00%	FAST	382465.6	99.80%	-0.20%	SLOW	FAIL	5/8" x 3/4"
60	1/25/2024	66706295	583642.2	583650	78.00%	-22.00%	SLOW	583659.7	97.00%	-3.00%	SLOW	583758.6	98.90%	-1.10%	SLOW	FAIL	5/8" x 3/4"
61	4/4/2024	57482617	8433007.1	8433016.6	95.00%	-5.00%	SLOW	8433026.7	101.00%	1.00%	FAST	8433126.1	99.40%	-0.60%	SLOW	PASS	1"
62	4/4/2024	69719510	874204.5	874206.6	21.00%	-79.00%	SLOW	874207.9	13.00%	-87.00%	SLOW	874215.5	7.60%	-92.40%	SLOW	FAIL	1"
63	4/4/2024	47902770	775677.3	775686.8	95.00%	-5.00%	SLOW	775696.9	101.00%	1.00%	FAST	775796	99.10%	-0.90%	SLOW	PASS	1"
64	4/4/2024	20316877	1248659	1248668.5	95.00%	-5.00%	SLOW	1248678.6	101.00%	1.00%	FAST	1248777.8	99.20%	-0.80%	SLOW	PASS	1"
65	4/4/2024	46524208	1865918.8	1865928.5	97.00%	-3.00%	SLOW	1865938.6	101.00%	1.00%	FAST	1865962.2	23.60%	-76.40%	SLOW	FAIL	1"
66	4/4/2024	71177516	731319.8	731327.5	77.00%	-23.00%	SLOW	731337.3	98.00%	-2.00%	SLOW	731435.1	97.80%	-2.20%	SLOW	FAIL	5/8" x 3/4"
67	4/4/2024	71177150	897336.4	897345.8	94.00%	-6.00%	SLOW	897355.9	101.00%	1.00%	FAST	897456	100.10%	0.10%	FAST	FAIL	5/8" x 3/4"
68	4/4/2024	71176866	547120.1	547129.4	93.00%	-7.00%	SLOW	547139.5	101.00%	1.00%	FAST	547239.7	100.20%	0.20%	FAST	FAIL	5/8" x 3/4"
69	4/4/2024	71177374	466335.6	466342.7	71.00%	-29.00%	SLOW	466352.7	100.00%	0.00%	NORMAL	466451.9	99.20%	-0.80%	SLOW	FAIL	5/8" x 3/4"
70	4/4/2024	71177142	906208.7	906215.9	72.00%	-28.00%	SLOW	906225.7	98.00%	-2.00%	SLOW	906324.1	98.40%	-1.60%	SLOW	FAIL	5/8" x 3/4"
71	4/4/2024	71177434	605983	605983.1	1.00%	-99.00%	SLOW	605993.1	100.00%	0.00%	NORMAL	606092.7	99.60%	-0.40%	SLOW	FAIL	5/8" x 3/4"
72	4/4/2024	75736117	99695.6	99705.2	96.00%	-4.00%	SLOW	99714.8	96.00%	-4.00%	SLOW	99814.4	99.60%	-0.40%	SLOW	FAIL	5/8" x 3/4"
73	4/4/2024	82225588	3113956.5	3113956.5	0.00%	-100.00%	SLOW	3113965.2	87.00%	-13.00%	SLOW	3114063.7	98.50%	-1.50%	SLOW	FAIL	5/8" x 3/4"
74	4/4/2024	71176912	147612	147621.1	91.00%	-9.00%	SLOW	147631	99.00%	-1.00%	SLOW	147731.3	100.30%	0.30%	FAST	FAIL	5/8" x 3/4"
75	4/4/2024	71176843	722368.3	722377.4	91.00%	-9.00%	SLOW	722387.5	101.00%	1.00%	FAST	722487.5	100.00%	0.00%	NORMAL	FAIL	5/8" x 3/4"
76	4/4/2024	71177468	846225.3	846234.4	91.00%	-9.00%	SLOW	846244.5	101.00%	1.00%	FAST	846343.9	99.40%	-0.60%	SLOW	FAIL	5/8" x 3/4"

1/4 GPM for 10 Gallons			2 GPM for 10 Gallons			15 GPM for 100 Gallons			Overall Test Summary	
95.0 to 101.0% = Accuracy Range			98.5 to 101.5% = Accuracy Range			98.5 to 101.5% = Accuracy Range				
Failure Rate MID Flow	67	88.16%	Failure Rate MID Flow	25	32.89%	Failure Rate MID Flow	13	17.11%	69	90.79%
Pass Rate MID Flow	9	11.84%	Pass Rate MID Flow	51	67.11%	Pass Rate MID Flow	63	82.89%	7	9.21%
Total Tests	76	100.00%	Total Tests	76	100.00%	Total Tests	76	100.00%	76	100.00%