Sent: Tuesday, December 20, 2022 9:52 AM

Subject: RCIS Message - LG&E/KU Cold weather Alert

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator Subject: LG&E/KU Cold weather Alert

DateTime Posted: 12/20/2022 2:50:59 PM UTC

Message:

Due to the powerful winter storm forecast to impact Kentucky and southern Indiana Thursday into the Christmas holiday weekend. Minor snow accumulations appear likely Thursday night through Friday, and a rapid drop in temperature and high winds will likely worsen the impact of the any snow accumulations. Wind gusts late Thursday night through Friday could be in the 40-50 mph range. These winds along with the frigid temperatures will result in dangerous wind chills. The cold weather will last through Christmas.

LG&E/KU will enter into a Cold Weather Alert for the LG&E/KU service territory from 1200 EST on 12/22/2022 thru 1200 EST on 12/26/2022.

Sent: Friday, December 23, 2022 6:13 AM **Subject:** RCIS Message - LGE/KU Alert Status

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: LGE/KU Alert Status

DateTime Posted: 12/23/2022 11:11:26 AM UTC

Message:

At 05:10CPT LGE/KU will be entering into a Generation Alert Status and will remain there until further notice.

Sent: Friday, December 23, 2022 1:41 PM
Subject: RCIS Message - LGE/KU EEA Status

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: LGE/KU EEA Status Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 3

DateTime Posted: 12/23/2022 6:40:44 PM UTC

Message:

13:36 – LGE/KU has entered into an EEA 3

Sent: Friday, December 23, 2022 2:57 PM
Subject: RCIS Message - LGE/KU EEA Status

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: LGE/KU EEA Status Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 1

DateTime Posted: 12/23/2022 7:56:15 PM UTC

Message:

13:52CPT - LGE/KU BA has reduced their EEA status from an EEA3 to an EEA2

Sent: Friday, December 23, 2022 4:51 PM

Subject: RCIS Message - EEA Status

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: EEA Status

Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 3

DateTime Posted: 12/23/2022 9:49:21 PM UTC

Message:

16:45 - LGE/KU has escalated their EEA status from EEA2 to an EEA3

Sent: Saturday, December 24, 2022 12:57 AM Subject: RCIS Message - LGEE/KU BA EEA 2

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: LGEE/KU BA EEA 2 Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 2

DateTime Posted: 12/24/2022 5:56:22 AM UTC

Message:

LGE/KU BA has terminated the EEA3 and Declared an EEA2.

Sent: Saturday, December 24, 2022 2:01 AM

Subject: RCIS Message - EEA 3

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: EEA 3

Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 1

DateTime Posted: 12/24/2022 6:59:18 AM UTC

Message:

LGEE/KU BA has declared an EEA3

Sent: Saturday, December 24, 2022 12:33 PM

Subject: RCIS Message - EEA Status

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: EEA Status

Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 2

DateTime Posted: 12/24/2022 5:32:47 PM UTC

Message:

11:21CPT - LGE/KU BA has reduced their EEA status from an EEA3 to an EEA2

Sent: Saturday, December 24, 2022 2:15 PM

Subject: RCIS Message - LGEE EEA Status from EEA-2 to EEA-0

EXTERNAL email. STOP and THINK before responding, clicking on links, or opening attachments.

Posted By: TVA Reliability Coordinator

Subject: LGEE EEA Status from EEA-2 to EEA-0

Reliability Coordinator: TVA Balancing Authority: LGEE

EEA Level: 2

DateTime Posted: 12/24/2022 7:14:18 PM UTC

Message:

1306 CPT - LGEE EEA status changing from EEA-2 to EEA-0