Message

From: Pfeiffer, Morgan [redacted]
Sent: 1/11/2023 3:02:10 PM
To: Jones, Jason [redacted]; Hawk, Daniel [redacted]
Subject: Action Items from AAR
Attachments: EPRP After Action Review Form - Dec 23, 2022.docx

Below are the follow up items I captured from the AAR meeting today along with the updated AAR form.

Dan- do you want me to remove the items that were tabled for the load shed discussion?

Follow up items:

- Sena- revisit training; TCC did not have an understanding prior to shedding load that DCC was going to open Distribution feeder breakers after Transmission breakers were opened
- Downs- revisit cold weather PPE/equipment including the tires on bucket truck
- Jones?- how do customers get notified of load shed versus outage (knowing whether to report)
- ALL Ops Managers?- re-emphasize use of photos in OMA. Can be added to any event or by entering a damage assessment

Thanks-

Morgan Pfeiffer
Emergency Preparedness Planner | System Restoration & Distribution Operations
LG&E and KU Energy LLC
820 W Broadway, Louisville, KY 40202
M: [redacted] | **O:** [redacted]
lge-ku.com

Business Use