

ClosedDate	AeOperatingClass	MxProcNm	EquipmentNumber	EquipmentType	Position	Comments
2/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	0688	CapacitorBank	542-0344 Line	Maintenance Performed: Inspected Maintained By: Joshua Oschwald Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 36
8/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	0688	CapacitorBank	542-0344 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 92
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	420002	CapacitorBank	767-2413 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 29
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	470000	CapacitorBank	423-2403 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 74
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	540001	CapacitorBank	774-2429 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 40
4/16/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0035	CapacitorBank	456-0608 Line	Maintenance Performed: inspected, found offline fue to plant closed Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature: 47
11/9/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0049	CapacitorBank	777-0430 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 122.6 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 81
4/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0071	CapacitorBank	686-0876 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: Manual SW Status Inspection Time: Closed Temperature:
1/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0073	CapacitorBank	686-0879 Line	Maintenance Performed: INSPECTED - FOUND OK Maintained By: J. PATRICK Test Values: 123.9 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 49
3/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0094	CapacitorBank	531-0907 Line	Maintenance Performed: INSPECTION - FOUND SWITCHES WILL NOT CLOSE Maintained By: J. PATRICK Test Values: 124.5 Control Operation Position: SW Status Inspection Time: Open Temperature: 70
9/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0109	CapacitorBank	728-0644 Line	Maintenance Performed: INSPECTION Maintained By: TL WATTS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
8/30/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0123	CapacitorBank	805-0605 Line	Maintenance Performed: INSPECTION- BANK OK, CONTROLLER NEEDS REPAIR Maintained By: J. PATRICK Test Values: 124.2 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 88
3/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0124	CapacitorBank	456-0607 Line	Maintenance Performed: INSPECTION Maintained By: UNKNOWN Test Values: 122.2 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 63
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0134	CapacitorBank	692-0912 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 51
5/24/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0139	CapacitorBank	633-0639 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 88
1/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0167	CapacitorBank	737-0600 Line	Maintenance Performed: INSPECTION - FOUND OFFLINE Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 33
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0174	CapacitorBank	091-0921 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 81
1/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0197	CapacitorBank	727-0613 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
12/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0203	CapacitorBank	872-0940 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 38
8/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0204	CapacitorBank	406-0617 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 124.0 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 83
3/2/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0205	CapacitorBank	727-0612 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 123.8 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 33
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0208	CapacitorBank	798-0610 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 82
8/29/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0210	CapacitorBank	686-0878 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 61

9/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0212	CapacitorBank	839-0636 Line	Maintenance Performed: INSPECTION Maintained By: TL WATTS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0223	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 61
4/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0261	CapacitorBank	686-0876 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
4/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0274	CapacitorBank	223-0947 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature: 79
7/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0277	CapacitorBank	824-0961 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 123.1 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 92
5/16/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0282	CapacitorBank	824-0960 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature: 79
7/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0286	CapacitorBank	885-0856 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 91
7/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0312	CapacitorBank	416-0630 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 121.5 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
8/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0333	CapacitorBank	805-0605 Line	Maintenance Performed: INSPECTION- CONTROL OK, BANK FUSE BLOWN Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
8/15/2019 0:00	Distribution Lines	CM - Capacitor Bank	BC0333	CapacitorBank	805-0605 Line	Maintenance Performed: INSPECTION- CONTROL OK, BANK FUSE BLOWN Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
8/30/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0336	CapacitorBank	805-0605 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 88
7/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0342	CapacitorBank	885-0856 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 121.1 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 91
7/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0345	CapacitorBank	885-0856 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
6/19/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0347	CapacitorBank	819-0806 Line	Maintenance Performed: INSPECTION Maintained By: T. JACKSON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
9/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0364	CapacitorBank	199-0634 Line	Maintenance Performed: INSPECTION Maintained By: TL WATTS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 70
2/4/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0382	CapacitorBank	727-0612 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 37
3/15/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0386	CapacitorBank	175-0614 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 37
4/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0389	CapacitorBank	175-0615 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 1237 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 47
3/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0402	CapacitorBank	456-0607 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 59
1/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0411	CapacitorBank	686-0879 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 48
4/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0412	CapacitorBank	686-0876 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 124.5 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
5/28/2021 0:00	Distribution Lines	CM - Capacitor Bank	BC0412	CapacitorBank	686-0876 Line	Maintenance Performed: DISREGARD Maintained By: DISREGARD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0414	CapacitorBank	512-0950 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 122.3 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 53
4/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0415	CapacitorBank	690-0855 Line	Maintenance Performed: Inspected OK Maintained By: J Patrick Test Values: Control Operation Position: Automatic SW Status Inspection Time: Temperature: 64

7/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0424	CapacitorBank	416-0630 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 84
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0438	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 61
8/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0462	CapacitorBank	805-0605 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 81
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0479	CapacitorBank	433-0628 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 59
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0482	CapacitorBank	433-0627 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 19
6/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0489	CapacitorBank	683-0779 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 82
4/16/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0492	CapacitorBank	456-0608 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 46
8/8/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0494	CapacitorBank	406-0617 Line	Maintenance Performed: INSPECTION- FOUND OK Maintained By: J. PATRICK Test Values: 124.4/123.3 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
3/31/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0495	CapacitorBank	223-0947 Line	Maintenance Performed: Inspected OK Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 48
4/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0499	CapacitorBank	223-0948 Line	Maintenance Performed: Inspected, found offline, left offline Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature:
3/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0502	CapacitorBank	737-0601 Line	Maintenance Performed: INSPECTION- FOUND A PHASE CURRNT HIGH 39.6 Maintained By: J. PATRICK Test Values: 121.7 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 62
4/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0504	CapacitorBank	023-0808 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 30
4/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0512	CapacitorBank	023-0808 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 41
7/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0518	CapacitorBank	824-0961 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 92
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0519	CapacitorBank	531-0909 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 121.9 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 62
4/23/2021 0:00	Distribution Lines	CM - Capacitor Bank	BC0519	CapacitorBank	531-0909 Line	Maintenance Performed: DISREGARD-AL Maintained By: E028070 Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/3/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0520	CapacitorBank	697-0900 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 122.3 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 25
4/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0521	CapacitorBank	023-0808 Line	Maintenance Performed: Inspected OK Maintained By: J PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 59
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0524	CapacitorBank	531-0909 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 63
2/3/2021 0:00	Distribution Lines	CM - Capacitor Bank	BC0529	CapacitorBank	697-0903 Line	Maintenance Performed: INSPECITON - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 36
6/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0535	CapacitorBank	824-0960 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 122.2 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 76
2/3/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0536	CapacitorBank	697-0901 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 125.1 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 25
6/16/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0539	CapacitorBank	824-0960 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 79
3/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0545	CapacitorBank	456-0607 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 57

4/16/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0546	CapacitorBank	456-0608 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature: 46
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0570	CapacitorBank	692-0912 Line	Maintenance Performed: INSPECTION - CAP BANK IS ON AN OPEN LINE TO OLD WAREHOUSE, MAY NEED TO BE REMOVED Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 51
7/7/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0578	CapacitorBank	416-0629 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 122.3 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 88
4/27/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0583	CapacitorBank	091-0920 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
9/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0594	CapacitorBank	680-0642 Line	Maintenance Performed: INSPECTION Maintained By: TL WATTS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 83
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0595	CapacitorBank	433-0628 Line	Maintenance Performed: Inspectd Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
11/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0625	CapacitorBank	539-0969 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 123.8 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 58
3/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0702	CapacitorBank	090-0622 Line	Maintenance Performed: Inspection Maintained By: J Patrick Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 73
3/15/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0703	CapacitorBank	175-0614 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 122.5 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 38
3/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0706	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND B PHASE FUSE BLOWN Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 73
3/10/2021 0:00	Distribution Lines	CM - Capacitor Bank	BC0706	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND B PHASE FUSE BLOWN Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 73
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0707	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 51
5/5/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0711	CapacitorBank	766-0847 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 52
2/26/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0712	CapacitorBank	690-0855 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 39
2/26/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0713	CapacitorBank	690-0855 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 124.9 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 39
6/12/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0717	CapacitorBank	819-0806 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 88
5/26/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0726	CapacitorBank	512-0950 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 35
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0729	CapacitorBank	692-0913 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 50
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0731	CapacitorBank	531-0907 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 65
3/1/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0732	CapacitorBank	531-0908 Line	Maintenance Performed: INSPECTION - NO CONTROLS FOUND Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Open Temperature: 45
3/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0733	CapacitorBank	531-0907 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 125.1 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 65
2/3/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0736	CapacitorBank	697-0902 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 126.2 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 22

1/14/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0740	CapacitorBank	839-0636 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 28
3/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0755	CapacitorBank	690-0851 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/15/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0777	CapacitorBank	091-0920 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 46
2/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0781	CapacitorBank	663-0799 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 32
8/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0799	CapacitorBank	406-0617 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 124.4 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 84
5/12/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0800	CapacitorBank	819-0805 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 125.4 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
5/12/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0833	CapacitorBank	819-0805 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
3/6/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0835	CapacitorBank	433-0627 Line	Maintenance Performed: INSPECTION Maintained By: TIM DUVALL Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 35
4/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0855	CapacitorBank	899-0081 Line	Maintenance Performed: INSPECTION Maintained By: J PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 64
8/8/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0979	CapacitorBank	406-0617 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 86
6/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0983	CapacitorBank	824-0960 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 123.5 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 73
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0987	CapacitorBank	433-0627 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 24
3/6/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0987	CapacitorBank	433-0627 Line	Maintenance Performed: INSPECTION Maintained By: TIM DUVALL Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 35
5/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0987	CapacitorBank	433-0627 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 67
3/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0992	CapacitorBank	692-0914 Line	Maintenance Performed: INSPECTION - FOUND OFFLINE Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 31
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	BC0993	CapacitorBank	773-0930 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 121.4 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 82
1/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	BC1001	CapacitorBank	737-0600 Line	Maintenance Performed: INSPECTION - FOUND OFFLINE Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 28
5/26/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	C1434	CapacitorBank	512-0950 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 85
5/5/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2101	CapacitorBank	766-0847 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 52
5/24/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2193	CapacitorBank	633-0639 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 88
5/25/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2195	CapacitorBank	633-0639 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 89
5/25/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2196	CapacitorBank	633-0639 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
5/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2198	CapacitorBank	766-0849 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 64
5/1/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2199	CapacitorBank	766-0849 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 122.5 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 65

7/28/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2200	CapacitorBank	416-0630 Line	Maintenance Performed: INSPECTION Maintained By: J. BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 92
7/28/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2202	CapacitorBank	416-0630 Line	Maintenance Performed: INSPECTION Maintained By: J. BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 90
7/28/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2203	CapacitorBank	416-0630 Line	Maintenance Performed: INSPECTION Maintained By: J. BLACK Test Values: 122.6 Control Operation Position: SW Status Inspection Time: Temperature: 90
8/5/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2204	CapacitorBank	416-0631 Line	Maintenance Performed: INSPECTION Maintained By: J. BLACK Test Values: 122.2 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 84
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	C2206	CapacitorBank	433-0626 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 50
3/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	C2206	CapacitorBank	433-0626 Line	Maintenance Performed: INSPECTED Maintained By: TIM DUVAL Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 51
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	C2209	CapacitorBank	433-0627 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 25
11/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	C2894	CapacitorBank	539-0969 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
6/17/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2911	CapacitorBank	069-2325 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 124.4 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 82
5/5/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2945	CapacitorBank	091-0922 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 52
4/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2946	CapacitorBank	737-0602 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
4/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	C2947	CapacitorBank	686-0876 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
10/15/2020 9:14	Transmission	Remove - CapacitorBank	CAP000115	CapacitorBank	912-Offline-Transmission	[MxOrder - 2020-4077761 / Remove - CapacitorBank]
1/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-11	CapacitorBank	649-2301 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 34
3/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-11	CapacitorBank	649-2301 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 53
1/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-12	CapacitorBank	649-2300 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 34
3/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-12	CapacitorBank	649-2300 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 51
1/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-13	CapacitorBank	589-2145 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 37
5/18/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-13	CapacitorBank	589-2145 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.8 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75
1/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-14	CapacitorBank	589-2145 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 37
5/24/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-14	CapacitorBank	589-2145 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.4 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 90
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-NA-39	CapacitorBank	811-2419 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
5/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CAPBK-UNK-1	CapacitorBank	512-0950 Line	Maintenance Performed: INSPECTION Maintained By: UNKNOWN Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/15/2019 0:00	Distribution Lines	CM - Capacitor Control	CAPC000755	CapacitorControl	805-0605 Line	Maintenance Performed: INSPECTION- CONTROL OK, BANK FUSE BLOWN Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80

3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0013	CapacitorBank	513-2231 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0014	CapacitorBank	513-2231 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 59
5/18/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0206	CapacitorBank	849-2103 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.2 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 76
4/30/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0268	CapacitorBank	849-2103 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 76
4/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0281	CapacitorBank	589-2146 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 124.1 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 66
4/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0284	CapacitorBank	589-2146 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 66
4/29/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0285	CapacitorBank	589-2146 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 66
5/18/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0286	CapacitorBank	592-2147 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 73
2/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0320	CapacitorBank	094-2166 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 47
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0405	CapacitorBank	767-2414 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: 123 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
1/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0406	CapacitorBank	845-2458 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 40
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0407	CapacitorBank	845-2457 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 38
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0409	CapacitorBank	845-2457 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 43
2/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0410	CapacitorBank	845-2458 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 38
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0412	CapacitorBank	767-2411 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 29
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0415	CapacitorBank	767-2410 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 25
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0416	CapacitorBank	767-2410 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 54
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0418	CapacitorBank	767-2411 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0420	CapacitorBank	767-2415 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 25
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0421	CapacitorBank	767-2410 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
4/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0423	CapacitorBank	767-2414 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
4/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0425	CapacitorBank	767-2414 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0426	CapacitorBank	767-2415 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 25
4/1/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0428	CapacitorBank	767-2414 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0429	CapacitorBank	767-2414 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 58
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0430	CapacitorBank	767-2410 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 58

1/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0490	CapacitorBank	809-2332 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 52
2/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0491	CapacitorBank	455-2477 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 124.6 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 36
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0493	CapacitorBank	605-2455 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 49
3/13/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0499	CapacitorBank	605-2453 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 65
4/1/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0500	CapacitorBank	605-2452 Line	Maintenance Performed: inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 41
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0502	CapacitorBank	452-2334 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 31
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0503	CapacitorBank	605-2452 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 50
3/14/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0504	CapacitorBank	605-2453 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 59
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0506	CapacitorBank	605-2452 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 49
3/21/2019 0:00	Distribution Lines	CM - Capacitor Bank	CC0516	CapacitorBank	793-2437 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 49
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0518	CapacitorBank	793-2439 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 47
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0519	CapacitorBank	556-2465 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 49
3/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0520	CapacitorBank	793-2437 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 120 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 47
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0521	CapacitorBank	793-2438 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 47
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0522	CapacitorBank	556-2466 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 46
3/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0523	CapacitorBank	556-2466 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 48
3/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0524	CapacitorBank	793-2439 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 120.9 Control Operation Position: SW Status Inspection Time: Closed Temperature: 48
3/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0525	CapacitorBank	597-2404 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 122.6 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 54
1/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0531	CapacitorBank	597-2404 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 38
1/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0532	CapacitorBank	597-2405 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 34
1/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0533	CapacitorBank	556-2465 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 40
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0536	CapacitorBank	562-2441 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 125.3 Control Operation Position: SW Status Inspection Time: Closed Temperature: 57
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0537	CapacitorBank	562-2440 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 58
3/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0538	CapacitorBank	562-2440 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 125.1 Control Operation Position: Automatic SW Status Inspection Time: Temperature: 57
3/18/2019 0:00	Distribution Lines	CM - Capacitor Bank	CC0544	CapacitorBank	774-2428 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 49
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0545	CapacitorBank	774-2428 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 49
3/8/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0546	CapacitorBank	774-2429 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Temperature: 39

3/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0548	CapacitorBank	774-2431 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 45
3/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0549	CapacitorBank	774-2431 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0550	CapacitorBank	774-2430 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 47
3/11/2019 0:00	Distribution Lines	CM - Capacitor Bank	CC0551	CapacitorBank	774-2430 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0552	CapacitorBank	774-2430 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 50
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0559	CapacitorBank	604-2444 Line	Maintenance Performed: Inspection Maintained By: E011553 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 45
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0561	CapacitorBank	759-2451 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 22
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0562	CapacitorBank	759-2451 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 23
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0567	CapacitorBank	681-2443 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 43
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0568	CapacitorBank	681-0000 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 41
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0575	CapacitorBank	611-2433 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 25
3/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0576	CapacitorBank	611-2433 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 49
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0577	CapacitorBank	611-2433 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 25
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0578	CapacitorBank	611-2433 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 27
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0586	CapacitorBank	611-2434 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 45
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0587	CapacitorBank	611-2432 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 31
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0588	CapacitorBank	611-2432 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 49
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0589	CapacitorBank	611-2436 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 40
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0590	CapacitorBank	611-2434 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: 120v Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 47
3/4/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0592	CapacitorBank	611-2435 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 31
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0593	CapacitorBank	611-2434 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 54
3/11/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0599	CapacitorBank	064-2401 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 43
7/30/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0613	CapacitorBank	069-2237 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.7 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
2/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0614	CapacitorBank	833-2314 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: Manual SW Status Inspection Time: Temperature: 36
7/31/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0614	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
8/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0614	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
7/30/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0616	CapacitorBank	461-2171 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 83

5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0617	CapacitorBank	461-2171 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
2/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0618	CapacitorBank	833-2314 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: 125.4 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 37
8/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0618	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 124.6 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 87
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0620	CapacitorBank	687-2224 Line	Maintenance Performed: Inspected Maintained By: John Black Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 73
8/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0622	CapacitorBank	069-2326 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 95
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0623	CapacitorBank	833-2314 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 44
7/31/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0623	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 83
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0623	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 97
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0624	CapacitorBank	833-2314 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0624	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 69
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0624	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 95
2/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0625	CapacitorBank	545-2321 Line	Maintenance Performed: Inspected. Maintained By: J. Black Test Values: 122 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 41
2/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0626	CapacitorBank	545-2321 Line	Maintenance Performed: Inspected Maintained By: J. Black Test Values: 122 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 41
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0630	CapacitorBank	429-2313 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: 122.6 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 52
7/8/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0630	CapacitorBank	429-2313 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 121.7 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 89
6/1/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0631	CapacitorBank	833-2109 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 122.5 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 77
2/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0634	CapacitorBank	545-2323 Line	Maintenance Performed: Inspected Maintained By: J. Black Test Values: 125 Control Operation Position: SW Status Inspection Time: Temperature: 43
8/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0634	CapacitorBank	545-2323 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 88
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0635	CapacitorBank	545-2323 Line	Maintenance Performed: Inspected Maintained By: J Oschwald Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 57
7/30/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0635	CapacitorBank	545-2323 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 83
8/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0635	CapacitorBank	545-2323 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 91
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0638	CapacitorBank	545-2324 Line	Maintenance Performed: Inspected Maintained By: J Oschwald Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0638	CapacitorBank	545-2324 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 97
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0640	CapacitorBank	540-0334 Line	Maintenance Performed: Inspected Maintained By: J Oschwald Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60

2/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0641	CapacitorBank	829-2320 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 51
2/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0644	CapacitorBank	429-2154 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 48
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0644	CapacitorBank	429-2154 Line	Maintenance Performed: INSPECTION Maintained By: HARRISON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 98
2/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0645	CapacitorBank	829-2318 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 50
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0648	CapacitorBank	833-2314 Line	Maintenance Performed: INSPECTION Maintained By: HARRISON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 97
8/3/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0653	CapacitorBank	857-0330 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.1 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75
8/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0655	CapacitorBank	542-0342 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 91
2/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0661	CapacitorBank	857-0331 Line	Maintenance Performed: Inspected Maintained By: Joshua Oschwald Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 46
8/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0661	CapacitorBank	857-0331 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 83
8/4/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0661	CapacitorBank	857-0331 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 78
2/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0662	CapacitorBank	857-0331 Line	Maintenance Performed: Inspected Maintained By: Joshua Oschwald Test Values: 123.7 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 46
2/13/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0670	CapacitorBank	829-2319 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 41
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0671	CapacitorBank	833-2161 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0671	CapacitorBank	833-2161 Line	Maintenance Performed: INSPECTION Maintained By: J. HARRISON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 91
2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0673	CapacitorBank	140-0333 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 49
3/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0673	CapacitorBank	140-0333 Line	Maintenance Performed: INSPECTION Maintained By: WARD SCHOON Test Values: Control Operation Position: SW Status Inspection Time: Closed Temperature: 57
8/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0677	CapacitorBank	429-2154 Line	Maintenance Performed: INSPECTION Maintained By: HARRISON Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 97
6/17/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0678	CapacitorBank	461-2171 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 122.3 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 82
2/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0680	CapacitorBank	429-2154 Line	Maintenance Performed: Inspected Maintained By: J Harrison Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
8/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0680	CapacitorBank	429-2154 Line	Maintenance Performed: INSPECTION Maintained By: J. HARRISON Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
8/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0682	CapacitorBank	069-2237 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 118.7 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 81
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0685	CapacitorBank	687-2312 Line	Maintenance Performed: Inspected Maintained By: L Gross Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 32
2/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0686	CapacitorBank	542-0342 Line	Maintenance Performed: Inspected Maintained By: J. Black Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 42
8/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	CC0686	CapacitorBank	542-0342 Line	Maintenance Performed: INSPECTION Maintained By: J. OSCHWALD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 93
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC2165	CapacitorBank	774-2430 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 46

3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC2169	CapacitorBank	774-2428 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 49
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC2172	CapacitorBank	608-2459 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 70
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	CC2176	CapacitorBank	527-2423 Line	Maintenance Performed: Inspection Maintained By: E011308 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 74
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0006	CapacitorBank	513-2231 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 57
3/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0050	CapacitorBank	513-2231 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 59
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0071	CapacitorBank	774-2430 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 50
3/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0072	CapacitorBank	774-2467 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 54
4/15/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0079	CapacitorBank	091-0923 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 122.6 Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 48
4/15/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC0080	CapacitorBank	091-0923 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 122.1 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 47
6/17/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	KC100	CapacitorBank	683-0779 Line	Maintenance Performed: INSPECTION Maintained By: J. PATRICK Test Values: 122 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75
1/12/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC107	CapacitorBank	737-0600 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 1242 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 28
3/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC108	CapacitorBank	737-0601 Line	Maintenance Performed: INSPECTION - FOUND OFFLINE Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 62
3/5/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC109	CapacitorBank	737-0601 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 37
3/3/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC110	CapacitorBank	737-0601 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 124.1 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 41
5/27/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	KC115	CapacitorBank	687-2312 Line	Maintenance Performed: INSPECTION Maintained By: JOHN BLACK Test Values: 123.1 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 85
1/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	KC141	CapacitorBank	805-0659 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 38
12/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC142	CapacitorBank	805-0659 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 35
8/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC144	CapacitorBank	686-0878 Line	Maintenance Performed: INSPECTION - FOUND OK Maintained By: J. PATRICK Test Values: 125.1 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 91
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC163	CapacitorBank	809-2331 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 33
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC164	CapacitorBank	811-2418 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 35
1/31/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC165	CapacitorBank	811-2418 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 21
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC166	CapacitorBank	811-2419 Line	Maintenance Performed: Inspection Maintained By: E011553 Test Values: 124.6 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 21
3/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC167	CapacitorBank	811-2420 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55

1/31/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC168	CapacitorBank	811-2420 Line	Maintenance Performed: Inspection Maintained By: E009370 Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 21
1/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC169	CapacitorBank	455-2477 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
2/21/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC170	CapacitorBank	552-2462 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 124.1 Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 45
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC171	CapacitorBank	455-2479 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 123.8 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 37
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC172	CapacitorBank	552-2463 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 123.1 Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 39
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC173	CapacitorBank	552-2463 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 123.5 Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 20
2/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	KC174	CapacitorBank	552-2464 Line	Maintenance Performed: Inspection Maintained By: N110852 Test Values: 124.7 Control Operation Position: SW Status Inspection Time: Closed Temperature: 38
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0001	CapacitorBank	HB-1145 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0002	CapacitorBank	WT-1210 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0003	CapacitorBank	AK-1295 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0004	CapacitorBank	ML-1283 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0005	CapacitorBank	BY-1284 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0006	CapacitorBank	SH-1284 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0007	CapacitorBank	AK-1291 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
						TEST MXORDER TO ARM - KARLA KISER
						[MxOrder - 2022-4716876 / CM - Capacitor Bank]
8/1/2022 0:00	Distribution Lines	CM - Capacitor Bank	LC0007	CapacitorBank	AK-1291 Line	*** ARM Work Request Number: 6988625
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0008	CapacitorBank	GI-0003 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0009	CapacitorBank	TE-1247 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0010	CapacitorBank	HK-1241 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0012	CapacitorBank	HC-1293 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0013	CapacitorBank	DX-1220 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0015	CapacitorBank	TE-1242 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0016	CapacitorBank	CL-1230 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0017	CapacitorBank	FV-1137 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC0018	CapacitorBank	AL-1442 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC1093	CapacitorBank	HI-1101 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC1095	CapacitorBank	WO-1179 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC1096	CapacitorBank	HN-1200 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC1097	CapacitorBank	HN-1200 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/5/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	LC1098	CapacitorBank	TE-1246 Line	Maintenance Performed: Inspection Maintained By: D. Britt Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/23/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0001	CapacitorBank	195-1310 Line	Maintenance Performed: inspection Maintained By: r abernathy Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 65
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0001	CapacitorBank	195-1310 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 88
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0002	CapacitorBank	753-1322 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 74
7/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0002	CapacitorBank	753-1322 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0003	CapacitorBank	410-1327 Line	Maintenance Performed: inspection Maintained By: f frazer Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature:
4/23/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0005	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 65
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0005	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
4/23/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0006	CapacitorBank	195-1312 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 64
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0006	CapacitorBank	195-1312 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 87
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0007	CapacitorBank	581-1318 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 67
8/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0007	CapacitorBank	581-1318 Line	Maintenance Performed: inspection Maintained By: rob, tracy, tb Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 79
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0008	CapacitorBank	581-1316 Line	Maintenance Performed: inspection Maintained By: r abernathy Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 67
8/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0008	CapacitorBank	581-1316 Line	Maintenance Performed: inspection Maintained By: tracy, rob, tb Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0009	CapacitorBank	753-1320 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0009	CapacitorBank	753-1320 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0010	CapacitorBank	753-1322 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
7/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0010	CapacitorBank	753-1322 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
4/23/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0016	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: r abernathy Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0016	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/23/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0017	CapacitorBank	401-1325 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

8/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0017	CapacitorBank	401-1325 Line	Maintenance Performed: inspection Maintained By: rob, tracy, tb Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0020	CapacitorBank	581-1316 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 67
8/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0020	CapacitorBank	581-1316 Line	Maintenance Performed: inspection Maintained By: rob, tracy, tb Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 79
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0021	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 81
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0021	CapacitorBank	195-1311 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 81
4/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0037	CapacitorBank	401-1324 Line	Maintenance Performed: inspection Maintained By: t holeman Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 58
8/18/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0037	CapacitorBank	401-1324 Line	Maintenance Performed: inspection Maintained By: d stewart Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 79
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0101	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0101	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0101	CapacitorBank	508-1728 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0206	CapacitorBank	764-1529 Line	Maintenance Performed: inspection Maintained By: devin w Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 77
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0207	CapacitorBank	764-1530 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0208	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 60
7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0208	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 86
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0208	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 75
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0209	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 61
7/9/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0209	CapacitorBank	862-0560 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 92
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0209	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 80
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0210	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0210	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0213	CapacitorBank	438-1714 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0213	CapacitorBank	438-1714 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 72
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0213	CapacitorBank	438-1714 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0214	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0214	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 70

7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0214	CapacitorBank	438-1715 Line	Maintenance Performed: inspection - out of service Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0215	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0215	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0215	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: b shoulder Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0216	CapacitorBank	438-1714 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0216	CapacitorBank	438-1714 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: Manual SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0217	CapacitorBank	673-1703 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 73
8/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0217	CapacitorBank	673-1703 Line	Maintenance Performed: inspection Maintained By: b shoulder Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 77
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0217	CapacitorBank	673-1703 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 83
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0219	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0219	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0219	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0220	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 39
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0220	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 62
7/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0220	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
4/30/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0221	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 56
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0221	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 77
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0221	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: SW Status Inspection Time: Closed Temperature: 83
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0222	CapacitorBank	852-1502 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
5/18/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0222	CapacitorBank	852-1502 Line	Maintenance Performed: inspection Maintained By: S Saxon Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
7/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0222	CapacitorBank	852-1502 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0223	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature: 60
7/9/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0223	CapacitorBank	862-0560 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 92
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0223	CapacitorBank	862-0560 Line	Maintenance Performed: INSPECTION Maintained By: S SAXON Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature: 85
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0224	CapacitorBank	425-1507 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 66

7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0224	CapacitorBank	425-1507 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0224	CapacitorBank	425-1507 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 72
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0225	CapacitorBank	425-1509 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: Automatic SW Status Inspection Time: Temperature: 65
7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0225	CapacitorBank	425-1509 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0225	CapacitorBank	425-1509 Line	Maintenance Performed: inspections Maintained By: t bingam Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 72
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0226	CapacitorBank	822-1515 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 70
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0228	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d spriggs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 38
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0228	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0234	CapacitorBank	822-1514 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 65
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0236	CapacitorBank	421-1525 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: o Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 70
12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0237	CapacitorBank	764-1531 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 26
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0239	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0239	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: T bingham Test Values: ok Control Operation Position: SW Status Inspection Time: Open Temperature: 70
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0239	CapacitorBank	862-0560 Line	Maintenance Performed: INSPECTION Maintained By: S SAXON Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
4/15/2019 0:00	Distribution	CapacitorBank Line Inspection	WC0240	CapacitorBank	912-Offline-Distribution	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
6/8/2020 0:00	Distribution	CapacitorBank Line Inspection	WC0240	CapacitorBank	912-Offline-Distribution	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 91
6/22/2021 0:00	Distribution	CapacitorBank Line Inspection	WC0240	CapacitorBank	912-Offline-Distribution	Maintenance Performed: INSPECTION Maintained By: OK Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 73
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0241	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0241	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0241	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: SW Status Inspection Time: Closed Temperature: 82
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0242	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0242	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0242	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0244	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:

5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0244	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0245	CapacitorBank	673-1704 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature: 73
8/7/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0245	CapacitorBank	673-1704 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0245	CapacitorBank	673-1704 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0248	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: on Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 26
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0248	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 83
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0249	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0249	CapacitorBank	421-1526 Line	Maintenance Performed: INSPECTION Maintained By: S TOMES Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0250	CapacitorBank	419-0558 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0250	CapacitorBank	419-0558 Line	Maintenance Performed: inspection - not used Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0251	CapacitorBank	671-1503 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
7/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0251	CapacitorBank	671-1503 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0251	CapacitorBank	671-1503 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature: 74
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0252	CapacitorBank	852-1501 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: oka Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 62
5/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0252	CapacitorBank	852-1501 Line	Maintenance Performed: inspection Maintained By: T Bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 80
7/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0252	CapacitorBank	852-1501 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Temperature: 85
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0253	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0253	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0253	CapacitorBank	574-1712 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0254	CapacitorBank	498-1544 Line	Maintenance Performed: inspection Maintained By: d spriggs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 38
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0254	CapacitorBank	498-1544 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 70
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0256	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d spriggs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0256	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0257	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d spriggs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 38
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0257	CapacitorBank	498-1541 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 70

4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0259	CapacitorBank	426-1511 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0259	CapacitorBank	426-1511 Line	Maintenance Performed: inspection Maintained By: b shoulder Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 87
7/19/2021 0:00	Distribution Lines	CM - Capacitor Bank	WC0259	CapacitorBank	426-1511 Line	Maintenance Performed: HOLD CARDED OUT OF SERVICE Maintained By: T BINGHAM Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0260	CapacitorBank	425-1508 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 55
7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0260	CapacitorBank	425-1508 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 90
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0260	CapacitorBank	425-1508 Line	Maintenance Performed: INSPECTION Maintained By: B SHOULDERS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0262	CapacitorBank	708-1518 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 70
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0263	CapacitorBank	671-1503 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 75
6/8/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0263	CapacitorBank	671-1503 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 88
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0263	CapacitorBank	671-1503 Line	Maintenance Performed: INSPECTION Maintained By: S SAXON Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Temperature: 73
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0264	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 60
5/18/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0264	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: S saxon Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0264	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 73
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0265	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 61
7/24/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0265	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 86
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0265	CapacitorBank	862-0560 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 73
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0266	CapacitorBank	498-1544 Line	Maintenance Performed: inspection Maintained By: d spriggs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0266	CapacitorBank	498-1544 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/15/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0267	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature: 58
6/11/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0267	CapacitorBank	862-1506 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 80
7/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0267	CapacitorBank	862-1506 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: SW Status Inspection Time: Closed Temperature: 85
12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0268	CapacitorBank	764-1531 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0269	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0269	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 77

7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0269	CapacitorBank	574-1711 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: SW Status Inspection Time: Closed Temperature: 82
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0301	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 72
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0301	CapacitorBank	438-1715 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0304	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: s saxon Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
5/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0304	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 72
7/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0304	CapacitorBank	574-1710 Line	Maintenance Performed: inspection Maintained By: b shoulders Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 84
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0313	CapacitorBank	822-1516 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0400	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0400	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0400	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0401	CapacitorBank	770-1492 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0401	CapacitorBank	770-1492 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0404	CapacitorBank	718-0446 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0404	CapacitorBank	718-0446 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 54
5/21/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0404	CapacitorBank	718-0446 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0405	CapacitorBank	653-0816 Line	Maintenance Performed: INSPECTION- not working Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0405	CapacitorBank	653-0816 Line	Maintenance Performed: inspection - offline Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0406	CapacitorBank	653-0815 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0406	CapacitorBank	653-0815 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0407	CapacitorBank	653-0815 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0408	CapacitorBank	653-0816 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0408	CapacitorBank	653-0816 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0410	CapacitorBank	702-1450 Line	Maintenance Performed: INSPECTION Maintained By: S TOMES Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 79
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0410	CapacitorBank	702-1450 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0412	CapacitorBank	782-0823 Line	Maintenance Performed: INSPECTION Maintained By: SPRIGGS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0412	CapacitorBank	782-0823 Line	Maintenance Performed: inspection- off line Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0413	CapacitorBank	803-0818 Line	Maintenance Performed: inspection - offline Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0414	CapacitorBank	803-0819 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 79
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0414	CapacitorBank	803-0819 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 80
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0415	CapacitorBank	803-0819 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0415	CapacitorBank	803-0819 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 80
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0417	CapacitorBank	782-0822 Line	Maintenance Performed: INSPECTION Maintained By: SPRIGGS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 83
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0417	CapacitorBank	782-0822 Line	Maintenance Performed: inspection - will not close Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0418	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 40
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0418	CapacitorBank	613-1443 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 65
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0418	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0419	CapacitorBank	794-0839 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0419	CapacitorBank	794-0839 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Open Temperature: 82
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0420	CapacitorBank	005-1476 Line	Maintenance Performed: INSPECTION Maintained By: SPRIGGS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0420	CapacitorBank	005-1476 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0422	CapacitorBank	447-0832 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 53
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0422	CapacitorBank	447-0832 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/21/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0422	CapacitorBank	447-0832 Line	Maintenance Performed: inspection Maintained By: J blanford Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 80
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0423	CapacitorBank	712-0827 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0423	CapacitorBank	712-0827 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: Manual SW Status Inspection Time: Temperature: 76
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0424	CapacitorBank	712-0827 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: no Control Operation Position: SW Status Inspection Time: Closed Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0424	CapacitorBank	712-0827 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 76
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0425	CapacitorBank	712-0825 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: bad Control Operation Position: SW Status Inspection Time: Open Temperature: 83
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0425	CapacitorBank	712-0825 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: bad Control Operation Position: SW Status Inspection Time: Open Temperature: 80
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0426	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0426	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0427	CapacitorBank	770-1491 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85

5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0442	CapacitorBank	787-1473 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0442	CapacitorBank	787-1473 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 62
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0443	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 40
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0443	CapacitorBank	613-1443 Line	Maintenance Performed: inspection Maintained By: JB& TWO Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 65
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0443	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
2/25/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0444	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 55
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0444	CapacitorBank	613-1443 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 65
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0444	CapacitorBank	613-1443 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 68
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0445	CapacitorBank	794-0837 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0445	CapacitorBank	794-0837 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 82
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0447	CapacitorBank	794-0837 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0447	CapacitorBank	794-0837 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0449	CapacitorBank	510-1461 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 58
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0449	CapacitorBank	510-1461 Line	Maintenance Performed: inspection Maintained By: TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0450	CapacitorBank	640-1467 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 55
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0450	CapacitorBank	640-1467 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0450	CapacitorBank	640-1467 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 68
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0451	CapacitorBank	012-1428 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 40
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0451	CapacitorBank	012-1428 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0451	CapacitorBank	012-1428 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0452	CapacitorBank	787-1472 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 46
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0452	CapacitorBank	787-1472 Line	Maintenance Performed: inspection Maintained By: c Edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 56
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0452	CapacitorBank	787-1472 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0453	CapacitorBank	712-0825 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0453	CapacitorBank	712-0825 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0454	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0454	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0456	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 56
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0456	CapacitorBank	502-1427 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 58
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0456	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 60
7/18/2019 0:00	Distribution	CapacitorBank Line Inspection	WC0457	CapacitorBank	EAS-Distribution-Offline	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution	CapacitorBank Line Inspection	WC0457	CapacitorBank	EAS-Distribution-Offline	Maintenance Performed: inspection - offline Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0459	CapacitorBank	702-1450 Line	Maintenance Performed: INSPECTION Maintained By: S TOMES Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0459	CapacitorBank	702-1450 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0460	CapacitorBank	100-1676 Line	Maintenance Performed: inspection- bank gone Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0461	CapacitorBank	770-1492 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0461	CapacitorBank	770-1492 Line	Maintenance Performed: inspection Maintained By: j randolph Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 89
8/13/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0464	CapacitorBank	869-0810 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 77
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0465	CapacitorBank	005-1477 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 89
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0465	CapacitorBank	005-1477 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0466	CapacitorBank	764-1529 Line	Maintenance Performed: inspection Maintained By: devin w Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/13/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0467	CapacitorBank	869-0810 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 88
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0467	CapacitorBank	869-0810 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0468	CapacitorBank	764-1529 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 44
8/13/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0469	CapacitorBank	869-0809 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 88
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0470	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0470	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 89
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0471	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0471	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0473	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0473	CapacitorBank	699-1807 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: SW Status Inspection Time: Closed Temperature: 88
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0474	CapacitorBank	699-1805 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:

6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0474	CapacitorBank	699-1805 Line	Maintenance Performed: inspection - off line Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0475	CapacitorBank	005-1476 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0475	CapacitorBank	005-1476 Line	Maintenance Performed: inspection - offline Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0478	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 39
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0478	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0478	CapacitorBank	827-1554 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
1/2/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0479	CapacitorBank	827-1553 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 39
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0479	CapacitorBank	827-1553 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0479	CapacitorBank	827-1553 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
7/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0480	CapacitorBank	803-0818 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
7/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0480	CapacitorBank	803-0818 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0481	CapacitorBank	702-1450 Line	Maintenance Performed: INSPECTION Maintained By: S TOMES Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 77
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0481	CapacitorBank	702-1450 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
8/12/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0483	CapacitorBank	702-1451 Line	Maintenance Performed: INSPECTION Maintained By: S TOMES Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/21/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0483	CapacitorBank	702-1451 Line	Maintenance Performed: inspection- offline Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0484	CapacitorBank	822-1514 Line	Maintenance Performed: inspection Maintained By: rafe Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 65
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0485	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: devin w Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0485	CapacitorBank	421-1526 Line	Maintenance Performed: inspection- offline Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
10/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0486	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: d williamson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 70
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0486	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
7/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0601	CapacitorBank	142-1666 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0601	CapacitorBank	142-1666 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0605	CapacitorBank	797-1606 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/28/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0605	CapacitorBank	797-1606 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 80
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0605	CapacitorBank	797-1606 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0606	CapacitorBank	797-1607 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:

5/28/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0606	CapacitorBank	797-1607 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 76
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0606	CapacitorBank	797-1607 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0607	CapacitorBank	682-1683 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/29/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0607	CapacitorBank	682-1683 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0607	CapacitorBank	682-1683 Line	Maintenance Performed: INSPECTION Maintained By: J BOREN Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0608	CapacitorBank	468-1668 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0611	CapacitorBank	571-1645 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0611	CapacitorBank	571-1645 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0611	CapacitorBank	571-1645 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0614	CapacitorBank	405-1649 Line	Maintenance Performed: insepction Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0614	CapacitorBank	405-1649 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0614	CapacitorBank	405-1649 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0615	CapacitorBank	405-1651 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 85
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0615	CapacitorBank	405-1651 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0615	CapacitorBank	405-1651 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0616	CapacitorBank	817-1673 Line	Maintenance Performed: insepction Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0616	CapacitorBank	817-1673 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0618	CapacitorBank	817-1673 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature:
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0619	CapacitorBank	817-1674 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0619	CapacitorBank	817-1674 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 80
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0620	CapacitorBank	410-1327 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0626	CapacitorBank	736-1912 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0626	CapacitorBank	736-1912 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 82
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0628	CapacitorBank	736-1911 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: SW Status Inspection Time: Closed Temperature: 80
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0628	CapacitorBank	736-1911 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 81
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0631	CapacitorBank	771-1643 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/28/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0631	CapacitorBank	771-1643 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:

7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0631	CapacitorBank	771-1643 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0633	CapacitorBank	771-1643 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/28/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0633	CapacitorBank	771-1643 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 82
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0633	CapacitorBank	771-1643 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0637	CapacitorBank	665-1626 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0637	CapacitorBank	665-1626 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0637	CapacitorBank	665-1626 Line	Maintenance Performed: INSPECTION Maintained By: J BOREN Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 78
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0639	CapacitorBank	815-1907 Line	Maintenance Performed: inspection Maintained By: j frazier Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/29/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0639	CapacitorBank	815-1907 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: no Control Operation Position: SW Status Inspection Time: Temperature:
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0639	CapacitorBank	815-1907 Line	Maintenance Performed: INSPECTION Maintained By: J BOREN Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 81
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0641	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 85
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0641	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0641	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0643	CapacitorBank	866-1618 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0643	CapacitorBank	866-1618 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0644	CapacitorBank	866-1618 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
7/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0644	CapacitorBank	866-1618 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0645	CapacitorBank	006-1603 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0645	CapacitorBank	006-1603 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0645	CapacitorBank	006-1603 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0646	CapacitorBank	006-1603 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0646	CapacitorBank	006-1603 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0647	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0647	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 77
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0650	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 85
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0650	CapacitorBank	641-0919 Line	Maintenance Performed: INSPECTION Maintained By: D TRAVIS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 78
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0651	CapacitorBank	467-1914 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

5/29/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0651	CapacitorBank	467-1914 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0651	CapacitorBank	467-1914 Line	Maintenance Performed: INSPECTION Maintained By: C MCGHEE Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 89
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0656	CapacitorBank	467-1916 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 81
5/29/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0656	CapacitorBank	467-1916 Line	Maintenance Performed: INSPECTION Maintained By: D TRAVIS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0658	CapacitorBank	797-1606 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/28/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0658	CapacitorBank	797-1606 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 83
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0658	CapacitorBank	797-1606 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
7/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0660	CapacitorBank	405-1650 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0660	CapacitorBank	405-1650 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0660	CapacitorBank	405-1650 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0666	CapacitorBank	006-1602 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0666	CapacitorBank	006-1602 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0668	CapacitorBank	480-1623 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0668	CapacitorBank	480-1623 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0668	CapacitorBank	480-1623 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0671	CapacitorBank	480-1622 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0671	CapacitorBank	480-1622 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0674	CapacitorBank	866-1617 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0674	CapacitorBank	866-1617 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0675	CapacitorBank	418-1329 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0675	CapacitorBank	418-1329 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0678	CapacitorBank	736-1913 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0682	CapacitorBank	771-1642 Line	Maintenance Performed: inspection Maintained By: j frazier Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/29/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0682	CapacitorBank	771-1642 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0682	CapacitorBank	771-1642 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:

6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0683	CapacitorBank	410-1328 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0683	CapacitorBank	410-1328 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 86
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0686	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0686	CapacitorBank	439-1609 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0686	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a gruggs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 89
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0688	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 90
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0688	CapacitorBank	439-1612 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0688	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 86
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0690	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0690	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0690	CapacitorBank	439-1609 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0690	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0691	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/8/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0691	CapacitorBank	439-1609 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: GOOD Control Operation Position: SW Status Inspection Time: Temperature:
6/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0691	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0695	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 83
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0695	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0695	CapacitorBank	641-0919 Line	Maintenance Performed: INSPECTION Maintained By: J BOREN Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 81
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0696	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature: 85
6/1/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0696	CapacitorBank	641-0919 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 74
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0699	CapacitorBank	410-1328 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0699	CapacitorBank	410-1328 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0700	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0700	CapacitorBank	497-0657 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
7/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0700	CapacitorBank	497-0657 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution	CapacitorBank Line Inspection	WC0704	CapacitorBank	912-Offline-Distribution	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:

12/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0710	CapacitorBank	421-1526 Line	Maintenance Performed: inspection Maintained By: s tomes Test Values: no Control Operation Position: SW Status Inspection Time: Temperature: 26
7/23/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0710	CapacitorBank	421-1526 Line	Maintenance Performed: inspection - offline Maintained By: s tomes Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/22/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0713	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0713	CapacitorBank	439-1612 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0713	CapacitorBank	439-1612 Line	Maintenance Performed: inspection Maintained By: a Grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0714	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 90
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0714	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/9/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0714	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
7/3/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0715	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0715	CapacitorBank	439-1609 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0716	CapacitorBank	410-1328 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0716	CapacitorBank	410-1328 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0717	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/3/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0717	CapacitorBank	497-0657 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0717	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0719	CapacitorBank	576-1615 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/11/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0719	CapacitorBank	576-1615 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0723	CapacitorBank	100-1676 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/17/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0725	CapacitorBank	736-1912 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0725	CapacitorBank	736-1912 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/17/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0725	CapacitorBank	736-1912 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/2/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0726	CapacitorBank	693-0654 Line	Maintenance Performed: inspection Maintained By: d travis Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/17/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0726	CapacitorBank	693-0654 Line	Maintenance Performed: inspection Maintained By: j pendley Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0728	CapacitorBank	497-0656 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0728	CapacitorBank	497-0656 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0728	CapacitorBank	497-0656 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0729	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: bird Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0729	CapacitorBank	497-0657 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0729	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/18/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0730	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0730	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
6/10/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0730	CapacitorBank	497-0657 Line	Maintenance Performed: inspection Maintained By: a grubbs Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0731	CapacitorBank	665-1626 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
6/5/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0731	CapacitorBank	665-1626 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0731	CapacitorBank	665-1626 Line	Maintenance Performed: inspection Maintained By: j boren Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
6/20/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0732	CapacitorBank	410-1327 Line	Maintenance Performed: inspection Maintained By: j frazer Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
6/4/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0732	CapacitorBank	410-1327 Line	Maintenance Performed: INSPECTION Maintained By: A GRUBBS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Temperature:
6/22/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0732	CapacitorBank	410-1327 Line	Maintenance Performed: inspection Maintained By: j boren Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0733	CapacitorBank	410-1328 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature:
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0734	CapacitorBank	410-1327 Line	Maintenance Performed: INSPECTION Maintained By: J FRAZER Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
7/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0734	CapacitorBank	410-1327 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Temperature: 86
6/19/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0735	CapacitorBank	665-1626 Line	Maintenance Performed: inspection Maintained By: bird Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 85
7/8/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0735	CapacitorBank	665-1626 Line	Maintenance Performed: INSPECTION Maintained By: J PENDLEY Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0800	CapacitorBank	689-1407 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0800	CapacitorBank	689-1407 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 58
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0800	CapacitorBank	689-1407 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0801	CapacitorBank	689-1408 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
5/21/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0801	CapacitorBank	689-1408 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature: 83
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0803	CapacitorBank	004-1750 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0803	CapacitorBank	004-1750 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0804	CapacitorBank	004-1751 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0804	CapacitorBank	004-1751 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 70
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0804	CapacitorBank	004-1751 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:

2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0805	CapacitorBank	888-1437 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 45
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0805	CapacitorBank	888-1437 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0805	CapacitorBank	888-1437 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0806	CapacitorBank	610-0747 Line	Maintenance Performed: INSPECTION Maintained By: D LUCK Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0806	CapacitorBank	610-0747 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0806	CapacitorBank	610-0747 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0807	CapacitorBank	004-1751 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0807	CapacitorBank	004-1751 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 70
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0807	CapacitorBank	004-1751 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0808	CapacitorBank	492-1742 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0808	CapacitorBank	492-1742 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0808	CapacitorBank	492-1742 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0810	CapacitorBank	640-1468 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0810	CapacitorBank	640-1468 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0810	CapacitorBank	640-1468 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0811	CapacitorBank	510-1461 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0811	CapacitorBank	510-1461 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 65
5/21/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0811	CapacitorBank	510-1461 Line	Maintenance Performed: INSPECTION Maintained By: COY E Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0812	CapacitorBank	458-1404 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 58
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0812	CapacitorBank	458-1404 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0812	CapacitorBank	458-1404 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0813	CapacitorBank	610-0747 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 40
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0813	CapacitorBank	610-0747 Line	Maintenance Performed: inspection Maintained By: TWO & BB Test Values: Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0814	CapacitorBank	012-1431 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0814	CapacitorBank	012-1431 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0814	CapacitorBank	012-1431 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/27/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0815	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 56

5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0815	CapacitorBank	502-1427 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 58
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0815	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0816	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0816	CapacitorBank	502-1427 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 58
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0816	CapacitorBank	502-1427 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 60
3/8/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0817	CapacitorBank	648-1762 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0817	CapacitorBank	648-1762 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0817	CapacitorBank	648-1762 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0818	CapacitorBank	496-1759 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature: 55
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0818	CapacitorBank	496-1759 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0818	CapacitorBank	496-1759 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0820	CapacitorBank	888-1437 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0820	CapacitorBank	888-1437 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0821	CapacitorBank	888-1437 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 60
6/7/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0821	CapacitorBank	888-1437 Line	Maintenance Performed: INSPECTION Maintained By: D LUCK Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0822	CapacitorBank	508-1726 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 48
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0822	CapacitorBank	508-1726 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0822	CapacitorBank	508-1726 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0826	CapacitorBank	865-1731 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0826	CapacitorBank	865-1731 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0826	CapacitorBank	865-1731 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 80
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0827	CapacitorBank	648-1761 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 40
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0827	CapacitorBank	648-1761 Line	Maintenance Performed: inspection Maintained By: BB & TWO Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 70
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0827	CapacitorBank	648-1761 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0828	CapacitorBank	865-1733 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 55

5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0828	CapacitorBank	865-1733 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0828	CapacitorBank	865-1733 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0831	CapacitorBank	496-1760 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 55
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0831	CapacitorBank	496-1760 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0831	CapacitorBank	496-1760 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0832	CapacitorBank	640-1468 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 55
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0832	CapacitorBank	640-1468 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 60
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0832	CapacitorBank	640-1468 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0834	CapacitorBank	689-1407 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0834	CapacitorBank	689-1407 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 75
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0834	CapacitorBank	689-1407 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 62
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0836	CapacitorBank	689-1408 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0836	CapacitorBank	689-1408 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 58
5/21/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0836	CapacitorBank	689-1408 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 85
2/26/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0837	CapacitorBank	012-1431 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 40
5/13/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0837	CapacitorBank	012-1431 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 55
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0837	CapacitorBank	012-1431 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 68
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0838	CapacitorBank	610-0746 Line	Maintenance Performed: INSPECTION Maintained By: D LUCK Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0838	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: r robinson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 65
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0838	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 85
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0839	CapacitorBank	610-0747 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 80
3/6/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0840	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0840	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: TWO & BB Test Values: no Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0844	CapacitorBank	610-0746 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0844	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: r robinson Test Values: Control Operation Position: SW Status Inspection Time: Temperature:

5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0844	CapacitorBank	610-0746 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
3/8/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0845	CapacitorBank	648-1762 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 55
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0845	CapacitorBank	648-1762 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0845	CapacitorBank	648-1762 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0847	CapacitorBank	648-1763 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 40
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0847	CapacitorBank	648-1763 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0847	CapacitorBank	648-1763 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 80
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0848	CapacitorBank	648-1763 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0848	CapacitorBank	648-1763 Line	Maintenance Performed: inspection Maintained By: BB & TWO Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/20/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0848	CapacitorBank	648-1763 Line	Maintenance Performed: inspection Maintained By: t overfeild Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0850	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 57
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0850	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 76
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0850	CapacitorBank	508-1728 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0851	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0851	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 75
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0851	CapacitorBank	508-1728 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0852	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0852	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0852	CapacitorBank	508-1728 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0853	CapacitorBank	508-1726 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 48
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0853	CapacitorBank	508-1726 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0853	CapacitorBank	508-1726 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 65
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0854	CapacitorBank	508-1725 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 48
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0854	CapacitorBank	508-1725 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0854	CapacitorBank	508-1725 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 65

2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0855	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0855	CapacitorBank	508-1728 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 76
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0855	CapacitorBank	508-1728 Line	Maintenance Performed: INSPECTION Maintained By: J BLANFORD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 65
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0857	CapacitorBank	492-1742 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 50
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0857	CapacitorBank	492-1742 Line	Maintenance Performed: inspection Maintained By: TWO & JB Test Values: Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 70
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0857	CapacitorBank	492-1742 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0858	CapacitorBank	492-1742 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature: 50
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0858	CapacitorBank	492-1742 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0858	CapacitorBank	492-1742 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 75
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0861	CapacitorBank	004-1750 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: Control Operation Position: SW Status Inspection Time: Temperature:
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0861	CapacitorBank	004-1750 Line	Maintenance Performed: inspection Maintained By: c edens Test Values: Control Operation Position: SW Status Inspection Time: Temperature: 80
5/14/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0861	CapacitorBank	004-1750 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: SW Status Inspection Time: Temperature:
2/28/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0862	CapacitorBank	496-1759 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 55
5/14/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0862	CapacitorBank	496-1759 Line	Maintenance Performed: inspection Maintained By: JB & TWO Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 65
5/13/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0862	CapacitorBank	496-1759 Line	Maintenance Performed: INSPECTION Maintained By: T OVERFIELD Test Values: OK Control Operation Position: Manual SW Status Inspection Time: Open Temperature: 70
3/7/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0864	CapacitorBank	004-1750 Line	Maintenance Performed: INSPECTION Maintained By: C EDENS Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/15/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0864	CapacitorBank	004-1750 Line	Maintenance Performed: inspection Maintained By: r robinson Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Open Temperature:
5/19/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0864	CapacitorBank	004-1750 Line	Maintenance Performed: inspection Maintained By: t overfield Test Values: ok Control Operation Position: Manual SW Status Inspection Time: Closed Temperature: 80
4/16/2019 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0866	CapacitorBank	852-1501 Line	Maintenance Performed: inspection Maintained By: t bingham Test Values: ok Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 60
5/20/2020 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0866	CapacitorBank	852-1501 Line	Maintenance Performed: inspection Maintained By: S Saxon Test Values: ok Control Operation Position: SW Status Inspection Time: Temperature:
7/16/2021 0:00	Distribution Lines	CapacitorBank Line Inspection	WC0866	CapacitorBank	852-1501 Line	Maintenance Performed: INSPECTION Maintained By: T BINGHAM Test Values: OK Control Operation Position: Automatic SW Status Inspection Time: Closed Temperature: 75