























































2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Hyd Recloser Timing Test Form	370564
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	One Shot Operation Correct	Yes
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Test Comments	Internal inspection passed. HI Pot passed. One Shot passed. Minimum Trip passed. Did not get to finish testing due to urgency of Line Crew needing Recloser. Did finish testing its mate RC1333 which tested good
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Test Pass Fail	Pass
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Bushing Condition	Good
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Equipment Properly Labeled?	y
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Follow-up Action Required?	n
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	General Comments	ok
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	General Condition Gaskets	OK all gaskets
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 1	Pass
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 2	NA
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 3	NA
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Hyd Recloser Timing Test Form	890400
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Oil Dielectric Test	25.70 KV
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	One Shot Operation Correct	Yes
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Test Comments	There were no post maintenance procedures required.
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001334	RecloserHydraulic	869-0811 B-Line	Hydraulic Recloser Overhaul Inspection	Test Pass Fail	Pass
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Bushing Condition	Good
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Equipment Properly Labeled?	y
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Follow-up Action Required?	n
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	General Comments	Oil not tested, Brand New
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	General Condition Gaskets	OK all gaskets
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 1	Pass
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 2	Pass
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 3	Pass
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hyd Recloser Timing Test Form	370565
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	One Shot Operation Correct	Yes
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Test Comments	Did not get to finish testing due to urgency of Line Crew needing Recloser. Internal inspection was good, One shot, Minimum trip, and HI Pot passed. Mate to this recloser was tested and passed.
2/11/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Test Pass Fail	Pass
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Bushing Condition	Good
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Equipment Properly Labeled?	y
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Follow-up Action Required?	n
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	General Comments	ok
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	General Condition Gaskets	OK all gaskets
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 1	Pass
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 2	NA
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 3	NA
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Hyd Recloser Timing Test Form	890401
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Oil Dielectric Test	30.10 KV
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	One Shot Operation Correct	Yes
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Test Comments	There were no post maintenance procedures required.
6/2/2022 0:00	Distribution Lines	Hydraulic Recloser Overhaul	RC001335	RecloserHydraulic	869-0811 C-Line	Hydraulic Recloser Overhaul Inspection	Test Pass Fail	Pass
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	A Ø Operations Counter	0
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	B Ø Operations Counter	0
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Battery Bank Volts	0.0 VDC
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	C Ø Operations Counter	0
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Control Cable Condition	Good
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Control Operation Checked	n
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Follow-up Action Required?	y
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Free of Visible Damage/Leaks	n
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	General Comments	need off report
10/25/2022 0:00	Distribution Lines	Breckenridge Annual Control Inspection	RCC000695	RecloserControl	BR-1185-Line	RecloserControl Line Visual Inspection	Lamp Test Lights Operational?	Yes
8/17/2023 14:32	Distribution Lines	Electronic Recloser Control Test Inspection	RCC901802	RecloserControl	588-2524 Line	Recloser Annual Control Inspection	Follow-up Action Required?	n
8/17/2023 14:32	Distribution Lines	Electronic Recloser Control Test Inspection	RCC901802	RecloserControl	588-2524 Line	Recloser Annual Control Inspection	General Comments	line crew inspection
8/17/2023 14:32	Distribution Lines	Electronic Recloser Control Test Inspection	RCC901802	RecloserControl	588-2524 Line	Recloser Annual Control Inspection	Reason For Inspection	Routine Insp
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	Bushing Condition	Good
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	Equipment Properly Labeled?	y
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	Follow-up Action Required?	n
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	General Comments	repainted recloser and replaced c phase counter
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	General Condition Gaskets	OK all gaskets
10/9/2019 0:00	Distribution Lines	Hydraulic Recloser Overhaul	WX0037	RecloserHydraulic	006-1603-Line	Hydraulic Recloser Overhaul Inspection	Hi-Pot Pole 1	Pass

















