

Inspection Number	Vault Name	Vault Address	Inspection Date	Next Inspection Due	Question	Answer
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	13
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6244237	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE

6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	BARCODE	FALSE
6334864	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/15/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	13
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01

6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	BARCODE	TRUE
6415623	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/30/2019 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	11
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE

6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6436438	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	1/28/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	Anything not listed?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	15
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6567799	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	7/8/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	Vault cleaned during this inspection?	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	11
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE

6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	BARCODE	TRUE
6665600	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	12/31/2020 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	Anything not listed?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	13
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6766770	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	6/8/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	09
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE

6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	BARCODE	TRUE
6861171	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	10/13/2021 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	Anything not listed?	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
6932763	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/17/2022 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	Anything not listed?	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	10
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE

7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	BARCODE	FALSE
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7019269	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	9/6/2022 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	Anything not listed?	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	11
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VAULT LADDER	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7112306	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	3/1/2023 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	Anything not listed?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	Lighting and Receptacles	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VAULT LADDER	TRUE



7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	CABLE TAGS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	SCADA SENSORS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IR SERVICE LEADS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	AD-6 MULTIPLIER	01
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	BARCODE	FALSE
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7217632	VT0001 1ST & BROADWAY	101 W Broadway Louisville KY 40202	8/21/2023 0:00	8/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE

6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243278	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/8/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6334349	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/25/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6433082	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	1/22/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6562591	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	7/7/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE



6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6664661	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	FALSE

6766659	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856483	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928701	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	3/15/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	Anything not listed?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7017669	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	Anything not listed?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE

7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109605	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Anything not listed?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7215151	VT0002 1ST & CONGRESS	218 S 1st ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	BARCODE	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	BARCODE	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	BARCODE	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	BARCODE	FALSE
6292534	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	6/27/2019 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	BARCODE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	BARCODE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	BARCODE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	BARCODE	TRUE
6413505	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/13/2019 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6540834	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	5/19/2020 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE



6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	BARCODE	TRUE
6636537	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	9/10/2020 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE

6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	BARCODE	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6700603	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	3/2/2021 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	BARCODE	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	BARCODE	TRUE
6805616	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/12/2021 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE

6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE



6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	BARCODE	TRUE
6899835	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/10/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	Anything not listed?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	BARCODE	FALSE
6997434	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	8/2/2022 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	Anything not listed?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE

7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7096997	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	2/2/2023 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	Anything not listed?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7199153	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	7/10/2023 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	Anything not listed?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	Lighting and Receptacles	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	VAULT LADDER	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	CABLE TAGS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	TRANSFORMER GASKETS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SCADA COLLECTOR BOX	TRUE

7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	SCADA SENSORS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IR PROTECTOR LEADS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IR SERVICE LEADS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	AD-6 MULTIPLIER	01
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	BARCODE	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	BARCODE	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	BARCODE	FALSE
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7288709	VT0003 1ST & JEFFERSON	100 W Jefferson Louisville KY 40202	12/7/2023 0:00	6/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	Lighting and Receptacles	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE



6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	Lighting and Receptacles	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE

6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6271281	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	6/6/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	Lighting and Receptacles	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	BARCODE	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	BARCODE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	BARCODE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	BARCODE	TRUE
6398260	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	11/19/2019 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	BARCODE	TRUE

6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	BARCODE	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	BARCODE	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	BARCODE	TRUE
6523455	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	4/17/2020 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	BARCODE	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	BARCODE	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	BARCODE	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	BARCODE	FALSE
6618695	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	8/4/2020 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	BARCODE	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	BARCODE	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	BARCODE	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	BARCODE	FALSE
6681288	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/26/2021 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	Anything not listed?	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	BARCODE	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	BARCODE	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	BARCODE	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	BARCODE	FALSE
6784444	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/21/2021 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	Lighting and Receptacles	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	SWITCH POSITION	CLOSED
6886590	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	1/13/2022 0:00	4/5/2024 0:00	Elbow Assembly and Cable	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	Anything not listed?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	SWITCH POSITION	CLOSED
6983325	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	7/6/2022 0:00	4/5/2024 0:00	Elbow Assembly and Cable	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	Anything not listed?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	BARCODE	FALSE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	SWITCH POSITION	CLOSED
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7082028	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	12/14/2022 0:00	4/5/2024 0:00	Elbow Assembly and Cable	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	Anything not listed?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	Lighting and Receptacles	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BARCODE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BARCODE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BARCODE	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	SWITCH POSITION	CLOSED
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7169437	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	5/10/2023 0:00	4/5/2024 0:00	Elbow Assembly and Cable	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	Anything not listed?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	Lighting and Receptacles	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	VAULT LADDER	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	CABLE TAGS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SCADA SENSORS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IR SERVICE LEADS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	AD-6 MULTIPLIER	01
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	BARCODE	FALSE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	SWITCH POSITION	CLOSED
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7257925	VT0004 1ST & MARKET	100 W Market Louisville KY 40202	10/5/2023 0:00	4/5/2024 0:00	Elbow Assembly and Cable	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6280271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	6/14/2019 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	VULT CLEANED DURING THIS INSPECTION?	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	VULT LADDER	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	BARCODE	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	BARCODE	TRUE

6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	BARCODE	TRUE
6404053	VT0005 208 W MARKET	208 W Market Louisville KY 40202	12/6/2019 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	BARCODE	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	BARCODE	TRUE
6536522	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/6/2020 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	BARCODE	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	BARCODE	TRUE
6630340	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/31/2020 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE



6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6696330	VT0005 208 W MARKET	208 W Market Louisville KY 40202	2/12/2021 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	Anything not listed?	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	BARCODE	TRUE
6793675	VT0005 208 W MARKET	208 W Market Louisville KY 40202	8/3/2021 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE

6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6894049	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/26/2022 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	Anything not listed?	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990219	VT0005 208 W MARKET	208 W Market Louisville KY 40202	7/21/2022 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01

7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7089271	VT0005 208 W MARKET	208 W Market Louisville KY 40202	1/6/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7180026	VT0005 208 W MARKET	208 W Market Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	TRUE
7268178	VT0005 208 W MARKET	208 W Market Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6308499	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/10/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE

6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6422193	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	12/27/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6545948	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	7/1/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	VAULT LADDER	TRUE

6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	BARCODE	FALSE
6661129	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	11/23/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6745388	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	4/7/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	Vault cleaned during this inspection?	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	Vault Ladder	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE

6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6827498	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	9/15/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE

6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01

6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916523	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	3/2/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	Anything not listed?	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7016215	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/19/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	Anything not listed?	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7104725	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/16/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	Anything not listed?	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7207071	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	8/7/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	Anything not listed?	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7303916	VT0006 224 S 4TH	224 S 4th ST Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	Anything not listed?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE

6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6300211	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	5/7/2019 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	Anything not listed?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE

6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	BARCODE	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	BARCODE	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	BARCODE	FALSE
6377865	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/3/2019 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	Anything not listed?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE



6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	BARCODE	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	BARCODE	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	BARCODE	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	BARCODE	FALSE
6461528	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	2/7/2020 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	Anything not listed?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE

6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	BARCODE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	BARCODE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	BARCODE	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	BARCODE	FALSE
6574649	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/10/2020 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	Anything not listed?	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6720635	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	1/7/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	Anything not listed?	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE

6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	BARCODE	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6771433	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	7/6/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Anything not listed?	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Vault Cleaned during this inspection?	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Catch pans, debris shields	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Lighting and receptacles	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	blowers and ductwork	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	sidewalk surface area	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	Vault Ladder	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE

6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	BARCODE	FALSE
6877828	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	12/10/2021 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	Anything not listed?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE



6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	BARCODE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	BARCODE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	BARCODE	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	BARCODE	FALSE
6967573	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	4/27/2022 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	Anything not listed?	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE

7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	BARCODE	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	BARCODE	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	BARCODE	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	BARCODE	FALSE
7041995	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	10/6/2022 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	Anything not listed?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	Vault LADDER	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	BARCODE	FALSE
7130327	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	3/23/2023 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	Anything not listed?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	Lighting and Receptacles	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	VAULT LADDER	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	CABLE TAGS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	SCADA SENSORS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IR SERVICE LEADS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	AD-6 MULTIPLIER	01
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	BARCODE	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	BARCODE	FALSE
7231847	VT0008 2ND & WALNUT	501 S 2nd ST Louisville KY 40202	9/6/2023 0:00	3/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301383	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/3/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6417202	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/20/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE

6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543087	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659593	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	11/4/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE

6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733834	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	3/23/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6819748	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/20/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	Anything not listed?	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	TRUE



6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	TRUE
6904615	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BARCODE	FALSE



7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000769	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	8/5/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7096998	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	2/2/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE

7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199154	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	7/10/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01

7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7288710	VT0009 311 W Muhammad Ali	311 W Muhammad Ali Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	Anything not listed?	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE

6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	BARCODE	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	BARCODE	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	BARCODE	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	BARCODE	FALSE
6238378	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/22/2019 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	Anything not listed?	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	BARCODE	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	BARCODE	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	BARCODE	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339595	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/19/2019 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Anything not listed?	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Vault cleaned during this inspection?	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Catch pans, debris shields	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Lighting and receptacles	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Blowers and ductwork	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Number of ducts available	02
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Sidewalk surface area	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Ceiling, walls, and floor	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Ceiling h-beams, supports	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Hatchway frames, slabs, caulk	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Vent grates, frames, caulk	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Entrance grates, hinges, locks	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Vault ladder	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Drywell drainage	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Cable bus and connections	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Protector, service lead connections	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Service duct seals	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Cable tags	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Primary arc proofing tape	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Ground, neutral cables	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Transformer floor beams	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Transformer leaks location	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Transformer gaskets	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Transformer case rust location	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Pressure relief valve	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Transformer primary switch, lock	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Protector housing rust	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	Protector switch, lock	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	SCADA collector box	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	SCADA protector boxes	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	SCADA wiring and hangers	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	SCADA sensors	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IR bus connections	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IR protector leads	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IR service leads	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IR primary elbows, terms	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	AD-6 multiplier	01
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS transformer missing?	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS transformer information incorrect?	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	BARCODE	TRUE



6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6428762	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/16/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	Anything not listed?	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6558884	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	7/6/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	Anything not listed?	TRUE

6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	BARCODE	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	BARCODE	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6663781	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	12/21/2020 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	Anything not listed?	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00

6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	BARCODE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	BARCODE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	BARCODE	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6762211	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	5/20/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	Anything not listed?	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	BARCODE	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	BARCODE	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	BARCODE	FALSE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6852380	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	9/28/2021 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	Anything not listed?	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	CABLE TAGS	TRUE

6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	BARCODE	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	BARCODE	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	BARCODE	FALSE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6924277	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	3/8/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	Anything not listed?	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE



7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	BARCODE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	BARCODE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	BARCODE	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7013979	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/31/2022 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	Anything not listed?	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE



7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	BARCODE	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	BARCODE	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	BARCODE	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109204	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	2/23/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	Anything not listed?	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE

7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	BARCODE	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	BARCODE	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	BARCODE	FALSE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211091	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	8/8/2023 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	Anything not listed?	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	Lighting and Receptacles	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	VAULT LADDER	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	CABLE TAGS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	SCADA SENSORS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IR SERVICE LEADS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	AD-6 MULTIPLIER	01
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	BARCODE	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	BARCODE	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	BARCODE	FALSE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7304607	VT0012 3RD & Muhammad Ali	451 S 3rd ST Louisville KY 40202	1/23/2024 0:00	7/23/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	Anything not listed?	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	BARCODE	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	BARCODE	TRUE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	BARCODE	TRUE

6307591	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/11/2019 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	Anything not listed?	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	Lighting and Receptacles	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	BARCODE	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6423089	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/2/2020 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	Anything not listed?	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE

6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6548930	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/1/2020 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	Anything not listed?	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	BARCODE	TRUE
6661130	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	11/24/2020 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	Anything not listed?	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	BARCODE	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	BARCODE	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	BARCODE	TRUE
6745528	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	4/8/2021 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	Anything not listed?	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	BARCODE	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	BARCODE	TRUE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	BARCODE	FALSE
6828228	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	9/10/2021 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	Anything not listed?	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	Lighting and Receptacles	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE

6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	BARCODE	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	BARCODE	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	BARCODE	FALSE
6913563	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/24/2022 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	Anything not listed?	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	Lighting and Receptacles	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	BARCODE	FALSE

7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	BARCODE	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	BARCODE	FALSE
7004961	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	8/17/2022 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	Anything not listed?	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	Lighting and Receptacles	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7103475	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	2/14/2023 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	Anything not listed?	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	Lighting and Receptacles	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	BARCODE	FALSE
7206849	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	7/26/2023 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	Anything not listed?	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	Lighting and Receptacles	TRUE



7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	VAULT LADDER	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	DRYWELL DRAINAGE	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SERVICE DUCT SEALS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	CABLE TAGS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	TRANSFORMER GASKETS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	SCADA SENSORS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IR BUS CONNECTIONS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IR PROTECTOR LEADS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IR SERVICE LEADS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	AD-6 MULTIPLIER	01
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	BARCODE	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS PROTECTOR MISSING	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	BARCODE	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	BARCODE	TRUE
7297936	VT0013 3RD & YORK	806 S 3rd ST Louisville KY 40202	1/10/2024 0:00	7/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE



6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301384	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/3/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	FALSE

6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6417203	VT0014 424 W MARKET	424 W Market Louisville KY 40202	12/23/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE

6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	BARCODE	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6544294	VT0014 424 W MARKET	424 W Market Louisville KY 40202	6/30/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6659669	VT0014 424 W MARKET	424 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE

6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	BARCODE	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742871	VT0014 424 W MARKET	424 W Market Louisville KY 40202	3/30/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE



6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6823804	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE

6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909304	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	Anything not listed?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE

7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000953	VT0014 424 W MARKET	424 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	Anything not listed?	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	Lighting and Receptades	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE

7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099561	VT0014 424 W MARKET	424 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	Anything not listed?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE

7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7202812	VT0014 424 W MARKET	424 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	Anything not listed?	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE
7293369	VT0014 424 W MARKET	424 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	BARCODE	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	BARCODE	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	BARCODE	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	BARCODE	FALSE
6292535	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	6/28/2019 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	Lighting and Receptacles	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	BARCODE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	BARCODE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	BARCODE	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	BARCODE	FALSE
6414501	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	12/13/2019 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6540835	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	5/20/2020 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	BARCODE	FALSE
6637532	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	9/11/2020 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6701285	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	3/3/2021 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	Anything not listed?	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE

6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	BARCODE	FALSE
6806534	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/17/2021 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	Anything not listed?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE



6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
6902123	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/14/2022 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	Anything not listed?	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	BARCODE	FALSE
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000245	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	8/3/2022 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	Anything not listed?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE

7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7095596	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	2/1/2023 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	Anything not listed?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE

7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7198979	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	7/6/2023 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	Anything not listed?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	Lighting and Receptacles	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	VAULT LADDER	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	DRYWELL DRAINAGE	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SERVICE DUCT SEALS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	CABLE TAGS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	TRANSFORMER GASKETS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SCADA COLLECTOR BOX	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	SCADA SENSORS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IR BUS CONNECTIONS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IR PROTECTOR LEADS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IR SERVICE LEADS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	AD-6 MULTIPLIER	01
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS PROTECTOR MISSING	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	BARCODE	FALSE
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7287232	VT0015 4TH & JEFFERSON	240 S 4th ST Louisville KY 40202	11/27/2023 0:00	5/27/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE

6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243279	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/13/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6337337	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE

6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6434035	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE

6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01

6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6563921	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	BARCODE	FALSE
6665601	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	12/29/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE

6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6766660	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	5/28/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6856484	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	10/6/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6928702	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	3/16/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	Anything not listed?	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	BARCODE	FALSE

7018525	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	9/2/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	Anything not listed?	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7109606	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	2/28/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Anything not listed?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7215152	VT0016 4TH & YORK	752 S 4th ST Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE

6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	BARCODE	FALSE
6301385	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/2/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	BARCODE	TRUE
6416215	VT0017 510 W MARKET	510 W Market Louisville KY 40202	12/19/2019 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE



6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6543025	VT0017 510 W MARKET	510 W Market Louisville KY 40202	5/28/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	INSPECTION CALLED OFF	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6642354	VT0017 510 W MARKET	510 W Market Louisville KY 40202	10/28/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE

6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	BARCODE	TRUE
6739236	VT0017 510 W MARKET	510 W Market Louisville KY 40202	11/17/2020 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6742872	VT0017 510 W MARKET	510 W Market Louisville KY 40202	3/26/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	Anything not listed?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE

6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	BARCODE	TRUE
6822386	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/31/2021 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	Anything not listed?	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	BARCODE	TRUE
6909305	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/17/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	Anything not listed?	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	BARCODE	FALSE
7000954	VT0017 510 W MARKET	510 W Market Louisville KY 40202	8/10/2022 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	Anything not listed?	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7099562	VT0017 510 W MARKET	510 W Market Louisville KY 40202	2/7/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	Anything not listed?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VULT CLEANED DURING THIS INSPECTION?	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VULT LADDER	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE

7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	BARCODE	TRUE
7202813	VT0017 510 W MARKET	510 W Market Louisville KY 40202	7/18/2023 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	Anything not listed?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	Lighting and Receptacles	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VAULT LADDER	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	CABLE TAGS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	SCADA SENSORS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR SERVICE LEADS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	AD-6 MULTIPLIER	01
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE

7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	BARCODE	TRUE
7293370	VT0017 510 W MARKET	510 W Market Louisville KY 40202	1/2/2024 0:00	7/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6263458	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/15/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6384818	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/27/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	Anything not listed?	FALSE

6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6480298	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	2/21/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE



6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6583121	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/16/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	02

6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6670852	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	1/13/2021 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6775853	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	7/8/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6879350	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	12/21/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6971973	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	5/10/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	Anything not listed?	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	CABLE TAGS	TRUE

7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7050422	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	10/19/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	Anything not listed?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE



7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7138006	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	4/10/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	Anything not listed?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7241169	VT0018 518 S 4TH ST	518 S 4th ST Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE

6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	BARCODE	FALSE
6297548	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/2/2019 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	BARCODE	TRUE
6416216	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	12/19/2019 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Vault cleaned during this inspection?	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Catch pans, debris shields	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Lighting and receptacles	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Blowers and ductwork	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Number of ducts available	00
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Sidewalk surface area	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Ceiling, walls, and floor	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Ceiling I-beams, supports	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Hatchway frames, slabs, caulk	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Vent grates, frames, caulk	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Entrance grates, hinges, locks	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Vault ladder	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Drywell drainage	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Cable bus and connections	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Protector, service lead connections	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	Service duct seals	TRUE

6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6543026	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	5/28/2020 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	INSPECTION CALLED OFF	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE



6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	BARCODE	TRUE
6642355	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	10/15/2020 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00



6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6818489	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	3/30/2021 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	Anything not listed?	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	BARCODE	TRUE
6823805	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	9/1/2021 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	Anything not listed?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	TRUE

6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	BARCODE	TRUE
6909364	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/18/2022 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	Anything not listed?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE

7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	BARCODE	FALSE
7001666	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	8/12/2022 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	Anything not listed?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE



7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7101207	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	2/9/2023 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	Anything not listed?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE



7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	BARCODE	TRUE
7203079	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	7/24/2023 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	Anything not listed?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	Lighting and Receptacles	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	VAULT LADDER	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	CABLE TAGS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	SCADA SENSORS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IR BUS CONNECTIONS	TRUE

7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IR SERVICE LEADS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	AD-6 MULTIPLIER	01
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BARCODE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BARCODE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BARCODE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BARCODE	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	BARCODE	TRUE
7296459	VT0019 5TH & JEFFERSON	441 W Jefferson Louisville KY 40202	1/9/2024 0:00	7/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE

6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6277008	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	6/12/2019 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE

6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	BARCODE	FALSE
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6402052	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	11/26/2019 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6528254	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	4/28/2020 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE



6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	BARCODE	FALSE
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6624618	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	8/21/2020 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE



6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6692127	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/29/2021 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE

6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	BARCODE	FALSE
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6785770	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/28/2021 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE

6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6890651	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/25/2022 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	Anything not listed?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE

6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	BARCODE	FALSE
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
6990155	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	7/20/2022 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE

7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7088573	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	1/4/2023 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01



7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7178956	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	5/31/2023 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	Anything not listed?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	Lighting and Receptacles	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VAULT LADDER	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	CABLE TAGS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SCADA SENSORS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR SERVICE LEADS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	AD-6 MULTIPLIER	01
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE



7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	BARCODE	FALSE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	SWITCH POSITION	CLOSED
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7267422	VT0020 KELLER BUILDING	433 W Main ST Louisville KY 40202	10/16/2023 0:00	4/16/2024 0:00	Elbow Assembly and Cable	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE

6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6288729	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/25/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	BARCODE	FALSE
6411328	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	12/12/2019 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE

6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	LOW
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	BARCODE	FALSE
6539939	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	5/14/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	BARCODE	FALSE
6635145	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	9/8/2020 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	Anything not listed?	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	BARCODE	FALSE
6700435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/26/2021 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BARCODE	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BARCODE	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	BARCODE	FALSE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800962	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	8/12/2021 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	Anything not listed?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899836	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	2/10/2022 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	Anything not listed?	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6997435	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	7/28/2022 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	Anything not listed?	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7092787	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	1/24/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	Anything not listed?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE



7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190896	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	6/27/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	Anything not listed?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	Lighting and Receptacles	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VAULT LADDER	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	DRYWELL DRAINAGE	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SERVICE DUCT SEALS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	CABLE TAGS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	TRANSFORMER GASKETS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SCADA COLLECTOR BOX	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SCADA WIRING AND HANGERS	TRUE

7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	SCADA SENSORS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IR BUS CONNECTIONS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IR PROTECTOR LEADS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IR SERVICE LEADS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	AD-6 MULTIPLIER	01
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS PROTECTOR MISSING	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281049	VT0021 5TH AVE OFFICE BLDG	444 S 5th ST Louisville KY 40202	11/15/2023 0:00	5/15/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	Anything not listed?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6288730	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/25/2019 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	Anything not listed?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	VAULT LADDER	TRUE

6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	BARCODE	TRUE
6411329	VT0022 609 W MAIN	609 W Main Louisville KY 40202	12/12/2019 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	Anything not listed?	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE

6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6539940	VT0022 609 W MAIN	609 W Main Louisville KY 40202	5/14/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	Anything not listed?	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	BARCODE	TRUE
6635146	VT0022 609 W MAIN	609 W Main Louisville KY 40202	9/9/2020 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	Anything not listed?	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6700531	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/26/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	Anything not listed?	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE

6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	BARCODE	TRUE
6800963	VT0022 609 W MAIN	609 W Main Louisville KY 40202	8/12/2021 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	Anything not listed?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE

6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	BARCODE	TRUE
6899837	VT0022 609 W MAIN	609 W Main Louisville KY 40202	2/10/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	Anything not listed?	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	BARCODE	FALSE
6997436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	7/28/2022 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	Anything not listed?	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE



7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	BARCODE	FALSE



7092788	VT0022 609 W MAIN	609 W Main Louisville KY 40202	1/24/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	Anything not listed?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7190897	VT0022 609 W MAIN	609 W Main Louisville KY 40202	6/28/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	Anything not listed?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	Lighting and Receptacles	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VAULT LADDER	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	DRYWELL DRAINAGE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SERVICE DUCT SEALS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	CABLE TAGS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	TRANSFORMER GASKETS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SCADA COLLECTOR BOX	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	SCADA SENSORS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IR BUS CONNECTIONS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IR PROTECTOR LEADS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IR SERVICE LEADS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	AD-6 MULTIPLIER	01
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS PROTECTOR MISSING	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	BARCODE	TRUE
7281436	VT0022 609 W MAIN	609 W Main Louisville KY 40202	11/16/2023 0:00	5/16/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6253464	VT0023 620 W MAIN	620 W Main Louisville KY 40202	5/10/2019 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01



6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6382105	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/20/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6474672	VT0023 620 W MAIN	620 W Main Louisville KY 40202	2/13/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE





6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE

6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577544	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/13/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6668372	VT0023 620 W MAIN	620 W Main Louisville KY 40202	1/8/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE



6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6772306	VT0023 620 W MAIN	620 W Main Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE





6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6876068	VT0023 620 W MAIN	620 W Main Louisville KY 40202	12/7/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6965797	VT0023 620 W MAIN	620 W Main Louisville KY 40202	4/20/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE



7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7037933	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/30/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL



7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7125800	VT0023 620 W MAIN	620 W Main Louisville KY 40202	3/17/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE



7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE

7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7228158	VT0023 620 W MAIN	620 W Main Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	BARCODE	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	BARCODE	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	BARCODE	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	BARCODE	FALSE
6278985	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2019 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	VULT CLEANED DURING THIS INSPECTION?	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	VULT LADDER	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	BARCODE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	BARCODE	TRUE

6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	BARCODE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	BARCODE	TRUE
6404054	VT0024 633 W MAIN	633 W Main Louisville KY 40202	12/5/2019 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	BARCODE	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	BARCODE	TRUE

6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6535807	VT0024 633 W MAIN	633 W Main Louisville KY 40202	5/6/2020 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	BARCODE	TRUE
6630341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	9/1/2020 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6696849	VT0024 633 W MAIN	633 W Main Louisville KY 40202	2/23/2021 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	Anything not listed?	FALSE



6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	BARCODE	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	BARCODE	TRUE
6799722	VT0024 633 W MAIN	633 W Main Louisville KY 40202	8/4/2021 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	BARCODE	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6894979	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/27/2022 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	Anything not listed?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	02

6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	BARCODE	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	BARCODE	TRUE
6990341	VT0024 633 W MAIN	633 W Main Louisville KY 40202	7/26/2022 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	Anything not listed?	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE

7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7091460	VT0024 633 W MAIN	633 W Main Louisville KY 40202	1/13/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	Anything not listed?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	BARCODE	FALSE
7183598	VT0024 633 W MAIN	633 W Main Louisville KY 40202	6/14/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	Anything not listed?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	Lighting and Receptacles	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	VAULT LADDER	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	DRYWELL DRAINAGE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SERVICE DUCT SEALS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	CABLE TAGS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	TRANSFORMER GASKETS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SCADA COLLECTOR BOX	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	SCADA SENSORS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IR BUS CONNECTIONS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IR PROTECTOR LEADS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IR SERVICE LEADS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	AD-6 MULTIPLIER	01
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	BARCODE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS PROTECTOR MISSING	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	BARCODE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	BARCODE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	BARCODE	TRUE
7274544	VT0024 633 W MAIN	633 W Main Louisville KY 40202	10/31/2023 0:00	4/30/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	CABLE TAGS	TRUE



6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6244238	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/21/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	BARCODE	TRUE
6343220	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	Anything not listed?	TRUE

6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6437385	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BARCODE	TRUE

6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6567800	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6665602	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	12/30/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6766771	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	6/17/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6866766	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	11/11/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	Anything not listed?	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6950711	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/25/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	Anything not listed?	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7024239	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	9/14/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	Anything not listed?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7116056	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	3/8/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	Anything not listed?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE



7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7222236	VT0025 640 S 4TH ST	640 S 4th ST Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	BARCODE	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	BARCODE	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	BARCODE	FALSE
6280525	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/14/2019 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404055	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	Anything not listed?	TRUE
6404055	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	BARCODE	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	BARCODE	TRUE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	BARCODE	FALSE
6404055	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	12/4/2019 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE

6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	BARCODE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	BARCODE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	BARCODE	TRUE
6534903	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	5/5/2020 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	BARCODE	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	BARCODE	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	BARCODE	TRUE
6629541	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/28/2020 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	Anything not listed?	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	BARCODE	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	BARCODE	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	BARCODE	TRUE
6696331	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	2/23/2021 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6799723	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE

6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	BARCODE	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	BARCODE	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	BARCODE	TRUE
6799723	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6896719	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	Anything not listed?	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6991074	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE

6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	BARCODE	TRUE
6991074	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	Anything not listed?	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	BARCODE	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	BARCODE	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	BARCODE	TRUE
7092126	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	1/18/2023 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186471	VT0026 642 S STH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	Anything not listed?	FALSE

7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	BARCODE	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	BARCODE	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	BARCODE	FALSE
7186471	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	6/21/2023 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	Anything not listed?	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	Lighting and Receptacles	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SIDEWALK SURFACE AREA	TRUE

7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	VAULT LADDER	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	DRYWELL DRAINAGE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SERVICE DUCT SEALS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	CABLE TAGS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	TRANSFORMER GASKETS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SCADA COLLECTOR BOX	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	SCADA SENSORS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IR BUS CONNECTIONS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IR PROTECTOR LEADS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IR SERVICE LEADS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	AD-6 MULTIPLIER	01
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	BARCODE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS PROTECTOR MISSING	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	BARCODE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	BARCODE	TRUE
7278084	VT0026 642 S 5TH	642 S 5th ST Louisville KY 40202	11/8/2023 0:00	5/8/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE

6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243202	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/1/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6329178	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/23/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE



6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6430691	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	1/17/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	FALSE

6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6559856	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE

6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	FALSE
6664662	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE

6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766772	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE

6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861994	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936668	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/18/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	Anything not listed?	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE

7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7020003	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	9/7/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	Anything not listed?	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112383	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	Anything not listed?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7218470	VT0027 6TH & MAIN	600 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	Anything not listed?	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	BARCODE	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	BARCODE	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	BARCODE	FALSE
6297474	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/1/2019 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	Anything not listed?	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE

6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	BARCODE	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	BARCODE	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	BARCODE	TRUE
6415279	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/18/2019 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	Anything not listed?	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE



6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	BARCODE	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	BARCODE	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	BARCODE	TRUE
6542925	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	5/26/2020 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	Anything not listed?	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01

6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	BARCODE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	BARCODE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	BARCODE	TRUE
6640915	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	9/16/2020 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	Anything not listed?	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE

6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6704239	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	3/10/2021 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	Anything not listed?	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	BARCODE	FALSE
6810541	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/19/2021 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	Anything not listed?	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SEWAGE SURFACE AREA	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
6903868	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/15/2022 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	Anything not listed?	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SEWAGE SURFACE AREA	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	BARCODE	FALSE
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000692	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	8/4/2022 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	Anything not listed?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7096999	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	2/2/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	Anything not listed?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	CABLE TAGS	TRUE



7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7199155	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	7/11/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	Anything not listed?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	Lighting and Receptacles	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	VAULT LADDER	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	CABLE TAGS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	SCADA SENSORS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IR SERVICE LEADS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	AD-6 MULTIPLIER	01
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	BARCODE	FALSE
7289496	VT0028 6TH & MARKET	600 W Market Louisville KY 40202	12/6/2023 0:00	6/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	BARCODE	FALSE
6243280	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/14/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE

6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	BARCODE	TRUE
6338192	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/26/2019 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6434036	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/23/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	TRUE



6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	BARCODE	TRUE
6563922	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	7/8/2020 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6665603	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	1/5/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE



6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6771258	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	6/16/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	Anything not listed?	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	BARCODE	TRUE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	BARCODE	FALSE
6865983	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	11/10/2021 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	Anything not listed?	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	BARCODE	FALSE
6950430	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/24/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	Anything not listed?	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE

7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	BARCODE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	BARCODE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	BARCODE	TRUE
7023393	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	9/13/2022 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	Anything not listed?	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	VAULT LADDER	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE

7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	BARCODE	FALSE
7115972	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	3/7/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Anything not listed?	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Lighting and Receptacles	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	Vault LADDER	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	DRYWELL DRAINAGE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SERVICE DUCT SEALS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	CABLE TAGS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER GASKETS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA COLLECTOR BOX	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	SCADA SENSORS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR BUS CONNECTIONS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PROTECTOR LEADS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR SERVICE LEADS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	AD-6 MULTIPLIER	01



7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR MISSING	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	BARCODE	TRUE
7221461	VT0029 6TH & Muhammad Ali	607 W Muhammad Ali Louisville KY 40202	8/24/2023 0:00	2/24/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6293839	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	6/28/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6414502	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	12/17/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	Anything not listed?	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE

6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6542361	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	5/22/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	Anything not listed?	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE

6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6639062	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	9/15/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	Anything not listed?	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	Lighting and Receptacles	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704134	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	3/4/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	Anything not listed?	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	09
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6807422	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/17/2021 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE



6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6902124	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/14/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	Anything not listed?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE

7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
7000246	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	8/3/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	Anything not listed?	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE

7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7095597	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	2/1/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	Anything not listed?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE

7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7198980	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Anything not listed?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7286306	VT0030 717 W MAIN ST	717 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	Anything not listed?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	BARCODE	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	BARCODE	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	BARCODE	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	BARCODE	FALSE
6248398	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/16/2019 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	INSPECTION CALLED OFF	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	Anything not listed?	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	04
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	BARCODE	TRUE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6360461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/15/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	Anything not listed?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE

6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	BARCODE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	BARCODE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	BARCODE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	BARCODE	TRUE
6444636	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	8/20/2019 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	Anything not listed?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6572043	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	2/6/2020 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	Anything not listed?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE

6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	BARCODE	TRUE
6573924	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/10/2020 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	Anything not listed?	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	VAULT LADDER	TRUE

6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6667461	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	1/8/2021 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	Anything not listed?	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE



6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6772307	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	7/6/2021 0:00	3/11/2024 0:00	BARCODE	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	Anything not listed?	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	BARCODE	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	BARCODE	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	BARCODE	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	BARCODE	FALSE
6877829	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	12/20/2021 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	Anything not listed?	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE

6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
6971948	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	5/3/2022 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	Anything not listed?	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE

7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	BARCODE	FALSE
7046051	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	10/13/2022 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7134596	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/6/2023 0:00	3/11/2024 0:00	INSPECTION CALLED OFF	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	Anything not listed?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE

7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	BARCODE	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	BARCODE	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	BARCODE	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	BARCODE	FALSE
7236357	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	4/7/2023 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	Anything not listed?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	Lighting and Receptacles	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	VAULT LADDER	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	CABLE TAGS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE

7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	SCADA SENSORS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IR SERVICE LEADS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	AD-6 MULTIPLIER	01
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	BARCODE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS PROTECTOR MISSING	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	BARCODE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	BARCODE	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	BARCODE	FALSE
7239873	VT0031 726 W MAIN ST	726 W Main Louisville KY 40202	9/11/2023 0:00	3/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	Anything not listed?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE



6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	BARCODE	FALSE
6277009	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2019 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	Anything not listed?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	Lighting and Receptacles	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	Vault LADDER	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	BARCODE	TRUE
6402936	VT0032 741 W MAIN	741 W Main Louisville KY 40202	11/27/2019 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	Lighting and Receptacles	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE

6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6528304	VT0032 741 W MAIN	741 W Main Louisville KY 40202	4/29/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	INSPECTION CALLED OFF	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE

6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6625739	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/26/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	BARCODE	TRUE
6690802	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/27/2020 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6791527	VT0032 741 W MAIN	741 W Main Louisville KY 40202	2/11/2021 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	BARCODE	TRUE
6793313	VT0032 741 W MAIN	741 W Main Louisville KY 40202	8/3/2021 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	BARCODE	TRUE
6894050	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/26/2022 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	Anything not listed?	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE

6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990220	VT0032 741 W MAIN	741 W Main Louisville KY 40202	7/22/2022 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	Anything not listed?	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01

7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7089947	VT0032 741 W MAIN	741 W Main Louisville KY 40202	1/11/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	Anything not listed?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	Lighting and Receptacles	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE

7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7182720	VT0032 741 W MAIN	741 W Main Louisville KY 40202	6/13/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	Anything not listed?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	Lighting and Receptacles	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	VAULT LADDER	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	CABLE TAGS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE

7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	SCADA SENSORS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IR SERVICE LEADS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	AD-6 MULTIPLIER	01
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	BARCODE	FALSE
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7273981	VT0032 741 W MAIN	741 W Main Louisville KY 40202	10/23/2023 0:00	4/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	Vault LADDER	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	LOW
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	BARCODE	FALSE
6243203	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/7/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	CABLE TAGS	TRUE

6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	BARCODE	TRUE
6333092	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/24/2019 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6431786	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	1/22/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6562592	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	7/7/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE

6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	BARCODE	TRUE
6664663	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	12/30/2020 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	Anything not listed?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6766773	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	6/9/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE



6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	BARCODE	FALSE
6861995	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	10/19/2021 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	Anything not listed?	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE

6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
6936669	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/22/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	Anything not listed?	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	BARCODE	FALSE
7021708	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	9/8/2022 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	Anything not listed?	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	BARCODE	FALSE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7112665	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	3/2/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	Anything not listed?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	Lighting and Receptacles	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VAULT LADDER	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	CABLE TAGS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	SCADA SENSORS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR SERVICE LEADS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	AD-6 MULTIPLIER	01
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	FALSE

7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	BARCODE	TRUE
7218471	VT0033 7TH & MAIN	701 W Main Louisville KY 40202	8/22/2023 0:00	2/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE

6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6270321	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	6/4/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6396418	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	11/15/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE

6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6520463	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	4/15/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6617066	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	8/3/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6680420	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/22/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01

6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE

6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6781249	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/21/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6886591	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	1/13/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983326	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	7/6/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	Anything not listed?	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE

7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7082029	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	12/14/2022 0:00	4/2/2024 0:00	Anything not listed?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE

7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7169438	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	5/10/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	Anything not listed?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CABLE TAGS	TRUE

7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7257926	VT0034 7TH & MARKET	704 W Market Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE



6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	SWITCH POSITION	OPEN
6235172	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/21/2019 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	BARCODE	FALSE
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6320518	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/17/2019 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6426738	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/10/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE

6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6555164	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	7/2/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	BARCODE	FALSE
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6661984	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	12/3/2020 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	CABLE TAGS	TRUE



6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	BARCODE	FALSE

6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6751987	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	4/14/2021 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	Anything not listed?	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	BARCODE	FALSE
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6831097	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	9/15/2021 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	Anything not listed?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE

6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
6916524	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	3/2/2022 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	Anything not listed?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED

7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	BARCODE	FALSE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7010826	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/23/2022 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	Anything not listed?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE



7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7106237	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	2/16/2023 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	Anything not listed?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE

7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	BARCODE	FALSE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7207072	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	8/10/2023 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	Anything not listed?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	Lighting and Receptacles	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	NUMBER OF DUCTS AVAILABLE	01

7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VAULT LADDER	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	DRYWELL DRAINAGE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SERVICE DUCT SEALS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	CABLE TAGS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	TRANSFORMER GASKETS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SCADA COLLECTOR BOX	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SCADA SENSORS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IR BUS CONNECTIONS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IR PROTECTOR LEADS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IR SERVICE LEADS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	AD-6 MULTIPLIER	01
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS PROTECTOR MISSING	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	BARCODE	FALSE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	SWITCH POSITION	CLOSED
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7306095	VT0035 800 APARTMENTS	800 S 4th ST Louisville KY 40202	1/31/2024 0:00	7/31/2024 0:00	Elbow Assembly and Cable	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		Anything not listed?	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		VAULT CLEANED DURING THIS INSPECTION?	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		CATCH PANS, DEBRIS SHIELDS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		HANGERS, HARDWARE - CEILING, WALLS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		Lighting and Receptacles	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		BLOWERS AND DUCTWORK	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		NUMBER OF DUCTS AVAILABLE	20
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SIDEWALK SURFACE AREA	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		CEILING, WALLS, AND FLOOR	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		CEILING I-BEAMS, SUPPORTS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		HATCHWAY FRAMES, SLABS, CAULK	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		VENT GRATES, FRAMES, CAULK	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		ENTRANCE GRATES, HINGES, LOCKS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		VAULT LADDER	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		DRYWELL DRAINAGE	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		CABLE BUS AND CONNECTIONS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SERVICE DUCT SEALS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		CABLE TAGS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PRIMARY ARC PROOFING TAPE	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		GROUND, NEUTRAL CABLES	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		TRANSFORMER FLOOR BEAMS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		TRANSFORMER LEAKS LOCATION	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		TRANSFORMER GASKETS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		TRANSFORMER CASE RUST LOCATION	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PRESSURE RELIEF VALVE	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PROTECTOR HOUSING RUST	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PROTECTOR SWITCH, LOCK	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SCADA COLLECTOR BOX	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SCADA PROTECTOR BOXES	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SCADA WIRING AND HANGERS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		SCADA SENSORS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IR BUS CONNECTIONS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IR PROTECTOR LEADS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IR SERVICE LEADS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IR PRIMARY ELBOWS, TERMS	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		AD-6 MULTIPLIER	01
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IS TRANSFORMER MISSING?	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		PRIMARY SWITCH OIL LEVEL	NORMAL
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		BARCODE	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00		MAIN TANK OIL LEVEL	NORMAL

6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	IS PROTECTOR MISSING	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	BARCODE	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	BARCODE	FALSE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248399	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	4/12/2019 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	Anything not listed?	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	Lighting and Receptacles	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	BLOWERS AND DUCTWORK	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	NUMBER OF DUCTS AVAILABLE	01
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SIDEWALK SURFACE AREA	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	CEILING, WALLS, AND FLOOR	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	VAULT LADDER	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	DRYWELL DRAINAGE	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	CABLE BUS AND CONNECTIONS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SERVICE DUCT SEALS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	CABLE TAGS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	GROUND, NEUTRAL CABLES	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	TRANSFORMER GASKETS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PRESSURE RELIEF VALVE	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PROTECTOR HOUSING RUST	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PROTECTOR SWITCH, LOCK	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SCADA COLLECTOR BOX	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SCADA PROTECTOR BOXES	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SCADA WIRING AND HANGERS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	SCADA SENSORS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IR BUS CONNECTIONS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IR PROTECTOR LEADS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IR SERVICE LEADS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	AD-6 MULTIPLIER	01
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS TRANSFORMER MISSING?	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	BARCODE	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	MAIN TANK OIL LEVEL	NORMAL
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS PROTECTOR MISSING	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	BARCODE	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	BARCODE	FALSE

6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6359258	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	8/7/2019 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	Anything not listed?	FALSE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	Lighting and Receptacles	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	BLOWERS AND DUCTWORK	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	NUMBER OF DUCTS AVAILABLE	02
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SIDEWALK SURFACE AREA	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	CEILING, WALLS, AND FLOOR	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	VAULT LADDER	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	DRYWELL DRAINAGE	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	CABLE BUS AND CONNECTIONS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SERVICE DUCT SEALS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	CABLE TAGS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	GROUND, NEUTRAL CABLES	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	TRANSFORMER GASKETS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	PRESSURE RELIEF VALVE	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	PROTECTOR HOUSING RUST	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	PROTECTOR SWITCH, LOCK	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SCADA COLLECTOR BOX	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SCADA PROTECTOR BOXES	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SCADA WIRING AND HANGERS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	SCADA SENSORS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IR BUS CONNECTIONS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IR PROTECTOR LEADS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IR SERVICE LEADS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	AD-6 MULTIPLIER	01
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IS TRANSFORMER MISSING?	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IS PROTECTOR MISSING	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6442255	VT0036 801 W JEFFERSON	801 W Jefferson Louisville KY 40202	2/5/2020 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 Anything not listed?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 CATCH PANS, DEBRIS SHIELDS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 Lighting and Receptacles	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 NUMBER OF DUCTS AVAILABLE	00
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 SIDEWALK SURFACE AREA	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 CEILING, WALLS, AND FLOOR	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 CEILING I-BEAMS, SUPPORTS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 HATCHWAY FRAMES, SLABS, CAULK	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 VENT GRATES, FRAMES, CAULK	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00 ENTRANCE GRATES, HINGES, LOCKS	TRUE



6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	BARCODE	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	BARCODE	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	BARCODE	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	BARCODE	FALSE
6275437	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/11/2019 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	Anything not listed?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	BARCODE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	BARCODE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	BARCODE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	BARCODE	TRUE
6401089	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/22/2019 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	CABLE TAGS	TRUE

6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6587378	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	4/24/2020 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	BARCODE	TRUE
6622774	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	8/20/2020 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE

6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6691376	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/29/2021 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	BARCODE	TRUE
6785771	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/28/2021 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6890652	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/25/2022 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	Anything not listed?	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	BARCODE	FALSE
6990156	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	7/21/2022 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	Anything not listed?	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	BARCODE	FALSE

7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7089948	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	1/11/2023 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	Anything not listed?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7182721	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	6/14/2023 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	Anything not listed?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	Lighting and Receptacles	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	VAULT LADDER	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	DRYWELL DRAINAGE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SERVICE DUCT SEALS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	CABLE TAGS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	TRANSFORMER GASKETS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SCADA COLLECTOR BOX	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	SCADA SENSORS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IR BUS CONNECTIONS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IR PROTECTOR LEADS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IR SERVICE LEADS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	AD-6 MULTIPLIER	01
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS PROTECTOR MISSING	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	BARCODE	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	BARCODE	FALSE
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7274545	VT0037 8TH & MARKET	740 W Market Louisville KY 40202	11/1/2023 0:00	5/1/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	BARCODE	FALSE
6228724	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/13/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL



6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6315975	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/12/2019 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE

6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6424029	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	1/8/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE

6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6552999	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	7/2/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	Lighting and Receptacles	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	03

6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	BARCODE	TRUE
6661985	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	12/4/2020 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE



6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752923	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	4/22/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	Anything not listed?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01



6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	BARCODE	FALSE
6836049	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	9/23/2021 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	Anything not listed?	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
6920172	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	3/4/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	Anything not listed?	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	BARCODE	FALSE

71012280	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/25/2022 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	Anything not listed?	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	Anything not listed?	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH



7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7107799	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/23/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	Anything not listed?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE



7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	BARCODE	TRUE
7211092	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	8/14/2023 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	Anything not listed?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	Lighting and Receptacles	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VAULT LADDER	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	CABLE TAGS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	SCADA SENSORS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR SERVICE LEADS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	AD-6 MULTIPLIER	01
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7311638	VT0038 ACTORS THEATRE	310 W Main Louisville KY 40202	2/5/2024 0:00	8/5/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6339576	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/26/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6346998	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/1/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE







6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6438340	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/29/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6567847	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE

6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665604	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE

6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771259	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	6/17/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6866767	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	11/11/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE



6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6950712	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	15

7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7029191	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	9/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7116332	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	3/8/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7222237	VT0039 AHRENS SCHOOL	546 S 1st ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE



6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	BARCODE	FALSE
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6287710	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	6/21/2019 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE

6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	BARCODE	TRUE
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6409079	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	12/10/2019 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	Anything not listed?	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE

6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6538146	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	5/8/2020 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	BARCODE	FALSE
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6631819	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	9/2/2020 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE

6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE



6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6696922	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	2/24/2021 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE

6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	BARCODE	FALSE
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6799827	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	8/5/2021 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6895910	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/27/2022 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE

6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	Anything not listed?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	FALSE

6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	BARCODE	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6990342	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/26/2022 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	Anything not listed?	FALSE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7091461	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	1/17/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE





7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
7186393	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	7/5/2023 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Anything not listed?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Lighting and Receptacles	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VAULT LADDER	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	CABLE TAGS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SCADA SENSORS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR SERVICE LEADS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	AD-6 MULTIPLIER	01
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE

7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	BARCODE	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	SWITCH POSITION	CLOSED
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7286307	VT0040 AMERICAN LIFE	403 W Main Louisville KY 40202	11/20/2023 0:00	5/20/2024 0:00	Elbow Assembly and Cable	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VAULT LADDER	TRUE

6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	BARCODE	FALSE
6280526	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/14/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE

6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	BARCODE	TRUE
6404056	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	12/3/2019 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6533967	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	5/1/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	BARCODE	TRUE
6628072	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/27/2020 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE

6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6695646	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	2/11/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Vault cleaned during this inspection?	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Catch pans, debris shields	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Lighting and receptacles	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Blowers and ductwork	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Number of ducts available	00
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Sidewalk surface area	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Ceiling, walls, and floor	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Ceiling I-beams, supports	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Hatchway frames, slabs, caulk	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Vent grates, frames, caulk	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Entrance grates, hinges, locks	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Vault ladder	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Drywell drainage	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Cable bus and connections	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Protector, service lead connections	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Service duct seals	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Cable tags	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Primary arc proofing tape	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Ground, neutral cables	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Transformer floor beams	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Transformer leaks location	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Transformer gaskets	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Transformer case rust location	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	Pressure relief valve	TRUE

6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	BARCODE	TRUE
6793314	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	8/3/2021 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	Anything not listed?	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6894051	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/27/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	Anything not listed?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	Vault cleaned during this inspection?	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	BARCODE	TRUE



6990343	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	7/26/2022 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	Anything not listed?	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7091463	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	1/17/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	Anything not listed?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	BARCODE	FALSE
7186394	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	6/20/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	Anything not listed?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	Lighting and Receptacles	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VAULT LADDER	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	CABLE TAGS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	SCADA SENSORS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IR SERVICE LEADS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	AD-6 MULTIPLIER	01

7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	BARCODE	TRUE
7277380	VT0041 ARMORY	435 S 6th ST Louisville KY 40202	11/9/2023 0:00	5/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	Anything not listed?	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6269237	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/31/2019 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Vault Cleaned During This Inspection?	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Catch Pans, Debris Shields	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Hangers, Hardware - Ceiling, Walls	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Blowers and Ductwork	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Number of Ducts Available	00
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Sidewalk Surface Area	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Ceiling, Walls, and Floor	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Ceiling I-Beams, Supports	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Hatchway Frames, Slabs, Caulk	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Vent Grates, Frames, Caulk	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Entrance Grates, Hinges, Locks	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Vault Ladder	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Drywell Drainage	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Cable Bus and Connections	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Protector, Service Lead Connections	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Service Duct Seals	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Cable Tags	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Primary Arc Proofing Tape	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Ground, Neutral Cables	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Transformer Floor Beams	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Transformer Leaks Location	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Transformer Gaskets	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Transformer Case Rust Location	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Pressure Relief Valve	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Transformer Primary Switch, Lock	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Protector Housing Rust	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Protector Switch, Lock	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SCADA Collector Box	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SCADA Protector Boxes	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SCADA Wiring and Hangers	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SCADA Sensors	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IR Bus Connections	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IR Protector Leads	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IR Service Leads	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IR Primary Elbows, Terms	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	AD-6 Multiplier	01
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS Transformer Missing?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS Transformer Information Incorrect?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Primary Switch Oil Level	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Barcode	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Main Tank Oil Level	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS Transformer Missing?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS Transformer Information Incorrect?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Primary Switch Oil Level	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Barcode	TRUE



6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	BARCODE	FALSE
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6394415	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	11/5/2019 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Vault Cleaned During This Inspection?	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Catch Pans, Debris Shields	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Hangers, Hardware - Ceiling, Walls	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Blowers and Ductwork	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Number of Ducts Available	01
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Sidewalk Surface Area	TRUE

6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE

6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6510778	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	4/1/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE



6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	BARCODE	FALSE
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6609545	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/23/2020 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6674588	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/20/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE





6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE

6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	BARCODE	FALSE
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6780484	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	7/16/2021 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE



6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
6884300	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	1/12/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	Anything not listed?	FALSE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983207	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	6/29/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL



7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE



7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR MISSING	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	BARCODE	FALSE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7076992	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	12/7/2022 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	Anything not listed?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE



7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	BARCODE	FALSE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	SWITCH POSITION	CLOSED
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7165820	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	5/3/2023 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	Anything not listed?	FALSE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	Lighting and Receptacles	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	VAULT LADDER	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	DRYWELL DRAINAGE	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SERVICE DUCT SEALS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	CABLE TAGS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER GASKETS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA COLLECTOR BOX	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	SCADA SENSORS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR BUS CONNECTIONS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR PROTECTOR LEADS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR SERVICE LEADS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	AD-6 MULTIPLIER	01



7254120	VT0042 ARTS CENTER	533 W Main Louisville KY 40202	10/2/2023 0:00	4/2/2024 0:00	Elbow Assembly and Cable	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	Lighting and Receptacles	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6270322	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	6/4/2019 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	SCADA SENSORS	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	BARCODE	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	BARCODE	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	BARCODE	TRUE
6396419	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	11/13/2019 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	Anything not listed?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE

6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6522522	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	4/9/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	BARCODE	FALSE
6614078	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/29/2020 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6677986	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/22/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	BARCODE	FALSE
6781250	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/21/2021 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	Anything not listed?	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	Vault cleaned during this inspection?	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE



6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6886592	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	1/14/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	Anything not listed?	TRUE



6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE

6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	TRUE
6983985	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	7/12/2022 0:00	4/9/2024 0:00	BARCODE	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Anything not listed?	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Vault cleaned during this inspection?	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Catch pans, debris shields	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Lighting and receptacles	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Blowers and ductwork	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Number of ducts available	00
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Sidewalk surface area	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Ceiling, walls, and floor	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Ceiling I-beams, supports	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Hatchway frames, slabs, caulk	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Vent grates, frames, caulk	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Entrance grates, hinges, locks	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Vault ladder	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Drywell drainage	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Cable bus and connections	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Protector, service lead connections	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Service duct seals	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Cable tags	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Primary arc proofing tape	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Ground, neutral cables	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Transformer floor beams	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Transformer leaks location	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Transformer gaskets	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Transformer case rust location	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Pressure relief valve	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Transformer primary switch, lock	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Protector housing rust	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Protector switch, lock	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	SCADA collector box	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	SCADA protector boxes	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	SCADA wiring and hangers	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	SCADA sensors	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IR bus connections	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IR protector leads	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IR service leads	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IR primary elbows, terms	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	AD-6 multiplier	01
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS transformer missing?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS transformer information incorrect?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Barcode	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Main tank oil level	NORMAL
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	Primary switch oil level	NORMAL
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS protector missing	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS service or main missing?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS service or main info wrong?	FALSE

7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7084685	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	12/20/2022 0:00	4/9/2024 0:00	BARCODE	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	Anything not listed?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE

7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7172928	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	5/17/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	Anything not listed?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	Lighting and Receptacles	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VAULT LADDER	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	DRYWELL DRAINAGE	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SERVICE DUCT SEALS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	CABLE TAGS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	TRANSFORMER GASKETS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PRESSURE RELIEF VALVE	TRUE

7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SCADA COLLECTOR BOX	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	SCADA SENSORS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IR BUS CONNECTIONS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IR PROTECTOR LEADS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IR SERVICE LEADS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	AD-6 MULTIPLIER	01
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR MISSING	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7261721	VT0043 AVERY FEDERAL	515 W Market Louisville KY 40202	10/9/2023 0:00	4/9/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	VAULT LADDER	TRUE



6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE



6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	BARCODE	FALSE
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6269164	VT0044 BOC	800 W Broadway Louisville KY 40202	5/30/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	BARCODE	TRUE
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6394416	VT0044 BOC	800 W Broadway Louisville KY 40202	11/6/2019 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE

6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	BARCODE	TRUE
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6510872	VT0044 BOC	800 W Broadway Louisville KY 40202	4/2/2020 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6610390	VT0044 BOC	800 W Broadway Louisville KY 40202	7/24/2020 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE



6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE



6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	BARCODE	FALSE
6675306	VT0044 BOC	800 W Broadway Louisville KY 40202	1/20/2021 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6780485	VT0044 BOC	800 W Broadway Louisville KY 40202	7/15/2021 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE



6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE

6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6883421	VT0044 BOC	800 W Broadway Louisville KY 40202	1/11/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	Anything not listed?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SEWALK SURFACE AREA	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE

6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE

6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6983120	VT0044 BOC	800 W Broadway Louisville KY 40202	6/23/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	Anything not listed?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE



7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7074623	VT0044 BOC	800 W Broadway Louisville KY 40202	12/1/2022 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	Anything not listed?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE

7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7162930	VT0044 BOC	800 W Broadway Louisville KY 40202	4/27/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	Anything not listed?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	Lighting and Receptacles	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	VAULT LADDER	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	DRYWELL DRAINAGE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SERVICE DUCT SEALS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	CABLE TAGS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	TRANSFORMER GASKETS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SCADA COLLECTOR BOX	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SCADA SENSORS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IR BUS CONNECTIONS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IR PROTECTOR LEADS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IR SERVICE LEADS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	AD-6 MULTIPLIER	01
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED

7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	SWITCH POSITION	CLOSED
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	Elbow Assembly and Cable	TRUE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR MISSING	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7250559	VT0044 BOC	800 W Broadway Louisville KY 40202	9/26/2023 0:00	3/26/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	CABLE TAGS	TRUE

6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE



6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6300295	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/14/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE





6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6383877	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/26/2019 0:00	3/14/2024 0:00	BARCODE	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6479216	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	2/19/2020 0:00	3/14/2024 0:00	BARCODE	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE

6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	TRUE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6581479	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/14/2020 0:00	3/14/2024 0:00	BARCODE	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE







6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669131	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	1/12/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	TRUE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775781	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	7/7/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE

6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	SWITCH POSITION	CLOSED
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	Elbow Assembly and Cable	TRUE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6878581	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	12/17/2021 0:00	3/14/2024 0:00	BARCODE	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	Anything not listed?	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE



6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	BARCODE	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	BARCODE	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6971055	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	5/3/2022 0:00	3/14/2024 0:00	BARCODE	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	Anything not listed?	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	Lighting and Receptacles	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	BARCODE	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	BARCODE	FALSE
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7049400	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	10/19/2022 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE





7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VAULT LADDER	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	DRYWELL DRAINAGE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SERVICE DUCT SEALS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	CABLE TAGS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	TRANSFORMER GASKETS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SCADA COLLECTOR BOX	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	SCADA SENSORS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IR BUS CONNECTIONS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IR PROTECTOR LEADS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IR SERVICE LEADS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	AD-6 MULTIPLIER	01
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BARCODE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BARCODE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BARCODE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BARCODE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	BARCODE	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7138007	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	4/7/2023 0:00	3/14/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE





7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	BARCODE	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	BARCODE	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	BARCODE	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	BARCODE	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR MISSING	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7239874	VT0045 BOC DATA CENTER	720 S 8th ST Louisville KY 40202	9/14/2023 0:00	3/14/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE





6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6301386	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/2/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE



6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6416217	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/19/2019 0:00	6/4/2024 0:00	BARCODE	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	Lighting and Receptacles	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE



6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	SWITCH POSITION	CLOSED
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	Elbow Assembly and Cable	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6543027	VT0046 BACONS	400 W Liberty Louisville KY 40202	6/29/2020 0:00	6/4/2024 0:00	BARCODE	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE

6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	SWITCH POSITION	CLOSED
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	Elbow Assembly and Cable	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00	BARCODE	TRUE



6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 SWITCH POSITION	CLOSED
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 Elbow Assembly and Cable	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 SWITCH POSITION	CLOSED
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 Elbow Assembly and Cable	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 SWITCH POSITION	CLOSED
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 Elbow Assembly and Cable	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 MAIN TANK OIL LEVEL	NORMAL
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS PROTECTOR MISSING	FALSE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 IS PROTECTOR INFO INCORRECT	TRUE
6659594	VT0046 BACONS	400 W Liberty Louisville KY 40202	11/5/2020 0:00	6/4/2024 0:00 BARCODE	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 Anything not listed?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 CATCH PANS, DEBRIS SHIELDS	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 Lighting and Receptacles	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00 NUMBER OF DUCTS AVAILABLE	01

6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE



6733933	VT0046 BACONS	400 W Liberty Louisville KY 40202	3/25/2021 0:00	6/4/2024 0:00	BARCODE	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	TRUE



6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6821456	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/26/2021 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	Anything not listed?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL





6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6907878	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/16/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000771	VT0046 BACONS	400 W Liberty Louisville KY 40202	8/9/2022 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE



7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7098757	VT0046 BACONS	400 W Liberty Louisville KY 40202	2/3/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE





7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	SWITCH POSITION	CLOSED
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	Elbow Assembly and Cable	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS PROTECTOR MISSING	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7199881	VT0046 BACONS	400 W Liberty Louisville KY 40202	7/12/2023 0:00	6/4/2024 0:00	BARCODE	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	Anything not listed?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	Lighting and Receptacles	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	VAULT LADDER	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	DRYWELL DRAINAGE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SERVICE DUCT SEALS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	CABLE TAGS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER GASKETS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA COLLECTOR BOX	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SCADA SENSORS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR BUS CONNECTIONS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR PROTECTOR LEADS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR SERVICE LEADS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	AD-6 MULTIPLIER	01
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SWITCH POSITION	CLOSED
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	Elbow Assembly and Cable	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	BARCODE	TRUE
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	SWITCH POSITION	CLOSED
7291551	VT0046 BACONS	400 W Liberty Louisville KY 40202	12/4/2023 0:00	6/4/2024 0:00	RUST OR DAMAGE PRESENT	TRUE



6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6277010	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	6/12/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE





6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6402053	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/21/2019 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE

6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6524612	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	4/23/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE



6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6621709	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/20/2020 0:00	5/29/2024 0:00	BARCODE	FALSE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	INSPECTION CALLED OFF	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6691377	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/2/2021 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01







6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6787817	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	2/11/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE



6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	SWITCH POSITION	OPEN
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6890329	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	8/4/2021 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE

6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6894980	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/27/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	Anything not listed?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE



6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	BARCODE	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6990344	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/26/2022 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE







7091464	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	1/17/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Anything not listed?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE

7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SWITCH POSITION	OPEN
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Anything not listed?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE





7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SWITCH POSITION	CLOSED
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	SWITCH POSITION	OPEN
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	Elbow Assembly and Cable	TRUE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7186395	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	7/6/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	Anything not listed?	FALSE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	Lighting and Receptacles	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	VAULT LADDER	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	CABLE TAGS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	SCADA SENSORS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IR SERVICE LEADS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	AD-6 MULTIPLIER	01
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	BARCODE	FALSE
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7287233	VT0047 BANK OF LOUISVILLE	500 W BROADWAY Louisville KY 40202	11/29/2023 0:00	5/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6248401	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/25/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BARCODE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BARCODE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BARCODE	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	BARCODE	FALSE
6368952	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/8/2019 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE





6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	SWITCH POSITION	CLOSED
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	Elbow Assembly and Cable	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6443293	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	2/4/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	SWITCH POSITION	CLOSED
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	Elbow Assembly and Cable	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	BARCODE	FALSE
6573197	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	7/9/2020 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666584	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	1/5/2021 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE











6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	BARCODE	FALSE
6870810	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	11/18/2021 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE



6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	Anything not listed?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE





6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
6955116	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	4/8/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	Anything not listed?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	AD-6 MULTIPLIER	01
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	SWITCH POSITION	CLOSED
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	Elbow Assembly and Cable	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	BARCODE	FALSE
7031547	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	9/21/2022 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	Anything not listed?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SCADA COLLECTOR BOX	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SCADA SENSORS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IR BUS CONNECTIONS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IR PROTECTOR LEADS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IR SERVICE LEADS	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS PROTECTOR MISSING	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	SWITCH POSITION	CLOSED
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	Elbow Assembly and Cable	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	BARCODE	FALSE
7120380	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	3/10/2023 0:00	2/28/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	Anything not listed?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	Lighting and Receptacles	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	VAULT LADDER	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	DRYWELL DRAINAGE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	SERVICE DUCT SEALS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	CABLE TAGS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER GASKETS	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE





7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 SWITCH POSITION	CLOSED
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 Elbow Assembly and Cable	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 SWITCH POSITION	CLOSED
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 Elbow Assembly and Cable	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR MISSING	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR INFO INCORRECT	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR MISSING	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR INFO INCORRECT	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR MISSING	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS PROTECTOR INFO INCORRECT	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 SWITCH POSITION	CLOSED
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 Elbow Assembly and Cable	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN MISSING?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 IS SERVICE OR MAIN INFO WRONG?	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 BARCODE	FALSE
7223972	VT0048 BELKNAP BLDG	111 E Main Louisville KY 40202	8/28/2023 0:00	2/28/2024 0:00 VISUAL INSPECTION SERV/MAIN	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 Anything not listed?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 CATCH PANS, DEBRIS SHIELDS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 Lighting and Receptacles	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 NUMBER OF DUCTS AVAILABLE	00
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 SIDEWALK SURFACE AREA	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 CEILING, WALLS, AND FLOOR	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 CEILING I-BEAMS, SUPPORTS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 HATCHWAY FRAMES, SLABS, CAULK	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 VENT GRATES, FRAMES, CAULK	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 ENTRANCE GRATES, HINGES, LOCKS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 VAULT LADDER	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 DRYWELL DRAINAGE	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 CABLE BUS AND CONNECTIONS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00 PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6239349	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/1/2019 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	Anything not listed?	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	Vault cleaned during this inspection?	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6329179	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/23/2019 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	Anything not listed?	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6430692	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	1/17/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE

6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6559857	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE



6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664664	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	12/29/2020 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	Anything not listed?	TRUE



6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE

6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766661	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	6/4/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	Anything not listed?	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE

6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6859624	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	10/12/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	Anything not listed?	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
6932589	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	3/16/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	Anything not listed?	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7018526	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	9/2/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	Anything not listed?	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01



7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109607	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	2/28/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	Anything not listed?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE



7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7215153	VT0049 BENSINGER BUILDING	315 W Market Louisville KY 40202	8/23/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE

6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6244239	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/27/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE

6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	BARCODE	TRUE
6348172	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/3/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED

6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6440119	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/31/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Vault Cleaned During This Inspection?	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Catch Pans, Debris Shields	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Hangers, Hardware - Ceiling, Walls	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Blowers and Ductwork	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Number of Ducts Available	00
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Sidewalk Surface Area	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Ceiling, Walls, and Floor	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Ceiling I-Beams, Supports	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Hatchway Frames, Slabs, Caulk	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Vent Grates, Frames, Caulk	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Entrance Grates, Hinges, Locks	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Vault Ladder	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Drywell Drainage	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Cable Bus and Connections	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Protector, Service Lead Connections	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Service Duct Seals	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Cable Tags	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Primary Arc Proofing Tape	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Ground, Neutral Cables	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Transformer Floor Beams	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Transformer Leaks Location	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Transformer Gaskets	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Transformer Case Rust Location	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Pressure Relief Valve	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Transformer Primary Switch, Lock	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Protector Housing Rust	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Protector Switch, Lock	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SCADA Collector Box	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SCADA Protector Boxes	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SCADA Wiring and Hangers	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SCADA Sensors	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IR Bus Connections	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IR Protector Leads	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IR Service Leads	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IR Primary Elbows, Terms	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	AD-6 Multiplier	01
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS Transformer Missing?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS Transformer Information Incorrect?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Primary Switch Oil Level	NORMAL
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Barcode	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Main Tank Oil Level	NORMAL
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS Transformer Missing?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS Transformer Information Incorrect?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Primary Switch Oil Level	NORMAL



6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6569964	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	7/9/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE



6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6666585	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	1/6/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE

6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6771334	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	6/30/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00

6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	FALSE

6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6873510	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	11/23/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE

6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957100	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	4/14/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01

7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7034437	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE



7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124726	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	SWITCH POSITION	CLOSED
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	Elbow Assembly and Cable	TRUE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	BARCODE	TRUE

7226692	VT0050 BERNHEIM BUILDING	111 S 7th ST Louisville KY 40202	8/29/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	Anything not listed?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6229628	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/14/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	Anything not listed?	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE

6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	BARCODE	TRUE
6316028	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/12/2019 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	Anything not listed?	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	VAULT LADDER	TRUE







6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6424030	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/7/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	Anything not listed?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	BARCODE	TRUE
6552909	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	7/2/2020 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	Anything not listed?	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661986	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	12/4/2020 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE

6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	BARCODE	TRUE
6752924	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	4/14/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	Anything not listed?	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE



6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	BARCODE	FALSE
6831098	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	9/21/2021 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	Anything not listed?	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE



6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6919961	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	3/3/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	Anything not listed?	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	BARCODE	FALSE
7011606	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/24/2022 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	Anything not listed?	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01

7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	BARCODE	FALSE
7107111	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	2/21/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	Anything not listed?	FALSE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE





7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	BARCODE	TRUE
7210857	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	8/9/2023 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	Anything not listed?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	Lighting and Receptacles	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VAULT LADDER	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	CABLE TAGS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	SCADA SENSORS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IR SERVICE LEADS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	AD-6 MULTIPLIER	01
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE



7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	BARCODE	TRUE
7305348	VT0052 BROADWAY PROJECT	636 S 2nd ST Louisville KY 40202	1/25/2024 0:00	7/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	Anything not listed?	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	Lighting and Receptacles	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE

6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6269165	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	5/29/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	Anything not listed?	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	Lighting and Receptacles	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BARCODE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BARCODE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BARCODE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BARCODE	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	BARCODE	FALSE
6393473	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	10/31/2019 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	Anything not listed?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE

6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BARCODE	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6507215	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	3/26/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	Anything not listed?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	Vault Cleaned During This Inspection?	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	Vault Ladder	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE

6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BARCODE	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	BARCODE	FALSE
6607167	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/22/2020 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	Anything not listed?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE



6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6673804	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/15/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	Anything not listed?	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE



6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BARCODE	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	BARCODE	FALSE
6776810	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	7/14/2021 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	Anything not listed?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	Vault cleaned during this inspection?	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	Vault Ladder	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE

6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	SWITCH POSITION	CLOSED
6882673	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	1/7/2022 0:00	3/25/2024 0:00	Elbow Assembly and Cable	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	Anything not listed?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	CABLE TAGS	TRUE

6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	SWITCH POSITION	CLOSED
6980134	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	6/14/2022 0:00	3/25/2024 0:00	Elbow Assembly and Cable	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	Anything not listed?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BARCODE	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	BARCODE	FALSE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	SWITCH POSITION	CLOSED
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7069278	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	11/21/2022 0:00	3/25/2024 0:00	Elbow Assembly and Cable	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	Anything not listed?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE

7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	BARCODE	FALSE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	SWITCH POSITION	CLOSED



7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7156778	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	4/24/2023 0:00	3/25/2024 0:00	Elbow Assembly and Cable	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	Anything not listed?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	Lighting and Receptacles	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VAULT LADDER	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	DRYWELL DRAINAGE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SERVICE DUCT SEALS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	CABLE TAGS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	TRANSFORMER GASKETS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SCADA COLLECTOR BOX	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SCADA SENSORS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IR BUS CONNECTIONS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IR PROTECTOR LEADS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IR SERVICE LEADS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	AD-6 MULTIPLIER	01
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS PROTECTOR MISSING	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	BARCODE	FALSE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	SWITCH POSITION	CLOSED
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7248901	VT0053 BROADWAY RENAISSANCE	642 S 3rd ST Louisville KY 40202	9/25/2023 0:00	3/25/2024 0:00	Elbow Assembly and Cable	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6247415	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/22/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6344294	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/31/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE

6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6437386	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/28/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6567801	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE

6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6665605	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	Vault cleaned during this inspection?	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	Vault Ladder	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE



6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771261	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	6/22/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE



6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6869263	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	11/12/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	BARCODE	TRUE
6951518	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	4/5/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7029192	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	9/16/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	BARCODE	TRUE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7117130	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	3/9/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	TRUE
7223065	VT0055 BROWN GARAGE	663 S 4th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6300212	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/30/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE





6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6372227	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/23/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE

6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6456079	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	2/6/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573925	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/10/2020 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE

6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6667462	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	1/7/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE

6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE



6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6771434	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	7/1/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE



6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6875315	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	11/24/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE

6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957188	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	4/15/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7035458	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	9/28/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE

7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7124727	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	3/15/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	TRUE



7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7226693	VT0056 BROWN HOTEL (SWK)	675 S 4TH ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	Anything not listed?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE



6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6292725	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	6/28/2019 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	Anything not listed?	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE



6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	BARCODE	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	BARCODE	FALSE
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6414503	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/17/2019 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	Anything not listed?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6542363	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	5/22/2020 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	Anything not listed?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE

6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE



6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	BARCODE	FALSE
6639063	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	9/16/2020 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	Anything not listed?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE



6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	BARCODE	FALSE
6704240	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	3/9/2021 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	Anything not listed?	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6809702	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/19/2021 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE



6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	Anything not listed?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6903869	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/15/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	Anything not listed?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE

7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7000693	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	8/4/2022 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	Anything not listed?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	06



7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7096259	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	2/1/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	Anything not listed?	FALSE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
7198981	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	7/12/2023 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE



7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	Lighting and Receptacles	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VAULT LADDER	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	CABLE TAGS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SCADA SENSORS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IR SERVICE LEADS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	AD-6 MULTIPLIER	01
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE

7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	SWITCH POSITION	CLOSED
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	Elbow Assembly and Cable	TRUE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	BARCODE	FALSE
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7290982	VT0058 BROWN OFFICE BLDG	321 W Broadway Louisville KY 40202	12/12/2023 0:00	6/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	Anything not listed?	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE

6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244240	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/22/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE



6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6344295	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	Anything not listed?	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6438341	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/29/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	INSPECTION CALLED OFF	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6567848	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/8/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	BARCODE	FALSE
6662222	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/10/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	Anything not listed?	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	BARCODE	FALSE

6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6768248	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	1/7/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Anything not listed?	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL

6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771435	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	7/2/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	Anything not listed?	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6876069	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	12/3/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	Anything not listed?	TRUE

6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	BARCODE	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6963561	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	4/19/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	Anything not listed?	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE



7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7037039	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/29/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01

7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7125024	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7227433	VT0059 BYCKS	536 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE



6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6248249	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE





6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351156	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	8/1/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6438342	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE





6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6569178	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE





6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6666586	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE





6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE

6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771335	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873511	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE



6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957101	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034438	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Vault LADDER	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124728	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE







7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227434	VT0060 CAPITAL HOLDING (NORTH)	210 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE

6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED

6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	BARCODE	FALSE
6244243	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE



6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	BARCODE	TRUE
6351157	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	8/2/2019 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6439298	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/30/2020 0:00	3/5/2024 0:00	BARCODE	TRUE





6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE

6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	BARCODE	TRUE
6569181	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	7/9/2020 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE



6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	BARCODE	TRUE
6666590	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	1/6/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE



6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6771339	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	6/30/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE

6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED

6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	BARCODE	FALSE
6873514	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	11/23/2021 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE



6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6957102	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	4/14/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE



7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7034439	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/28/2022 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00

7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA COLLECTOR BOX	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SCADA SENSORS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR BUS CONNECTIONS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR PROTECTOR LEADS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR SERVICE LEADS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	AD-6 MULTIPLIER	01
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS PROTECTOR MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE

7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	SWITCH POSITION	CLOSED
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	Elbow Assembly and Cable	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	BARCODE	FALSE
7124729	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	3/16/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Anything not listed?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	Lighting and Receptacles	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VAULT LADDER	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	DRYWELL DRAINAGE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	SERVICE DUCT SEALS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	CABLE TAGS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER GASKETS	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE



7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	BARCODE	TRUE
7227435	VT0061 CAPITAL HOLDING (SOUTH)	212 S 4th ST Louisville KY 40202	9/5/2023 0:00	3/5/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	BARCODE	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	BARCODE	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	BARCODE	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	BARCODE	FALSE
6287711	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/21/2019 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	BARCODE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	BARCODE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	BARCODE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	BARCODE	TRUE
6409081	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	12/10/2019 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE

6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	BARCODE	FALSE
6538147	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	5/8/2020 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	BARCODE	TRUE
6631820	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	9/3/2020 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	Anything not listed?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	BARCODE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	BARCODE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	BARCODE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	BARCODE	TRUE
6696981	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	2/24/2021 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	BARCODE	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	BARCODE	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	BARCODE	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	BARCODE	FALSE
6799828	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	8/6/2021 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	Anything not listed?	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6896720	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/28/2022 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	Anything not listed?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	BARCODE	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6991076	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	7/27/2022 0:00	5/21/2024 0:00	BARCODE	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	Anything not listed?	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7093442	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	1/25/2023 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	Anything not listed?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190975	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	6/29/2023 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	Anything not listed?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	Lighting and Receptacles	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE

7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	VAULT LADDER	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	CABLE TAGS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	SCADA SENSORS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IR SERVICE LEADS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	AD-6 MULTIPLIER	01
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	BARCODE	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	BARCODE	FALSE
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7281676	VT0062 CATHEDRAL (5TH ST)	443 S 5th ST Louisville KY 40202	11/21/2023 0:00	5/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	Anything not listed?	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE



6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	BARCODE	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	BARCODE	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	BARCODE	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	BARCODE	FALSE
6287712	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/20/2019 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	Anything not listed?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE

6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	BARCODE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	LOW
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	BARCODE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	BARCODE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	BARCODE	TRUE
6408256	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	12/6/2019 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	Anything not listed?	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	VAULT LADDER	TRUE

6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6536523	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	5/7/2020 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	Anything not listed?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6631065	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	9/1/2020 0:00	5/22/2024 0:00	BARCODE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Anything not listed?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Vault cleaned during this inspection?	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Catch pans, debris shields	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Lighting and receptacles	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Blowers and ductwork	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Number of ducts available	02
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Sidewalk surface area	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Ceiling, walls, and floor	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Ceiling I-beams, supports	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Hatchway frames, slabs, caulk	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Vent grates, frames, caulk	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Entrance grates, hinges, locks	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Vault ladder	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Drywell drainage	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Cable bus and connections	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Protector, service lead connections	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Service duct seals	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Cable tags	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	Primary arc proofing tape	TRUE

6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6696850	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/24/2021 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	INSPECTION CALLED OFF	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	Anything not listed?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE



6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	BARCODE	TRUE
6799829	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	8/6/2021 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	Anything not listed?	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	BARCODE	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6988895	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	2/1/2022 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	Anything not listed?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE

6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	BARCODE	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	BARCODE	TRUE
6993339	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	7/27/2022 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	Anything not listed?	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SIWALK SURFACE AREA	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE

7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7093443	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	1/25/2023 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	Anything not listed?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE

7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7190976	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	6/29/2023 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	Anything not listed?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	Lighting and Receptacles	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	VAULT LADDER	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	DRYWELL DRAINAGE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SERVICE DUCT SEALS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	CABLE TAGS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	TRANSFORMER GASKETS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SCADA COLLECTOR BOX	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	SCADA SENSORS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IR BUS CONNECTIONS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IR PROTECTOR LEADS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IR SERVICE LEADS	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	AD-6 MULTIPLIER	01
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS PROTECTOR MISSING	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	BARCODE	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	BARCODE	FALSE
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7281677	VT0065 CHRIST CHURCH CATHEDRAL(2ND ST)	421 S 2nd ST Louisville KY 40202	11/22/2023 0:00	5/22/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	03
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6260800	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	5/13/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	03
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6382963	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	9/18/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE







6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6472417	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	2/14/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6578393	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/14/2020 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE



6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	LOW
6669135	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	1/12/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE







6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6775788	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	7/7/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6878590	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	12/16/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE





6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6970305	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/29/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	Anything not listed?	FALSE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7043645	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	10/12/2022 0:00	3/12/2024 0:00	BARCODE	FALSE





7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	BARCODE	TRUE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7133868	VT0066 CITIZENS BANK (30TH FL)	500 W Jefferson Louisville KY 40202	4/5/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE







6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR MISSING?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR MISSING	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR MISSING	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR MISSING	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6308789	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	2/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE







6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	BARCODE	FALSE
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6339659	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/12/2019 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE



6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BARCODE	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6424031	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/8/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE





6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	BARCODE	FALSE
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6553000	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	8/5/2020 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SEWAGE SURFACE AREA	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE



6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6682282	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/27/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE





6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	BARCODE	FALSE
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6784503	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/23/2021 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6888041	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	1/19/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	Anything not listed?	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE



6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
6986442	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	7/14/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	Anything not listed?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	BARCODE	FALSE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	SWITCH POSITION	CLOSED
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7086100	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	12/28/2022 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	Anything not listed?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	BARCODE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	BARCODE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	LOW
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	BARCODE	TRUE
7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



7175208	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	5/25/2023 0:00	4/17/2024 0:00	Elbow Assembly and Cable	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	Anything not listed?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	Lighting and Receptacles	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	VAULT LADDER	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	DRYWELL DRAINAGE	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SERVICE DUCT SEALS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	CABLE TAGS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	TRANSFORMER GASKETS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SCADA COLLECTOR BOX	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	SCADA SENSORS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IR BUS CONNECTIONS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IR PROTECTOR LEADS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IR SERVICE LEADS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	AD-6 MULTIPLIER	01
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	BARCODE	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	BARCODE	TRUE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	LOW
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	BARCODE	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7265243	VT0067 CITIZENS BANK (SDWK)	500 W Jefferson Louisville KY 40202	10/17/2023 0:00	4/17/2024 0:00	BARCODE	TRUE





6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	02
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	BARCODE	FALSE
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6232699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/15/2019 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	Anything not listed?	FALSE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6316884	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/16/2019 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	BARCODE	FALSE
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6425803	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	1/9/2020 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	Anything not listed?	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL



6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	BARCODE	FALSE
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6553856	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	7/2/2020 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	Anything not listed?	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE

6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS HIGH SIDE SWITCH MISSING?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	IS HIGH SIDE SWITCH INFO INCORRECT?	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	BARCODE	FALSE
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6661988	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	12/18/2020 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	Anything not listed?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE

6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	BARCODE	FALSE
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6761529	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	5/19/2021 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	Anything not listed?	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6851699	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	9/29/2021 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE





6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
6924386	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	3/9/2022 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Anything not listed?	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Vault Cleaned During This Inspection?	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Catch Pans, Debris Shields	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Hangers, Hardware - Ceiling, Walls	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Blowers and Ductwork	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Number of Ducts Available	00
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Sidewalk Surface Area	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Ceiling, Walls, and Floor	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Ceiling I-Beams, Supports	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Hatchway Frames, Slabs, Caulk	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Vent Grates, Frames, Caulk	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Entrance Grates, Hinges, Locks	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Vault Ladder	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Drywell Drainage	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Cable Bus and Connections	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Protector, Service Lead Connections	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Service Duct Seals	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Cable Tags	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Primary Arc Proofing Tape	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Ground, Neutral Cables	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Transformer Floor Beams	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Transformer Leaks Location	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Transformer Gaskets	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Transformer Case Rust Location	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Pressure Relief Valve	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Transformer Primary Switch, Lock	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Protector Housing Rust	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Protector Switch, Lock	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	SCADA Collector Box	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	SCADA Protector Boxes	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	SCADA Wiring and Hangers	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	SCADA Sensors	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IR Bus Connections	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IR Protector Leads	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IR Service Leads	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IR Primary Elbows, Terms	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	AD-6 Multiplier	01
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS Transformer Missing?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS Transformer Information Incorrect?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Barcode	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Main Tank Oil Level	NORMAL
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Primary Switch Oil Level	NORMAL
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS Transformer Missing?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS Transformer Information Incorrect?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Barcode	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Main Tank Oil Level	NORMAL

7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	BARCODE	FALSE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7014847	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/31/2022 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	Anything not listed?	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE

7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7109206	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/23/2023 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	Anything not listed?	FALSE

7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	BARCODE	FALSE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7211094	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	8/15/2023 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	Anything not listed?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	Lighting and Receptacles	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VAULT LADDER	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	DRYWELL DRAINAGE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SERVICE DUCT SEALS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	CABLE TAGS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	TRANSFORMER GASKETS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SCADA COLLECTOR BOX	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SCADA SENSORS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IR BUS CONNECTIONS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IR PROTECTOR LEADS	TRUE

7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IR SERVICE LEADS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	AD-6 MULTIPLIER	01
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS PROTECTOR MISSING	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	BARCODE	FALSE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	SWITCH POSITION	CLOSED
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7308374	VT0068 CITY HALL	609 W Jefferson Louisville KY 40202	2/7/2024 0:00	8/7/2024 0:00	Elbow Assembly and Cable	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE

6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	BARCODE	FALSE
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6249599	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/9/2019 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE





6381128	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/17/2019 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE

6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6472348	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	2/13/2020 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00	BARCODE	TRUE

6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 SWITCH POSITION	CLOSED
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 Elbow Assembly and Cable	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 BARCODE	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 SWITCH POSITION	CLOSED
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 Elbow Assembly and Cable	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 BARCODE	TRUE
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 SWITCH POSITION	CLOSED
6577545	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/14/2020 0:00	3/18/2024 0:00 Elbow Assembly and Cable	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 Anything not listed?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 CATCH PANS, DEBRIS SHIELDS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 Lighting and Receptacles	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 NUMBER OF DUCTS AVAILABLE	00
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SIDEWALK SURFACE AREA	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 CEILING, WALLS, AND FLOOR	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 CEILING I-BEAMS, SUPPORTS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 HATCHWAY FRAMES, SLABS, CAULK	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 VENT GRATES, FRAMES, CAULK	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 ENTRANCE GRATES, HINGES, LOCKS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 VAULT LADDER	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 DRYWELL DRAINAGE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 CABLE BUS AND CONNECTIONS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SERVICE DUCT SEALS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 CABLE TAGS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PRIMARY ARC PROOFING TAPE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 GROUND, NEUTRAL CABLES	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 TRANSFORMER FLOOR BEAMS	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 TRANSFORMER LEAKS LOCATION	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 TRANSFORMER GASKETS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 TRANSFORMER CASE RUST LOCATION	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PRESSURE RELIEF VALVE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PROTECTOR HOUSING RUST	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PROTECTOR SWITCH, LOCK	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SCADA COLLECTOR BOX	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SCADA PROTECTOR BOXES	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SCADA WIRING AND HANGERS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 SCADA SENSORS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IR BUS CONNECTIONS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IR PROTECTOR LEADS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IR SERVICE LEADS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IR PRIMARY ELBOWS, TERMS	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 AD-6 MULTIPLIER	01
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00 MAIN TANK OIL LEVEL	NORMAL

6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	BARCODE	TRUE
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6669136	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	1/12/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE



6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE

6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6775789	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	7/8/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE



6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	BARCODE	FALSE
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6879358	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	12/22/2021 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	Anything not listed?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE

6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
6972209	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	5/13/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	Anything not listed?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE





7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	BARCODE	FALSE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7052519	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	10/25/2022 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	Anything not listed?	FALSE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
7141766	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	4/11/2023 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE



7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	Lighting and Receptacles	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	VAULT LADDER	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SERVICE DUCT SEALS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	CABLE TAGS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	TRANSFORMER GASKETS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SCADA SENSORS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IR BUS CONNECTIONS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IR PROTECTOR LEADS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IR SERVICE LEADS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	AD-6 MULTIPLIER	01
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	BARCODE	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	SWITCH POSITION	CLOSED
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7241497	VT0069 CLOCK TOWER	113 E Main Louisville KY 40202	9/18/2023 0:00	3/18/2024 0:00	Elbow Assembly and Cable	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE



6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6253465	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/9/2019 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE

6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BARCODE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BARCODE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BARCODE	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	BARCODE	FALSE
6381129	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/17/2019 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	05
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	CABLE TAGS	TRUE

6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6472349	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	2/13/2020 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	VAULT LADDER	TRUE

6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	BARCODE	FALSE
6577546	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/14/2020 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	BARCODE	FALSE
6669137	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/13/2021 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE



6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	BARCODE	FALSE

6775859	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	7/9/2021 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	Anything not listed?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6880136	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	1/6/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	Anything not listed?	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE

6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
6979501	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	5/20/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Anything not listed?	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Vault cleaned during this inspection?	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Catch pans, debris shields	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Hangers, hardware - ceiling, walls	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Lighting and receptacles	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Blowers and ductwork	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Number of ducts available	04
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Sidewalk surface area	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Ceiling, walls, and floor	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Ceiling h-beams, supports	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Hatchway frames, slabs, caulk	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Vent grates, frames, caulk	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Entrance grates, hinges, locks	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Vault ladder	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Drywell drainage	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Cable bus and connections	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Protector, service lead connections	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Service duct seals	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Cable tags	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Primary arc proofing tape	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Ground, neutral cables	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Transformer floor beams	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Transformer leaks location	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Transformer gaskets	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Transformer case rust location	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Pressure relief valve	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Transformer primary switch, lock	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Protector housing rust	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Protector switch, lock	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	SCADA collector box	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	SCADA protector boxes	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	SCADA wiring and hangers	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	SCADA sensors	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IR bus connections	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IR protector leads	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IR service leads	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IR primary elbows, terms	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	AD-6 multiplier	01
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS transformer missing?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS transformer information incorrect?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Barcode	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Main tank oil level	NORMAL
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Primary switch oil level	NORMAL
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS transformer missing?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS transformer information incorrect?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	Barcode	FALSE

7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	BARCODE	FALSE
7056526	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	11/2/2022 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	Anything not listed?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BARCODE	FALSE



7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BARCODE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BARCODE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BARCODE	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	BARCODE	FALSE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145981	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	4/18/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	Anything not listed?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	Lighting and Receptacles	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	VAULT LADDER	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	DRYWELL DRAINAGE	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SERVICE DUCT SEALS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	CABLE TAGS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	TRANSFORMER GASKETS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SCADA COLLECTOR BOX	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	SCADA SENSORS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IR BUS CONNECTIONS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IR PROTECTOR LEADS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IR SERVICE LEADS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	AD-6 MULTIPLIER	01
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE

7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS PROTECTOR MISSING	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	BARCODE	FALSE
7245262	VT0070 COMMERCE BUILDING	300 W Liberty Louisville KY 40202	9/20/2023 0:00	3/20/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	Anything not listed?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	Vault LADDER	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE



6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	BARCODE	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	BARCODE	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	BARCODE	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	BARCODE	FALSE
6280272	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/13/2019 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	Anything not listed?	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	BARCODE	TRUE
6402937	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	12/3/2019 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	Anything not listed?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6533968	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	5/1/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE



6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS PROTECTOR MISSING	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	BARCODE	TRUE
6628073	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/28/2020 0:00	5/6/2024 0:00	IS PROTECTOR MISSING	FALSE











6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	BARCODE	TRUE
6799725	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	8/5/2021 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Anything not listed?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Vault LADDER	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	BARCODE	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	SWITCH POSITION	CLOSED
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	Elbow Assembly and Cable	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	BARCODE	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	BARCODE	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	BARCODE	FALSE
6895912	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/28/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	Anything not listed?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE





6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	BARCODE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	BARCODE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	BARCODE	TRUE
6991077	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	7/27/2022 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	Anything not listed?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	BARCODE	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	BARCODE	FALSE
7092127	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	1/18/2023 0:00	5/6/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	Anything not listed?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	BARCODE	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	BARCODE	TRUE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	BARCODE	FALSE
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7186472	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	6/21/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	Lighting and Receptacles	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	VAULT LADDER	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	DRYWELL DRAINAGE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SERVICE DUCT SEALS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	CABLE TAGS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	TRANSFORMER GASKETS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SCADA COLLECTOR BOX	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	SCADA SENSORS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IR BUS CONNECTIONS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IR PROTECTOR LEADS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IR SERVICE LEADS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	AD-6 MULTIPLIER	01
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	BARCODE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	BARCODE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	BARCODE	TRUE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	PRIMARY SWITCH OIL LEVEL	LOW
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS PROTECTOR MISSING	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7278085	VT0071 CONVENTION CENTER JEFFERSON (EAST)	231 W Jefferson Louisville KY 40202	11/6/2023 0:00	5/6/2024 0:00	BARCODE	TRUE



6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	Anything not listed?	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE





6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6248252	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	4/9/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	Anything not listed?	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE



6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6357356	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	8/6/2019 0:00	3/13/2024 0:00	BARCODE	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	Anything not listed?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE



6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	TRUE
6441312	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/31/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	Anything not listed?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE





6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6569965	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/9/2020 0:00	3/13/2024 0:00	BARCODE	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	Anything not listed?	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE



6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666591	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	1/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	Anything not listed?	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	06
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE





6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771340	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	7/6/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	Anything not listed?	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	BARCODE	FALSE
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6877831	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	12/17/2021 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE



6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	Lighting and Receptacles	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	NUMBER OF DUCTS AVAILABLE	07
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
6971056	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	5/4/2022 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED



7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	VAULT LADDER	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	DRYWELL DRAINAGE	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SERVICE DUCT SEALS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	BARCODE	FALSE
7046838	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	10/14/2022 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE









7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	CABLE TAGS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	TRANSFORMER GASKETS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SCADA COLLECTOR BOX	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SCADA SENSORS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IR BUS CONNECTIONS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IR PROTECTOR LEADS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IR SERVICE LEADS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	AD-6 MULTIPLIER	01
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	SWITCH POSITION	CLOSED
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	Elbow Assembly and Cable	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR MISSING	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7238249	VT0072 CONVENTION CENTER (WEST)	301 W Jefferson Louisville KY 40202	9/13/2023 0:00	3/13/2024 0:00	BARCODE	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE





6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	BARCODE	FALSE
6243209	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/8/2019 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	BARCODE	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6334350	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/25/2019 0:00	2/29/2024 0:00	BARCODE	TRUE



6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	BARCODE	TRUE
6433085	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/22/2020 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6562597	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	7/8/2020 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01





6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE

6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	BARCODE	TRUE
6665610	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	1/5/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	Anything not listed?	FALSE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6771266	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	6/23/2021 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	Anything not listed?	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SEWAGE SURFACE AREA	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	BARCODE	FALSE
6870084	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	11/16/2021 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL







6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
6954900	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	4/7/2022 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	Anything not listed?	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IR SERVICE LEADS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	AD-6 MULTIPLIER	01
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	BARCODE	FALSE
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7030826	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	9/21/2022 0:00	2/29/2024 0:00	IS TRANSFORMER MISSING?	FALSE







7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR MISSING	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	BARCODE	FALSE
7120381	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	3/10/2023 0:00	2/29/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Anything not listed?	FALSE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	Lighting and Receptacles	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	VAULT LADDER	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	DRYWELL DRAINAGE	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SERVICE DUCT SEALS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	CABLE TAGS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER LEAKS LOCATION	FALSE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER GASKETS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA COLLECTOR BOX	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	SCADA SENSORS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR BUS CONNECTIONS	TRUE
7223974	VT0074 COURIER JOURNAL & TIMES	651 S 6th ST Louisville KY 40202	8/30/2023 0:00	2/29/2024 0:00	IR PROTECTOR LEADS	TRUE



6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	02
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6308556	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/12/2019 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE



6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE



6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	BARCODE	FALSE
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6415547	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/11/2019 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE



6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6423090	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/3/2020 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01



6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6550064	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	7/1/2020 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	BARCODE	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6661132	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	11/24/2020 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE





6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE

6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6745529	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	4/8/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	BARCODE	FALSE
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6828229	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	9/14/2021 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE





6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
6916425	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/24/2022 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	Anything not listed?	FALSE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE



7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7004963	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/18/2022 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	Anything not listed?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7104129	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	2/15/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7206930	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	8/1/2023 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE





7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	FALSE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SWITCH POSITION	CLOSED
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7300908	VT0075 COURIER JOURNAL 480VOLTS	525 W Broadway Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Elbow Assembly and Cable	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE





6306429	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/3/2019 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	BARCODE	TRUE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6417205	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	12/23/2019 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	BARCODE	TRUE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	BARCODE	TRUE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	BARCODE	TRUE
6544296	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	6/30/2020 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	BARCODE	TRUE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6659671	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	11/18/2020 0:00	7/11/2024 0:00	BARCODE	TRUE







6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	BARCODE	TRUE
6742951	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	3/31/2021 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	Anything not listed?	FALSE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6823807	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	9/2/2021 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01



6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE

6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR MISSING	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
6909422	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/18/2022 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	Anything not listed?	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE





7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	BARCODE	FALSE
7001669	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	8/12/2022 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	Anything not listed?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	BARCODE	FALSE
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7101208	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	2/9/2023 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	BARCODE	TRUE
7203080	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	7/24/2023 0:00	7/11/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Anything not listed?	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	Lighting and Receptacles	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	VAULT LADDER	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	DRYWELL DRAINAGE	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SERVICE DUCT SEALS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	CABLE TAGS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	TRANSFORMER GASKETS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SCADA COLLECTOR BOX	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	SCADA SENSORS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IR BUS CONNECTIONS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IR PROTECTOR LEADS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IR SERVICE LEADS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	AD-6 MULTIPLIER	01
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	BARCODE	TRUE
7296461	VT0076 COURIER JOURNAL ANNEX 480VOLTS (BUILDING)	640 S 5th ST Louisville KY 40202	1/11/2024 0:00	7/11/2024 0:00	MAIN TANK OIL LEVEL	NORMAL





6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	BARCODE	FALSE
6249600	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/8/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	Anything not listed?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE

6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	BARCODE	TRUE

6380058	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/28/2019 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	Anything not listed?	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	BARCODE	TRUE
6458468	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	2/7/2020 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	INSPECTION CALLED OFF	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	Anything not listed?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	Lighting and Receptacles	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VAULT LADDER	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	Anything not listed?	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6574651	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	8/5/2020 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE





6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6777859	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/27/2021 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	Anything not listed?	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE

6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE

6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	BARCODE	TRUE
6784504	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/23/2021 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	Anything not listed?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6888042	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	1/19/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	Anything not listed?	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE



6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6986443	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	7/15/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	Anything not listed?	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE

7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	TRUE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	BARCODE	FALSE
7087027	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	12/30/2022 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	Anything not listed?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	CABLE TAGS	TRUE

7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7176309	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	5/30/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	Anything not listed?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	Lighting and Receptacles	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VAULT LADDER	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	DRYWELL DRAINAGE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SERVICE DUCT SEALS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	CABLE TAGS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	TRANSFORMER GASKETS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SCADA COLLECTOR BOX	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	SCADA SENSORS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IR BUS CONNECTIONS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IR PROTECTOR LEADS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IR SERVICE LEADS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	AD-6 MULTIPLIER	01
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS PROTECTOR MISSING	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	BARCODE	TRUE

7267423	VT0077 COURTHOUSE ANNEX	215 S 6th ST Louisville KY 40202	10/18/2023 0:00	4/18/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	Anything not listed?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE



6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6263460	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/14/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	Anything not listed?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	BARCODE	FALSE
6383878	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/25/2019 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	Anything not listed?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE

6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6477880	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	2/19/2020 0:00	3/21/2024 0:00	Anything not listed?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE

6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	BARCODE	TRUE
6581481	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/14/2020 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	Anything not listed?	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE

6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE



6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	BARCODE	TRUE
6669138	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/13/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	Anything not listed?	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL

6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	BARCODE	FALSE
6775860	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	7/9/2021 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	Anything not listed?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE

6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6880137	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	1/5/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	Anything not listed?	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE

6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
6979376	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	5/19/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	Anything not listed?	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE

7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE



7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	BARCODE	FALSE
7055768	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	11/1/2022 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	Anything not listed?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE

7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7145847	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	4/20/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	Anything not listed?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	Lighting and Receptacles	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VAULT LADDER	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	DRYWELL DRAINAGE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SERVICE DUCT SEALS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	CABLE TAGS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	TRANSFORMER GASKETS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SCADA COLLECTOR BOX	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	SCADA SENSORS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IR BUS CONNECTIONS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IR PROTECTOR LEADS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IR SERVICE LEADS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	AD-6 MULTIPLIER	01
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS PROTECTOR MISSING	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	BARCODE	TRUE
7246717	VT0078 DUKE OF YORK APTS	751 S 2nd ST Louisville KY 40202	9/21/2023 0:00	3/21/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE



6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SWITCH POSITION	OPEN
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SWITCH POSITION	OPEN
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SWITCH POSITION	OPEN
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6243282	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/15/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE





6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SWITCH POSITION	OPEN
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	BARCODE	FALSE
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6339120	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/30/2019 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE



6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SWITCH POSITION	OPEN
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6436439	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	1/24/2020 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE





6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 SWITCH POSITION	CLOSED
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 Elbow Assembly and Cable	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 BARCODE	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 SWITCH POSITION	CLOSED
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 Elbow Assembly and Cable	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 IS HIGHSIDE SWITCH MISSING?	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 RUST OR DAMAGE PRESENT	TRUE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 BARCODE	FALSE
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 SWITCH POSITION	CLOSED
6564905	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	7/7/2020 0:00	2/23/2024 0:00 Elbow Assembly and Cable	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 Anything not listed?	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 CATCH PANS, DEBRIS SHIELDS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 Lighting and Receptacles	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 NUMBER OF DUCTS AVAILABLE	02
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SIDEWALK SURFACE AREA	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 CEILING, WALLS, AND FLOOR	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 CEILING I-BEAMS, SUPPORTS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 HATCHWAY FRAMES, SLABS, CAULK	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 VENT GRATES, FRAMES, CAULK	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 ENTRANCE GRATES, HINGES, LOCKS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 VAULT LADDER	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 DRYWELL DRAINAGE	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 CABLE BUS AND CONNECTIONS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SERVICE DUCT SEALS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 CABLE TAGS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PRIMARY ARC PROOFING TAPE	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 GROUND, NEUTRAL CABLES	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 TRANSFORMER FLOOR BEAMS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 TRANSFORMER LEAKS LOCATION	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 TRANSFORMER GASKETS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 TRANSFORMER CASE RUST LOCATION	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PRESSURE RELIEF VALVE	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PROTECTOR HOUSING RUST	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PROTECTOR SWITCH, LOCK	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SCADA COLLECTOR BOX	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SCADA PROTECTOR BOXES	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SCADA WIRING AND HANGERS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 SCADA SENSORS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IR BUS CONNECTIONS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IR PROTECTOR LEADS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IR SERVICE LEADS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IR PRIMARY ELBOWS, TERMS	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 AD-6 MULTIPLIER	01
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 BARCODE	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00 MAIN TANK OIL LEVEL	NORMAL



6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	BARCODE	FALSE
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6664670	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	12/31/2020 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	BARCODE	FALSE



6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	SWITCH POSITION	CLOSED
6766778	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	6/15/2021 0:00	2/23/2024 0:00	Elbow Assembly and Cable	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	Anything not listed?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	BARCODE	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL





6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00 SWITCH POSITION	CLOSED
6865285	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	10/21/2021 0:00	2/23/2024 0:00 Elbow Assembly and Cable	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 Anything not listed?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 VAULT CLEANED DURING THIS INSPECTION?	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 CATCH PANS, DEBRIS SHIELDS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 HANGERS, HARDWARE - CEILING, WALLS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 Lighting and Receptacles	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 BLOWERS AND DUCTWORK	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 NUMBER OF DUCTS AVAILABLE	03
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SIDEWALK SURFACE AREA	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 CEILING, WALLS, AND FLOOR	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 CEILING I-BEAMS, SUPPORTS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 HATCHWAY FRAMES, SLABS, CAULK	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 VENT GRATES, FRAMES, CAULK	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 ENTRANCE GRATES, HINGES, LOCKS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 VAULT LADDER	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 DRYWELL DRAINAGE	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 CABLE BUS AND CONNECTIONS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SERVICE DUCT SEALS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 CABLE TAGS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PRIMARY ARC PROOFING TAPE	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 GROUND, NEUTRAL CABLES	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 TRANSFORMER FLOOR BEAMS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 TRANSFORMER LEAKS LOCATION	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 TRANSFORMER GASKETS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 TRANSFORMER CASE RUST LOCATION	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PRESSURE RELIEF VALVE	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PROTECTOR HOUSING RUST	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PROTECTOR SWITCH, LOCK	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SCADA COLLECTOR BOX	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SCADA PROTECTOR BOXES	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SCADA WIRING AND HANGERS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 SCADA SENSORS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IR BUS CONNECTIONS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IR PROTECTOR LEADS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IR SERVICE LEADS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IR PRIMARY ELBOWS, TERMS	TRUE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 AD-6 MULTIPLIER	01
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 BARCODE	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 MAIN TANK OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 BARCODE	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 MAIN TANK OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 PRIMARY SWITCH OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 BARCODE	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 MAIN TANK OIL LEVEL	NORMAL
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER MISSING?	FALSE
6937669	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/23/2022 0:00	2/23/2024 0:00 IS TRANSFORMER INFORMATION INCORRECT?	FALSE



7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	Lighting and Receptacles	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	BARCODE	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7022568	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	9/9/2022 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE





7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	NUMBER OF DUCTS AVAILABLE	04
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	VAULT LADDER	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	DRYWELL DRAINAGE	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SERVICE DUCT SEALS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	CABLE TAGS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	TRANSFORMER GASKETS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SCADA COLLECTOR BOX	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	SCADA SENSORS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IR BUS CONNECTIONS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IR PROTECTOR LEADS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IR SERVICE LEADS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	AD-6 MULTIPLIER	01
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	BARCODE	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS PROTECTOR MISSING	FALSE
7113403	VT0079 FEDERAL BUILDING 480 VOLTS	620 S 6th ST Louisville KY 40202	3/7/2023 0:00	2/23/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE







6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6248406	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/12/2019 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE



6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE

6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	BARCODE	FALSE
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6359259	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	8/7/2019 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE

6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6442256	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	2/4/2020 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	Anything not listed?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01

6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	BARCODE	FALSE
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6573199	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/9/2020 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE

6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6666592	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	1/7/2021 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE



6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	HIGH
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6771440	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	7/2/2021 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	Vault CLEANED DURING THIS INSPECTION?	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE

6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE

6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	BARCODE	FALSE
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6876072	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	12/10/2021 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	Anything not listed?	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	08
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	TRUE

6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
6967574	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	4/27/2022 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	Anything not listed?	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	02
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE

7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	HIGH
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	BARCODE	FALSE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7041999	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	10/7/2022 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	Anything not listed?	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	03
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE



7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	01
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7131111	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	3/24/2023 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	Anything not listed?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	Lighting and Receptacles	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BLOWERS AND DUCTWORK	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SIDEWALK SURFACE AREA	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VAULT LADDER	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	DRYWELL DRAINAGE	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SERVICE DUCT SEALS	TRUE

7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	CABLE TAGS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER GASKETS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRESSURE RELIEF VALVE	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR HOUSING RUST	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA COLLECTOR BOX	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA PROTECTOR BOXES	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA WIRING AND HANGERS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SCADA SENSORS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR BUS CONNECTIONS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR PROTECTOR LEADS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR SERVICE LEADS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	AD-6 MULTIPLIER	02
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	HIGH
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER MISSING?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR MISSING	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH MISSING?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	IS HIGHSIDE SWITCH INFO INCORRECT?	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	BARCODE	FALSE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	SWITCH POSITION	CLOSED
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	RUST OR DAMAGE PRESENT	TRUE
7232610	VT0080 FEDERAL BUILDING (BDWY)	611 W Broadway Louisville KY 40202	9/12/2023 0:00	3/12/2024 0:00	Elbow Assembly and Cable	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01

6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6272236	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	6/6/2019 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE

6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BARCODE	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BARCODE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BARCODE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BARCODE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	BARCODE	TRUE
6398262	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	11/15/2019 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE

6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6520464	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	4/16/2020 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE



6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	Lighting and Receptacles	FALSE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	BARCODE	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	TRUE
6617891	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	8/4/2020 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	VAULT LADDER	TRUE

6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	BARCODE	FALSE
6681289	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/26/2021 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	Anything not listed?	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	Lighting and Receptacles	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE

6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BARCODE	TRUE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	BARCODE	FALSE
6784445	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/22/2021 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	Anything not listed?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	00
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	VENT GRATES, FRAMES, CAULK	TRUE

6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	ENTRANCE GRATES, HINGES, LOCKS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	VAULT LADDER	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	DRYWELL DRAINAGE	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	CABLE BUS AND CONNECTIONS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PROTECTOR, SERVICE LEAD CONNECTIONS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SERVICE DUCT SEALS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	CABLE TAGS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PRIMARY ARC PROOFING TAPE	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	GROUND, NEUTRAL CABLES	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	TRANSFORMER FLOOR BEAMS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	TRANSFORMER LEAKS LOCATION	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	TRANSFORMER GASKETS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	TRANSFORMER CASE RUST LOCATION	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PRESSURE RELIEF VALVE	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	TRANSFORMER PRIMARY SWITCH, LOCK	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PROTECTOR HOUSING RUST	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PROTECTOR SWITCH, LOCK	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SCADA COLLECTOR BOX	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SCADA PROTECTOR BOXES	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SCADA WIRING AND HANGERS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	SCADA SENSORS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IR BUS CONNECTIONS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IR PROTECTOR LEADS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IR SERVICE LEADS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IR PRIMARY ELBOWS, TERMS	TRUE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	AD-6 MULTIPLIER	01
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BARCODE	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS TRANSFORMER MISSING?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS TRANSFORMER INFORMATION INCORRECT?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	PRIMARY SWITCH OIL LEVEL	NORMAL
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BARCODE	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	MAIN TANK OIL LEVEL	NORMAL
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BARCODE	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS PROTECTOR MISSING	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS PROTECTOR INFO INCORRECT	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BARCODE	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS SERVICE OR MAIN MISSING?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	IS SERVICE OR MAIN INFO WRONG?	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	BARCODE	FALSE
6887356	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	1/14/2022 0:00	4/10/2024 0:00	VISUAL INSPECTION SERV/MAIN	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	Anything not listed?	FALSE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	VAULT CLEANED DURING THIS INSPECTION?	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	CATCH PANS, DEBRIS SHIELDS	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	HANGERS, HARDWARE - CEILING, WALLS	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	Lighting and Receptacles	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	BLOWERS AND DUCTWORK	TRUE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	NUMBER OF DUCTS AVAILABLE	01
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	SIDEWALK SURFACE AREA	FALSE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	CEILING, WALLS, AND FLOOR	FALSE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	CEILING I-BEAMS, SUPPORTS	FALSE
6983987	VT0081 FEDERAL RESERVE BANK	508 W Liberty Louisville KY 40202	7/12/2022 0:00	4/10/2024 0:00	HATCHWAY FRAMES, SLABS, CAULK	TRUE