Mill Creek Gypsum Processing Plant (GPP) Winterization Checklist

This Plan includes the GPP building and SPP building, Gypsum Barge Loading, Transfer Towers and Fly Ash Silos

Supplies Checklist Complete by October 1st annually	Initial
Salt Bins are full and placed at main entry ways and trucks scales	_____
1 full tote of Liquid Heat stored in SPP building	_____
2 pump sprayers for Liquid Heat stored in SPP building	_____
2 Torpedo Heaters (in working order and fueled)	_____
1 stored in SPP building Maintenance Shop	_____
1 stored in GPP building Conex Box	_____
Winter PPE stocked in Control Room	_____
(Ice Cleats, Insulated Work Gloves, Face Socks, Balaclavas, etc)	_____
2 Shovels	_____
1 stored in SPP building Maintenance Shop	_____
1 stored in GPP building Conex Box	_____
Antifreeze stored in Air Compressor Room	_____
Meals stocked in GPP Control Room	_____

Contact LG&E Supervisor or Mill Creek Commercial Operations [redacted] *to order supplies*

Work Order Checklist	Due Date	Initial
Building Heater and Heat Trace PM#00057538 has been completed by I&E	15-Oct	_____
Gate 3 Truck Wash has been winterized by Charah and carded	31-Oct	_____
Check Exterior doors are operational and secure	15-Oct	_____
Ranger doors have been installed and fluids checked	15-Nov	_____

Operational Procedures if Temps/Wind Chill falls below XXX

Consider continuous operation of Conveyor Belts

Apply Liquid Heat to Conveyor Belts as needed to reduce material build-up on rollers

Crack open low point drains and traps on Instrument & Station air systems

Close ALL exterior doors and louvers

Check Seal water drains for potential freezing/plugging

Revised 9-12-2022