

**East Kentucky Power
Operating Report
Rollup Report for Selected Units (Inc. OMC)**

Rollup

**Selected
Units:**

SPUR1

SPUR2

SPUR3

SPUR4

**East Kentucky Power
Operating Report
Rollup Report for Selected Units (Inc. OMC)**

*Rollup***Rollup**

Unit Rating	1346.00
Net Dep. Capacity	1346.00
Net Gen (mwh)	7497121.00
Gross Gen (mwh)	7500224.00
Station Svc(mwh)	3103.00
Net Ht Rt(btu/kwh)	10534.09
Gross Ht Rt(btu/kwh)	10529.73
Period Hours	8760.00
Available Hours	28822.60
Service Hours	27899.71
Condensing Hours	0.00
Actual Starts	23.00
Attempted Starts	24.00
Hydro Gen Starts	0.00
Hydro Pump Starts	0.00
Eq. Avail. Factor	80.81
Net Capacity Factor	63.58
Generation Use Factor	78.68
Eq. Forced Out. Rate	1.48
Availability Factor	82.18
Starting Reliability	95.83
EFORD(%)	1.46
MMBTUs (x1000)	78975.31
Coal-Burned (tons)	3427768.00
Coal-Average HHV	11519.93
Coal-%Ash	11.22
Coal-%Sulfur	3.18
Coal-%Moisture	9.84
#2Oil-Burned(gal)	0.00
#2Oil-Average HHV	0.00
#2Oil-%Sulfur	0.00
Gas-Burned(mcf)	0.00
Gas-Average HHV	0.00