

Work Order Details

CO128770: U2 CHECK CALIBRATION OF CONDENSATE CYCLE, VALVES & TRANSMITTERS (12 MO OUTAGE)

U2 CHECK CALIBRATION OF CONDENSATE CYCLE, VALVES & TRANSMITTERS (12 MO OUTAGE)

Asset: CO1572 U2 CONDENSER **Model:**
Location: CP2-CIRC-WTR 03711 COOPER UNIT 2 CIRCULATING WATER SYSTEM **Product Version:** 2 PASS

Sched Start:	4/5/2025	Business Unit:	COOP-Cooper Station	Job Plan:	PM_2044
Sched Finish:	4/6/2025	Priority:	3 (Low - Routine)	Supervisor:	
Target Start:	4/7/2025	Work Type:	PM-Preventative Maint	Lead:	
Target Finish:	4/8/2025	Status:	WSCH	Vendor:	
Actual Start:		Parent:		Reported by:	03659
Actual Finish:		Failure Class:		Reported by:	Mike Stanton
Report Date:	10/28/2024	Problem Code:		Defect Tag:	NO
Craft:	CI	PM Number:	PM1228	Commodity:	
Unit:	2	GL Account:	513000~CP02~300~3000~03711~BASE~00~00000~00000	Comdty Grp:	
Outage:	Outage	UNID:		Classification:	

Tasks

WO Task	Task ID	Craft	Description	Status	Sched Start	Sched Finish	Est Hours	Actual Start	Actual Finish
CO128771	1	CI	CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS---FWH	WSCH	4/5/25	4/6/25	15		
CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS---FWH									

Instructions: ***INSTRUCTIONS***
 [Step 1]: 
 10Clean and Inspect Controllers and Valves for damage and proper operation.
 20Check for air leaks, hesitation or iratic motion / Repair if present.
 30Check for worn or tight linkage connections / Repair or replace if needed.
 40Warning! Isolation and bleeding off of all air and air supply will be needed when repairs are made.
 50Check for proper Crack Off of Primary Valve at appropriate PSI
 60Check Secondary Valve
 70Check Emergency Valve
 80Check for proper feedback to control room if applicable
 90If trouble exist with positioned, refer to Calibration and/ or Maintenance sections in the
 91controller and / or valve manual. Repair or replace if needed

CO128772	2	CI	CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS--HOTWELL	WSCH	4/5/25	4/5/25	5		
CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS--HOTWELL									

Instructions: ***INSTRUCTIONS***
 [Step 1]: 
 10Clean and Inspect Controllers and Valves for damage and proper operation.

Work Order Details

CO128770: U2 CHECK CALIBRATION OF CONDENSATE CYCLE, VALVES & TRANSMITTERS (12 MO OUTAGE)

Tasks										
WO Task	Task ID	Craft	Description	Status	Sched Start	Sched Finish	Est Hours	Actual Start	Actual Finish	
			20Check for air leaks, hesitation or iratic motion / Repair if present. 30Check for worn or tight linkage connections / Repair or replace if needed. 40Warning! Isolation and bleeding off of all air and air supply will be needed when repairs are made. 50Check for proper Crack Off of Primary Valve at appropriate PSI 60Check Secondary Valve 70Check Emergency Valve 80Check for proper feedback to control room if applicable 90If trouble exist with positioned, refer to Calibration and/ or Maintenance sections in the 91controller and / or valve manual. Repair or replace if needed							
CO128773	3	CI	CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS--DA	WSCH	4/5/25	4/5/25	10			
			CHECK CALIBRATION OF CONDENSATE CYCLE, VALVE AND TRANSMITTERS--DA							

Instructions:

INSTRUCTIONS
 [Step 1]: 
 10Clean and Inspect Controllers and Valves for damage and proper operation.
 20Check for air leaks, hesitation or iratic motion / Repair if present.
 30Check for worn or tight linkage connections / Repair or replace if needed.
 40Warning! Isolation and bleeding off of all air and air supply will be needed when repairs are made.
 50Check for proper Crack Off of Primary Valve at appropriate PSI
 60Check Secondary Valve
 70Check Emergency Valve
 80Check for proper feedback to control room if applicable
 90If trouble exist with positioned, refer to Calibration and/ or Maintenance sections in the
 91controller and / or valve manual. Repair or replace if needed

Planned Labor										
Task ID	Craft	Skill Level	Labor	Vendor	Contract	Qty	Hours	Rate	Line Cost	
1	CI					3	15:00			
2	CI					3	05:00			
3	CI					3	10:00			
							Total Planned Labor:			

Report EK_woprint.rptdesign