

Work Order Details

SP255856: UNIT 2 TEST IGNITORS AND OIL GUNS, CLEAN AS NECESSARY - WEEKLY PM (4 NIGHTS)

UNIT 2 CLEAN AND TEST IGNITORS AND OIL GUNS - WEEKLY PM

4 NIGHTS

Asset: **Location:** SP02.BO.FOS Unit 02 Fuel Oil Ignition System **Model:** **Product Version:**

Sched Start:		Business Unit:	SPUR-Spurlock Station	Job Plan:	OPS.053
Sched Finish:		Priority:	3 (Low - Routine)	Supervisor:	
Target Start:	12/27/2024	Work Type:	PM-Preventative Maint	Lead:	
Target Finish:	12/27/2024	Status:	WCMP	Vendor:	
Actual Start:	12/30/2024	Parent:		Reported by:	03890
Actual Finish:	12/30/2024	Failure Class:		Reported by:	Kathy Lippert
Report Date:	11/25/2024	Problem Code:		Defect Tag:	NO
Craft:	OPERATIONS	PM Number:	PM4001	Commodity:	
Unit:	2	GL Account:	512000~SP02~400~3000~03200~BASE~00~00000~00000	Comdty Grp:	
Outage:	No Outage	UNID:		Classification:	

Tasks										
WO Task	Task ID	Craft	Description	Status	Sched Start	Sched Finish	Est Hours	Actual Start	Actual Finish	
SP255857	10	OPERATIONS	UNIT 2 - CLEAN AND TEST IGNITORS AND OIL GUNS - WEEKLY PM	WCMP			4			

Instructions:

INSTRUCTIONS
 [Step 1]:
 * BE SURE TO FOLLOW ALL EKPC SAFETY PROCEDURES

Unit 2 ignitors
 1) Close manual air and oil valves turn.
 2) Remove quick connect air and oil fittings.
 3) Unlatch and remove upper and lower ignitors.
 4) Clean nozzles, wire a brush, and reinstall ignitors.
 5) Insure that the slot on the upper ignitor faces down.
 6) Check DIRTY/CLEAN indicator on fuel oil filters. Unscrew filter and clean, if necessary.
 7) Check Invalco flow control orifice strainers by removing assembly and checking screen.
 8) Test fire the ignitors (coordinate with Unit Operator)

Unit 2 oil guns
 1) Close manual air and oil valves turn.

Work Order Details

SP255856: UNIT 2 TEST IGNITORS AND OIL GUNS, CLEAN AS NECESSARY - WEEKLY PM (4 NIGHTS)

Tasks										
WO Task	Task ID	Craft	Description	Status	Sched Start	Sched Finish	Est Hours	Actual Start	Actual Finish	
			2) Loosen T-handle and pull out warm up gun. 3) Clean nozzles, wire a brush, and reinstall. 4) Test fire the oil guns (coordinate with Unit Operator)							
* WHEN COMPLETE BE SURE TO INPUT ANY IMPORTANT NOTES ON THE WORK ORDER AND MARK THE TASK AS "WORK COMPLETE".										

Planned Labor										
Task ID	Craft	Skill Level	Labor	Vendor	Contract	Qty	Hours	Rate	Line Cost	
10	OPERATIONS					2	02:00			
										Total Planned Labor:

Log			
Date	Class	Created By	Description
12/30/2024 02:47:52 AM	WORKORDER	02591 Jason Hunt	Unit 2 Test Igniters and Oil Guns
B Ignitor Corner 2 and De Corner 2 Ignitor Valve Won't Open work order 259672 M Davis/L Isaac worked on it but couldn't get it to work.			

Report EK_woprint.rptdesign